

NPDES PERMIT

issued to

Fiberoptics Technology, Inc.
28 Quasset Road
Pomfret, CT 06258

Location Address:

28 Quasset Road
Pomfret

Facility ID: 112-021

Permit ID: CT0026832

Receiving Stream: Wappoquia Brook

Permit Expires: March 5, 2011

SECTION 1: GENERAL PROVISIONS

- (A) This permit is reissued in accordance with section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), and Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and section 402(b) of the Clean Water Act, as amended, 33 USC 1251, et. seq., and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer an N.P.D.E.S. permit program.
- (B) Fiberoptics Technology, Inc. ("Permittee"), shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to section 22a-430 of the CGS and are hereby incorporated into this permit. Your attention is especially drawn to the notification requirements of subsection (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) and (l)(2) of section 22a-430-3.

section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (l) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations (Upsets)
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

section 22a-430-4 Procedures and Criteria

- (a)Duty to Apply
 - (b)Duty to Reapply
 - (c)Application Requirements
 - (d)Preliminary Review
 - (e)Tentative Determination
 - (f)Draft Permits, Fact Sheets
 - (g)Public Notice, Notice of Hearing
 - (h)Public Comments
 - (i)Final Determination
 - (j)Public Hearings
 - (k)Submission of Plans and Specifications. Approval.
 - (l)Establishing Effluent Limitations and Conditions
 - (m)Case by Case Determinations
 - (n)Permit issuance or renewal
 - (o)Permit Transfer
 - (p)Permit revocation, denial or modification
 - (q)Variances
 - (r)Secondary Treatment Requirements
 - (s)Treatment Requirements for Metals and Cyanide
 - (t)Discharges to POTWs - Prohibitions
- (C) Violations of any of the terms, conditions, or limitations contained in this permit may subject the permittee to enforcement action including, but not limited to, seeking penalties, injunctions and/or forfeitures pursuant to applicable sections of the CGS and RCSA.
- (D) Any false statement in any information submitted pursuant to this permit may be punishable as a criminal offense under section 22a-438 or 22a-131a of the CGS or in accordance with section 22a-6, under section 53a-157b of the CGS.
- (E) The authorization to discharge under this permit may not be transferred without prior written approval of the Commissioner. To request such approval, the permittee and proposed transferee shall register such proposed transfer with the Commissioner, at least 30 days prior to the transferee becoming legally responsible for creating or maintaining any discharge which is the subject of the permit transfer. Failure, by the transferee, to obtain the Commissioner's approval prior to commencing such discharge(s) may subject the transferee to enforcement action for discharging without a permit pursuant to applicable sections of the CGS and RCSA.
- (F) No provision of this permit and no action or inaction by the Commissioner, shall be construed to constitute an assurance by the Commissioner that the actions taken by the permittee pursuant to this permit will result in compliance or prevent or abate pollution.
- (G) Nothing in this permit shall relieve the permittee of other obligations under applicable federal, state and local law.
- (H) An annual fee shall be paid for each year this permit is in effect as set forth in section 22a-430-7 of the Regulations of Connecticut State Agencies.

SECTION 2: DEFINITIONS

(A) The definitions of the terms used in this permit shall be the same as the definitions contained in section 22a-423 of the CGS and section 22a-430-3(a) and 22a-430-6 of the RCSA, except for "No observable acute effect level (NOAEL)" which is redefined below.

(B) In addition to the above, the following definitions shall apply to this permit:

"-----" in the limits column on the monitoring table means a limit is not specified but a value must be reported on the DMR

"Annual" in the context of any sampling frequency found in Section 5, shall mean the sample must be collected in the month of May.

"Average Monthly Limit"; means the maximum allowable "Average Monthly Concentration" as defined in section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g. mg/l); otherwise, it means "Average Monthly Discharge Limitation" as defined in section 22a-430-3(a) of the RCSA.

"Critical Test Concentration (CTC)" means the specified effluent dilution at which the permittee is to conduct a single-concentration Aquatic Toxicity test.

"Daily Concentration" means the concentration of a substance as measured in a daily composite sample, or, the arithmetic average of all grab sample results defining a grab sample average.

"Daily Quantity" means the quantity of waste discharged during an operating day.

"Instantaneous Limit" means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

"In stream Waste Concentration (IWC)" means the concentration of a discharge in the receiving water after mixing has occurred in the allocated zone of influence.

"Maximum Daily Limit", means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g. mg/l); otherwise, it means the maximum allowable "Daily Quantity" as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity it means "Maximum Daily Flow" as defined in section 22a-430-3(a) of the RCSA.

"NA" as a Monitoring Table abbreviation means "not applicable".

"NR" as a Monitoring Table abbreviation means "not required".

"No Observable Acute Effect Level (NOAEL)" means any concentration equal to or less than the critical test concentration in a single concentration (pass/fail) toxicity test conducted pursuant to section 22a-430-3(j)(7)(A)(i) RCSA demonstrating greater than 90% or greater survival of test organisms at the CTC.

"Quarterly", in the context of a sampling frequency, means sampling is required in the months of February, May, August, and November.

"Semi-Annual" in the context of a sampling frequency, means the sample must be collected in the months of May and August.

"ug/l" means micrograms per liter.

SECTION 3: COMMISSIONER'S DECISION

- (A) The Commissioner of Environmental Protection ("Commissioner") has issued a final determination and found that the continuance of the existing system to treat the discharge will protect the waters of the state from pollution. The Commissioner's decision is based on **Application No. 199500224 (92-146)** for permit reissuance received on June 12, 1992 and the administrative record established in the processing of that application.
- (B) The Commissioner hereby authorizes the Permittee to discharge in accordance with the provisions of this permit, the above referenced application, and all approvals issued by the Commissioner or his authorized agent for the discharges and/or activities authorized by, or associated with, this permit.
- (C) The Commissioner reserves the right to make appropriate revisions to the permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the CGS or regulations adopted thereunder, as amended. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

SECTION 4: GENERAL EFFLUENT LIMITATIONS

- (A) No discharge shall contain, or cause in the receiving stream, a visible oil sheen or floating solids; or, cause visible discoloration or foaming in the receiving stream.
- (B) No discharge shall cause acute or chronic toxicity in the receiving water body beyond any zone of influence specifically allocated to that discharge in this permit.
- (C) The temperature of any discharge shall not increase the temperature of the receiving stream above 85°F, or, in any case, raise the normal temperature of the receiving stream more than 4°F.

SECTION 5: SPECIFIC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- (A) The discharge(s) shall not exceed and shall otherwise conform to the specific terms and conditions listed below. The discharge is restricted by, and shall be monitored in accordance with, the table below:

Table A

Monitoring Location: 1

Discharge Serial Number: 001-1

Wastewater Description: Treated groundwater remediation wastewaters

Monitoring Location Description: at effluent pipe from Air Stripping Tower

PARAMETER	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING				Minimum Level Test
		Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ¹	Sample Type or Measurement to be reported	Instantaneous limit or required range	Sample/Reporting Frequency	Sample Type or measurement to be reported ²		
1,1 Dichloroethane	ug/l	NA	NA	NR	NA	150.0	Monthly	Grab	*	
1,2 Dichloroethane	ug/l	NA	NA	NR	NA	50.0	Monthly	Grab	*	
1,1 Dichloroethylene	ug/l	NA	NA	NR	NA	3.2	Monthly	Grab	*	
Methylene Chloride	ug/l	NA	NA	NR	NA	50.0	Monthly	Grab	*	
1,1,1 Trichloroethane	ug/l	NA	NA	NR	NA	11.0	Monthly	Grab	*	
Tetrachloroethylene	ug/l	NA	NA	NR	NA	8.9	Monthly	Grab	*	
Trichloroethylene	ug/l	NA	NA	NR	NA	81.0	Monthly	Grab	*	
Flow, Total ³	gpd	NA	5,000	Daily/Monthly	Daily Flow	NA	NR	NA	*	
pH	S.U.	NA	NA	NR	NA	6.0-9.0	Monthly	Instantaneous	*	

Table Footnotes:

¹ The first entry in this column is the 'Sample Frequency'. If this entry is not followed by a 'Reporting Frequency' and the 'Sample Frequency' is more frequent than monthly then the 'Reporting Frequency' is monthly. If the 'Sample frequency' is specified as monthly, or less frequent, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.

² Minimum Level Test refers to Section 6 Paragraph (A)(3) of this permit.

³ For this parameter the permittee shall maintain at the facility a record of the Total Daily Flow for each day of discharge and shall report the Average Daily Flow and the Maximum Daily Flow for each month.

TABLE B

Discharge Serial Number (DSN):001-1		Monitoring Location: T				
Wastewater Description: Treated groundwater remediation wastewaters						
Monitoring Location Description: at effluent pipe from air stripping tower						
PARAMETER	Units	Maximum Daily Limit	Maximum Instantaneous Limit	Sampling Frequency	Sample Type	Minimum Level Analysis See Section 6
Aquatic Toxicity, Daphnia, Pulex ¹	%	NA	NOAEL= 100%	Semi-annual	Grab	
Aquatic Toxicity, Pimephales promelas ¹	%	NA	NOAEL= 100%	Semi-annual	Grab	
Chlorine, Total Residual	mg/l	NA	-----	Semi-annual	Grab	
Copper, Total	mg/l	NA	-----	Semi-annual	Grab	*
Iron, Total	mg/l	NA	-----	Semi-annual	Grab	
Lead, Total	mg/l	NA	-----	Semi-annual	Grab	*
Nitrogen, Ammonia (total as N)	mg/l	NA	-----	Semi-annual	Grab	
Suspended Solids, Total	mg/l	NA	-----	Semi-annual	Grab	
Zinc, Total	mg/l	NA	-----	Semi-annual	Grab	*
1,1 Dichloroethane	ug/l	NA	150.0	Semi-annual	Grab	*
1,2 Dichloroethane	ug/l	NA	50.0	Semi-annual	Grab	*
1,1 Dichloroethylene	ug/l	NA	3.2	Semi-annual	Grab	*
Methylene Chloride	ug/l	NA	50.0	Semi-annual	Grab	*
Tetrachloroethylene	ug/l	NA	8.9	Semi-annual	Grab	*
1,1,1 Trichloroethane	ug/l	NA	11.0	Semi-annual	Grab	*
Trichloroethylene	ug/l	NA	81.0	Semi-annual	Grab	*

Remarks:

Note: All analysis shall be on the same sample.

¹ The results of the Toxicity Tests are recorded in % survival, however, the permittee shall report pass/fail on the DMR based on criteria in Section 6(B) of this permit.

- (1) All samples shall be comprised of only the wastewater described in this table. Samples shall be collected prior to combination with receiving waters or wastewater of any other type, and after all approved treatment units, if applicable. All samples collected shall be representative of the discharge during standard operating conditions.
- (2) In cases where limits and sample type are specified but sampling is not required by this permit, the limits specified shall apply to all samples which may be collected and analyzed by the Department of Environmental Protection personnel, the permittee, or other parties.
- (3) The limits imposed on the discharges listed in this permit take effect on the issuance date of this permit, hence any sample taken after this date which, upon analysis, shows an exceedance of permit limits will be considered non-compliance.

The monitoring requirements begin on the date of issuance of this permit if the issuance date is on or before the 12th day of a month. For permits issued on or after the 13th day of a month, monitoring requirements begin the 1st day of the following month.

SECTION 6: SAMPLE COLLECTION, HANDLING and ANALYTICAL TECHNIQUES

(A) Chemical Analysis

- (1) Chemical analyses to determine compliance with effluent limits and conditions established in this permit shall be performed using the methods approved pursuant to the Code of Federal Regulations, Part 136 of title 40 (40 CFR 136) unless an alternative method has been approved in writing pursuant to 40 CFR 136.4 or as provided in section 22a-430-3(j)(7) of the RCSA. Chemicals which do not have methods of analysis defined in 40 CFR 136 shall be analyzed in accordance with methods specified in this permit.
- (2) All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal as defined in 40 CFR 136 unless otherwise specified.
- (3) The Minimum Levels specified below represent the concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Section 5 Tables A and B. Analyses for these parameters must include check standards within ten percent of the specified Minimum Level or calibration points equal to or less than the specified Minimum Level.

<u>Parameter</u>	<u>Minimum Level</u>
1,1 Dichloroethane	1.0 ug/L
1,2 Dichloroethane	1.0 ug/L
1,1 Dichloroethylene	1.0 ug/L
Methylene Chloride	1.0 ug/L
1,1,1 Trichloroethane	0.5 ug/L
Trichloroethylene	1.0 ug/L
Tetrachloroethylene	1.0 ug/L
Copper	5.0 ug/L
Lead	5.0 ug/L
Zinc	10.0 ug/L

Cadmium,	0.5 ug/l.
Arsenic,	5.0 ug/l
Mercury	0.2 ug/l

- (4) The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible consistent with the requirements of this section of the permit.
- (5) Effluent analyses for which quantification was verified during the analysis at or below the minimum levels specified in this section and which indicate that a parameter was not detected shall be reported as "less than x" where 'x' is the numerical value equivalent to the analytical method detection limit for that analysis.
- (6) Results of effluent analyses which indicate that a parameter was not present at a concentration greater than or equal to the Minimum Level specified for that analysis shall be considered equivalent to zero (0.0) for purposes of determining compliance with effluent limitations or conditions specified in this permit.

(B) Acute Aquatic Toxicity Test

- (1) Samples for monitoring of Aquatic Toxicity shall be collected and handled as prescribed in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA/821-R-02-012).
 - (a) Grab samples shall be chilled immediately following collection. Samples shall be held at 4 degrees Centigrade until Aquatic Toxicity testing is initiated.
 - (b) Effluent samples shall not be dechlorinated, filtered, or modified in any way, prior to testing for Aquatic Toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility.
 - (c) Chemical analyses of the parameters identified in Section 5 Tables A and B shall be conducted on an aliquot of the same sample tested for Aquatic Toxicity.
 - (i) At a minimum, pH, specific conductance, total alkalinity, total hardness, and total residual chlorine shall be measured in the effluent sample and, during Aquatic Toxicity tests, in the highest concentration of test solution and in the dilution (control) water at the beginning of the test and at test termination. If Total Residual Chlorine is not detected at test initiation, it does not need to be measured at test termination. Dissolved oxygen, pH, and temperature shall be measured in the control and all test concentrations at the beginning of the test, daily thereafter, and at test termination.
 - (d) Tests for Aquatic Toxicity shall be initiated within 24 hours of sample collection.
- (2) Monitoring for Aquatic Toxicity to determine compliance with the permit limit on Aquatic Toxicity (invertebrate) above shall be conducted for 48-hours utilizing neonatal Daphnia pulex (less than 24-hours old)
- (3) Monitoring for Aquatic Toxicity to determine compliance with the permit limit on Aquatic Toxicity (vertebrate) above shall be conducted for 48-hours utilizing larval Pimephales promelas (1-14 days old with no more than 24-hours range in age).

- (4) Tests for Aquatic Toxicity shall be conducted as prescribed for static non-renewal acute tests in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA/821-R-02-012), except as specified below.
- (a) For Aquatic Toxicity Limits and for monitoring only conditions, expressed as an NOAEL value, Pass/Fail (single-concentration) tests shall be conducted at a specified Critical Test Concentration (CTC) equal to the Aquatic Toxicity Limit, as prescribed in section 22A-430-3(j)(7)(A)(I) of the Regulations of Connecticut State Agencies.
 - (b) Organisms shall not be fed during the tests.
 - (c) Copper nitrate shall be used as the reference toxicant in tests with freshwater organisms.
 - (d) Synthetic freshwater prepared with deionized water adjusted to a hardness of 50 mg/L (plus or minus 5 mg/L) as CaCO₃ shall be used as dilution water in tests with freshwater organisms.
- (5) Compliance with limits on Aquatic Toxicity shall be demonstrated when the results of a valid pass/fail Aquatic Toxicity test indicates there is greater than 90% or greater survival in the undiluted effluent.

SECTION 8: REPORTING REQUIREMENTS

- (A) The results of chemical analyses and any aquatic toxicity test required above shall be entered on the Discharge Monitoring Report (DMR), provided by this office, and reported to the Bureau of Water Management (Attn: DMR Processing) at the following address. The report shall also include a detailed explanation of any violations of the limitations specified. The DMR shall be received at this address by the last day of the month following the month in which samples are collected.

Bureau of Water Management (Attn: DMR Processing)
Connecticut Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

- (B) Complete and accurate aquatic toxicity test data, including percent survival of test organisms in each replicate test chamber, LC50 values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test, including measured daily flow and hours of operation for the 30 consecutive operating days prior to sample collection if compliance with a limit on Aquatic Toxicity is based on toxicity limits based on actual flows described in Section 7, shall be entered on the Aquatic Toxicity Monitoring Report form (ATMR) and sent to the Bureau of Water Management at the following address by the last day of the month following the month in which samples are collected.

Bureau of Water Management (Attn: Aquatic Toxicity)
Connecticut Department of Environmental Protection
79 Elm St.
Hartford, Ct 06106-5127

- (C) If this permit requires monitoring of a discharge on a calendar basis (e.g. Monthly, quarterly, etc.), but a discharge has not occurred within the frequency of sampling specified in the permit, the Permittee must submit the DMR and ATMR, as scheduled, indicating "NO DISCHARGE". For those permittees whose

required monitoring is discharge dependent (e.g. per batch), the minimum reporting frequency is monthly. Therefore, if there is no discharge during a calendar month for a batch discharge, a DMR must be submitted indicating such by the end of the following month.

SECTION 9: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS

- (A) If any sample analysis indicates that an Aquatic Toxicity effluent limitation in Section 5 of this permit has been exceeded, or that the test was invalid, another sample of the effluent shall be collected and tested for Aquatic Toxicity and associated chemical parameters, as described above in Section 5 and Section 6, and the results reported to the Bureau of Water Management (Attn: DMR Processing), at the address listed above, within 30 days of the exceedance or invalid test. Results of all tests, whether valid or invalid, shall be reported.
- (B) If any two consecutive test results or any three test results in a twelve month period indicates that an Aquatic Toxicity Limit has been exceeded, the permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and shall submit a report to Bureau of Water Management (Attn: Aquatic Toxicity) for the review and approval of the Commissioner in accordance with section 22a-430-3(j)(10)(c) of the RCSA describing proposed steps to eliminate the toxic impact of the discharge on the receiving water body. Such a report shall include a proposed time schedule to accomplish toxicity reduction and the permittee shall comply with any schedule approved by the Commissioner.
- (C) The permittee shall notify the Bureau of Water Management, Permitting and Enforcement Division, within 72 hours and in writing within thirty days of the discharge of any substance listed in the application but not listed in the permit if the concentration or quantity of that substance exceeds two times the level listed in the application.

This permit is hereby issued on the 6TH DAY OF MARCH, 2006.

GINA MCCARTHY
Gina McCarthy
Commissioner

GM/GLL

DATA TRACKING AND TECHNICAL FACT SHEET

Permittee: *Fiberoptics Technology, Inc.*

PAMS Company ID: 19141

PERMIT, ADDRESS, AND FACILITY DATA

PERMIT #: CT0026832 APPLICATION #: 92-146 (199500224) FACILITY ID. 112-021

<p><u>Mailing Address:</u></p> <p>Street: 28 Quasset Road</p> <p>City: Pomfret ST: CT Zip: 06258</p> <p>Contact Name: Keith Knowlton</p> <p>Phone No.: (860) 928-0443</p>	<p><u>Location Address:</u></p> <p>Street: 28 Quasset Road</p> <p>City: Pomfret ST: CT Zip: 06258</p> <p>DMR Contact: Keith Knowlton</p> <p>Phone No.: (860) 928-0443</p>
--	--

PERMIT INFORMATION

DURATION 5 YEAR X 10 YEAR ___ 30 YEAR ___

TYPE New ___ Reissuance X Modification ___

CATEGORIZATION POINT (X) NON-POINT () GIS #

NPDES (X) PRETREAT () GROUND WATER(UIC) () GROUND WATER (OTHER) ()

NPDES MAJOR(MA) ___
 NPDES SIGNIFICANT MINOR or PRETREAT SIU (SI) ___
 NPDES or PRETREATMENT MINOR (MI) X

PRETREAT SIGNIFICANT INDUS USER(SIU) ___
 PRETREAT CATEGORICAL (CIU) ___
 Note: If it's a CIU then check off SIU

POLLUTION PREVENTION MANDATE ___ ENVIRONMENTAL EQUITY ISSUE ___

COMPLIANCE SCHEDULE YES ___ NO X

POLLUTION PREVENTION ___ TREATMENT REQUIREMENT ___ WATER CONSERVATION ___

WATER QUALITY REQUIREMENT ___ REMEDIATION X OTHER ___

IS THE PERMITTEE SUBJECT TO A PENDING ENFORCEMENT ACTION? NO ___ YES X

The company was issued Administrative Order No. WC3979, requiring groundwater remediation on-site back on February 4, 1985. The Waste Management Bureau is actively working on this project.

OWNERSHIP CODE

Private X Federal ___ State ___ Municipal (town only) ___ Other public ___

DEP STAFF ENGINEER Gary Leavitt

PERMIT FEES

<i>Discharge Code</i>	<i>DSN Number</i>	<i>Annual Fee</i>
1090000	DSN 001	4,087.50

FOR NPDES DISCHARGES

Drainage basin Code: 3709

Present/Future Water Quality Standard: A/A

NATURE OF BUSINESS GENERATING DISCHARGE

This is a groundwater contamination remediation system discharge.

PROCESS AND TREATMENT DESCRIPTION (by DSN)

The pumped groundwater is treated by an air stripping column prior to being discharged to the storm drain.

RESOURCES USED TO DRAFT PERMIT

X Department File Information

X Connecticut Water Quality Standards

BASIS FOR LIMITATIONS, STANDARDS OR CONDITIONS

X In order to meet in-stream water quality (See General Comments)

GENERAL COMMENTS

The need for inclusion of water quality based discharge limitations in this permit was evaluated consistent with Connecticut Water Quality Standards and criteria, pursuant to 40 CFR 122.44(d). Each parameter was evaluated for consistency with the available aquatic life criteria (acute and chronic) and human health (fish consumption only) criteria, considering the zone of influence allocated to the facility where appropriate. The statistical procedures outlined in the EPA Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001) were employed to calculate the need for such limits. Comparison of monitoring data and its inherent variability with the calculated water quality based limits indicates a low statistical probability of exceeding such limits. Therefore, the following water quality based limits were included in the permit at this time.

<i>1,1 Dichloroethane</i>	<i>150 ug/l,</i>	<i>1,2 Dichloroethane</i>	<i>50 ug/l</i>
<i>1,1 Dichloroethylene</i>	<i>3.2 ug/l</i>	<i>Methylene Chloride</i>	<i>50 ug/l</i>
<i>1,1,1 Trichloroethane</i>	<i>11 ug/l</i>	<i>Tetrachlorethylene</i>	<i>8.9 ug/l</i>
<i>Trichloroethylene</i>	<i>81 ug/l</i>		