

79 Elm Street • Hartford, CT 06106-5127

www.ct.gov/deep

Affirmative Action/Equal Opportunity Employer

MUNICIPAL NPDES PERMIT

issued to

Permittee: Town of Killingly Bruce Chimento, P.E. P.O. Box 6000 Danielson, CT 06239 **Location Address:** 31 Wauregan Road Danielson, CT 06239

Facility ID: 069-001

Permit ID: CT0101257

Permit Expires: May 9, 2017

Receiving Stream: Quinebaug River

Design Flow Rate: 8.0 MGD

SECTION 1: GENERAL PROVISIONS

- (A) This permit is reissued in accordance with Section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), and Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and Section 402(b) of the Clean Water Act, as amended, 33 USC 1251, et. seq., and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer a N.P.D.E.S. permit program.
- (B) The Town of Killingly ("permittee"), shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to Section 22a-430 of the CGS and are hereby incorporated into this permit. Your attention is especially drawn to the notification requirements of subsection (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) of Section 22a-430-3. To the extent this permit imposes conditions more stringent than those found in the regulations, this permit shall apply.

Section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty to Comply
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (I) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

Section 22a-430-4 Procedures and Criteria

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review
- (e) Tentative Determination

- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing
- (h) Public Comments
- (i) Final Determination
- (j) Public Hearings
- (k) Submission of Plans and Specifications. Approval.
- (I) Establishing Effluent Limitations and Conditions
- (m) Case-by-Case Determinations
- (n) Permit Issuance or Renewal
- (o) Permit or Application Transfer
- (p) Permit Revocation, Denial or Modification
- (q) Variances
- (r) Secondary Treatment Requirements
- (s) Treatment Requirements
- (t) Discharges to POTWs Prohibitions
- (C) Violations of any of the terms, conditions, or limitations contained in this permit may subject the permittee to enforcement action including, but not limited to, seeking penalties, injunctions and/or forfeitures pursuant to applicable sections of the CGS and RCSA.
- (D) Any false statement in any information submitted pursuant to this Section of the permit may be punishable as a criminal offense under Section 22a-438 or 22a-131a of the CGS or in accordance with Section 22a-6, under Section 53a-157b of the CGS.
- (E) The permittee shall comply with Section 22a-416-1 through Section 22a-416-10 of the RCSA concerning operator certification.
- (F) No provision of this permit and no action or inaction by the Commissioner shall be construed to constitute an assurance by the Commissioner that the actions taken by the permittee pursuant to this permit will result in compliance or prevent or abate pollution.
- (G) Nothing in this permit shall relieve the permittee of other obligations under applicable federal, state and local law.
- (H) An annual fee shall be paid for each year this permit is in effect as set forth in Section 22a-430-7 of the RCSA. As of October 1, 2009 the annual fee is \$ 2807.50.

SECTION 2: DEFINITIONS

- (A) The definitions of the terms used in this permit shall be the same as the definitions contained in Section 22a-423 of the CGS and Section 22a-430-3(a) and 22a-430-6 of the RCSA, except for "Composite" and "No Observable Acute Effect Level (NOAEL)" which are redefined below.
- (B) In addition to the above, the following definitions shall apply to this permit:

"-----" in the limits column on the monitoring tables in Attachment 1 means a limit is not specified but a value must be reported on the DMR, MOR and/or the ATMR.

"Annual" in the context of any sampling frequency, shall mean the sample must be collected in the months of July, August or September.

"Average Monthly Limit" means the maximum allowable "Average Monthly Concentration" as defined in Section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g. mg/l); otherwise, it means "Average Monthly Discharge Limitation" as defined in Section 22a-430-3(a) of the RCSA.

"Bi-Monthly" in the context of any sampling frequency, shall mean once every two months including the months of January, March, May, July, September, and November.

"Bi-Weekly" in the context of any sampling frequency, shall mean once every two weeks.

"**Composite**" or "(**C**)" means a sample consisting of a minimum of eight aliquot samples collected at equal intervals of no less than 30 minutes and no more than 60 minutes and combined proportionally to flow over the sampling period

provided that during the sampling period the peak hourly flow is experienced.

"Critical Test Concentration" or "(CTC)" means the specified effluent dilution at which the permittee is to conduct a single-concentration Aquatic Toxicity Test.

"Daily Composite" or "(DC)" means a composite sample taken over a full operating day consisting of grab samples collected at equal intervals of no more than sixty (60) minutes and combined proportionally to flow; or, a composite sample continuously collected over a full operating day proportionally to flow.

"Daily Concentration" means the concentration of a substance as measured in a daily composite sample, or, arithmetic average of all grab sample results defining a grab sample average.

"Daily Quantity" means the quantity of waste discharged during an operating day.

"Geometric Mean" is the "n"th root of the product of "n" observations.

"Infiltration" means water other than wastewater that enters a sewer system (including sewer system and foundation drains) from the ground through such means as defective pipes, pipe joints, connections, or manholes. Infiltration does not include, and is distinguished from, inflow.

"Inflow" means water other than wastewater that enters a sewer system (including sewer service connections) from sources such as, but not limited to, roof leaders, cellar drains, yard drains, area drains, drains from springs and swampy areas, cross connections between storm sewers and sanitary sewers, catch basins, cooling towers, storm waters, surface runoff, street wash waters, or drainage. Inflow does not include, and is distinguished from, infiltration.

"Instantaneous Limit" means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

"In-stream Waste Concentration" or "(IWC)" means the concentration of a discharge in the receiving water after mixing has occurred in the allocated zone of influence.

"MGD" means million gallons per day.

"Maximum Daily Limit" means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g. mg/l), otherwise, it means the maximum allowable "Daily Quantity" as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity it means "Maximum Daily Flow" as defined in Section 22a-430-3(a) of the RCSA.

"Monthly Minimum Removal Efficiency" means the minimum reduction in the pollutant parameter specified when the effluent average monthly concentration for that parameter is compared to the influent average monthly concentration.

"NA" as a Monitoring Table abbreviation means "not applicable".

"NR" as a Monitoring Table abbreviation means "not required".

"No Observable Acute Effect Level" or "(NOAEL)" means any concentration equal to or less than the critical test concentration in a single concentration (pass/fail) toxicity test, conducted pursuant to Section 22a-430-3(j)(7)(A)(i) of the RCSA, demonstrating 90% or greater survival of test organisms at the CTC.

"Quarterly" in the context of any sampling frequency, shall mean sampling is required in the months of January, April, July and October.

"Range During Sampling" or "(RDS)" as a sample type means the maximum and minimum of all values recorded as a result of analyzing each grab sample of; 1) a Composite Sample, or, 2) a Grab Sample Average. For those permittees with pH meters that provide continuous monitoring and recording, Range During Sampling means the maximum and minimum readings recorded with the continuous monitoring device during the Composite or Grab Sample Average sample collection.

"Range During Month" or "(RDM)" as a sample type means the lowest and the highest values of all of the monitoring data for the reporting month.

"Sanitary Sewage" means wastewaters from residential, commercial and industrial sources introduced by direct

connection to the sewerage collection system tributary to the treatment works including non-excessive inflow/infiltration sources.

"Twice per Month" in the context of any sampling frequency, mean two samples per calendar month collected no less than 12 days apart.

"ug/I" means micrograms per liter

"Work Day" in the context of a sampling frequency means, Monday through Friday excluding holidays.

SECTION 3: COMMISSIONER'S DECISION

- (A) The Commissioner of Energy and Environmental Protection ("Commissioner") has issued a final decision and found continuance of the existing system to treat the discharge will protect the waters of the state from pollution. The Commissioner's decision is based on application ##200601397 for permit reissuance received on April 20, 2006 and the administrative record established in the processing of that application.
- (B) The Commissioner hereby authorizes the Permittee to discharge in accordance with the provisions of this permit, the above referenced application, and all approvals issued by the Commissioner or his authorized agent for the discharges and/or activities authorized by, or associated with, this permit.
- (C) The Commissioner reserves the right to make appropriate revisions to the permit, if required after Public Notice, in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the CGS or regulations adopted thereunder, as amended. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

SECTION 4: GENERAL LIMITATIONS AND OTHER CONDITIONS

- (A) The Permittee shall not accept any new sources of non-domestic wastewater conveyed to its POTW through its sanitary sewerage system or by any means other than its sanitary sewage system unless the generator of such wastewater; (a) is authorized by a permit issued by the Commissioner under Section 22a-430 CGS (individual permit), or, (b) is authorized under Section 22a-430b (general permit), or, (c) has been issued an emergency or temporary authorization by the Commissioner under Section 22a-6k. All such non-domestic wastewaters shall be processed by the POTW via receiving facilities at a location and in a manner prescribed by the permittee which are designed to contain and control any unplanned releases.
- (B) No new discharge of domestic sewage from a single source to the POTW in excess of 50,000 gallons per day may be authorized by the permittee until the discharger has registered the discharge under the "General Permit for Domestic Sewage", as amended, pursuant to Section 22a-430b of the CGS.
- (C) The permittee shall maintain a system of user charges based on actual use sufficient to operate and maintain the POTW (including the collection system) and replace critical components.
- (D) The permittee shall maintain a sewer use ordinance that is consistent with the Model Sewer Ordinance for Connecticut Municipalities prepared by the Department of Energy and Environmental Protection. The Commissioner of Energy and Environmental Protection alone may authorize certain discharges which may not conform to the Model Sewer Ordinance.
- (E) No discharge shall contain or cause in the receiving stream a visible oil sheen, floating solids, visible discoloration, or foaming.
- (F) No discharge shall cause acute or chronic toxicity in the receiving water body beyond any Zone Of Influence (ZOI) specifically allocated to that discharge in this permit.
- (G) The permittee shall maintain an alternate power source adequate to provide full operation of all pump stations in the sewerage collection system and to provide a minimum of primary treatment and disinfection at the water pollution control facility to insure that no discharge of untreated wastewater will occur during a failure of a primary power source.
- (H) The average monthly effluent concentration shall not exceed 15% of the average monthly influent concentration for BOD₅ and Total Suspended Solids for all daily composite samples taken in any calendar month.

- (I) Any new or increased amount of sanitary sewage discharge to the sewer system is prohibited where it will cause a dry weather overflow or exacerbate an existing dry weather overflow.
- (J) Sludge Conditions
 - (1) The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices, including but not limited to 40 CFR Part 503.
 - (2) If an applicable management practice or numerical limitation for pollutants in sewage sludge more stringent than existing federal and state regulations is promulgated under Section 405(d) of the Clean Water Act (CWA), this permit shall be modified or revoked and reissued to conform to the promulgated regulations.
 - (3) The permittee shall give prior notice to the Commissioner of any change(s) planned in the permittees' sludge use or disposal practice. A change in the permittees' sludge use or disposal practice may be a cause for modification of the permit.
 - (4) Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.
- (K) This permit becomes effective on the 1st day of the month following the date of signature.
- (L) When the arithmetic mean of the average daily flow from the POTW for the previous 180 days exceeds 90% of the design flow rate, the permittee shall develop and submit within one year, for the review and approval of the Commissioner, a plan to accommodate future increases in flow to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (M) When the arithmetic mean of the average daily BOD_5 or TSS loading into the POTW for the previous 180 days exceeds 90% of the design load rate, the permittee shall develop and submit for the review of the Commissioner within one year, a plan to accommodate future increases in load to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (N) During the period beginning after the implementation of phosphorus removal but no later than 1095 days after permit issuance, lasting until expiration, the discharge shall not exceed the total phosphorus Average Seasonal Load as follows:

When the total phosphorus Average Seasonal Load in the effluent exceeds the permitted Average Seasonal Load Cap of 18.23 pounds of total phosphorus/day for any two consecutive calendar years or any two of three consecutive calendar years, the permittee shall develop and submit for the review any approval of the Commissioner a plan to reduce future Total Phosphorus in the effluent. This plan shall be submitted by September 30 of the year following the requirement of the report and upon approval of the plan by the Commissioner, the permittee shall implement the recommended improvement in accordance with the approved schedule.

- (O) On or before July 31st of each calendar year the main flow meter shall be calibrated by an independent contractor in accordance with the manufacturer's specifications. The actual record of the calibration shall be retained onsite and, upon request, the permittee shall submit to the Commissioner a copy of that record.
- (P) The permittee shall operate and maintain all processes as installed in accordance with the approved plans and specifications and as outlined in the associated operation and maintenance manual. This includes but is not limited to all recycle pumping systems, aeration equipment, aeration tank cycling, mixing equipment, anoxic basin, chemical feed systems, effluent filters or any other process equipment necessary for the optimal removal of pollutants. The permittee shall not bypass or fail to operate any of the approved process equipment without the written approval of the Commissioner.
- (Q) The permittee is hereby authorized to accept septage at the treatment facility; or other locations as approved by the Commissioner.
- (R) The temperature of any discharge shall not increase the temperature of the receiving stream above 85°F, or, in any case, raise the normal temperature of the receiving stream more than 4°F.

SECTION 5: SPECIFIC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- (A) The discharge(s) shall not exceed and shall otherwise conform to the specific terms and conditions listed in this permit. The discharge is restricted by, and shall be monitored in accordance with Tables A through G incorporated in this permit as Attachment 1.
- (B) The Permittee shall monitor the performance of the treatment process in accordance with the Monthly Operating Report (MOR) incorporated in this permit as Attachment 2.

SECTION 6: SAMPLE COLLECTION, HANDLING and ANALYTICAL TECHNIQUES

- (A) Chemical Analysis
 - (1) Chemical analyses to determine compliance with effluent limits and conditions established in this permit shall be performed using the methods approved pursuant to the Code of Federal Regulations, Part 136 of Title 40 (40 CFR 136) unless an alternative method has been approved in writing pursuant to 40 CFR 136.4 or as provided in Section 22a-430-3-(j)(7) of the RCSA. Chemicals which do not have methods of analysis defined in 40 CFR 136 or the RCSA shall be analyzed in accordance with methods specified in this permit.
 - (2) All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal, as defined in 40 CFR 136 unless otherwise specified.
 - (3) Grab samples shall be taken during the period of the day when the peak hourly flow is normally experienced.
 - (4) Samples collected for bacteriological examination shall be collected between the hours of 11 a.m. and 3 p.m. or at that time of day when the peak hourly flow is normally experienced. A chlorine residual sample must be taken at the same time and the results recorded.
 - (5) The Minimum Levels specified below represent the concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Attachment 1, Tables A and C. Analyses for these parameters must include check standards within ten percent of the specified Minimum Level or calibration points equal to or less than the specified Minimum Level.

Parameter	<u>Minimum Level</u>
Aluminum	0.050 mg/l
Antimony, Total	0.010 mg/l
Arsenic, Total	0.005 mg/l
Beryllium, Total	0.001 mg/l
Cadmium, Total	0.0005 mg/l
Chlorine, Total Residual	0.050 mg/l
Chromium, Total	0.005 mg/l
Chromium, Total Hexavalent	0.010 mg/l
Copper, Total	0.005 mg/l
Cyanide, Total	0.010 mg/l
Iron, Total	0.040 mg/l
Lead, Total	0.005 mg/l
Mercury, Total	0.0002 mg/l
Nickel, Total	0.005 mg/l
Selenium, Total	0.005 mg/l
Silver, Total	0.002 mg/l
Thallium, Total	0.005 mg/l
Zinc, Total	0.020 mg/l

- (6) The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible consistent with the requirements of this Section of the permit.
- (7) Effluent analyses for which quantification was verified during the analysis at or below the minimum levels specified in this Section and which indicate that a parameter was not detected shall be reported as "less than x" where 'x' is the numerical value equivalent to the analytical method detection limit for that analysis.
- (8) Results of effluent analyses which indicate that a parameter was not present at a concentration greater than or

equal to the Minimum Level specified for that analysis shall be considered equivalent to zero (0.0) for purposes of determining compliance with effluent limitations or conditions specified in this permit.

- (B) Acute Aquatic Toxicity Test
 - (1) Samples for monitoring of Acute Aquatic Toxicity shall be collected and handled as prescribed in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA-821-R-02-012).
 - (a) Composite samples shall be chilled as they are collected. Grab samples shall be chilled immediately following collection. Samples shall be held at 0 6°C until Acute Aquatic Toxicity testing is initiated.
 - (b) Effluent samples shall not be dechlorinated, filtered, or, modified in any way, prior to testing for Aquatic Toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility. Facilities with effluent dechlorination and/or filtration designed as part of the treatment process are not required to obtain approval from the Commissioner.
 - (c) Samples shall be taken after dechlorination for Acute Aquatic Toxicity unless otherwise approved in writing by the Commissioner for monitoring at this facility.
 - (d) Chemical analyses of the parameters identified in Attachment 1, Table C shall be conducted on an aliquot of the same sample tested for Acute Aquatic Toxicity.
 - (i) At a minimum, pH, specific conductance, total alkalinity, total hardness, and total residual chlorine shall be measured in the effluent sample and, during Acute Aquatic Toxicity tests, in the highest concentration of the test and in the dilution (control) water at the beginning of the test and at test termination. If total residual chlorine is not detected at test initiation, it does not need to be measured at test termination. Dissolved oxygen, pH, and temperature shall be measured in the control and all test concentrations at the beginning of the test, daily thereafter, and at test termination.
 - (e) Tests for Acute Aquatic Toxicity shall be initiated within 36 hours of sample collection.
 - (2) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (invertebrate) shall be conducted for 48 hours utilizing neonatal (less than 24 hours old) *Daphnia pulex.*
 - (3) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (vertebrate) shall be conducted for 48 hours utilizing larval (1 to 14-day old with no more than 24 hours range in age) *Pimephales promelas*.
 - (4) Tests for Acute Aquatic Toxicity shall be conducted as prescribed for static non-renewal acute tests in "Methods for measuring the Acute Aquatic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA/821-R-02-012), except as specified below.
 - (a) For Acute Aquatic Toxicity limits, and for monitoring only conditions, expressed as a NOAEL value, Pass/Fail (single concentration) tests shall be conducted at a specified Critical Test Concentration (CTC) equal to the Aquatic Toxicity limit, (100% in the case of monitoring only conditions), as prescribed in Section 22a-430-3(j)(7)(A)(i) of the RCSA.
 - (b) Organisms shall not be fed during the tests.
 - (c) Synthetic freshwater prepared with deionized water adjusted to a hardness of 50±5 mg/L as CaCO₃ shall be used as dilution water in the tests.
 - (d) Copper nitrate shall be used as the reference toxicant.
 - (5) For monitoring only conditions, toxicity shall be demonstrated when the results of a valid pass/fail Acute Aquatic Toxicity indicates less than 90% survival in the effluent at the CTC (100%).
- (C) Chronic Aquatic Toxicity Test for Freshwater Discharges
 - (1) Chronic Aquatic Toxicity testing of the discharge shall be conducted annually during July, August, or September of each year.

- (2) Chronic Aquatic Toxicity testing shall be performed on the discharge in accordance with the test methodology established in "Short-Term Methods for Estimating The Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms" (EPA-821-R-02-013) as referenced in 40 CFR 136 for *Ceriodaphnia* survival and reproduction and Fathead minnow larval survival and growth.
 - (a) Chronic Aquatic Toxicity tests shall utilize a minimum of five effluent dilutions prepared using a dilution factor of 0.5 (100% effluent, 50% effluent, 25% effluent, 12.5% effluent, 6.25% effluent).
 - (b) Quinebaug River water collected immediately upstream of the area influenced by the discharge shall be used as control (0% effluent) and dilution water in the toxicity tests.
 - (c) A laboratory water control consisting of synthetic freshwater prepared in accordance with EPA-821-R-02-013 at a hardness of 50±5 mg/l shall be used as an additional control (0% effluent) in the toxicity tests.
 - (d) Daily composite samples of the discharge (final effluent following disinfection) and grab samples of the Quinebaug river for use as site water control and dilution water, shall be collected on day 0 for test solution renewal on day 1 and day 2 of the test; day 2, for test solution renewal on day 3 and day 4 of the test; and day 4, for test solution renewal for the remainder of the test. Samples shall not be pH or hardness adjusted, or chemically altered in any way.
- (3) All samples of the discharge and Quinebaug River water used in the Chronic Aquatic Toxicity test shall, at a minimum, be analyzed and results reported in accordance with the provisions listed in Section 6(A) of this permit following the parameters listed in Table C included herein.

SECTION 7: RECORDING AND REPORTING REQUIREMENTS

(A) The results of chemical analyses and any aquatic toxicity test required above in Section 5 and the referenced Attachment 1 shall be entered on the Discharge Monitoring Report (DMR) and reported to the Bureau of Water Protection and Land Reuse. The report shall also include a detailed explanation of any violations of the limitations specified. The DMR must be received at the following address by the 15th day of the month following the month in which samples are collected.

> ATTN: Municipal Wastewater Monitoring Coordinator Connecticut Department of Energy and Environmental Protection Bureau of Water Protection and Land Reuse, Planning and Standards Division 79 Elm Street Hartford, Connecticut 06106-5127

- (1) For composite samples, from other than automatic samplers, the instantaneous flow and the time of each aliquot sample collection shall be recorded and maintained at the POTW.
- (B) Complete and accurate test data, including percent survival of test organisms in each replicate test chamber, LC_{50} values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test, shall be entered on the Aquatic Toxicity Monitoring Report form (ATMR) and sent to the Bureau of Water Protection and Land Reuse at the address specified above in Section 7 (A) of this permit by the 15th day of the month following the month in which samples are collected.
- (C) The results of the process monitoring required above in Section 5 shall be entered on the Monthly Operating Report (MOR) form included herein as Attachment 2, and reported to the Bureau of Water Protection and Land Reuse. The MOR report shall also be accompanied by a detailed explanation of any violations of the limitations specified. The MOR must be received at the address specified above in Section 7 (A) of this permit by the 15th day of the month following the month in which the data and samples are collected.
- (D) A complete and thorough report of the results of the chronic toxicity monitoring outlined in Section 6(C) shall be prepared as outlined in Section 10 of EPA-821-R-02-013 and submitted to the Department for review on or before December 31 of each calendar year to the address specified above in Section 7 (A) of this permit.
- (E) NetDMR Reporting Requirements
 - (1) Unless otherwise approved in writing by the Commissioner, no later than one-hundred and twenty (120) days after the issuance of this permit, the Permittee shall begin reporting to the Department electronically using NetDMR, a web-

based tool that allows Permittees to electronically submit discharge monitoring reports (DMRs) and other required reports through a secure internet connection. Specific requirements regarding subscription to NetDMR and submittal of data and reports in hard copy form and for submittal using NetDMR are described below:

(a) NetDMR Subscriber Agreement

On or before fifteen (15) days after the issuance of this permit, the Permittee and/or the person authorized to sign the Permittee's discharge monitoring reports ("Signatory Authority") as described in RCSA Section 22a-430-3(b)(2) shall contact the Department and initiate the subscription process for electronic submission of Discharge Monitoring Report (DMR) information. On or before ninety (90) days after issuance of this permit the Permittee shall submit a signed and notarized copy of the *Connecticut DEP NetDMR Subscriber Agreement* to the Department.

(b) Submittal of Reports Using NetDMR

Unless otherwise approved by the Commissioner, on or before one-hundred and twenty (120) days after issuance of this permit, the Permittee and/or the Signatory Authority shall electronically submit DMRs and reports required under this permit to the Department using NetDMR in satisfaction of the DMR submission requirement of this permit. DMRs shall be submitted electronically to the Department no later than the 15th day of the month following the completed reporting period.

(c) Submittal of NetDMR Opt-Out Requests

If the Permittee is able to demonstrate a reasonable basis, such as technical or administrative infeasibility, that precludes the use of NetDMR for electronically submitting DMRs and reports, the Commissioner may approve the submission of DMRs and other required reports in hard copy form ("opt-out request"). Opt-out requests must be submitted in writing to the Department for written approval on or before fifteen (15) days prior to the date a Permittee would be required under this permit to begin filing DMRs and other reports using NetDMR. This demonstration shall be valid for twelve (12) months from the date of the Department's approval and shall thereupon expire. At such time, DMRs and reports shall be submitted electronically to the Department using NetDMR unless the Permittee submits a renewed opt-out request and such request is approved by the Department.

All opt-out requests and requests for the NetDMR subscriber form should be sent to the following address:

Attn: NetDMR Coordinator Connecticut Department of Energy and Environmental Protection Water Permitting and Enforcement Division – 2nd Floor 79 Elm Street Hartford, CT 06106-5127

SECTION 8: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS, BYPASSES, MECHANICAL FAILURES, AND MONITORING EQUIPMENT FAILURES

- (A) If any Acute Aquatic Toxicity sample analysis indicates toxicity, or that the test was invalid, an additional sample of the effluent shall be collected and tested for Acute Aquatic Toxicity and associated chemical parameters, as described above in Section 5 and Section 6, and the results reported to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity) via the ATMR form (see Section 7 (B)) within 30 days of the previous test. These test results shall also be reported on the next month's DMR report pursuant to Section 7 (A). The results of all toxicity tests and associated chemical parameters, valid and invalid, shall be reported.
- (B) If any two consecutive Acute Aquatic Toxicity test results or any three Acute Aquatic Toxicity test results in a twelve month period indicates toxicity, the permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and shall submit a report, to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity), for the review and written approval of the Commissioner in accordance with Section 22a-430-3(j)(10)(c) of the RCSA describing proposed steps to eliminate the toxic impact of the discharge on the receiving water body. Such a report shall include a proposed time schedule to accomplish toxicity reduction and the permittee shall comply with any schedule approved by the Commissioner.
- (C) Section 22a-430-3(k) of the RCSA shall apply in all instances of bypass including a bypass of the treatment plant or a component of the sewage collection system planned during required maintenance. The Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal

Facilities Section (860) 424-3704, the Department of Public Health, Water Supply Section (860) 509-7333 and Recreation Section (860) 509-7297, and the local Director of Health shall be notified within 2 hours of the permittee learning of the event by telephone during normal business hours. If the discharge or bypass occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday), notification shall be made within 2 hours of the permittee learning of the event to the Emergency Response Unit at (860) 424-3338 and the Department of Public Health at (860) 509-8000. A written report shall be submitted to the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section within five days of the permittee learning of each occurrence, or potential occurrence, of a discharge or bypass of untreated or partially treated sewage.

The written report shall contain:

- (a) The nature and cause of the bypass, permit violation, treatment component failure, and/or equipment failure,
- (b) the time the incident occurred and the anticipated time which it is expected to continue or, if the condition has been corrected, the duration,
- (c) the estimated volume of the bypass or discharge of partially treated or raw sewage,
- (d) the steps being taken to reduce or minimize the effect on the receiving waters, and
- (e) the steps that will be taken to prevent reoccurrence of the condition in the future.
- (D) Section 22a-430-3(j) 11 (D) of the RCSA shall apply in the event of any noncompliance with a maximum daily limit and/or any noncompliance that is greater than two times any permit limit. The permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse Planning and Standards Division, Municipal Facilities Section except, if the noncompliance occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the permittee may wait to make the verbal report until 10:30 am of the next business day after learning of the noncompliance.
- (E) Section 22a-430-3(j) 8 of the RCSA shall apply in all instances of monitoring equipment failures that prevent meeting the requirements in this permit. In the event of any such failure of the monitoring equipment including, but not limited to, loss of refrigeration for an auto-sampler or lab refrigerator or loss of flow proportion sampling ability, the permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section except, if the failure occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the permittee may wait to make the verbal report until 10:30 am of the next business day after learning of the failure.
- (F) In addition to the reporting requirements contained in Section 22a-430-3(i), (j), and (k) of the Regulations of Connecticut State Agencies, the permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section concerning the failure of any major component of the treatment facilities which the permittee may have reason to believe would result in an effluent violation.

SECTION 9: COMPLIANCE SCHEDULE

- (A) The permittee shall achieve the final water quality-based effluent limits for **phosphorus** for DSN 001-1 established in Section 5 of this permit, in accordance with the following:
 - (a) On or before <u>120 days</u> after the date of issuance of this permit the permittee shall retain one or more qualified consultants acceptable to the Commissioner to prepare the documents and implement or oversee the actions required by this permit and shall, by that date, notify the Commissioner in writing of the identity of such consultant(s). The municipality shall retain one or more qualified consultants acceptable to the Commissioner until this permit is fully complied with, and, within ten days after retaining any consultant other than the one originally identified under this paragraph, the municipality shall notify the Commissioner in writing of the identity of such other consultant. The consultant(s) retained shall be a qualified professional engineer licensed to practice in Connecticut. The permittee shall submit to the Commissioner a description of a consultant's education, experience and training which is relevant to the work required by this permit within ten days after a request for such a description. Nothing in this paragraph shall preclude the Commissioner from finding a previously acceptable.
 - (b) On or before 270 days after the date of issuance of this permit, the permittee shall submit for the Commissioner's

review and written approval a comprehensive and thorough engineering report which describes and evaluates alternative actions which may be taken by permittee to achieve compliance with the Phosphorus limitations in Section 5 of this permit. Such report shall:

- (a) List all permits and approvals required for each alternative, including but not limited to any permits required under Sections 22a-32, 22a-42a, 22a-342, 22a-361, 22a-368 or 22a-430 of the CGS,
- (b) Propose a preferred alternative or combination of alternatives with supporting justification therefore,
- (c) State in detail the most expeditious schedule for performing each alternative, and
- (d) Propose a detailed program and schedule to perform all actions required to implement the preferred alternative, including but not limited to a schedule for submission of engineering plans and specifications for any new equipment, the start and completion of any construction activities and applying for and obtaining all permits and approvals required for such actions.
- (B) Unless another deadline is specified in writing by the Commissioner, on or before 150 days after approval of the engineering report, the permittee shall (1) submit for the Commissioner's review and written approval, contract plans and specifications for the approved remedial actions, a revised list of all permits and approvals required for such actions and a revised schedule for applying for and obtaining such permits and approvals; and (2) submit applications for all permits and approvals required under Sections 22a-430 and 22a-416 of the CGS. The permittee shall obtain all required permits and approvals.
- (C) The permittee shall submit to the Commissioner semi-annual status reports beginning <u>sixty</u> days after the date of approval of the report referenced in Section 9(A) above. Status reports shall include, but not be limited to, a detailed description of progress made by the permittee in performing actions required by this Section of the permit in accordance with the approved schedule including, but not limited to, development of engineering plans and specifications, construction activity, contract bidding, operational changes, preparation and submittal of permit applications, and any other actions specified in the program approved pursuant to paragraph 9(A) of this Section.
- (D) The permittee shall perform the approved actions in accordance with the approved schedule, but in no event shall the approved actions be completed later than <u>1095</u> days after the date of issuance of this permit. Within fifteen days after completing such actions, the permittee shall certify to the Commissioner in writing that the actions have been completed as approved.
- (E) The permittee shall use best efforts to submit to the Commissioner all documents required by this Section of the permit in a complete and approvable form. If the Commissioner notified the permittee that any document or other action is deficient, and does not approve it with conditions or modifications, it is deemed disapproved, and the permittee shall correct the deficiencies and resubmit it within the time specified by the Commissioner or, if no time is specified by the Commissioner, within thirty days of the Commissioner's notice of deficiencies. In approving any document or other action under this Compliance Schedule, the Commissioner may approve the document or other action as submitted or performed or with such conditions or modifications as the Commissioner deems necessary to carry out the purposes of this Section of the permit. Nothing in this paragraph shall excuse noncompliance or delay.
- (F) Dates. The date of submission to the Commissioner of any document required by this section of the permit shall be the date such document is received by the Commissioner. The date of any notice by the Commissioner under this section of the permit, including but not limited to notice of approval or disapproval of any document or other action, shall be the date such notice is personally delivered or the date three days after it is mailed by the Commissioner, whichever is earlier. Except as otherwise specified in this permit, the word "day" as used in this Section of the permit means calendar day. Any document or action which is required by this Section only of the permit, to be submitted, or performed, by a date which falls on, Saturday, Sunday, or, a Connecticut or federal holiday, shall be submitted or performed on or before the next day which is not a Saturday, Sunday, or Connecticut or federal holiday.
- (G) Notification of noncompliance. In the event that the permittee becomes aware that it did not or may not comply, or did not or may not comply on time, with any requirement of this Section of the permit or of any document required hereunder, the permittee shall immediately notify the Commissioner and shall take all reasonable steps to ensure that any noncompliance or delay is avoided or, if unavoidable, is minimized to the greatest extent possible. In so notifying the Commissioner, the permittee shall state in writing the reasons for the noncompliance or delay and propose, for the review and written approval of the Commissioner, dates by which compliance will be achieved, and the permittee shall comply with any dates which may be approved in writing by the Commissioner.

PERMIT # CT 0101257 PA

PAGE 11

Notification by the permittee shall not excuse noncompliance or delay, and the Commissioner's approval of any compliance dates proposed shall not excuse noncompliance or delay unless specifically so stated by the Commissioner in writing.

- (F) Notice to Commissioner of changes. Within fifteen days of the date the permittee becomes aware of a change in any information submitted to the Commissioner under this Section of the permit, or that any such information was inaccurate or misleading or that any relevant information was omitted, the permittee shall submit the correct or omitted information to the Commissioner.
- (G) <u>Submission of documents</u>. Any document, other than a DMR, ATMR or MOR required to be submitted to the Commissioner under this Section of the permit shall, unless otherwise specified in writing by the Commissioner, be directed to:

Carlos Esguerra, Sanitary Engineer Department of Energy and Environmental Protection Bureau of Water Protection and Land Reuse, Planning and Standards Division 79 Elm Street Hartford, Connecticut 06106-5127

This permit is hereby issued on: 5/10/2012

Betsey Wingfield Bureau Chief Bureau of Water Protection and Land Reuse

ATTACHMENT 1

Tables A through G

PERMIT # CT 0101257

PAGE 13

TABLE A

Discharge Serial Number (DSN): 001-1				4	fonitoring Locat	ion: 1				
Wastewater Description: Sanitary Sewage										
Monitoring Location Description: Final Eff	fluent									
Allocated Zone of Influence (ZOI): 63 cfs				In-stream W	aste Concentrat	on (IWC): 16.4	%			
		FLOW	TIME BAS	SED MONIT	ORING	INSTAI MON	NTANEOUS ITORING		REPORT FORM	Minimum Level
PARAMETER	n n N	Average Monthly Limit	Maximum Daily Limit	Sample Freq.	Sample type	Instantaneous Limit or Required Range ²	Sample Freq.	Sample Type		Analysis Section 6
Alkalinity	mg/l	NA	NA	NR	NA		Monthly	Grab	MOR	
Biochemical Oxygen Demand (5 day) See remark F	mg/l	30	50	3 per week	Daily Composite	NA	NR	NA	DMR/MOR	
Chlorine, Total Residual May 1 st through September 30 th . See remark A	mg/l	0.05 ³	0.10 ³	4/Work Day	Grab	0.20	4/ Work Day	Grab	DMR/MOR	*
Copper, Total ⁸	mg/l	NA	1	Monthly	Daily Composite	NA	NR	NA	MOR/DMR	*
Fecal coliform. May 1^{st} through September $30^{th} 4$	Colonies per100 ml	NA	NA	NR	NA '	see remarks (B) and (C) below	3 per week	Grab	DMR/MOR	
Escherichia coli May 1ª through September 30 ^{th 5}	Coloníes per100 ml	NA	NA	NR	NA	see remarks (D) and (E) below	3 per week	Grab	DMR/MOR	
Flow	MGD			Continuous	Daily flow	NA	NR	NA	DMR/MOR	
Nitrogen, Ammonia (total as N)	mg/l	NA		Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Nitrate (total as N)	mg/l	NA	1	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Nitrite (total as N)	mg/l	NA	*****	Monthly	Daily Composite	, NA	NR	NA	MOR	
Nitrogen, Total Kjeldahl	mg/l	NA		Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total	mg/l	NA		Monthly	Daily Composite	NA	NR	NA	MOR	
Oxygen, Dissolved	mg/l	NA	NA	NR	NA		Work Day	Grab	MOR	
Hq	S.U.	NA	NA	NR	NA	6-9	Wọrk Day	Grab	DMR/MOR	
Phosphate, Ortho	mg/l	NA		Monthly	Daily Composite	NA	NR	NA	MOR	
Phosphorus, Total April 1 st through October 31 ^{st 6} November 1 st through March 30 th	ng/l	1.09 NA	2.18	Weekly Monthly	Daily Composite	NA	NR	NA	DMR/MOR	
Phosphorus, Total April 1st through October 31st	Ibs/day		NA	Weekly	Daily Composite	NA	NR	NA	MOR	

PERMIT # CT 0101257

PAGE 14

Phosphorus, Total (Average Seasonal Load Cap) ⁷ October	lbs/day		NA	Weekly	Calculated	NA	NR	NA	DMR/MOR	
Solids, Settleable	ml/l	NA	NA	NR	NA		Work Day	Grab	MOR	
Solids, Total Suspended ¹ , See remark F	ngn	30	50	3 per week	Daily Composite	NA	NR	NA	DMR/MOR	
Temperature	4,	NA	NA	NR	AN		Work Day	Grab	MOR	
Turbidity	UTU	NA	NA	NR	NA	******	Work Day	Grab	MOR	
Footnotes:	-		TABLE	S A - CONDITI	SNO					
 The permittee shall record and report on the monthly on the discharge monitoring report, the average daily The instantaneous limits in this column are maximum 	operating repo y flow and max n limits.	rt the minimum, n imum daily flow 1	naximum and to for each sampli	otal flow for eaching month.	h day of discharge and	the average daily	flow for each s	ampling mo	nth. The permittee sh	ll report,
3 The Maximum Daily Concentration to be reported sh mathematically averaging the results of the Maximum l	all be determin Daily Concentr	led by mathematic ations required ab	ally averaging ove.	the results of the	tour grab samples req	uired above. The	Average Month	lly Concentr	ration shall be determi	led by
⁴ During the period beginning at the date of issuance or otherwise conform to specific terms and conditions list	f this permit an ed	d lasting until the	implementation	n of Escherichia	coli monitoring at the	Water Pollution C	Control Facility,	the discharg	ge shall not exceed and	shall
5 During the period beginning after the implementation conform to the specific terms and conditions listed. Up	a of Escherichia on the impleme	a coli monitoring, entation of Escheri	but no later tha ichia Coli moni	n 730 days after ttoring, the perm	permit issuance, lastir ittee shall discontinue	ig until expiration fecal coliform mo	, the discharge s mitoring.	hall also not	t exceed and shall othe	rwise
6 During the period beginning after the implementation to the specific terms and conditions listed.	n of phosphoru	s removal but no l	ater than 1095	days after permi	t issuance, lasting unti	l expiration, the d	ischarge shall al	so not excee	ed and shall otherwise	conform
⁷ Compliance with the Average Seasonal Load Cap of (the current monthly average) and averaging it with the exceeds the permitted Average Seasonal Load Cap of 1 for the review and approval of the Commissioner a plan approval of the plan by the Commissioner, the permitte	[18.23 pounds] monthly avera [8.23 pounds of n to reduce futu e shall implem	per day is determi- ges from the prev f total phosphorus. ure total phosphoru ent the recommen	ned as follows: ious months du day for any tw as in the effluer ded improveme	 Calculating the rring the April 1s o consecutive ca at. This plan sha at in accordance 	he Average Seasonal I to through October 31s lendar years or any tw ill be submitted by Sep e with the approved sci	oad by taking the t season. 2. When o of three consecu- tember 30 of the hedule	average of the c the total phosph utive calendar ye year following th	current mon lorus Avera; ars, the peri ar requirem	ths' samples in pounds ge Seasonal Load in th mittee shall develop at ent of the report and u	per day e effluent d submit oon
⁸ During the period beginning at the date of issuance or of the 2-year monitoring period, the Commissioner will completion of said evaluation, the Commissioner will p comprehensive engineering report and a project schedu until the expiration of the permit as indicated in Table (f this permit an I evaluate the <i>n</i> provide the perr ule necessary to C below.	d lasting for two y nonitoring results nittee with revised achieve complian	cears, the permi to confirm or n a monitoring gu the with said lin	ittee shall monituate out the need in the need indance and requirates. If no perminities is the network of the	or the effluent in accor- for permanent limits. S irements that may incl anent limits are necess	dance with the sp should permanent ude but not limite ary, the permittee	ecific terms and limits be deeme d to the submiss shall continue to	conditions l d necessary ion of an in conduct he	listed above. Upon con and within 30 days af -system mass balance cavy metals monitorin	upletion er the study, a stating
 <u>Remarks:</u> (A) The use of chlorine for disinfection and sodium bis no earlier than April 15th, and any residual chlorine gate effluent shall not be greater than 0.2 mg/l, as an instant B) The geometric mean of the Fecal coliform bacteria v 100 milliliters. C) The geometric mean of the Fecal coliform bacteria v 100 milliliters. 	sulfite for dechl s or liquid and s ancous limit, au values for the e values for the e	orination shall be sodium bisulfite <i>n</i> nd 0.1 mg/l, as a <i>n</i> ffluent samples co ffluent samples co	discontinued ff nay be used up naximum daily ollected in a per ollected in a per	om October 1 st t until, but no late limit. The analy iod of thirty (30) iod of seven (7)	hrough April 30 th exco r than, October 15 th . D tical results shall be re consecutive days dur consecutive days duri	ept that chlorinati uring these times ported on the MC ing the period fron ag the period from	in April and Octionin R for the month m May 1 st throug 1 May 1 st throug	ation equip tober the tot is of April a gh Septembe h Septembe	ment may be started at al residual chlorine of ind October. er 30 th shall not exceed r 30 th shall not exceed	dd tested the 200 per 400 per

PAGE 15

•

	(continued):
	marks

Remarks (continued): D) The geometric mean of the Escherichia coli bacteria values for the effluent samples collected in a period of seven (7) consecutive days during the period from May 1st through September 30th shall not exceed 126 per 100 milliliters E) The amount of the Escherichia coli bacteria for any single effluent sample collected during the period from May 1st through September 30th shall not exceed 126

F) The Average Weekly discharge Limitation for BODs and Total Suspended Solids shall be 1.5 times the Average Monthly Limit listed above.

TABLE B

Discharge Serial Number (DSN): 001-1		Monitoring	Location: K		
Wastewater Description: Sanitary Sewage					
Monitoring Location Description: Final Effluent					
Allocated Zone of Influence (ZOI): 63 cfs	In	-stream Waste C	oncentration ((IWC): 16.4	%
		FLOW/TIM	E BASED MON	ITORING	
PARAMETERS	Units	Monthly Average Minimum	Sample Freq	Sample Type	REPORT FORM
Biochemical Oxygen Demand (5 day) Percent Removal ¹	%	85	3 per Week	Calculated ²	DMR/MOR
Solids, Total Suspended Percent Removal ¹	%	85	3 per Week	Calculated ²	DMR/MOR
TAB Footnotes:	LE B – CONDIT	TIONS			

¹ The discharge shall be less than 15% of the average monthly influent BOD₅ and suspended solids. ² Calculated based on the average monthly results described in Table A. Removal efficiency = ((Inf. (BOD or TSS) - Eff. (BOD or TSS)) / Inf. (BOD or TSS)) X 100

PERMIT # CT 0101257

TABLE C

Monitoring Location: T

Discharge Serial Number (DSN): 001-1

Wastewater Description: Sanitary Sewage

Monitoring Location Description: Final I	Cffluent aft	er dechlorination	facilities			
Allocated Zone of Influence (ZOI): 63 cfs			In-stream Wast	e Concentration (IWC)	: 16.4 %	
PARAMETER	Units	Maximum Daily Limit	Sampling Frequency	Sample Type	Reporting form	Minimum Level Analysis See Section 6
Aluminum, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Antimony, Total	mg/l		Quarterly	Daily Composite	ATMR	*
NOAEL Static 48Hr Acute D. Pulex ¹	% survival		Quarterly	Daily Composite	ATMR/DMR	
NOAEL Static 48Hr Acute Pimephales ¹	% survival		Quarterly	Daily Composite	ATMR/DMR	
Arsenic, Total	mg/l	E13512	Quarterly	Daily Composite	ATMR	*
Beryllium, Total	mg/i		Quarterly	Daily Composite	ATMR	*
BOD₅	mg/l	UN IN IN 101-10. AD	Quarterly	Daily Composite	ATMR	
Cadmium, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Chromium, Hexavalent	mg/l		Quarterly	Daily Composite	ATMR	×
Chromium, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Chlorine, Total Residual	mg/l	*****	Quarterly	Daily Composite	ATMR	*
Copper, Total ²	mg/l -		Quarterly	Daily Composite	ATMR	*
Cyanide, Amenable	mg/l		Quarterly	Daily Composite	ATMR	
Cyanide, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Iron, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Lead, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Mercury, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Nickel, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Nitrogen, Ammonia (total as N)	mg/l		Quarterly	Daily Composite	ATMR	*
Nitrogen, Nitrate, (total as N)	mg/l		Quarterly	Daily Composite	ATMR	
Nitrogen, Nitrite, (total as N)	mg/l		Quarterly	Daily Composite	ATMR	
Phenois, Total	mg/l		Quarterly	Daily Composite	ATMR	
Phosphorus, Total	Mg/l		Quarterly	Daily Composite	ATMR	
Selenium, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Silver, Total	mg/l		Quarterly	Daily Composite	ATMR	*
Suspended Solids, Total	mg/l		Quarterly	Daily Composite	ATMR	
Thallium, Total	mg/l	~	Quarterly	Daily Composite	ATMR	*
Zine, Total	mg/l		Quarterly	Daily Composite	ATMR	*

TABLE C - CONDITIONS

Remarks:¹ The results of the Toxicity Tests are recorded in % survival. The permittee shall report <u>% survival</u> on the DMR based on criteria in Section 6(B) of this permit.

²See table A, footnote 9.

ATMR – Aquatic Toxicity Monitoring Report

TABLE D

Discharge Serial Number: 001-1	Mor	nitoring Lo	cation: N		
Wastewater Description: Activat	ed Sludge				
Monitoring Location Description:	Each Aeration Unit			*******	**********
	REPÓRTING FOR	MAT	INSTANTANI	OUS MONITORING	REPORTING
PARAMETER			Sample Frequency	Sample Type	FORM
Oxygen, Dissolved	High & low for each W	VorkDay	4/WorkDay	Grab	MOR
Sludge Volume Index	WorkDay		WorkDay	Grab	MOR
Mixed Liquor Suspended Solids	WorkDay		WorkDay	Grab	MOR

TABLE E

Discharge Serial Number: 001-1		Mor	itoring Location: G				:
Wastewater Description: Sanitary Sewa	ge						
Monitoring Location Description: Influe	nt						
PARAMETER	Units	DMR REPORTING	FLOW/I MON	IME BASED ITORING	INSTANTA MONITC	NEOUS DRING	REPORTING FORM
		FORMAT	Sample Frequency	Sample Type	Sample Frequency	Sample Type	
Biochemical Oxygen Demand (5 day)	mg/l	Monthly average	3 per week	Daily Composite	NA	NA	DMR/MOR
Nitrogen, Ammonia (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrate (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrite (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total Kjeldahl	mg/i		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total	mg/l		Monthly	Daily Composite	NA	NA	MOR
Phosphate, Ortho	mg/l		Monthly	Daily Composite	NA	NA	MOR
Phosphorus, Total	mg/l		Monthly	Daily Composite	NA	NA	MOR
pH	S.U.		NA	NA	Work Day	Grab	MOR
Solids, Total Suspended	mg/l	Monthly average	3 per week	Daily Composite	NA	NA	DMR/MOR
Temperature	٩F		NA	NA	Work Day	Grab	MOR

TABLE F Discharge Serial Number: 001-1 Monitoring Location: P Wastewater Description: Primary Effluent Monitoring Location Description: Primary Sedimentation Basin Effluent INSTANTANEOUS MONITORING REPORTING TIME/FLOW BASED REPORTING MONITORING FORM FORMAT PARAMETER . Units Sample Sample Sample Sample type Frequency Frequency Туре Alkalinity, Total mg/l NA NA Monthly Grab MOR Biochemical Oxygen Demand (5 day) Monthly average Weekly NA NA MOR mg/i Composite Nitrogen, Ammonia (total as N) Monthly Composite NA NA MOR mg/l Nitrogen, Nitrate (total as N) mg/l Monthly Composite NA NA MOR Nitrogen, Nitrite (total as N) mg/l Monthly Composite NA NA MOR Nitrogen, Total Kjeldahl mg/l Monthly Composite NA NA MOR Nitrogen, Total Monthly Composite NA NA MOR mg/l pН S.U. NA NA Monthly Grab MOR Solids, Total Suspended NA NA mg/l Monthly average Weekly Composite MOR

Discharge Serial Number: 001-1 Monitoring Location: SL Wastewater Description: Dewatered sludge Monitoring Location Description: Dewatered sludge INSTANTANEOUS MONITORING **REPORTING FORM** PARAMETER Units Grab Sample Freq. Arsenic, Total mg/kg **Bi-monthly** DMR Beryllium, Total mg/kg **Bi-monthly** DMR Cadmium, Total mg/kg **Bi-monthly** DMR Chromium, Total mg/kg Bi-monthly DMR Copper, Total mg/kg Bi-monthly DMR Lead, Total mg/kg Bi-monthly DMR Mercury, Total mg/kg Bi-monthly DMR Nickel, Total mg/kg Bi-monthly DMR Nitrogen, Ammonia * Bi-monthly DMR* mg/kg Nitrogen, Nitrate (total as N) * **Bi-monthly** DMR* mg/kg Nitrogen, Organic * mg/kg Bi-monthly DMR* Nitrogen, Nitrite (total as N) * Bi-monthly DMR* mg/kg Nitrogen, Total * mg/kg **Bi-monthly** DMR* pH * S.U. DMR* Bi-monthly Polychlorinated Biphenyls mg/kg Bi-monthly DMR Solids, Fixed % Bi-monthly DMR Solids, Total % **Bi-monthly** DMR Solids, Volatile % Bi-monthly DMR Zinc, Total Bi-monthly DMR mg/kg

TABLE G

(*) required for composting or land application only

Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.

ATTACHMENT 2

MONTHLY OPERATING REPORT FORM

Facility: 31 Wauregan Road Town: Kiliingly Sample month: 069-001 Page 1 of 3 of MOR for permit #

CT0101257

Chief Plant Operator: Glen M. Tatro Phone: 860-779-5392 Permit expiration date:

Please return forms to: DEEP - BWPLR Municipal Facilities 79 Elm Street Hartford, CT 06105-5127

Date received: (stamped)

ſ		71	indus	gal	ay																					Τ	Τ			Τ						٦		
	Waste	accepter	septic	gai	work di											T																			T	T	T	
	ds	\uparrow	out	╡	~																					+	\uparrow					-			-+-	╡	╈	
	Dry sol	-		sqi	work di																														-+-	+		
ŀ	Vaste	edbu		bs	work					-		_			_																		-+			╉	╉	-
	~ ~	8	%	lids					_											\neg							-	_	-		-+	-+		╉		+	+	
	Retur	sludg	%	low so	work c														_								-	-	-	-	_				+	╉	╉	-
ľ	rickling	Filter	%	tum tum	work	den den																															1	
ł		M	0.0	2							_		_				_														_	-				+	-	-
	ank #4	high	D.O.	l/gm	yet .																																	
	ation T		SVI	-1	work o																																	
	Aer		MLSS																												1							
		wo	0.0																																			
	ank #3	high	D.O.	/om	A																															T		
	ation		Š		work d									_																								
	Aen		MLSS																																			
ĺ		No	0.0																																			
	irk #2	high	<u>0.0</u>	16m	ау																																	
	ation Ta		SVI		work da																																	
Π	Aera		MLSS																																			
		low	D.O.																																			
	Fank #1	high	D.O.		day																																	
	ration	1	SVI		work		 																															
R	Ae		MLSS																																			
nsocket,	0		M	bs.	-																																	
i, Woo	y Sludg		%	solids	rork da																							·										_
e & Liquic	Prìmar		Vol.	gal.	>																																	
ion: Cak			Total			1																																_
al Locat	tily Flow		Min.	MGD	đaily																																	
e Dispos	Õ		Max.																																			
Sludg		_		Units	Freq	1	1 7	3	4	5	6	7	8	6	6	11	12	13	14	15	16	17	18	19	8	21	22	23	24	25	26	27	28	29	8	33	Total	Аче

CT0101257 31 Wauregan Road Killingly Dage 2 of 3 MOR for permit # Sample month: Facility: Town:

Chief Plant Operator. Glen M. Tatro Phone: 860-779-5392 Permit expiration date:

Please return forms to:

DEEP - BWPLR Municipal Facilities 79 Elm Street Hartford, CT 06106-5127

Total P 2		EK.	p/q	April -	October																												
		Eff.	hgm	Monthly	Nov-March																												
Total P		Eff.	1/6m	Weekly	April-Oct																											 _	
		Inf.	lygm	monthly	NovMarch																												-
Temp.		Eff.	÷	Jay																													re [
		Inf.		work	-																												Insert he
H	-	Eff Eff.	ŝ.U.	thly work	day	 	 																			 		 				 	
		Inf. Prin	0,	vork mon	day		 			 																 							
richia			T	er	sk	 									<u>.</u>																		lge(lb/d):
Escher	රි		#/100	e e	Wee	 																				 							oad Avera
Fecal	Coliform		#/100 ml	3 per	week																												Seasonal Lo
eu	lai	łow	V	ž																													sphorus
e Chlor	Resid	hột	ů I	4/wc	đa	 		-		 																							the Pho
Chlorin	Dose		s – mg	Daily		 	 			 												ļ				 		 					calculate
dity.				÷	N N	 														. 						 							ober to c
Turbi		ũ	Z	0M	ę,													-								 				<u> </u>			ugh Oct
Settleable	Solids		Шш	work	day	 																											April thro
ijds	Final	Ēff.		3 per	week																												nonths of
ended So	Prim.	Eff.	убш	weekly		 												-		ļ													b/ch: 18
Suspi	Inf.			3 per	week	 									_				Ļ							 				 			data fro
	Final	Eff		3 per	week	 	 								-	ļ		 		ļ			<u> </u>						 	ļ	ļ		sphorus ad Cap
)D (5-day	Rough	Filter	1/6		Weekly	 	 								_		-												ļ	ļ		L	ble pho:
80	Prim.	Eff.	e		weekly								****	*****																			II availa orus Sea
	μ			3 per	week	 																											² Use a

÷ 5

Municipal Facilities 79 Elm Street Hartford, CT 06106-5127				Please return forms to:	DEP + BVVM	Municipal Facilities	79 Elm Street	Hartford, CT 06106-5127	Statement of Acknowledgement	-	I certify under penalty of law that this document	and all attachments were prepared under my	direction or supervision in accordance with a	system designed to assure that qualified	personnel properly gather and evaluate the	Information submitted. Based on my inquiry	of the person or persons who manage the	system, or those persons directly responsible	for gathering the information, the information	submitted is, to the best of my knowledge and	belief, true, accurate, and complete. I am aware	that there are significant penalties for submitting	false information including the possibility of fine	and imprisonment for knowing violations.	Authorized Official: Glen M. Tatro, United Water	Title: Project Manager		Signature:		Date:		
	Lowest	-0.0	ng/	Work																												
-	Total N	#3	mg/l	kjupou																												
	Total N	D4 C#	mol	monthly																							-				T	
	Total N	ž	mg/l	monthly																												
-779-5392 ation date:	TKN	ង រ	mg/l	monthly																												
Phone: 860 Permit expir	TKN	34 1 1 1 1	mg/i	monthly																·												
۰	TKN	7	'm"	monthly																									`			
	Nitrite	Nitrate	mg/i	monthly																												
	Nitrite	Nitrate Da cue	mg/l	monthly																												
	Nitrite	Nitrate		monthly																												
CT0101257	Ammonia		ugh ngh	monthly																												
Killingly 069-001 sermit #	Ammonia	3 	ug/	monthly	****						****			*****																		
nonth: (3 MOR for J	Ammonia		muen	monthly																												
Town: Sample r Page 3 o	Copper 1	Monthly	ся. mg/l	monthiy																												_
	<u>}</u>	1	uge L	Ą																												
	Alkafi			щощ																												
	60		mQN	thly																					 							
	Orth		in line	nom																												

Please return forms to: DEEP - BWPLR

Chief Plant Operator: Glen M. Tatro

31 Wauregan Road

Facility:

See footnote # 9 in table A of permit

·