

**AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the “CWA”, and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Boston Sand and Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114**

is authorized to discharge from a facility located at

**500 Front Street
Charlestown, MA 02129**

to receiving a water named

Unnamed Tributary to the Charles River (“Millers River”, Outfall 001)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the first day of the calendar month following sixty days after signature.

This permit and the authorization to discharge expire at midnight, five years from the last day of the month preceding the effective date.

This permit supersedes the permit issued on September 28, 2007.

This permit consists of Part I including effluent limitations and monitoring requirements, Attachments A (USEPA Region 1 Freshwater Acute Toxicity Procedure and Protocol) and B (USEPA Region 1 Freshwater Chronic Toxicity Procedure and Protocol), and Part II, the Standard Conditions.

Signed this 6th day of September , 2019

/S/SIGNATURE ON FILE

Ken Moraff, Director
Water Division
Environmental Protection Agency
Boston, MA

/S/SIGNATURE ON FILE

Lealdon Langley, Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge treated process water and stormwater through **Outfall Serial Number 001** to the Unnamed Tributary to the Charles River (“Millers River”)^{1,2}.

Effluent characteristic	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Flow	GPD	Report	Report	Continuous	Recorder
pH ⁵	S.U.	--	6.5 to 8.3	1/Month	Grab
Total Suspended Solids (TSS)	mg/L	20	45	1/Month	Grab
Turbidity	NTU	25	Report	1/Month	Grab
Total Sulfate	mg/L	250	Report	1/Quarter	Grab
Oil & Grease	mg/L	--	15	1/Month	Grab
Total Recoverable Copper ⁶	µg/L	--	29	1/Month	Grab
Dissolved Chromium (VI) ⁶	µg/L	--	16	1/Month	Grab
Total Recoverable Chromium	µg/L	--	Report	1/Month	Grab
Total Recoverable ⁶ Aluminum	µg/L	--	750	1/Month	Grab
Total Phosphorus	mg/L	--	Report	1/Quarter	Grab
<i>E. Coli</i>	cfu/100mL	--	Report	1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity (WET) Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁷⁻¹⁰	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Acute LC50 ⁶	%	LC50 ≥ 100%		1/Quarter	Grab
Chronic C-NOEC ⁶	%	NOEC ≥ 100%		1/Quarter	Grab
<i>Effluent Chemistry</i>					
Hardness	mg/L	Report		1/Quarter	Grab
pH	S.U.	Report		1/Quarter	Grab
Total Ammonia Nitrogen	µg/L	Report		1/Quarter	Grab
Total Residual Chlorine	µg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	µg/L	Report		1/Quarter	Grab
Total Recoverable Lead	µg/L	Report		1/Quarter	Grab
Total Recoverable Copper	µg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	µg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	µg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	µg/L	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁷⁻¹⁰	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Receiving Water Chemistry					
Hardness	mg/L	Report		1/Quarter	Grab
Total Organic Carbon	µg/L	Report		1/Quarter	Grab
Total Ammonia Nitrogen	µg/L	Report		1/Quarter	Grab
Total Residual Chlorine	µg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	µg/L	Report		1/Quarter	Grab
Total Recoverable Lead	µg/L	Report		1/Quarter	Grab
Total Recoverable Copper	µg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	µg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	µg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	µg/L	Report		1/Quarter	Grab
pH ¹¹	S.U.	Report		1/Quarter	Grab
Temperature ¹¹	°C	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.**Footnotes for monitoring at Outfall 001:**

1. Such discharge shall: 1) be limited and monitored by the permittee as specified below; and 2) not cause a violation of the State Surface Water Quality Standards (314 CMR 4.00) of the receiving water.
2. Effluent samples shall be representative of the discharge and shall be taken from Lagoon 9, as close as practicable to the overflow, during the discharge of effluent to the designated receiving water. Changes in sampling location must be approved in writing by the U.S. Environmental Protection Agency (EPA). Sampling discharges from the facility must yield data representative of the discharge under authority of CWA Section 308(a) and in accordance with 40 Code of Federal Regulations (C.F.R.) §122.41(j), §122.44(i), and §122.48. Samples shall be taken when discharging. During months when no tests are performed or required, NODI (no discharge) code 9 shall be entered for that month.
3. In accordance with 40 C.F.R. §122.44(i)(1)(iv), the permittee shall use sufficiently sensitive test procedures (i.e., methods) approved under 40 C.F.R. Part 136 or required under 40 C.F.R. Chapter I, Subchapter N or O, for the analysis of pollutants or pollutant parameters limited in this permit (except for WET limits). A method is considered “sufficiently sensitive” when either: (1) the method minimum level (ML) is at or below the level of the effluent limit established in this permit for the measured pollutant or pollutant parameter; or (2) the method has the lowest ML of the analytical methods approved under 40 C.F.R. Part 136 or required under 40 C.F.R. Chapter I, Subchapter N or O for the measured pollutant or pollutant parameter. The ML is not the minimum level of detection, but rather the lowest level at which the test equipment produces a recognizable signal and acceptable calibration point for a pollutant or pollutant parameter, representative of the lowest concentration at which a pollutant or pollutant parameter can be measured with a known level of confidence. For the purposes of this permit, the detection limit is the lowest concentration that can be reliably measured within specified limits of precision and accuracy for a specific laboratory analytical method during routine laboratory operating conditions (i.e., the level above which an actual value is reported for an analyte, and the level below which an analyte is reported as non-detect).
4. Sampling frequency of once per month is defined as the sampling of one (1) discharge event in each calendar month, when discharge occurs. Sampling frequency of 1/quarter is defined as the sampling of four (4) discharge events in each calendar year, when discharge occurs. Quarters are defined as the interval of time between the months of: January through March, inclusive; April through June, inclusive; July through September, inclusive; and October through December, inclusive. Quarterly sampling shall be performed concurrently with the monthly monitoring event. The permittee shall submit the results to EPA of any additional testing done to that required herein, if it is conducted in accordance with EPA approved methods consistent with the provisions of 40 C.F.R. §122.41(l)(4)(ii).
5. Requirement for State Certification. The pH of the effluent shall not be less than 6.5 standard units (SU), nor greater than 8.3 SU at any time, unless these values are exceeded due to natural causes. The pH shall be no more than 0.5 units outside the natural background range. For purposes of this permit, the permittee may, when discharging, measure the pH in the receiving water downstream of the facility at locations that are representative of the downstream condition

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

representative of the discharge mixed with the receiving water and the pH of all applicable sources water (e.g., stormwater and tap water). The permittee may use these measurements to demonstrate that the facility's discharge is not affecting the pH of the receiving water and/or to demonstrate compliance with state water quality standards. The downstream pH, and the discharge pH shall be measured on the same day, and source water pH conditions measured within 30 days. Receiving water pH sampling conditions and results shall be submitted as an attachment with the DMR."

6. See compliance schedule for chromium (VI), copper, aluminum, and Whole Effluent Toxicity in Part I.D.
7. WET test samples shall be collected quarterly during the months of January, April, July, and October. The test results shall be submitted by the last day of the month following the completion of the test. The permittee shall conduct acute and chronic WET tests specified in the WET test protocols can be found in Attachments A and B of the permit. The permittee shall test the daphnid, *Ceriodaphnia dubia*.
8. LC50 (lethal concentration to 50 percent) is the concentration of wastewater causing mortality to 50% of the test organisms. The C-NOEC (chronic no observed effect concentration) is the highest effluent concentration at which there is no statistically-significant adverse effect on the survival of the test organisms when compared with the diluent control survival at the time of observation.
9. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall either follow procedures outlined in Attachment A (Toxicity Test Procedure and Protocol) Section IV., DILUTION WATER in order to obtain an individual approval for use of an alternate dilution water, or the permittee shall follow the Self-Implementing Alternative Dilution Water Guidance, which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water (see page 4 in <https://www3.epa.gov/region1/npdes/permits/generic/Alternatedilutionwaterguidance.pdf>).
10. The permittee shall conduct the analyses specified in Attachments A and B, Part VI. CHEMICAL ANALYSIS, of this permit. Even where an alternate dilution water is permitted, the receiving water control (0% effluent) must still be analyzed. MLs and methods are specified in Attachments A and B, Part VI: CHEMICAL ANALYSIS. Sampling for any parameter required for WET may be used to satisfy any duplicative sampling required for that parameter in this permit, so long as the sampling requirement for WET is equivalent with the sampling requirements otherwise established for that parameter in this permit.
11. A pH and temperature measurement shall be taken of each receiving water sample at the time of collection and the results reported on the appropriate DMR. These pH and temperature measurements are independent from any pH and temperature measurements required by the WET testing protocols.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

2. The discharge shall not cause a violation of the water quality standards of the receiving waters.
3. The pH of the effluent shall not be less than 6.5 or greater than 8.3 at any time.
4. The discharge shall not cause objectionable discoloration of the receiving waters.
5. The effluent shall not contain a visible oil sheen, foam, or floating solids at any time.
6. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
7. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.
8. All existing manufacturing, commercial, mining and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge, on a routine basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. One hundred micrograms per liter (100 µg/l);
 - ii. Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 C.F.R. §122.21(g)(7); or
 - iv. Any other notification level established by the Director in accordance with 40 C.F.R. §122.44(f).
 - b. That any activity has occurred or will occur which would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. Five hundred micrograms per liter (500 µg/l);
 - ii. One milligram per liter (1 mg/l) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 C.F.R. §122.21(g)(7).
 - iv. Any other notification level established by the Director in accordance with 40 C.F.R. §122.44(f).

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

c. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the permit application.

9. The results of sampling for any parameter done in accordance with EPA approved methods above its required frequency must also be reported in accordance with 40 C.F.R. §122.41(l)(4)(ii).

PART I.B. STORMWATER POLLUTION PREVENTION PLAN

1. The permittee shall maintain a Stormwater Pollution Prevention Plan (SWPPP) designed to reduce, or prevent, the discharge of pollutants in stormwater to the receiving waters identified in this permit. The SWPPP shall be a written document and consistent with the terms of this permit. The permittee shall comply with the terms of its SWPPP.

2. The SWPPP, including the SWPPP site map, shall be updated and signed by the permittee within ninety (90) days after the effective date of this permit. The permittee shall certify that the SWPPP has been completed or updated and that it meets the requirements of the permit. The certification shall be signed in accordance with the requirements identified in 40 C.F.R. §122.22. A copy of this certification and a hardcopy of the SWPPP shall be sent to EPA and MassDEP within thirty (30) days after the certification date.

3. The SWPPP shall be consistent with the general provisions for SWPPPs included in the most current version of the Multi-Sector General Permit for Stormwater Discharges Associated with Industrial Activities (MSGP). (The current MSGP was effective June 4, 2015 – see https://www.epa.gov/sites/production/files/2015-10/documents/msgp2015_finalpermit.pdf). However, where any provision that applies to outfalls authorized under this permit differs from the requirements of a SWPPP prepared to meet the requirements of the MSGP, the requirements in this permit shall take precedence.

4. The SWPPP shall be prepared in accordance with good engineering practices, identify potential sources of pollution that may reasonably be expected to affect the quality of the stormwater discharges, and describe and ensure implementation of practices which will be used to reduce the pollutants and assure compliance with this permit. Specifically, the SWPPP shall contain the elements listed below:

a. A pollution prevention team responsible for developing, implementing, maintaining, revising and ensuring compliance with the SWPPP.

b. A site description which includes a list of activities at the facility; a site map showing drainage areas and direction of stormwater flows; receiving waters and outfall location; the location of industrial activities, storage, disposal, material handling; and all structural controls.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

c. A summary of all pollutant sources which includes all areas where spills have occurred or could occur. For each source, identify the expected drainage and the corresponding pollutant.

d. A description of all stormwater controls, both structural and non-structural. All BMPs shall be properly maintained and be in effective operating conditions. BMPs must be selected and implemented as non-numeric technology-based effluent limitations. BMPs must include good housekeeping measures, preventative maintenance programs, spill and leak prevention and response procedures, erosion and sediment controls, and runoff management practices. The SWPPP shall describe how the BMPs are appropriate for the facility.

e. A record of the following information for all chemical products that could potentially have an impact to stormwater associated with industrial activity as defined in §122.26(b)(14)(i)-(ix),(xi):

- i. Product name, chemical formula, and manufacturer;
- ii. Purpose or use of the chemical;
- iii. Safety Data Sheet (SDS) and Chemical Abstracts Service (CAS) Registry number for each chemical;
- iv. The frequency (e.g., hourly, daily), duration (e.g., hours, days), quantity (e.g., maximum and average), and method of application for the chemical; and
- v. The vendor's reported aquatic toxicity (NOAEL and/or LC50 in percent for aquatic organism(s)), when available.

f. A description of the training to be provided for employees to assure they understand the goals, objectives, and procedures of the SWPPP, the requirements of the NPDES permit, and their individual responsibilities for complying with the goals and objectives of the SWPPP and the NPDES permit.

g. Minimum documentation requirements are as follows:

- i. Records of operational and preventive maintenance activities, equipment inspections, procedure audits, and personnel training;
- ii. Records of the collection and analysis of samples, including, but not limited to, sample location, any calculations done at the time of sampling, any sampling or analytical methods used for samples analyzed on site, and sample results;
- iii. Any records of the collection and analysis of samples, the evaluation of design standards and operational changes, the selection, design, installation, and implementation of control measures, and/or evaluations, identifications, examinations and/or explanations documented in support of the residuals management BMP and/or environmental monitoring program requirement, below; and

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

iv. All documentation of SWPPP activities shall be kept at the facility for at least three years and provided to EPA or MassDEP upon request.

5. All areas identified in the SWPPP shall be inspected, at least on a quarterly basis. Inspections shall occur beginning the 1st quarter after the effective date of the permit. EPA considers quarters as follows: January to March; April to June; July to September; and October to December.

6. The permittee shall amend and update the SWPPP within 14 days for any changes at the facility affecting the SWPPP. Changes which may affect the SWPPP include, but are not limited to, the following activities: a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to the waters of the United States; a release of a reportable quantity of pollutants as described in 40 C.F.R. §302; or a determination by the permittee or EPA that the SWPPP appears to be ineffective in achieving the general objective of controlling pollutants in stormwater discharges associated with industrial activity. Any amended or new versions of the SWPPP shall be re-certified by the permittee. Such re-certifications also shall be signed in accordance with the requirements identified in 40 C.F.R. §122.22.

7. The permittee shall certify at least annually that the previous year's inspections and maintenance activities were conducted, results were recorded, and that records were maintained. Annual certifications also shall be signed in accordance with the requirements identified in 40 C.F.R. §122.22. The permittee shall keep a copy of the current SWPPP and all SWPPP certifications (the initial certification, recertifications, and annual certifications) signed during the effective period of this permit at the facility and shall make them available for inspection by EPA and MassDEP.

8. The SWPPP shall include best management practices (BMPs) for on-site activities that will minimize the discharge of pollutants in stormwater to waters of the United States. The permittee shall develop and implement site-specific BMPs; including BMPs to achieve the following:

- a. Store materials and equipment indoors such that contact with stormwater is limited and avoided whenever possible.
- b. Protect material stockpiles and equipment not stored indoors with weather-resistant covers to minimize exposure to rain and wind.
- c. Ensure stormwater not discharged through Outfall 001 remains on-site.
- d. Undertake reasonable efforts to control or reduce stormwater runoff volume to allow for proper operation of the WWTF.
- e. Ensure for proper cleanup of chemical spills that may come in contact with stormwater.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

- f. Use vacuum equipment to sweep all paved or impervious areas of its property draining to Outfall 001 where solids deposition may occur, including roads, driveways, parking areas, sidewalks, and loading areas.
- g. Inspect onsite pollution control measures more frequently following severe weather events or natural disasters when these conditions may result in increased pollutant discharges to the Unnamed Tributary.

Additionally, the permittee shall continue to implement site specific BMPs that are required for Sector E (Glass, Clay, Cement, Concrete, and Gypsum Products) of the current MSGP.

PART I.C. PHOSPHORUS CONTROL PLAN (PCP)

The PCP shall be developed and fully implemented during the permit term to meet the 62% phosphorus load reduction waste load allocation (WLA) set forth in the Lower Charles River TMDL. The permittee is required to develop and implement the following site-specific PCP:

1. Within two years of the effective date of the permit, in order to establish baseline conditions, the permittee shall:
 - a. complete the estimation of the average annual phosphorus load to the permitted outfall using influent and effluent phosphorus data, and
 - b. complete an evaluation of any additional structural or non-structural BMPs that reduce the phosphorus load to the Unnamed Tributary.
2. Within three-and-a-half years of the effective date of the permit, the permittee shall:
 - a. begin construction or implementation of BMPs designed to reduce phosphorus loads, and
 - b. monitor the effectiveness of those BMPs.
3. Within five years of the effective date of the permit, provide to EPA a report including:
 - a. a summary of phosphorus data analysis and phosphorus load estimation,
 - b. a description of the evaluation of additional phosphorus reduction BMPs beyond the WWTF (if applicable),
 - c. an operation, maintenance, and inspection plan of additional phosphorus reduction BMPs (if applicable),
 - d. a demonstration of the capacity of the entire facility to meet the 62% phosphorus WLA-based reduction target.

PART I.D. COMPLIANCE SCHEDULE FOR WHOLE EFFLUENT TOXICITY AND METALS

1. Within one year of the effective date of the permit, the permittee shall complete an evaluation of any additional treatment improvements and/or BMPs that reduce or eliminate aluminum, copper, and chromium (VI) loads to the Unnamed Tributary and reduce or eliminate toxicity in the effluent.
2. Within two years of the effective date of the permit, the permittee shall begin construction or implementation of treatment improvements and/or BMPs designed to reduce or eliminate aluminum, copper, and chromium (VI) loads to the Unnamed Tributary and reduce or eliminate toxicity in the effluent.
3. Within three years of the effective date of the permit, the permittee shall monitor the effectiveness of those treatment improvements and/or BMPs.
4. By January 15th of the fourth year after the effective date of the permit, provide to EPA a report including a summary of Whole Effluent Toxicity, aluminum, copper, and chromium (VI) data collected for the DMR, and any other data collected to support the development of treatment improvements and/or BMPs that reduce or eliminate aluminum, copper, and chromium (VI) loads to the Unnamed Tributary and reduce or eliminate toxicity in the effluent. This report shall detail progress towards meeting the final effluent limitations.
5. Within five years of the effective date of the permit, the final effluent limitations for Whole Effluent Toxicity, aluminum, copper, and chromium (VI) shall be met.
6. The final permit contains a schedule of compliance for these aluminum ending five years after the effective date of the permit. After this initial five year period, the permittee shall comply with the final effluent limits.

If during the five-year period after the effective date of the permit, Massachusetts adopts revised aluminum criteria, then the permittee may request a permit modification, pursuant to 40 C.F.R. § 122.62(a)(3), for a further delay of the effective date of the final aluminum effluent limit. If new aluminum criteria are approved by EPA before the effective date of the final aluminum effluent limit at the end of the five-year compliance period, the permittee may apply for a permit modification, pursuant to 40 C.F.R. § 122.62(a)(3), and request for a longer time to meet the aluminum limit and/or to revise the aluminum limit in Part I.A.1 of this permit based on whether there is reasonable potential for the facility's aluminum discharge to cause or contribute to a violation of the newly approved aluminum criteria and meeting applicable anti-degradation requirements.¹

¹ The final effluent limit of 750 µg/L for aluminum may be modified prior to the end of the five-year compliance schedule if warranted by the new criteria and a reasonable potential analysis and consistent with anti-degradation requirements. Such a modification would not trigger anti-backsliding prohibitions, as reflected in CWA 402 § (o) and 40 C.F.R. § 122.44(l).

PART I.E. REPORTING REQUIREMENTS

Unless otherwise specified in this permit, the Permittee shall submit reports, requests, and information and provide notices in the manner described in this section.

1. Submittal of DMRs Using NetDMR

The Permittee shall continue to submit its monthly monitoring data in discharge monitoring reports (DMRs) to EPA and the State no later than the 15th day of the month electronically using NetDMR. When the Permittee submits DMRs using NetDMR, it is not required to submit hard copies of DMRs to EPA or the State. NetDMR is accessed from the internet at <https://netdmr.zendesk.com/hc/en-us>.

2. Submittal of Reports as NetDMR Attachments

Unless otherwise specified in this permit, the Permittee shall electronically submit all reports to EPA as NetDMR attachments rather than as hard copies. See Part I.D.5. for more information on State reporting. Because the due dates for reports described in this permit may not coincide with the due date for submitting DMRs (which is no later than the 15th day of the month), a report submitted electronically as a NetDMR attachment shall be considered timely if it is electronically submitted to EPA using NetDMR with the next DMR due following the particular report due date specified in this permit.

3. Submittal of Requests and Reports to EPA

a. The following requests, reports, and information described in this permit shall be submitted to the EPA NPDES Applications Coordinator in the EPA Water Division:

- (1) Transfer of Permit notice;
- (2) Request for changes in sampling location;
- (3) Request to discharge new chemicals or additives;
- (4) Request for pH Effluent Limitation Adjustment;
- (5) Report on unacceptable dilution water/request for alternative dilution water for WET testing.

b. These reports, information, and requests shall be submitted to EPA electronically at R1NPDESReporting@epa.gov or by hard copy mail to the following address:

**U.S. Environmental Protection Agency
Water Division
EPA NPDES Applications Coordinator
5 Post Office Square - Suite 100 (06-03)
Boston, MA 02109-3912**

PART I.E. REPORTING REQUIREMENTS, cont'd.

4. Submittal of Reports in Hard Copy Form

a. The following notifications and reports shall be submitted as hard copy with a cover letter describing the submission. These reports shall be signed and dated originals submitted to EPA.

(1) Written notifications required under Part II

b. This information shall be submitted to EPA and MassDEP at the following addresses:

**U.S. Environmental Protection Agency
Enforcement and Compliance Assurance Division
Water Technical Unit
5 Post Office Square, Suite 100 (04-SMR)
Boston, MA 02109-3912**

**Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, MA 01887**

5. State Reporting

Transfer or termination of permit notices shall also specifically be submitted to:

**Massachusetts Department of Environmental Protection
Bureau of Water Resources
Surface Water Discharge Permitting Program
1 Winter Street, 5th Floor
Boston, MA 02108**

PART I.E. REPORTING REQUIREMENTS, cont'd.

Unless otherwise specified in this permit, duplicate signed copies of all reports, information, requests or notifications described in this permit, including the reports, information, requests or notifications described in Parts I.E.2, I.E.3, and I.E.4 also shall be submitted to the State at the following address:

**Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, Massachusetts 01887**

Hard copies of Whole Effluent Toxicity tests and reports only shall be submitted to:

**Massachusetts Department of Environmental Protection
Watershed Planning Program
8 New Bond Street
Worcester, MA 01606**

6. Verbal Reports and Verbal Notifications

- a. Any verbal reports or verbal notifications, if required in Parts I and/or II of this permit, shall be made to both EPA and to the State. This includes verbal reports and notifications which require reporting within 24 hours (e.g., Part II.B.4.c. (2), Part II.B.5.c. (3), and Part II.D.1.e.).
- b. Verbal reports and verbal notifications shall be made to EPA's Enforcement and Compliance Assurance Division at:

617-918-1510

PART I.F. STATE PERMIT CONDITIONS

1. This authorization to discharge includes two separate and independent permit authorizations. The two permit authorizations are (i) a federal National Pollutant Discharge Elimination System permit issued by the U.S. Environmental Protection Agency (EPA) pursuant to the Federal Clean Water Act, 33 U.S.C. §§1251 et seq.; and (ii) an identical state surface water discharge permit issued by the Commissioner of the Massachusetts Department of Environmental Protection (MassDEP) pursuant to the Massachusetts Clean Waters Act, M.G.L. c. 21, §§26-53, and 314 CMR 3.00. All of the requirements contained in this authorization, as well as the standard conditions contained in 314 CMR 3.19, are hereby incorporated by reference into this state surface water discharge permit.
2. This authorization also incorporates the state water quality certification issued by MassDEP under §401(a) of the Federal Clean Water Act, 40 C.F.R. 124.53, M.G.L. c. 21, §27 and 314 CMR 3.07. All of the requirements (if any) contained in MassDEP's water quality certification for the permit are hereby incorporated by reference into this state surface water discharge permit as special conditions pursuant to 314 CMR 3.11.
3. Each agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this permit shall be effective only with respect to the agency taking such action and shall not affect the validity or status of this permit as issued by the other agency, unless and until each agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this permit is declared invalid, illegal or otherwise issued in violation of state law such permit shall remain in full force and effect under federal law as a NPDES permit issued by the U.S. Environmental Protection Agency. In the event this permit is declared invalid, illegal or otherwise issued in violation of federal law, this permit shall remain in full force and effect under state law as a permit issued by the Commonwealth of Massachusetts.
4. The permittee shall ensure that sweepings collected at its facility are reused or disposed in a manner consistent with MassDEP's Policy #BWP-94-092: Reuse and Disposal of Street Sweepings.

Response to Public Comments
Reissuance of NPDES Permit NO. MA0000531
Boston Sand and Gravel
100 N. Washington Street, 2nd Floor
Boston, MA 02114

In accordance with the provisions of 40 C.F.R. §124.17, this document presents the U.S. Environmental Protection Agency's ("EPA" or "Region 1") responses to comments received on the draft National Pollutant Discharge Elimination System ("NPDES") Permit MA0000531. The responses to comments explain and support EPA's determinations that form the basis of the final permit.

From August 1, 2017, to August 30, 2017, EPA and the Massachusetts Department of Environmental Protection ("MassDEP") (together, the "Agencies") solicited public comments on a draft NPDES permit (MA0000531) developed pursuant to a permit application from Boston Sand & Gravel ("BS&G" or "the permittee"), for the reissuance of a NPDES permit to discharge commingled stormwater and process water for a Ready Mix Concrete operation from outfall number 001 to the Unnamed Tributary to the Charles River, known locally as "Millers River" (segment ID MA72-31). On March 5, 2019, the Region 1 Office of the United States Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) exercised their discretion to provide an additional opportunity for comment on certain revisions to the Draft Permit. This additional comment period was limited to the sole issue of the revised maximum daily total recoverable copper effluent limitation contained in the draft permit.

EPA Region 1 and MassDEP received written comments from Boston Sand & Gravel on the original draft permit dated August 30, 2017, and the draft permit dated April 2, 2019, pursuant to the additional comment period. EPA and MassDEP received no other comments. EPA's decision-making process has benefitted from the public comments and additional information submitted. After a review of the comments received, EPA and MassDEP have made a final decision to issue this permit authorizing the discharge. Below are the comments received and EPA's responses to those comments with a description of significant changes made to the public noticed permit as a result of those comments. Other minor editorial changes have been made to the final permit but are not discussed in this response.

A copy of the final permit may be obtained by writing or calling Undine Kipka, U. S. EPA, 5 Post Office Square, Suite 100 (Mail Code: 06-1), Boston, MA 02109-3912; Telephone: (617) 918-1335. A copy may also be obtained from the EPA Region 1 website at <https://www.epa.gov/npdes-permits/massachusetts-final-individual-npdes-permits>.

Changes from the draft permit to the final permitPart I.A.1: Effluent Limitation Table and Footnotes

1. Revised pH monitoring and compliance language has been added to Part I.A.1 footnote #5 (see response to comment #A.1).
2. Total Suspended Solids monitoring is reduced from 1/week to 1/month and Total Sulfate monitoring is reduced from 1/month to 1/quarter (see response to comment #A.2).
3. Daily maximum effluent limitations for aluminum (750 µg/L), copper (29 µg/L), and chromium (VI) (16 µg/L) based on the acute criteria are now included in the final permit. Monthly average effluent limitations for aluminum, copper, and chromium (VI) were removed from the final permit (see response to comment #A.3 and response to comment #B.2).
4. Total Petroleum Hydrocarbon (“TPH”) monitoring was removed from the final permit (see response to comment #A.6).
5. *E. Coli* monitoring has been reduced from 1/month to 1/quarter (see response to comment #A.7).
6. Total Phosphorus monitoring has been reduced from 1/month to 1/quarter. The Phosphorus Control Plan (“PCP”) has been retained in final permit Part I.C (see response to comment #A.8).

Draft Permit Part I.D: Source Identification and Reduction Plan (removed from final permit)

7. SIRP requirements for aluminum, copper, and chromium (VI) have been removed (see response to comment #A.3).
8. SIRP requirements *E. Coli* have been removed (see response to comment #A.7).

Final Permit Part I.D: Compliance Schedule

9. A compliance schedule of 5 years with annual interim steps to achieve revised effluent limitations for aluminum, copper, and chromium (VI), and the final effluent limitations for WET is included in a new permit section: Part I.D (see response to comment #A.10). Final permit monitoring and reporting requirements and state permit conditions are now in Part I.E and Part I.F, respectively, and are unchanged from the draft permit.

Note: comments have been grouped by letter. The letter “A” denotes comments from Boston Sand & Gravel received during the first comment period, and the letter “B” denotes comments received during the second comment period.

Comment A.1

Add Reporting Language for pH Exceedances Due to Natural Causes

The limits for pH have been reduced from 6.0 to 8.5 s.u. to 6.5 to 8.3 s.u. with the application of Massachusetts Water Quality Standards (MASWQS). The standards allow for variation outside of this range due to natural causes, up to 0.5 units. However, the current permit does not address how to report or document comparisons to natural causes.

A review of other NPDES permits show that the following language is often included (example is from permit number MA0040436 dated March 12, 2016) to address this concern:

“To demonstrate that pH values of the effluent are outside the permitted pH range due to natural causes, the permittee must show that pH measurements of the source (intake) water(s) and the effluent are the same. Documentation of such conditions must be submitted by the permittee with the discharge monitoring reports.”

BSG requests the above language be added to page 5 of 16 of the draft permit under paragraph Part I.A.5 for clarification. Since BSG uses stormwater and tap water as sources, both waters will be measured.

Response to Comment A.1

Boston Sand & Gravel (“BS&G”) requests an addition to pH monitoring requirements to accommodate for measuring stormwater and tap water impacts to the effluent pH.

Inclusion of a requirement or an option for source intake water monitoring and related facility-specific permit language is evaluated on a case-by-case basis. In the case of BS&G, stormwater and tap water pH changes to the effluent are not necessarily the result of “natural causes.” Based on current information, in this case EPA cannot assume that the source water pH range is within the natural background range. Therefore, EPA believes the language suggested by BS&G is not appropriate for inclusion in the permit at this time.

Nevertheless, in the absence of information to support BS&G’s request, EPA has included an option for BS&G to monitor receiving water pH to demonstrate compliance with Massachusetts Surface Water Quality Standards (*see* 314 CMR 4.05(3)(b)(3)) in Part I.A.1 footnote #5 of the final permit:

“For purposes of this permit, the permittee may, when discharging, measure the pH in the receiving water downstream of the facility at locations that are representative of the downstream condition representative of the discharge mixed with the receiving water and the pH of all applicable sources water (e.g., stormwater and tap water). The permittee may use these measurements to demonstrate that the facility’s discharge is not affecting the pH of the receiving water and/or to demonstrate compliance with state water quality standards. The downstream pH, and the discharge pH shall be measured on the same day, and source water pH conditions measured within 30 days. Receiving water pH sampling conditions and results shall be submitted as an attachment with the DMR.”

Comment A.2*Sampling Frequency Reduction Based on Compliance History*

USEPA's Interim Guidance for Performance-based Reductions of NPDES Permit Monitoring Frequencies (dated April 9, 1996) allows for a case-by-case assessment and relief of monitoring frequency for facilities who have consistently reported effluent analytical data that is below the permit limits within the past two years. With its continued implementation of water conservation practices and improved wastewater treatment technology implemented in 2016 and 2017 (described in more detail elsewhere), several parameters required under BSG's permit since 2007 have been measured in concentrations well below the permit limits. The table below shows data from Outfall 001 from August 2015 through August 2017 for selected parameters.

	<u>Long Term Average (LTA) of Monthly Average Results</u>	<u>Maximum of Monthly Averages</u>	<u>n</u>	<u>Monthly Average Permit Limit</u>	<u>LTA to Limit</u>	<u>Number of Exceedances</u>	<u>Current Frequency</u>	<u>New Requested Frequency</u>
Total Suspended Solids (mg/L)	3.65	17	26	20	18%	0	1/week	1 time per 2 months
Turbidity (NTU)	3.18	8.8	26	25	13%	0	1/week	1 time per 2 months
Sulfates (mg/L)	95.81	180	26	250	38%	0	1/month	1 time per quarter

BSG requests monitoring for total suspended solids (TSS), turbidity, and sulfates be reduced to the new requested frequencies listed above to reflect the lowered pollutant load contributed recently by the facility. BSG notes that the exceedances for these parameters described in the fact sheet are over two years old and are not representative of current or future discharges. Furthermore, if mass limits are provided (see below), some of the historical data may not have been considered exceedances.

As noted in the fact sheet, BSG has been monitoring oil and grease at Outfall 001 since 2012 at the recommendation of MADEP and has reported non detect values since December 2008, showing a minimal potential for contribution of this pollutant. Therefore, increasing monitoring requirements from quarterly to monthly is not warranted with the reissuance of the permit. BSG requests monitoring from oil and grease be maintained at a quarterly frequency.

Additionally, BSG requests that similar reduced frequencies be applied for other parameters, such as pH, for which BSG has not experienced an exceedance in the past 2 years. To avoid unnecessary sampling events, BSG requests that other report-only parameters also be permitted with reduced frequencies.

Response to Comment A.2

BS&G requests monitoring frequency reductions for TSS, turbidity and Total Sulfate, as well as "other report-only parameters." EPA is assuming that "other report-only parameters" includes all other parameters listed in the draft permit Part 1.A.1: pH, oil and grease, Total Petroleum Hydrocarbons (TPH), effluent hardness, receiving water hardness, phosphorus, and *E. Coli*. Below, we discuss each of these parameters.

In considering whether to reduce or maintain the monitoring frequencies of these parameters, the NPDES Permit Writer's Manual provides the following guidance regarding the appropriate establishment of monitoring frequencies in permits:

“The permit writer should establish monitoring frequencies sufficient to characterize the effluent quality and to detect events of noncompliance, considering the need for data and, as appropriate, the potential cost to the permittee.” (NPDES Permit Writers’ Manual, page 8-5)

In this matter, EPA also is informed by its Interim Guidance for Performance-based Reductions of NPDES Permit Monitoring Frequencies, 1996 (“Interim Guidance”). The Interim Guidance counsels for a case-by-case approach when discharges are found to be non-continuous. Specifically, the Interim Guidance states that:

“[e]ffluent averages from interrupted or discontinuous data sets may not be representative of long-term performance. Monitoring frequencies for discharges that are intermittent or short-term, such as seasonal discharges and highly variable batch processes, should not be assessed or reduced using the methods described in this guidance and would need to be considered on a case-by-case basis.” (Interim Guidance, at 6)

In response to comment #A.3, EPA discusses more fully its observation that BS&G’s discharge is non-continuous and the implications of that determination on the final effluent limitations for copper, aluminum and chromium (VI). For purposes of responding to the request made in comment #A.2 - that monitoring frequencies should be reduced for some parameters based on recent monitoring results - the parameters monitored at this facility each will be considered on a case-specific basis.

EPA agrees that the monitoring frequencies for the three parameters in the table referenced in comment #A.2, Total Suspended Solids (“TSS”), Total Sulfate and turbidity, can be reduced or maintained as follows:

- TSS monitoring is reduced from 1/week to 1/month. EPA believes that the non-compliance risk can be better assessed at this frequency rather than at the requested frequency of once every two months.
- Total Sulfate monitoring is reduced from 1/month to 1/quarter.
- Turbidity monitoring at a frequency of 1/month was proposed in the draft permit and is maintained at that frequency. EPA believes that the non-compliance risk can be better assessed at this frequency rather than at the requested frequency of once every two months.

If future performance levels for the removal or elimination of TSS, Sulfate, and turbidity levels in the discharge decrease, EPA may seek increased monitoring of these parameters in the future. (“Permit monitoring requirements may, at the permit authority’s option ... require increased monitoring if performance levels drop.” Interim Guidance, at 2-3).

With regard to monitoring frequency reductions for “other report-only parameters” Total Petroleum Hydrocarbons (“TPH”), effluent hardness, receiving water hardness, phosphorus, and *E. Coli*, changes in frequencies are briefly outlined below in the order that they are presented in draft permit Part I.A.1.

- TPH monitoring is eliminated because it is not necessary to demonstrate compliance with Massachusetts Surface Water Quality Standards. TPH monitoring is further addressed in response to comment #A.6.
- Effluent hardness and receiving water hardness monitoring has been retained to support the analysis of hardness-based criteria such as the nationally recommended copper criteria and new aluminum criteria that Massachusetts may incorporate into their water quality standards. See response to comments #A.3 and #B.2.

- Total Phosphorus and *E. coli* monitoring is reduced from 1/month to 1/quarter in the final permit as this frequency is sufficient to assess levels of these pollutants in the facility's discharge. Final permit requirements for these parameters are addressed in the response to comments #A.7 and #A.8.

The monitoring frequencies in the effluent limitation table in Part I.A.1 of the final permit have been changed accordingly. WET, pH, oil and grease, copper, chromium (VI) and aluminum monitoring is maintained at frequencies proposed in the draft permit as the monitoring is needed to assess compliance with final permit effluent limitations. Copper, chromium (VI) and aluminum effluent limitations are addressed in response to comment #A.3. WET effluent limitations are addressed in response to comment #A.9.

Note that, unless the permittee monitors the effluent more frequently than required by the permit for a given month, average monthly and daily maximum effluent limitations in the final permit apply to a single sample taken once a month for all parameters monitored at a frequency of 1/month. If more samples are taken in given month, Part I.A.9 of the final permit requires that the results of sampling for any parameter above its required frequency must be reported and may be submitted in the form of a short report as an attachment to the DMR. (Part I.A.9 is unchanged in the final permit).

Comment A.3

Reassessment of Reasonable Potential Analysis Using Recent Results for Metals

BSG has continually increased its efforts to implement best management practices (BMPs) and improved treatment to reduce the pollutant loading. In addition to implementing the BMPs described in the fact sheet, BSG initiated pilot testing to identify improved wastewater treatment chemicals. In September 2016, BSG began using Hubbard Hall treatment chemistry to increase metals removal efficiency by replacing the hydroxide precipitation with sulfide precipitation, which resulted in a significant reduction in discharge concentrations, as shown below. BSG implemented this change by adding Hubbard Hall T-500 to the influent to block house treatment system (the Lagoon 7 effluent). The treatment system still employs a coagulant (ferric chloride) and a polymer (anionic form) to form settleable metal precipitate floc. The ferric chloride chemistry product also contains hydrochloric acid.

Treatment Technology	Discharge January 2002 – September 2007			Discharge October 2007 – August 2016			Discharge September 2016 – July 2017		
	Hydroxide Precipitation Treatment (prior to Water Conservation Measures)			Hydroxide Precipitation Treatment (after Water Conservation Measures)			Hubbard Hall Treatment (after Water Conservation Measures)		
	Average	Maximum	n	Average	Maximum	n	Average	Maximum	n1
Copper (ug/l)	15.00	-	2	30.90	153.00	102	6.67	17.90	13
Chromium(VI) (ug/l)	-	-		157.92	2370.00	102	103.31	748.00	13
Aluminum (ug/l)	735.00	-	2	296.22	2800.00	102	228.12	1340.00	13
TSS (mg/L)	7.92	28.2	23	3.45	21	104	6.20	17	13
Turbidity (NTU)	4.14	126.23	69	2.76	17	104	4.19	8.8	13
Sulfates (mg/L)	84.76	993.25	69	70.83	260	104	106.08	180	13

1. Includes data from two sampling events during pilot testing.

Using the new treatment chemistry, analyses for copper would not have exceeded the proposed daily maximum limit of 29 ug/L and only one analysis for aluminum would have exceeded the daily maximum limit of 750 ug/L. Given the variance in the one event where aluminum exceeded the limit compared to other events since implementing the new treatment chemicals, this event is considered an anomaly.

Therefore, BSG requests that the reasonable potential analysis (RPA) be re-run with analytical data reported on the discharge monitoring reports (DMRs) since September 2016 to determine if water quality-based limits (WQBELs) are required. Additionally, if the revised RPA identifies any metals which do not require WQBELs, BSG requests they be removed from the requirement to develop a Source Identification and Reduction Plan.

Response to Comment A.3

In Comment #A.3, Boston Sand and Gravel requests the reasonable potential analysis for copper, chromium (IV) and aluminum be re-run using DMR data derived since September 2016, the time period after BS&G began using Hubbard Hall treatment chemistry to increase metals removal efficiency. Further, BS&G requests that the Source Identification Reduction Plan (“SIRP”) be removed for any metal that does not require a numeric water quality-based effluent limitation (“WQBEL”). Specifically, BS&G would like the modification of, and if applicable, the removal of numeric effluent limitations proposed in the draft permit for copper, chromium (IV) and aluminum. In comment #A.4 and comment #A.5, BS&G requests Technology-Based Effluent Limitations (“TBELs”) be considered as alternatives for the numeric WQBELs developed for these metals in the draft permit. In comment #B.2, BS&G requests the modification of, and if applicable, the removal of a technology-based effluent limitation (“TBEL”) developed for copper that was noticed during a second public notice period in March 2019. The consideration of the inter-related requests in comments #A.3, #A.4, #A.5, #A.9, #A.10 and #B.2, as well as the final determination for those numeric effluent limitations for those parameters, are discussed primarily in the response to this comment. Response to comment #B.2 discusses the basis for the selection of the final effluent limitation for copper in more detail. EPA responds to this comment by addressing the need for effluent limitations generally, the reasonable potential analyses conducted for this permit, the evaluation for the need for chronic criteria, the calculation of acute criteria, and, finally, the need for a Source Identification Reduction Plan (“SIRP”).

NPDES permit limits such as the WQBELs found in the permit for this facility are established on an individual basis via a reasonable potential analysis, as correctly noted by BS&G. EPA appreciates that BS&G has improved the treatment process at the facility and increased its efforts to implement Best Management Practices (“BMPs”) to reduce pollutant loadings. EPA is supportive of these types of proactive measures to reduce pollutants at industrial facilities. At the same time, however, effluent limitations are often necessary to ensure that pollutants from industrial facilities remain at levels that do not have a reasonable potential to cause or contribute to an exceedance of applicable water quality standards.

EPA’s Technical Support Document for Water Quality-based Toxics Control¹ (“TSD”) provides the methodology for making such a reasonable potential analysis determination in accordance with 40 C.F.R. § 122.44(d)(1)(ii). EPA, in response to comments and new information provided during the public comment period, may choose to re-evaluate the basis for effluent limitations, including, in some cases, the reasonable potential analysis. In response to BS&G’s comments, and based on the unique facts presented, EPA reconsidered the reasonable potential analysis used for the development of WQBELs for all metals in the Draft Permit using data representative of the new treatment chemistry used at the facility since September 2016. Significant to this decision to reconsider the reasonable potential analysis were the facts that a robust data set representative of the new treatment chemistry was available and that the current permit does not contain WQBELs for these metals.

In response to this comment, EPA re-evaluated DMR data recorded from October 2016 through the end of May 2018 to determine if there was reasonable potential to cause or contribute to a violation of acute criteria for copper, chromium (VI) and aluminum after new treatment for these metals was installed in September 2016. EPA concluded that there was reasonable potential to cause or contribute to a violation of acute criteria for chromium (VI) and aluminum based on this data set. The reasonable potential analyses for chromium (VI) and aluminum, as well as the final WQBELs for these two metals based on these criteria, are included in Attachment A.3.

As part of this analysis EPA initially concluded that the facility’s discharge did not have reasonable potential to cause or contribute to a violation of the applicable copper criterion. EPA then developed a technology-based effluent limitation for Total Recoverable Copper (26.3 µg/L), based on the performance of the new treatment chemistry. Because the basis of the effluent limitation changed, the copper effluent limitation in the draft permit was re-noticed from March 5, 2019 through April 3, 2019. The derivation of the draft TBEL for copper was explained in the supplemental fact sheet of the revised draft permit from the Renotice. The reconsideration of reasonable potential for copper and the subsequent development of a WQBEL for copper is further described in response to comment #B.2.

With regard to the chronic criteria for these metals, EPA has reviewed the additional information on the frequency and volume of the discharge for September 2016 through July 2017 that BS&G has submitted for the facility. In the draft permit, EPA established monthly average and daily maximum effluent limitations for copper, chromium (VI) and aluminum. However, based on the discharge frequency information submitted by the permittee, EPA considers the discharge to be non-continuous, and EPA is applying only the acute water quality criteria and not the chronic water quality criteria for developing WQBELs for these metals. The result of applying this consideration is that there are no applicable chronic criteria for these metals and therefore no reasonable potential for copper, chromium (VI) and aluminum in the effluent to cause or contribute to a violation of an applicable chronic criterion. Consequently, the monthly average effluent limitations for copper, chromium (VI) and aluminum based on the chronic

¹ See EPA’s Technical Support Document for Water Quality-based Toxics Control: EPA/505/2-90-001, pages 49-65 (1991).

criteria have been removed from the final permit. The final daily maximum effluent limitations for the metals are 29 µg/L for Total Recoverable Copper, 16 µg/L for Dissolved Chromium (VI), and 750 µg/L for Total Recoverable Aluminum. A compliance schedule to meet the final effluent limitations for the metals is discussed in response to comment #A.10.

Regarding BS&G request that the SIRP be removed for particular metals, SIRP requirements in draft permit Part I.D specific to copper, chromium (VI) and aluminum have been removed from the final permit. EPA believes that the final numeric effluent limitations for these parameters, the associated compliance schedule in Part I.D of the final permit, and the Stormwater Pollution Prevention Plan (“SWPPP”) in final permit, provide sufficient mechanisms for pollution control, compliance, and documentation. EPA believes that the numeric effluent limitations for copper, chromium (VI) and aluminum ensure that the discharge does not have a reasonable potential to cause or contribute to exceedances of the applicable water quality criteria.

As also noted in response to comment #A.2, hardness data may be used in assessing reasonable potential and deriving future WQBELs for other hardness-dependent metals such as cadmium and chromium, and deriving WQBELs for aluminum based on new aluminum criteria.

Comment A.4

Mass Limits for Metals Reflective of Water Conservation Practices

Per USEPA's NPDES Permit Writer's Manual (September 2010, EPA-833-K-10-001), USEPA supports the implementation of water conservation practices in conjunction with a well-operated wastewater treatment system. BSG has implemented numerous water reduction practices since September 2007, which have resulted in a 57% reduction of flow. Prior to these practices, the average daily discharge at Outfall 001 was 13,111 gallons per day (gpd). Since October 2007, the average daily discharge is 5,606 gpd. The table below shows the continued reduction of mass loading for copper, chromium (VI) and aluminum with the implementation of water conservation measures and improved wastewater treatment technologies. Rates for production of ready-mix products are also provided. Although a reduction in production was seen through the housing crisis beginning in 2008, a return to a higher average monthly production rate while still maintaining a lower mass load of pollutants is also indicative of the effectiveness of the controls implemented on site.

	<u>Average lb/day January 2002 – September 2007</u>	<u>Average lb/day October 2007 – August 2016</u>	<u>Average lb/day September 2016 – July 2017</u>
<u>Treatment Technology</u>	Hydroxide Precipitation Treatment (prior to Water Conservation Measures)	Hydroxide Precipitation Treatment (after Water Conservation Measures)	Hubbard Hall Treatment (after Water Conservation Measures)
Copper	0.0016	0.0013	0.0004
Chromium(VI)		0.0062	0.0051
Aluminum	0.0804	0.0125	0.0146
Monthly Ready- mix Production (yards)	21,875 Average 38,927 Maximum	18,436 Average 35,694 Maximum	25,579 Average 34,330 Maximum

The Permit Writer's Manual clearly states mass-based limits can be applied for technology-based effluent limitations (TBELs). However, there are no effluent limitation guidelines that apply to ready-mix facilities (SIC code 3273). BSG would welcome the opportunity to discuss an appropriate basis for developing mass-based limits which recognized the significant effort and costs the facility have invested

to reduce the pollutant load. For example, even applying the water quality-based effluent limitation as a mass limit using the facility flow from prior to October 2007 may be a viable application of best professional judgment (BPJ).

Response to Comment A.4

EPA has considered including mass-based limits for this permit but finds that concentration-based water quality based effluent limitations (“WQBELs”) are consistent with the law and more appropriate for the protection of the receiving water. 40 C.F.R. § 122.45(f)(1)(ii) requires that all permit limitations, standards, or prohibitions be expressed in terms of mass except when the applicable standards and limitations are expressed in terms of other units of measurement. In this case, the applicable water quality criteria for aluminum, copper, and chromium (VI) are expressed in concentration units. (See Nationally Recommended Criteria and 314 C.M.R. § 4.05(5)(e)). Therefore, EPA is retaining concentration-based limits for these parameters in the final permit. However, as the commenter points out, USEPA's NPDES Permit Writer's Manual does recognize that water conservation practices at a facility may reduce the overall pollutant load to the receiving water. As such, BS&G is encouraged to continue their water conservation practices and record those efforts in accordance with the Stormwater Pollution Prevention Plan (“SWPPP”) in the final permit.

See response to comment #A.3 and #B.2 for a discussion on the final numeric concentration-based effluent limitations for copper, chromium (VI), and aluminum.

Comment A.5

Adjustment for Source Water Pollutant Loads

NPDES regulations at 40 CFR 122.45(g) allow for adjustment of permit limits to account for source water concentrations if the permittee can show the treatment work would be compliant without the source water contribution, or limits are applied on a net basis (monitor influent and effluent). Previous analysis of tap water purchased from Boston Water and Sewer Commission (BWSC) show high levels of copper and aluminum. The tap water is used in the manufacturing process and recycled through the WWTP system and alone could exceed the proposed discharge limits of 18 ug/L monthly average and 29 ug/L daily maximum for copper. Although the discharge at Outfall 001 comes from a mixture of stormwater and tap water, the tap water makes up 88 to 98% of the water used on site (see Attachment 1 for detailed data between September 2016 and July 2017 which is indicative of a longer facility history). It should also be noted that, although tap water makes up the majority of the BSG effluent, the need to discharge is generally driven by rainfall volumes that are higher than the facility has the capacity to assimilate and consume in the process.

Parameter	BWSC Tap Water September 2016 (ug/l)	BWSC Tap Water August 2011 (ug/l)	Runoff from MassDOT drains August 2011 (ug/l)	Average Discharge Outfall 001 October 2007 – August 2016 (ug/l)	Average Discharge Outfall 001 September 2016 – July 2017 (ug/l)
Treatment Technology (after Water Conservation Measures)				Hydroxide Precipitation Treatment	Hubbard Hall Treatment
Copper	20	42.7	38.8	30.90	6.67
Aluminum	11	20	823	296.22	228.12

BSG also receives runoff from the Massachusetts Department of Transportation (MassDOT) roadways due to several broken or missing drain pipes that otherwise would route the flow away from the facility. BSG is reaching out to MassDOT in an attempt to rectify the broken infrastructure.

The facility has experienced significant reduction in copper and aluminum discharges since the implementation in September 2016 of the Hubbard Hall treatment products. All analyses for copper have been below the proposed permit limit since September 2016. Without the contribution from BWSC tap water, copper concentrations in the discharge would be expected to be very low and may not have triggered the reasonable potential analysis to require WQBELs, especially when DMR data since September 2016 is used (see discussion at number 3 above).

BSG requests that an adjustment for the pollutant load in the BWSC tap water be applied for copper and aluminum in the final permit. BSG requests the permit allow for the subtraction of 33.8 ug/L copper and 284.7 ug/L aluminum prior to reporting the analytical results (these values were derived from the average of the copper and aluminum data presented above).

Response to Comment A.5

BS&G requests that intake water credits for copper and aluminum be included in the final permit's effluent limitations for copper and aluminum.

As BS&G notes, NPDES regulations at 40 C.F.R. § 122.45(g) allow for intake water credits for technology-based effluent limitations ("TBELs"). However, water quality-based effluent limitations ("WQBELs"), such as those developed for copper, chromium (VI), and aluminum in the draft permit and the final permit, are not eligible for intake water credits that apply to "technology-based limitations and standards." (See 40 C.F.R. § 122.45(g)(ii)). Furthermore, in this case, the intake water is not drawn from the same body of water into which the discharge is made. (See 40 C.F.R. § 122.45(g)(4)). Therefore, water intake credits are not appropriate for use for these pollutants. See response to comment #A.3 and #B.2 for a discussion on the effluent limitations for copper, chromium (VI), and aluminum developed for the final permit.

EPA acknowledges that "during large storms, stormwater from the overhead highway overflows onto the site below." Fact sheet, at 6. EPA encourages BS&G to continue to work with MassDOT on mutual stormwater infrastructure improvements. BS&G is also encouraged to document any plans for infrastructure improvements and/or stormwater pollutant load reductions as part of the Stormwater Pollution Prevention Plan ("SWPPP"). Well-documented efforts on behalf of the facility to evaluate and

reduce stormwater pollution to the receiving water are compatible with a reasonable Best Management Practice (“BMP”) strategy and/or fall under general “good housekeeping” practices in a SWPPP.

Comment A.6

Monitoring Frequency Reduction for Total Petroleum Hydrocarbons

Monitoring for total petroleum hydrocarbons (TPH) was added to BSG’s permit for the first time. The intent expressed in the fact sheet was “to evaluate the petroleum content of the oil and grease monitored at the facility.” As noted above, the facility has reported non-detect oil and grease discharges at Outfall 001 since December 2008. Non-petroleum oils and greases would not be expected to be in the facility’s discharge due to the activities occurring on site. Furthermore, a search of USEPA’s Enforcement and Compliance History Online (ECHO) website did not reveal any other facilities in Massachusetts with TPH monitoring requirements. The requirement to monitor both TPH and oil and grease on a monthly schedule is excessive and unnecessary when one analyte (oil and grease) is indicative of the other (TPH). Therefore, BSG requests the monitoring for TPH be removed from the permit to avoid causing undue burden to the facility.

Response to Comment A.6

BS&G requests the removal of TPH monitoring.

The intent of the TPH monitoring requirement at this facility was to evaluate the more representative petroleum content of the effluent resulting from fueling spills with a parameter that is more targeted than oil and grease. Upon consideration of Comment #A.6, the TPH monitoring requirement in Part 1.A.1 has been eliminated since the oil and grease effluent limitation is sufficient to ensure the discharge’s compliance with the applicable Massachusetts Surface Water Quality Standards. Specifically, the oil and grease limit of 15 mg/L, included in the final permit because of fueling operations at the facility, satisfies the narrative Massachusetts Surface Water Quality standard to prevent a visible film on the Class B receiving water. (See 314 CMR §4.05(3)(b)(7)).

Comment A.7

Monitoring Frequency Reduction for E. Coli

Monitoring for *E. Coli* was added to BSG’s permit for the first time in light of the Final Pathogen TMDL for the Charles River Watershed, January 2007 (Control number CN 0156.0). Although the TMDL report recommends a basin-wide implementation of the TMDL, the Millers River watershed (MA 72-31) is not listed as an impaired waterway and the TMDL report places primary burden for pathogen causes on municipalities. BSG wishes to assist in the improvement of water quality in the Charles River watershed, and sees the value of collecting some *E. Coli* analysis from its Outfall 001 discharge (a sample collected in March 2012 in preparation of the renewal application was non-detect). However, BSG believes the nature of its business and well maintained status of its facility would not contribute significant amounts of *E. Coli* to Millers River and, if so proven by a reasonable amount of monitoring, monthly sampling for the life of the permit would not provide an environmental benefit. Monitoring *E. Coli* once per quarter for two years will result in a reasonable dataset with temporal variation to provide an adequate assessment. Therefore, BSG requests the monitoring frequency for *E. Coli* be changed to once per quarter for first 24 months of the permit.

Furthermore, the requirement to develop and implement a Source Identification and Reduction Plan (SIRP) for *E. Coli* would not be necessary if sampling reveals that *E. Coli* is not present at a concentration to be of a concern. Therefore, BSG requests the SIRP not be required unless the quarterly sampling shows *E. Coli* in concentrations averaging above 400 cfu/100 mL. If the SIRP cannot be removed, US EPA and MADEP should identify a level below which the SIRP is not required.

Response to Comment A.7

BS&G requests that monitoring requirement for *E. Coli* be reduced from monthly to quarterly and that the Source Identification and Reduction Plan (“SIRP”) requirement be eliminated unless future monitoring show *E. Coli* concentrations above 400 cfu/100mL.

EPA agrees with BS&G that the Final Pathogen TMDL for the Charles River Watershed, January 2007 (Control Number: CN 0156.0) was designed to control pathogens in the Charles River Watershed through a basin-wide approach to implementation of the TMDL. EPA also agrees with BS&G that to ensure the improvement of water quality in the Charles River, monitoring for *E. Coli* is warranted. Since there is limited historical data to assess the potential *E. Coli* contributions of BS&G stormwater and industrial runoff into the Charles River, EPA agrees that a quarterly, rather than a monthly, monitoring requirement for *E. Coli* is warranted at this time.

BS&G shall submit quarterly *E. Coli* results as part of its regular monitoring program. At this time, EPA is not requiring the development and implementation of a SIRP for *E. Coli*. If monitoring results show exceedances of the Massachusetts Surface Water Quality Standards for *E. Coli* (see 314 C.M.R. § 4.05(3)(b)(4)), EPA will reconsider this decision in the next permit cycle.

Comment A.8

Monitoring Frequency Reduction for Phosphorus

Similarly, monitoring for phosphorus was added to BSG’s permit for the first time in light of the Final Total Maximum Daily Load for Nutrients in the Lower Charles River Basin, Massachusetts (June 2007, control number CN 301.0). The TMDL did not include a specific waste load allocation (WLA) for Millers River but all tributaries to the Charles River are required to implement a 62% reduction in phosphorus as measured by a comparison of influent and effluent water. Due to its recycling and water conservation practices, BSG asserts that it may already be meeting the reduction requirements. BSG uses a mix of BWSC tap water and stormwater in its production practices and has in place several recycling activities that result in a final discharge that is 69 to 97% less than the total volume of water used in production. Attachment 1 shows data from September 2016 through July 2017 that is indicative of historical uses.

Therefore, BSG requests the permit include a preliminary study to collect data for a short period of time. If it is found that the effluent concentration of phosphorus is 62% (or greater) less than the influent, sample can be stopped and the Phosphorus Control Plan (PCP) can be omitted. Additionally, BSG requests the monitoring be established at once per quarter. The following language in the permit is requested to be added to Part I.A of the permit.

“Based on the permit[t]ee’s existing water conservation actions, monitoring for phosphorus will include a preliminary study to confirm phosphorus concentration in the effluent is a minimum of 62% less than the phosphorus concentration in the influent(s). The permittee shall monitor the influent(s) and Outfall 001 effluent for phosphorus quarterly for a period of 18 months. If at the end of this period, the phosphorus reduction is 62% or greater, monitoring for phosphorus can

cease. If effluent reduction is less than 62%, the permittee shall implement a Phosphorus Control Plan (PCP) as described in Part I.C. of this permit. If the PCP is required, quarterly monitoring shall resume for years of the permit to verify the effectiveness of the BMP(s) implemented.”

Response to Comment A.8

BS&G requests that it be allowed to conduct a preliminary study for phosphorus removal efficiencies. BS&G is expecting that the results from the study will demonstrate a 62% reduction in total phosphorous (“TP”) concentrations between influent and effluent and thus would eliminate the need for the Phosphorus Control Plan (“PCP”) requirements and lead to a reduction in the monitoring frequency for TP.

EPA agrees with BS&G that the Lower Charles River Basin Nutrient (Phosphorus) TMDL imposes a requirement that tributaries to the Charles River meet a reduction in annual loading of phosphorus to the Lower Charles². The TMDL requires that the reduction in phosphorus be achieved through Best Management Practices (“BMPs”) that are incorporated into a PCP³. BS&G discharges commingled process water and industrial stormwater to the Unnamed Tributary and thus is subject to a 62% TP load reduction⁴. Therefore, a PCP to reduce phosphorus loading and supplementary TP monitoring will continue to be part of the final permit requirements in Part I.C consistent with CWA §303(d)(3) and with maintaining Massachusetts Surface Water Quality Standards.

Additionally, it appears that BS&G misinterprets the 62% reduction expressed in the TMDL. The waste load allocation of the TMDL is not that each permittee at each outfall must ensure “a 62% reduction in phosphorus as measured by a comparison of influent and effluent water,” as related in the comment. Rather the TMDL calls for a 62% reduction of the annual mass loading of TP from baseline conditions. For BS&G this means a 62% load reduction in the annual TP effluent load from the baseline annual TP effluent load.

BS&G is welcome to expedite the documentation for steps in addressing phosphorus in accordance with the PCP, for example by including the results of a preliminary study as suggested by BS&G, as long as interim and final compliance schedule deadlines in final permit Part I.C are met. Note that there is flexibility in establishing baseline conditions in Part I.C as the facility has a limited drainage area compared to the other facilities subject to the TMDL and efforts on the part of the facility to reduce phosphorus in the discharge, for example by water recycling or reducing suspended solids, will contribute to demonstrating compliance with the permit’s PCP requirements.

Effluent monitoring for TP will be required on a quarterly basis in the final permit to supplement the PCP report. The need for a PCP and further TP effluent monitoring will be evaluated upon reissuance of the permit.

² Control Number: CN 301.0. The Unnamed Tributary, water segment MA72-31, is considered part of the “all other drainage systems that discharge directly to the Lower Charles”. See Final Total Maximum Daily Load for Nutrients in the Lower Charles River Basin at vii.

³ Final Total Maximum Daily Load for Nutrients in the Lower Charles River Basin, at 84.

⁴ Table ES-2 in Final Total Maximum Daily Load for Nutrients in the Lower Charles River Basin, at viii.

Comment A.9*Intermittent Discharge and WET Testing Frequency*

The nature of BSG's discharge to the Millers River is intermittent. Attachment 2 provides daily discharge information from September 2016 through July 2017. This period represents current operational conditions with the Hubbard Hall wastewater treatment practices and other treatment BMPs in place. BSG requests USEPA and MADEP consider the nature of its intermittent discharge when establishing sampling frequencies and remove monthly average numeric limits for copper, chromium (VI), and aluminum. Additional information regarding BSG's intermittent discharge was provided to USEPA and MADEP in a letter dated September 9, 2016.

Additionally, BSG requests whole effluent toxicity (WET) testing be maintained on an annual schedule. Our WET Testing contractor requires three to five weeks' notice to be able to receive and process a WET sample in order to accommodate the required species population and bench top space necessary to run the tests, making the scheduling of a WET test from an intermittent discharge difficult. Moreover, WET testing costs approximately \$6,000+ per event. An increase from annual to quarterly significantly impacts the viability of the facility and directly reduces funding that could be, in part, used for additional pollution prevention. Therefore, BSG requests EPA consider annual frequency for WET testing and removal of chronic WET testing.

Response to Comment A.9

This response addresses the commenter's request to reduce the monitoring frequency of Whole Effluent Toxicity ("WET") testing because of the cost of the WET test as well as logistical and scheduling challenges. The response to comment #A.3 addresses the commenter's request to consider the nature of the discharge in establishing monitoring requirements and to remove the monthly average numeric effluent limitations for copper, chromium (VI), and aluminum. The discharge is considered non-continuous and monthly average numeric effluent limitations for copper, chromium (VI), and aluminum have been removed from the final permit.

The draft permit includes acute and chronic WET effluent limitations ($LC50 \geq 100\%$; $C-NOEC \geq 100\%$) for the daphnid, *Ceriodaphnia dubia*. WET requirements for fathead minnow (*Pimephales promelas*) as a test species were already eliminated in the draft permit based on past results indicating that *Ceriodaphnia dubia* is the more sensitive of the two species. The acute and chronic effluent limitations ($LC50 \geq 100\%$; $C-NOEC \geq 100\%$) for the daphnid, *Ceriodaphnia dubia*, and quarterly monitoring frequency will be retained in the final permit because there is currently insufficient available information to suggest that the causes of reported chronic and acute toxicity have been eliminated and to determine whether acute and chronic toxicity causes in the effluent are related.

The permittee was previously subject to an annual monitoring frequency for both freshwater species. See Fact Sheet section 5.1.12 for a summary of WET data up until the issuance of the draft permit. In WET results submitted to the DMR for September 2017, 70.7% was reported for the acute daphnid endpoint and 100% was reported for the acute fathead minnow endpoint. In addition, a result of 25% was reported for the chronic daphnid endpoint (reproduction) and 100% was reported for the chronic fathead minnow endpoint (growth). Thus, retaining the acute and chronic effluent limitations and quarterly monitoring frequency for the daphnid in the final permit in light of the recent unfavorable results for this species will ensure that Massachusetts Surface Water Quality Standards will be met ("all surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife", 314 C.M.R. § 4.05(5)(e)).

However, in acknowledgement of recent changes in the facility's wastewater treatment operations, after submitting the successful results ($LC50 \geq 100\%$; $C-NOEC \geq 100\%$) of 4 acute and 4 chronic tests, performed quarterly in the first year of the permit as well as information on the possible and likely causes of prior acute and chronic toxicity, BS&G may request reduced monitoring for WET. Upon review of this information, EPA may reduce the monitoring frequency for one or both WET tests.

Comment A.10

Compliance Schedule

As noted by USEPA in the Fact Sheet, compliance with the new numeric limits may require a compliance schedule to enable adequate controls to be put in place. As noted above, BSG believes some numeric limits, such as copper, may be eliminated if an RPA using recent data and an allocation for intake water concentrations are implemented. Additionally, BSG is actively working towards further reducing and potentially eliminating its discharge to the Millers River, with a target of attaining zero discharge. Since 2016, BSG has retained the services of AECOM to not only assist with the NPDES permitting effort but to evaluate the process water discharge and the WWTP system, and options to improving the quality of the discharge to the Millers River. In September 2016, BSG switched treatment chemicals. The results to date show measured improvement in metals removal as well as toxicity. Along with chemical substitutions, BSG has made the following changes at the plant to improve the recycling of process water at the plant and vastly increase the use of process water into the ready-mix concrete production:

1. Installed pumps and sensors to improve pumping of process water from Center Pit holding tank to the Recycle Tank;
2. Adjusted all pumps and sensor levels for optimum operation;
3. Installed equipment to allow use of process water into all three production plants;
4. Updated the process for water management onsite; conducted training of plant maintenance staff on changes and the importance of maintenance of all related equipment;
5. Updated product formulations to use increasing levels of process water and actively track and report process water use in production; and
6. Included WWTP operability, discharge, and process water handling and use in production as the first item discussed at the weekly Operations Meeting, which includes Executive and Senior Management, Operations Managers, and EHS Department personnel.

In addition, since August 4, 2017, we have had zero discharge to the Millers River and have used between 38,000 and 42,000 gallons/week of process water in our concrete production. Our effort towards zero discharge continues with the following activities:

1. Contacting Mass Highway/DOT to acknowledge and eliminate the stormwater discharge from overhead highways onto BSG property (particularly in the area of the Gilmore Bridge);
2. Evaluating options for offsite transport and treatment of process water;
3. Continuing to evaluate changes to onsite procedures to improve process water generation and handling onsite; and
4. Contacting Boston Water and Sewer Commission to determine closest sewer connection and determining feasibility of connecting the local sewer system.
5. Evaluating onsite options for increasing storage for process/stormwater.

Therefore, BSG requests EPA consider a three-year compliance schedule for the implementation of numeric limits and quarterly WET testing, should they be required. The following recommendations can be included:

- For the first three years of the permit, monitor for copper, chromium (VI), and aluminum with no limits on a quarterly frequency and acute WET testing on an annual frequency.
- At the conclusion of 30 months after the permit issuance date, or before, BSG will submit a written plan documenting the implemented/planned facility changes to meet the numeric limits.
- The plan will include a schedule for the implementation of controls to meet the new numeric limits as soon as possible but no later than the end of year five of the permit.

Response to Comment A.10

In Fact Sheet section 5.4, EPA invited comment on the means for the facility to achieve compliance with new effluent limitations developed in the draft permit. EPA believes that a five-year compliance schedule to meet the final effluent limitations for aluminum, copper, chromium (VI), and WET is reasonable because the permittee has made a good faith effort to test and evaluate treatment and pollution prevention options, including implementing measures to reduce the overall pollutant loads to the receiving water. *See* 40 C.F.R. § 122.47. A five-year compliance schedule to meet the final effluent limitations for aluminum, copper, chromium (VI), and WET is now included in final permit Part I.D.

For a description of selected final effluent limitations for copper, chromium (VI), and aluminum, see the response to comment #A.3 and #B.2. WET testing frequency and other related final permit requirements are discussed in the response to comment #A.9.

On December 21, 2018, the Agency published revised national recommended aluminum water quality criteria for fresh waters.⁵ MassDEP is working in parallel on new state-specific aluminum criteria among other changes to the Massachusetts WQS.⁶ The Final Permit includes a five-year compliance schedule that can be extended by permit modification if Massachusetts has adopted new criteria during that time. If the Commonwealth adopts and EPA approves the new criteria, the permittee may request a permit modification to extend the compliance schedule or adjust the new aluminum limits, if appropriate.

Regarding the commenter's stated efforts towards zero discharge, EPA notes that in the event there is no current or future discharge from the facility, BS&G may request to terminate its individual NPDES permit in accordance with 40 C.F.R. § 122.64.

Comment A.11

Revision/Update to Fact Sheet 1.2.2 Wastewater Treatment (page 7 and 8 of 37)

The fact sheet describes the wastewater treatment process as,

“The water from Lagoon 7 is pumped to a 2-chamber, 1,800 gallon tank inside the block house building where chemical addition (ferric chloride coagulant, hydrochloric acid, and polymer)

⁵ More information about EPA's new aluminum criteria recommendations is available at <https://www.epa.gov/wqc/2018-final-aquatic-life-criteria-aluminum-freshwater>.

⁶ See more information at <https://www.mass.gov/regulations/314-CMR-4-the-massachusetts-surface-water-quality-standards#proposed-amendments-public-comment>.

promotes the flocculation of suspended solids. Coagulant and polymer injection pumps turn on automatically when the wastewater transfer pump starts. The coagulant and polymer pumps are set to deliver doses established during treatability studies, but may be manually adjusted to handle changes in solids loading.”

In August 2016, a modification to the wastewater treatment process chemistry, described above, was implemented to enhance the removal of influent heavy metals through chemical precipitation. This enhancement employs a proprietary sulfide-based treatment chemistry which precipitates dissolved metals as metal sulfides. The fact sheet description of the wastewater treatment process should be revised to read,

“The water from Lagoon 7 is pumped to a 2-chamber, 1,800 gallon tank inside the block house building where chemical addition (sulfide precipitant, ferric chloride coagulant, hydrochloric acid, and polymer) promotes the precipitation of dissolved metals and flocculation of suspended solids. Precipitant, coagulant, and polymer injection pumps turn on automatically when the wastewater transfer pump starts. The precipitant, coagulant, and polymer pumps are set to deliver doses established during treatability studies, but may be manually adjusted to handle changes in solids loading.”

Response to Comment A.11

BS&G requests an update to the language in the fact sheet that accompanied the draft permit regarding the wastewater treatment chemistry. The Fact Sheet is written to explain the conditions and requirements of the draft permit and is not rewritten as part of the final permit decision. However, the comments and EPA responses in this Response to Comments (“RTC”) document are part of the permit administrative record and EPA appreciates the updated facility information. EPA acknowledges this comment related to the Fact Sheet by restating it in full and explaining any consequences on the final permit. In this case, this response serves to acknowledge this updated information which does not affect permit conditions in the draft permit or final permit.

Comment A.12

Increased Stormwater Pollution Prevention Plan Requirements

BSG notes that the requirements for the Stormwater Pollution Prevention Plan (SWPPP) have changed significantly, including but not limited to, the requirement to submit the plan and record details regarding the application of treatment chemicals. This requirement goes well beyond the requirements of the EPA Stormwater MSGP. We have not seen this level of requirement in similar permits. In addition, the EPA Stormwater Permit Program does not apply to BSG’s facility. No justification for this additional burden was included in the fact sheet.

BSG believes its long term data for stormwater-based analyses are proof that the current plan and controls at the facility are adequate and the increased requirements are burdensome and unnecessary. As an example, Ready Mix Concrete operations (SIC code 3273) covered under the 2015 Multisector General Permit (MSGP) are only subject to 100 mg/L of total suspended solids. BSG’s long term average of 3.65 mg/L from August 2015 - August 2017 indicates the effectiveness of the plan. Furthermore, reporting detailed information on the use of chemicals on site would reveal business proprietary information that would place BSG at a disadvantage to its competitors.

Therefore, BSG request the requirement for submitting the SWPPP, recording detailed applications of chemicals and other new requirements be removed from the permit.

Response to Comment A.12

Federal regulations require stormwater discharges associated with specific categories of industrial activity to be covered under NPDES permits (unless otherwise excluded.) (40 C.F.R. § 122.26(b)(14)(i)-(xi)). BS&G asserts that the Stormwater Permit Program does not apply to BS&G's facility. The facility does not assert that it does not discharge stormwater. Nor does the facility specifically dispute that it falls within one of the specific categories of industrial activities to be covered. Indeed, it points to Ready Mix Concrete operations one of the "Sector E" class of facilities covered by EPA's regulations as an example. Accordingly, BS&G's industrial stormwater, described at 40 C.F.R. § 122.26(b)(14)(ii), requires NPDES permit coverage. Furthermore, the numeric effluent limits for TSS in the final permit have been carried forward from the current permit and are retained to avoid backsliding.

BS&G stated that since the stormwater Multi-Sector General Permit (MSGP) does not apply to the site they object to the specific manner in which EPA addresses, namely the requirement to submit a SWPPP, to include chemical reporting and "other new requirements." EPA has issued an MSGP which contains provisions that require industrial facilities in 29 different industrial sectors to, among other things, implement control measures and develop site-specific SWPPPs to comply with NPDES requirements. The SWPPP is a bedrock element of the MSGP and to stormwater pollution control management. The SWPPP is a minimum Best Available Technology Economically Achievable/Best Conventional Pollutant Control Technology ("BAT/BCT") technology-based effluent limitation ("TBEL") for stormwater and was appropriately included in the current permit, and then retained for the draft permit, as this facility discharges stormwater. At this time, EPA does not believe that all pollutants associated with stormwater at the facility are sufficiently controlled via existing numeric and non-numeric effluent limitations for individual pollutants, and EPA believes retaining the SWPPP, as a whole, is necessary for the final permit to avoid backsliding and meet the BAT/BCT TBEL.

The language in final permit Part I.B.4(e) regarding process chemicals and chemical additives has been retained so that EPA and MassDEP can access a record of any changes with respect to adding or replacing process chemicals via the SWPPP. Part I.B.4(e) specifies that information included in the SWPPP only pertains to products that could have an impact to stormwater if released. BS&G may proceed with normal operations after adding or replacing chemicals as long as the change is documented in the SWPPP. To the extent the SWPPP requirements in this permit vary from those contained in the 2015 MSGP, this individual permit reflects the unique facts present at BS&G, mainly that the stormwater may be commingled with non-stormwater. It is important for EPA and MassDEP to understand what may be contained in this commingled stormwater. Therefore, the SWPPP includes provisions for the BS&G to identify process chemicals and chemical additives.

As for proprietary information, BS&G may identify information submitted to EPA as Confidential Business Information (CBI). BS&G may assert a business confidentiality claim with respect to part or all of the information submitted to EPA in the manner described at 40 C.F.R. § 2.203(b). Information covered by such a claim will be disclosed by EPA only to the extent, and by means of the procedures, set forth in 40 C.F.R. Part 2, Subpart B. If no such claim accompanies the information when it is submitted to EPA, it may be made available to the public by EPA without further notice to BS&G.

Comment A.13*Plea for a Comprehensive and Collaborative Approach*

BSG has provided the comments above as individual issues in order to simplify and clarify the information provided herein. However, BSG recognizes that several of the requests are inter-related, such as the requests to update the RPA (number 3 above), the use of mass limits (number 4) and to provide an allocation for intake water pollutant loads (number 5). BSG requests that USEPA and MADEP consider all comments above comprehensively, as well as consideration for the small size of the facility, the costs associated with increased monitoring, and BSG's history of reducing pollutant loads.

BSG expects the requests included in this letter to result in changes to the draft permit. We stand ready to provide USEPA with additional information if necessary, and to collaborate on the development of the final permit. Additionally, BSG requests the opportunity to review the revised draft permit prior to finalization.

Response to Comment A.13

EPA agrees that many of the issues raised by BS&G, such as issues raised in comments #A.3, #A.4, #A.5, #A.9, and #B.2 are inter-related. The response to comment #A.3 addresses significantly related questions raised in comments #A.3, #A.4, #A.5, and #A.9. Other responses to comments are addressed on a more individual basis. EPA considered each comment. The factors EPA used in considering each comment, often including costs and B&SG's history of reducing pollutant loads, are often articulated in the response.

EPA completed this response to comments in accordance with the requirements of 40 C.F.R. § 124.17. EPA appreciates BS&G's collaboration on the final permit through its participation in the public comment process. Changes have been made in the final permit, and the response to comments includes a summary list of those changes (see page 2 of this document). No further information is requested of BS&G at this time, and EPA had adequate information to consider the respond to the comments BS&G provided.

The agencies, however, granted BS&G's request to meet in order for BS&G to be able to provide its comments in person. Such meeting occurred on May 28, 2019. Additionally, EPA accommodated BS&G's request to view the administrative record for the draft permit on March 27, 2019.

Consistent with 40 C.F.R. Part 124, EPA relies on the open and required public comment process for comments. It is not consistent with 40 C.F.R. Part 124 nor EPA's practice to provide an advanced copy of the final permit to the permittee for review and comment prior to final permit issuance. Moreover, to do so would impede Region 1's efforts aimed at expediting permitting.

Comment B.1*Comments Previously Submitted on the Draft NPDES Permit*

A previous draft permit was noticed to the public on July 31, 2017 to which BSG provided comments in a letter dated August 30, 2017 ("2017 Comments"). BSG understands that its 2017 Comments will be addressed with comments from the current comment period in a final permit to be issued after the close of the comment period and any public hearing. The 2017 Comments are applicable to the 2019 Draft Permit and BSG incorporates them into this comment letter by reference as if fully set forth herein.

Response to Comment B.1

EPA received the "2017 Comments" sent on August 30, 2017. These comments are addressed in responses #A.1 through #A.13.

Comment B.2*Atypical or Arbitrary Process Used to Calculate a Technology Based Effluent Limitation ("TBEL") for Copper*

In the 2017 Comments, BSG requested that the water-quality based effluent limitations ("WQBEL") included in the 2017 Draft Permit be reassessed because of BSG's ongoing efforts to implement best management practices ("BMPs") and improved wastewater treatment to reduce the pollutant loading. BSG requested that a reasonable potential analysis be rerun with the analytical data reported on the discharge monitoring reports ("DMR") since September 2016 to confirm if WQBEL are required and to remove those metals from the requirement to develop a Source Identification and Reduction Package.

In preparation of the 2019 Draft Permit, USEPA agreed to reassess BSG's DMR data and determined that the Facility's discharge did not have the reasonable potential to cause or contribute to a violation of the applicable acute copper criterion. USEPA determined that, based on this revised analysis, removing the maximum daily WQBEL for copper is appropriate.

There currently are no national effluent limitation guidelines ("NELGs") promulgated for copper at Ready-Mix Concrete facilities. Instead, USEPA took the unusual approach of establishing a site-specific TBEL for copper under 40 CFR 125.3. BSG believes that the methods used to develop the TBEL are inconsistent with existing USEPA protocols.

The Supplemental Fact Sheet issued with the 2019 Draft Permit states that USEPA considered specific factors used in the development of NELGs. For decades, USEPA has used the 99th percentile of daily concentrations to calculate a daily maximum limit and the 95th percentile of monthly average concentrations to calculate a monthly average limit when developing NELGs. This has been implemented in the development of numerous NELGs, including the Steam Electric Power Generating Point Source Category (in the Technical Development Document, USEPA 821-R-13-002, April 2013; Appendix B) and the Organic Chemicals, Plastics and Synthetic Fibers (OCPSF) Point Source Category (in the Technical Development Document USEPA 440-187-009, October 1987; Section VII). USEPA's Technical Support Document (TSD) for Water Quality-based Toxics Control (USE PA 505-2-90-001, March 1991) states "The daily maximum limits are usually based on the 99th percentile . . . Monthly average limits are in most cases based on the 95th percentile." USEPA's NPDES Permit Writer's Manual (USE PA 833-K-10-001, September 2010) recommends that permit writers use the procedures typically used to develop NELGs (such as those above) when developing case-by-case TBELs and explicitly states:

The daily variability factor is a statistical factor defined as the ratio of the estimated 99th percentile of a distribution of daily values divided by the mean of the distribution. Similarly, the monthly variability factor is typically defined as the estimated 95th percentile of the distribution of monthly averages divided by the mean of the distribution of monthly averages.

For BSG, USEPA used the 95th percentile to calculate a daily maximum limit. The USEPA fact sheet indicated that the source data for the calculation was monthly performance data, however, the 2007 NPDES permit required the analysis and reporting of copper as a daily maximum and the data was submitted via DMR to MADEP and USEPA as daily maximum data.

BSG objects to the current approach based on the following:

- a. The rationale for the approach that the USEPA used to develop the limit was not explained in the 2019 Supplemental Fact Sheet included with the 2019 Draft Permit. BSG could not replicate USEPA's calculations to attain the same results using data from October 2016 to March 2018. The 2019 Supplemental Fact Sheet did not include enough information to understand the basis of the TBEL calculations and the reasoning for the deviation from typical USEPA practice;
- b. BSG understands USEPA used its "RP_stats_analysis_QC" spreadsheet to calculate the TBEL. Although the instructions to this spreadsheet state that the permit writer has the discretion of using either the 99th or 95th percentile, the intent of the spreadsheet is to determine the permittee's "reasonable potential to exceed a receiving water quality standard" and therefore, the instructions are not directly applicable to using the spreadsheet for the purposes of determining a TBEL; and
- c. USEPA calculated the draft TBEL based on a data set from October 2016 - May 2018 (number of samples $\{n\} = 18$). BSG's current data set is larger ($n=24$), which is more representative of the variability of the effluent that would be seen over time. Calculation of a daily maximum limit using the 99th percentile with the larger data set results in a higher numeric limit than when using the smaller data set. Additional calculations using randomized example results within the current range of data (minimum of 2 ug/L and maximum of 28.2 ug/L) indicate that larger data sets may also result in different TBEL estimates.

BSG requests the permit limit for copper be reassessed using the full period of available data and following USEPA's typical practices of using the 99th percentile to develop a daily maximum TBEL, if one is needed at all.

Response to Comment B.2

Boston Sand & Gravel requests that EPA use the 99th percentile estimate of the facility's copper data to set the daily maximum limitation for copper or remove the effluent limitation if appropriate. BS&G correctly notes that the 95th and 99th percentiles of the lognormal distribution typically provide the average monthly and maximum daily limits, respectively.

The 95th and 99th percentiles of the copper data from October 2016 to May 2018 are 26.3 µg/L and 48.3 µg/L, respectively, using the formulas in Table E-1 of the TSD. The permittee reports a copper value to the DMR once a month. The percentile extrapolation procedure for daily maximum values from Table E-1 of the TSD was used. EPA used the 95th percentile estimate of the facility's copper data to set the daily maximum technology-based effluent limitation in the 2019 re-noticed draft permit.

Although the TSD and Permit Writer's Manual generally support using the 99th percentile for daily maximum limits *typically*, they also allow for the use of other values when appropriate. *See, e.g.,* TSD at E-15 ("The daily maximum permit limit is usually the 99th upper percentile value of the pollutant distribution. In certain cases, the 95th percentile value may be allowable."). In other words, based on the specific facts of a facility and its discharge, it may be appropriate to use the 95th percentile for a daily maximum limit.

After consideration of Boston Sand & Gravel's comment, however, EPA agrees that for this facility the 99th percentile estimate is more appropriate for use in setting a daily maximum limit. Importantly, EPA's

prior selection of the 95th percentile applied not only to the draft TBEL, but also for purposes of assessing whether the facility had reasonable potential to cause or contribute to a violation of the applicable acute copper criterion. (See Attachment A to the Supplemental Notice). EPA's 2019 Supplemental Notice compared the 95th percentile estimate of 26.3 µg/L to a site-specific criterion of 26.8 µg/L⁷ to reach its draft conclusion that the facility did not have reasonable potential. Because EPA agrees with BS&G that it is more appropriate to use the 99th percentile data for setting the daily maximum effluent permit limit, it necessarily must evaluate whether the facility's discharge at that level has reasonable potential to cause or contribute to a violation of the applicable acute copper criterion. (See CWA § 301(b)(1)(C)).

To capture the statistical variation in the effluent data, EPA referred to Appendix E, Lognormal Distribution and Permit Limit Derivations, of the Technical Support Document for Water Quality-based Toxics Control (USEPA. March 1991 [EPA/505/2-90-001]). This document provided technical guidance on the statistical procedures used to factor in the copper data submitted by the facility. A description of the lognormal distribution is provided in the Technical Support Document ("TSD") for Water Quality-based Toxics Control, Appendix E, Lognormal Distribution and Permit Limit Derivations. The available copper data were fitted to a lognormal distribution using the equations provided in the TSD.

Using the formulas in Table E-1 of the TSD, EPA calculates the 99th percentile of the copper data from October 2016 to May 2018 to be 48.3 µg/L. See Attachment B.2. Aside from the discharge being afforded no dilution, the 99th percentile of 48.3 µg/L is much higher than the acute criterion of 29 µg/L. Accordingly, EPA concludes that the facility has reasonable potential to cause or contribute to a violation of the applicable acute copper criterion. Therefore, the final permit includes a daily maximum effluent limit of 29 µg/L based on the acute copper criterion.

BS&G additionally comments that EPA should rerun its analysis using a larger data set. BS&G made a similar comment in its 2017 comments, comment #A.3. Following the receipt of comment #A.3, EPA and MassDEP determined that a re-examination of the effluent data was warranted to develop limits that will not only meet the criteria, but that also reflect the demonstrated performance of the facility based on the new chemical treatment used for metals installed in September 2016 (the "Hubbard Hall system"). Since EPA has already exercised its discretion to review a different data set, EPA is declining to repeat the exercise.

The requirement to impose a permit limit is not only premised on a finding that the pollutant discharges "are" at a level that "causes" violation of the applicable water quality standards, but the requirement is also triggered by a finding that the facility's pollutant discharges "may" be at a level that "contributes" to or has the "reasonable potential" to cause a violation. 40 C.F.R. § 122.44(d)(1)(i). The regulation requires water quality-based effluent limits even when there is some degree of uncertainty regarding both the precise pollutant discharge levels and the potential causal effects of those discharges, so long as the record is sufficient to establish that there is a "reasonable potential" for that discharge to cause or contribute to a violation of water quality standards. "Reasonable potential" requires some degree of certainty greater than a mere possibility, but it leaves to the permit writer's scientific and technical judgment how much certainty is necessary." In re Upper Blackstone, 14 E.A.D. 577, 599 n.29 (EAB 2010). "As in many science-based policymaking contexts, under the CWA the EPA is required to exercise its judgment even in the face of some scientific uncertainty." City of Taunton, Massachusetts v. EPA, 895 F.3d 120, 135 (1st Cir. 2018), cert. denied sub nom, quoting Upper Blackstone Water Pollution

⁷ Although EPA used the MA site-specific copper criterion of 26.8 µg/L for comparative purposes in the supplemental notice, MassDEP subsequently confirmed that there is no site-specific copper criterion applicable for this facility. Accordingly, the National Recommended Water Quality Criterion of 29 µg/L Total Recoverable Copper described in the fact sheet for the 2017 draft permit is the water-quality based effluent limitation applicable to this facility.

Abatement District v. EPA, 690 F.3d 9, 23 (1st Cir. 2019). The regulations, thus, require a precautionary approach when determining whether the permit must contain a water quality-based effluent limit for a particular pollutant. In re Upper Blackstone at 599. Accordingly, removing the copper effluent limitation altogether is inappropriate in this case.

Boston Sand & Gravel's desire for supposed greater scientific certainty in the form of a more robust data set, as a matter of law, cannot preclude or delay EPA from proceeding with the finalization of its proposed permit. As the EPA's Environmental Appeals Board recently explained: "scientific uncertainty is not a basis for delay in issuing an NPDES permit. The Board has specifically held that '[i]n the face of unavoidable scientific uncertainty, the Region is authorized, if not required, to exercise reasonable discretion and judgment.'" In re Upper Blackstone, 14 E.A.D. at 606 (quoting In re Dominion Energy Brayton Point, LLC, 13 E.A.D. 407, 426 (EAB 2007)). Indeed, the call for further study upon further study would amount to delays that would greatly undermine the ability of the Clean Water Act to achieve its objectives. *See id.* ("[M]ore than three decades ago, the D.C. Circuit aptly described the CWA's balance when confronted with a difficult situation and the obligation to eliminate water quality impairments: 'EPA may issue permits with conditions designed to reduce the level of effluent discharges to acceptable levels. This may well mean opting for a gross reduction in pollutant discharge rather than the finetuning suggested by numerical limitations. But this ambitious statute is not hospitable to the concept that the appropriate response to a difficult pollution problem is not to try at all.'" (quoting Nat. Resources Def. Council, Inc v. EPA, 568 F.2d 1369, 1380 (D.C. Cir. 1977)) (emphasis added by EAB).

EPA notes that Boston Sand & Gravel's comments suggest that even if it were to rerun the analysis with its preferred data set, it would "result in a higher" number for the 99th percentile. Comment #B.2. In other words, based on BS&G's characterization of its preferred data set, EPA's conclusion that the facility has the reasonable potential to cause or contribute to a violation of the applicable acute criterion would be further bolstered.

For all of these foregoing reasons, EPA will not, for the second time, rerun its analysis based on BS&G's preferred data set. EPA is relying on the dataset from October 2016 to May 2018 analyzed for the revised Draft Permit. Regarding replicability, EPA requested more details on the part of the analysis in the re-noticed draft permit that could not be replicated at a meeting with BS&G on May 28, 2019. BS&G has not provided more information regarding the issues with replicability noted in comment #B.2 to date. EPA notes that it has provided BS&G with the calculator tool needed to conduct the analysis and all necessary inputs in order to replicate EPA's calculations.

Comment B.3

Chronic Whole Effluent Toxicity Testing is not Appropriate for the Facility

BSG submitted a letter dated September 9, 2016 providing information to USEPA and MADEP that included information about BSG's intermittent flow (Attachment 1) and a discussion that chronic WET testing was not appropriate for the Facility's discharge. BSG also included this information in its 2017 Comments. As noted in the Fact Sheet for the 2017 Draft Permit, "[a]cute exposures of the effluent are typically considered for intermittent industrial stormwater discharges." It is particularly noteworthy that the dissolved salts at the Facility, which are mainly from the road system that encircle the Facility, contribute to the issue with the proposed toxicity testing.

The attached recent daily flow data further demonstrates the intermittent nature of the flow (Attachment 2). BSG requests that the chronic WET testing requirements be removed from the final permit. BSG also

requests that the intermittent nature of the discharge be considered when establishing permit limits for copper, chromium (VI) and aluminum.

The long-term exposure methodology used for chronic testing is not representative of BSG's discharge and therefore it overestimates the potential impact of the discharge. Chronic test methods from USEPA's Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, EPA-821-R-02-013, October 2001 as reference in Appendix B of the 2019 Draft Permit "are designed to provide dose--response information, expressed as the percent effluent concentration that affects the hatchability, gross morphological abnormalities, survival, growth, and/or reproduction within the prescribed period of time (four to seven days)." However, as shown in the attached flow data, BSG's intermittent flow typically does not discharge more than 5 consecutive days, if discharging at all. BSG notes that given the location of its discharge pipe alternatives may be considered to change the configuration of the pipe into the receiving water body to provide some dilution.

Response to Comment B.3

The request to eliminate chronic WET testing is addressed in the response to comment #A.9. Information on intermittent flow and implications for exposure has been addressed in responses to comments #A.2, #A.3 and #A.9.

Comment B.4

Collaboration to Establish Mass Limits has not Occurred

In its 2017 Comments, BSG requested mass limits be used in recognition of the water conservation practices implemented at the Facility resulting in a 59% reduction in flow between 2002 and 2019. The 2017 Comments state "BSG would welcome the opportunity to discuss an appropriate basis for developing mass-based limits which recognized the significant effort and costs the Facility have invested to reduce the pollutant load." Neither MADEP nor USEPA initiated collaboration on developing an appropriate approach, and the 2019 Draft Permit does not include revised limits for further review and comment to determine if such an approach has been applied. Prior to the issuance of a final permit, BSG requests confirmation if mass limits will be included and whether it will be allowed an opportunity to review how they were derived.

Response to Comment B.4

The request for mass-based limits is addressed in response to comment #A.4. For the reasons discussed in that response, the agencies have decided to reissue the permit with concentration-based metals limits.

EPA understands Boston Sand & Gravel's interest in continuing dialogue about the permit. The agencies have provided two comment periods for Boston Sand & Gravel to discuss its views and provide data for consideration, and have reviewed and considered all information provided as part of finalizing the permit. At this time there is no compelling reason for additional dialogue prior to issuing the final permit. (*See also* Response to Comment #A.13 for further discussion on requests for collaboration).

Comment B.5

Requests to Review Revised Draft Permit Prior to Finalization and for Public Hearing

In its 2017 Comments, BSG requested the opportunity to review the revised draft permit prior to finalization. However, only selected portions (specifically the copper limit) have been provided for review. Given the wide ranging and interconnected requests that BSG has made in its comment letters, a thorough review of the draft final permit prior to finalization would narrow any issues in a permit appeal to the extent any appeal is necessary. Therefore, BSG repeats its request to have the opportunity to review the revised draft permit prior to finalization. In addition, BSG respectfully requests pursuant to 40 CFR 124.11 that USEPA hold a public hearing concerning this draft permit. BSG suggests that a public hearing is appropriate under 40 CFR 124.12(a)(2) During a public hearing, BSG would address its 2017 and 2019 Comments on the revised draft permit as it believes a hearing would allow BSG to clarify numerous issues related to the permit decision.

Response to Comment B.5

The authority to hold a public hearing on a NPDES permit lies with the Regional Administrator, pursuant to 40 C.F.R. § 124.12(a), upon a finding of a significant degree of public interest, “on the basis of requests,” or a determination that the hearing might clarify issues in the permit decision, under subsection (b). In this case, no other requests for a public hearing were received. The comments were cogent, evidencing an understanding of the issues of the draft permit in light of the fact sheet explanations, and there was no need to further delay issuance of this permit for any additional clarification in light of that fact. EPA therefore decided not to hold a public hearing and sent a letter informing Boston Sand & Gravel of this decision on April 18, 2019.

See Response to Comment #A.13 regarding requests for collaboration and to review the draft permit prior to finalization.

Comment B.6

Request for a Comprehensive and Collaborative Approach

BSG requests that USEPA and MADEP consider all of its comments comprehensively, as well as the small size of the Facility, the costs associated with increased monitoring, and BSG's history of reducing pollutant loads in determining the final permit. In addition, BSG requests that USEPA and MADEP provide it with sufficient time to comply with any final permit.

Response to Comment B.6

EPA acknowledges this comment. The request for a compliance period for water quality-based effluent limitations was granted and explained in response to comment #A.10.

Attachment A.3

Reasonable Potential Analysis for Aluminum and Chromium (VI)

October 2016 – May 2018 DMR data, 18 data points

DMR data for months where there was no discharge were not used to determine reasonable potential. The applicable acute criterion for aluminum is 750 µg/L Total Recoverable Aluminum. The applicable acute criterion for chromium (VI) is 16 µg/L Dissolved Chromium (VI). There is reasonable potential for the discharge to cause or contribute to a violation of aluminum and chromium (VI) criteria because the criteria are lower than the projected 95th percentile metal concentration.

Aluminum - Lognormal distribution, no non-detects	
k = number of daily samples =	18
μ_y = mean of natural log of daily discharge =	5.09
s_y = standard deviation of natural log of daily discharge =	0.98
95 th percentile daily max estimate = $\exp(\mu_y + 1.645*s_y)$	
estimated daily max including dilution factor =	814 µg/L

Chromium (VI) - Lognormal distribution, some non-detects	
μ_y = mean of natural log of daily discharge =	4.52
$S(y_i - \mu_y)^2$ =	9.33
k = number of daily samples =	18
r = number of non-detects =	10
s_y^2 = estimated variance = $(S[(y_i - \mu_y)^2]) / (k-r-1)$ =	1.33
s_y = standard deviation = square root s_y^2 =	1.15
δ = number of non-detect values/number of samples =	0.56
z, 95 th percentile = z-score $[(0.95-\delta)/(1-\delta)]$ =	1.21
95 th percentile daily max estimate = $\exp(\mu_y + z\text{-score}*s_y)$	
estimated daily max including dilution factor =	374 µg/L

Attachment B.2

Reasonable Potential Analysis for Copper

October 2016 – May 2018 DMR data, 18 data points

DMR data for months where there was no discharge were not used to determine reasonable potential. The applicable acute criterion for aluminum is 29 µg/L Total Recoverable Copper. There is reasonable potential for the discharge to cause or contribute to a violation of the copper criterion because the criterion is lower than the projected 99th percentile copper concentration.

Copper - lognormal distribution, no non-detects	
k = number of daily samples =	18
μ_y = mean of natural log of daily discharge =	1.80
s_y = standard deviation of natural log of daily discharge =	0.89
99 th percentile daily max estimate = $\exp(\mu_y + 2.326*s_y)$	
estimated daily max including dilution factor =	48.3 µg/L

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA", and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Boston Sand and Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114**

is authorized to discharge from a facility located at

**500 Front Street
Charlestown, MA 02129**

to receiving a water named

Unnamed Tributary to the Charles River ("Millers River", Outfall 001)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the first day of the calendar month following sixty (60) days after signature if comments are received.*

This permit and the authorization to discharge expire at midnight, five (5) years from the last day of the month preceding the effective date.

This permit supersedes the permit issued on September 28, 2007.

This permit consists of 18 pages in Part I including effluent limitations and monitoring requirements, **a revised copper effluent limitation in Part I.A.1**, 15 pages in Attachments A (USEPA Region 1 Freshwater Acute Toxicity Procedure and Protocol, February 2011) and B (USEPA Region 1 Freshwater Chronic Toxicity Procedure and Protocol, March 2013), and 25 pages in Part II, the Standard Conditions.

Signed this day of , 2019

Ken Moraff, Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Lealdon Langley, Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

* Pursuant to 40 CFR 124.15(b)(3), if no comments requesting a change to the draft permit are received, the permit will become effective upon the date of signature.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge treated process water and stormwater through **Outfall Serial Number 001** to the Unnamed Tributary to the Charles River (“Millers River”)^{1,2}.

Effluent characteristic	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Flow	GPD	Report	Report	Continuous	Recorder
pH ⁵	S.U.	--	6.5 to 8.3	1/Month	Grab
Total Suspended Solids (TSS)	mg/L	20	45	1/Week	Grab
Turbidity	NTU	25	Report	1/Month	Grab
Total Sulfate	mg/L	250	Report	1/Month	Grab
Oil & Grease	mg/L	--	15	1/Month	Grab
Total Petroleum Hydrocarbons (TPH)	mg/L	--	Report	1/Month	Grab
Total Recoverable Copper	µg/L	18	29 26.3	1/Month	Grab
Dissolved Chromium (VI)	µg/L	11	16	1/Month	Grab
Total Recoverable Chromium	µg/L	--	Report	1/Month	Grab
Total Recoverable Aluminum	µg/L	87	750	1/Month	Grab
Hardness of Effluent	mg/L as CaCO ₃	--	Report	1/Month	Grab
Hardness of Receiving Water	mg/L as CaCO ₃	--	Report	1/Month	Grab
Total Phosphorus	mg/L	--	Report	1/Month	Grab
<i>E. Coli</i>	cfu/100mL	--	Report	1/Month	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity (WET) Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁶⁻⁹	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Acute LC50	%	LC50 ≥ 100%		1/Quarter	Grab
Chronic C-NOEC	%	NOEC ≥ 100%		1/Quarter	Grab
Effluent Chemistry					
Hardness	mg/L	Report		1/Quarter	Grab
Alkalinity	mg/L	Report		1/Quarter	Grab
pH	S.U.	Report		1/Quarter	Grab
Specific Conductance	μmhos/cm	Report		1/Quarter	Grab
Total Solids	mg/L	Report		1/Quarter	Grab
Total Dissolved Solids	mg/L	Report		1/Quarter	Grab
Total Ammonia Nitrogen	mg/L	Report		1/Quarter	Grab
Total Organic Carbon	mg/L	Report		1/Quarter	Grab
Total Residual Chlorine	mg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	mg/L	Report		1/Quarter	Grab
Total Recoverable Lead	mg/L	Report		1/Quarter	Grab
Total Recoverable Copper	mg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	mg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	mg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	mg/L	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁶⁻⁹	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Receiving Water Chemistry					
Hardness	mg/L	Report		1/Quarter	Grab
Alkalinity	mg/L	Report		1/Quarter	Grab
pH	S.U.	Report		1/Quarter	Grab
Specific Conductance	µmhos/cm	Report		1/Quarter	Grab
Total Solids	mg/L	Report		1/Quarter	Grab
Total Dissolved Solids	mg/L	Report		1/Quarter	Grab
Total Ammonia Nitrogen	mg/L	Report		1/Quarter	Grab
Total Organic Carbon	mg/L	Report		1/Quarter	Grab
Total Residual Chlorine	mg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	mg/L	Report		1/Quarter	Grab
Total Recoverable Lead	mg/L	Report		1/Quarter	Grab
Total Recoverable Copper	mg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	mg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	mg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	mg/L	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.**Footnotes for monitoring at Outfall 001:**

1. Such discharge shall: 1) be limited and monitored by the permittee as specified below; and 2) not cause a violation of the State Surface Water Quality Standards (314 CMR 4.00) of the receiving water.
2. Effluent samples shall be representative of the discharge and shall be taken from Lagoon 9, as close as practicable to the overflow, during the discharge of effluent to the designated receiving water. Changes in sampling location must be approved in writing by the U.S. Environmental Protection Agency (EPA). Sampling discharges from the facility must yield data representative of the discharge under authority of CWA Section 308(a) and in accordance with 40 Code of Federal Regulations (CFR) §122.41(j), §122.44(i), and §122.48. Samples shall be taken when discharging. During months when no tests are performed or required, NODI (no discharge) code 9 shall be entered for that month.
3. In accordance with 40 CFR §122.44(i)(1)(iv), the permittee shall use sufficiently sensitive test procedures (i.e., methods) approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O, for the analysis of pollutants or pollutant parameters limited in this permit (except for WET limits). A method is considered “sufficiently sensitive” when either: (1) the method minimum level (ML) is at or below the level of the effluent limit established in this permit for the measured pollutant or pollutant parameter; or (2) the method has the lowest ML of the analytical methods approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O for the measured pollutant or pollutant parameter. The ML is not the minimum level of detection, but rather the lowest level at which the test equipment produces a recognizable signal and acceptable calibration point for a pollutant or pollutant parameter, representative of the lowest concentration at which a pollutant or pollutant parameter can be measured with a known level of confidence. For the purposes of this permit, the detection limit is the lowest concentration that can be reliably measured within specified limits of precision and accuracy for a specific laboratory analytical method during routine laboratory operating conditions (i.e., the level above which an actual value is reported for an analyte, and the level below which an analyte is reported as non-detect).
4. Sampling frequency of once per week is defined as the sampling of one (1) discharge event in each calendar week, when discharge occurs. Sampling frequency of once per month is defined as the sampling of one (1) discharge event in each calendar month, when discharge occurs. Sampling frequency of 1/quarter is defined as the sampling of four (4) discharge events in each calendar year, when discharge occurs. Quarters are defined as the interval of time between the months of: January through March, inclusive; April through June, inclusive; July through September, inclusive; and October through December, inclusive. Quarterly sampling shall be performed concurrently with the monthly monitoring event. The permittee shall submit the results to EPA of any additional testing done to that required herein, if it is conducted in accordance with EPA approved methods consistent with the provisions of 40 CFR §122.41(l)(4)(ii).
5. Requirement for State Certification. The pH of the effluent shall not be less than 6.5 standard units (SU), nor greater than 8.3 SU at any time, unless these values are exceeded due to natural causes. The pH shall be no more than 0.5 units outside the natural background range.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

6. WET test samples shall be collected quarterly during the months of January, April, July, and October. The test results shall be submitted by the last day of the month following the completion of the test. The permittee shall conduct acute and chronic WET tests specified in the WET test protocols can be found in Attachments A and B of the permit. The permittee shall test the daphnid, *Ceriodaphnia dubia*.
7. LC50 (lethal concentration to 50 percent) is the concentration of wastewater causing mortality to 50% of the test organisms. The C-NOEC (chronic no observed effect concentration) is the highest effluent concentration at which there is no statistically-significant adverse effect on the survival of the test organisms when compared with the diluent control survival at the time of observation.
8. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall either follow procedures outlined in Attachment A (Toxicity Test Procedure and Protocol) Section IV., DILUTION WATER in order to obtain an individual approval for use of an alternate dilution water, or the permittee shall follow the Self-Implementing Alternative Dilution Water Guidance, which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water (see page 4 in <https://www3.epa.gov/region1/npdes/permits/generic/Alternatedilutionwaterguidance.pdf>).
9. The permittee shall conduct the analyses specified in Attachments A and B, Part VI. CHEMICAL ANALYSIS, of this permit. Even where an alternate dilution water is permitted, the receiving water control (0% effluent) must still be analyzed. MLs and methods are specified in Attachments A and B, Part VI: CHEMICAL ANALYSIS. Sampling for any parameter required for WET may be used to satisfy any duplicative sampling required for that parameter in this permit, so long as the sampling requirement for WET is equivalent with the sampling requirements otherwise established for that parameter in this permit.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

2. The discharge shall not cause a violation of the water quality standards of the receiving waters.
3. The pH of the effluent shall not be less than 6.5 or greater than 8.3 at any time.
4. The discharge shall not cause objectionable discoloration of the receiving waters.
5. The effluent shall not contain a visible oil sheen, foam, or floating solids at any time.
6. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
7. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.
8. All existing manufacturing, commercial, mining and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge, on a routine basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. One hundred micrograms per liter (100 µg/l);
 - ii. Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7); or
 - iv. Any other notification level established by the Director in accordance with 40 CFR §122.44(f).
 - b. That any activity has occurred or will occur which would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. Five hundred micrograms per liter (500 µg/l);
 - ii. One milligram per liter (1 mg/l) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7).
 - iv. Any other notification level established by the Director in accordance with 40 CFR §122.44(f).

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

c. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the permit application.

9. The results of sampling for any parameter done in accordance with EPA approved methods above its required frequency must also be reported in accordance with 40 CFR §122.41(l)(4)(ii).

PART I.B. STORMWATER POLLUTION PREVENTION PLAN

1. The permittee shall maintain a Stormwater Pollution Prevention Plan (SWPPP) designed to reduce, or prevent, the discharge of pollutants in stormwater to the receiving waters identified in this permit. The SWPPP shall be a written document and consistent with the terms of this permit. The permittee shall comply with the terms of its SWPPP.
2. The SWPPP, including the SWPPP site map, shall be updated and signed by the permittee within ninety (90) days after the effective date of this permit. The permittee shall certify that the SWPPP has been completed or updated and that it meets the requirements of the permit. The certification shall be signed in accordance with the requirements identified in 40 CFR §122.22. A copy of this certification and a hardcopy of the SWPPP shall be sent to EPA and MassDEP within thirty (30) days after the certification date.
3. The SWPPP shall be consistent with the general provisions for SWPPPs included in the most current version of the Multi-Sector General Permits for Stormwater Discharges Associated with Industrial Activities (MSGP). (The current MSGP was effective June 4, 2015 – see https://www.epa.gov/sites/production/files/2015-10/documents/msgp2015_finalpermit.pdf). However, where any provision that applies to outfalls authorized under this permit differs from the requirements of a SWPPP prepared to meet the requirements of the MSGP, the requirements in this permit shall take precedence.
4. The SWPPP shall be prepared in accordance with good engineering practices, identify potential sources of pollution that may reasonably be expected to affect the quality of the stormwater discharges, and describe and ensure implementation of practices which will be used to reduce the pollutants and assure compliance with this permit. Specifically, the SWPPP shall contain the elements listed below:
 - a. A pollution prevention team responsible for developing, implementing, maintaining, revising and ensuring compliance with the SWPPP.
 - b. A site description which includes a list of activities at the facility; a site map showing drainage areas and direction of stormwater flows; receiving waters and outfall location; the location of industrial activities, storage, disposal, material handling; and all structural controls.
 - c. A summary of all pollutant sources which includes all areas where spills have occurred or could occur. For each source, identify the expected drainage and the corresponding pollutant.
 - d. A description of all stormwater controls, both structural and non-structural. All BMPs shall be properly maintained and be in effective operating conditions. BMPs must be selected and implemented as non-numeric technology-based effluent limitations. BMPs must include good housekeeping measures, preventative maintenance programs, spill and leak prevention and response procedures, erosion and sediment controls, and runoff management practices. The SWPPP shall describe how the BMPs are appropriate for the facility.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

e. A record of the following information for all chemical products that could potentially have an impact to stormwater associated with industrial activity as defined in §122.26(b)(14)(i)-(ix),(xi):

- i. Product name, chemical formula, and manufacturer;
- ii. Purpose or use of the chemical;
- iii. Safety Data Sheet (SDS) and Chemical Abstracts Service (CAS) Registry number for each chemical;
- iv. The frequency (e.g., hourly, daily), duration (e.g., hours, days), quantity (e.g., maximum and average), and method of application for the chemical; and
- v. The vendor's reported aquatic toxicity (NOAEL and/or LC50 in percent for aquatic organism(s)), when available.

f. A description of the training to be provided for employees to assure they understand the goals, objectives, and procedures of the SWPPP, the requirements of the NPDES permit, and their individual responsibilities for complying with the goals and objectives of the SWPPP and the NPDES permit.

g. Minimum documentation requirements are as follows:

- i. Records of operational and preventive maintenance activities, equipment inspections, procedure audits, and personnel training;
- ii. Records of the collection and analysis of samples, including, but not limited to, sample location, any calculations done at the time of sampling, any sampling or analytical methods used for samples analyzed on site, and sample results;
- iii. Any records of the collection and analysis of samples, the evaluation of design standards and operational changes, the selection, design, installation, and implementation of control measures, and/or evaluations, identifications, examinations and/or explanations documented in support of the residuals management BMP and/or environmental monitoring program requirement, below; and
- iv. All documentation of SWPPP activities shall be kept at the facility for at least three years and provided to EPA or MassDEP upon request.

5. All areas identified in the SWPPP shall be inspected, at least on a quarterly basis. Inspections shall occur beginning the 1st quarter after the effective date of the permit. EPA considers quarters as follows: January to March; April to June; July to September; and October to December.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

6. The permittee shall amend and update the SWPPP within 14 days for any changes at the facility affecting the SWPPP. Changes which may affect the SWPPP include, but are not limited to, the following activities: a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to the waters of the United States; a release of a reportable quantity of pollutants as described in 40 CFR §302; or a determination by the permittee or EPA that the SWPPP appears to be ineffective in achieving the general objective of controlling pollutants in stormwater discharges associated with industrial activity. Any amended or new versions of the SWPPP shall be re-certified by the permittee. Such re-certifications also shall be signed in accordance with the requirements identified in 40 CFR §122.22.

7. The permittee shall certify at least annually that the previous year's inspections and maintenance activities were conducted, results were recorded, records were maintained, and that the facility is in compliance with the SWPPP. If the facility is not in compliance with any aspect of the SWPPP, the annual certification shall state the non-compliance and the remedies which are being undertaken. Such annual certifications also shall be signed in accordance with the requirements identified in 40 CFR §122.22. The permittee shall keep a copy of the current SWPPP and all SWPPP certifications (the initial certification, recertifications, and annual certifications) signed during the effective period of this permit at the facility and shall make them available for inspection by EPA and MassDEP.

8. The SWPPP shall include best management practices (BMPs) for on-site activities that will minimize the discharge of pollutants in stormwater to waters of the United States. The permittee shall develop and implement site-specific BMPs; including BMPs to achieve the following:

- a. Store materials and equipment indoors such that contact with stormwater is limited and avoided whenever possible.
- b. Protect material stockpiles and equipment not stored indoors with weather-resistant covers to minimize exposure to rain and wind.
- c. Ensure stormwater not discharged through Outfall 001 remains on-site.
- d. Undertake reasonable efforts to control or reduce stormwater runoff volume to allow for proper operation of the WWTF.
- e. Ensure for proper cleanup of chemical spills that may come in contact with stormwater.
- f. Use vacuum equipment to sweep all paved or impervious areas of its property draining to Outfall 001 where solids deposition may occur, including roads, driveways, parking areas, sidewalks, and loading areas.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

- g. Inspect onsite pollution control measures more frequently following severe weather events or natural disasters when these conditions may result in increased pollutant discharges to the Unnamed Tributary.

Additionally, the permittee shall continue to implement site specific BMPs that are required for Sector E (Glass, Clay, Cement, Concrete, and Gypsum Products) of the current MSGP.

PART I.C. PHOSPHORUS CONTROL PLAN (PCP)

The PCP shall be developed and fully implemented during the permit term to meet the 62% phosphorus load reduction waste load allocation (WLA) set forth in the Lower Charles River TMDL. The permittee is required to develop and implement the following site-specific PCP:

- Within two (2) years of the effective date of the permit, in order to establish baseline conditions, the permittee shall:
 - complete the estimation of the average annual phosphorus load to the permitted outfall using influent and effluent phosphorus data, and
 - complete an evaluation of any additional structural or non-structural BMPs that reduce the phosphorus load to the Unnamed Tributary.
- Within three-and-a-half (3.5) years of the effective date of the permit, the permittee shall:
 - begin construction or implementation of BMPs designed to reduce phosphorus loads, and
 - monitor the effectiveness of those BMPs.
- Within five (5) years of the effective date of the permit, provide to EPA a report including:
 - a summary of phosphorus data analysis and phosphorus load estimation,
 - a description of the evaluation of additional phosphorus reduction BMPs beyond the WWTF (if applicable),
 - an operation, maintenance, and inspection plan of additional phosphorus reduction BMPs (if applicable),
 - a demonstration of the capacity of the entire facility to meet the 62% phosphorus WLA-based reduction target.

PART I.D. SOURCE IDENTIFICATION AND REDUCTION PLAN (SIRP)Metals

The permittee shall continue to implement the Source Identification and Reduction Plan (SIRP) for copper, chromium (VI), and aluminum. In addition, the permittee shall

- attempt to eliminate, or reduce to the maximum extent possible, the discharge of these pollutants from the facility,
- take additional samples to characterize the concentration and variability of each of the metals in onsite source streams using sufficiently sensitive analytical methods,
- develop BMPs to significantly reduce or eliminate the pollutant loading(s) to the receiving water in the event the source(s) of these metals cannot be eliminated, and evaluate whether site-specific stormwater BMPs can be used in conjunction with commingled stormwater and process water treatment options (e.g. pH adjustment, flocculation, and/or coagulation in the Wastewater Treatment Facility) to reduce metals identified as contributing to or causing an excursion of water quality standards in the receiving water (including but not limited to copper, chromium(VI), and aluminum), and
- update or amend the SIRP with any BMPs resulting from the evaluation within one (1) year after the effective date of the permit.

Pathogens

The permittee shall develop and implement a Source Identification and Reduction Plan (SIRP) in order to

- eliminate or reduce the discharge of bacteria through the facility's stormwater system, e.g. identifying and eliminating illicit sewer connections to the facility's drainage system, and
- significantly reduce or eliminate the bacteria loading to the receiving water via the development of BMPs in the event the source(s) of bacteria cannot be eliminated.

PART I.E. MONITORING AND REPORTING

The monitoring program in the permit specifies sampling and analysis, which will provide continuous information on compliance and the reliability and effectiveness of the installed pollution abatement equipment. The approved analytical procedures found in 40 CFR Part 136 are required unless other procedures are explicitly required in the permit. The permittee is obligated to monitor and report sampling results to EPA and the MassDEP within the time specified within the permit. Unless otherwise specified in this permit, the permittee shall submit reports, requests, and information and provide notices in the manner described in this section.

1. Submittal of Reports as NetDMR Attachments

As the permittee is already using NetDMR, the permittee shall electronically submit all reports to EPA as NetDMR attachments rather than as hard copies, unless otherwise specified in this permit. Permittees shall continue to send hard copies of reports other than DMRs to MassDEP until further notice from MassDEP. (See Part I.E.5 for more information on state reporting.) Because the due dates for reports described in this permit may not coincide with the due date for submitting DMRs (which is no later than the 15th day of the month), a report submitted electronically as a NetDMR attachment shall be considered timely if it is electronically submitted to EPA using NetDMR with the next DMR due following the particular report due date specified in this permit.

2. Submittal of Requests and Reports to EPA/OEP

The following requests, reports, and information described in this permit shall be submitted to the EPA/OEP NPDES Applications Coordinator in the EPA Office Ecosystem Protection (OEP).

- a. Transfer of permit notice
- b. Request for changes in sampling location
- c. Request for reduction in WET testing requirement
- d. Report on unacceptable dilution water / request for alternative dilution water for WET testing
- e. Notification of proposal to add or replace chemicals, including chemical additives

3. Submittal of Requests and Reports to EPA/OEP

These reports, information, and requests shall be submitted to EPA/OEP electronically at R1NPDES.Notices.OEP@epa.gov.

PART I.E. MONITORING AND REPORTING, cont'd.**4. Submittal of Reports in Hard Copy Form**

The following notifications and reports shall be submitted as hard copy with a cover letter describing the submission. These reports shall be signed and dated originals submitted to EPA.

- a. Written notifications required under Part II
- b. Notice of unauthorized discharges
- c. Reports and DMRs submitted prior to the use of NetDMR

This information shall be submitted to EPA/OES and MassDEP at the following addresses:

U.S. Environmental Protection Agency
Office of Environmental Stewardship (OES)
Water Technical Unit
5 Post Office Square, Suite 100 (OES04-4)
Boston, MA 02109-3912

Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, MA 01887

5. State Reporting

Transfer or termination of permit notices shall also specifically be submitted to:

Massachusetts Department of Environmental Protection
Bureau of Water Resources
Wastewater Management Program
1 Winter Street, 5th Floor
Boston, MA 02108

PART I.E. MONITORING AND REPORTING, cont'd.

Unless otherwise specified in this permit, duplicate signed copies of all reports, information, requests or notifications described in this permit, including the reports, information, requests or notifications described in Parts I.E.2, I.E.3, and I.E.4 also shall be submitted to the State at the following address:

Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, Massachusetts 01887

Hard copies of Whole Effluent Toxicity tests and reports only shall be submitted to:

Massachusetts Department of Environmental Protection
Watershed Planning Program
8 New Bond Street
Worcester, MA 01606

7. Verbal Reports and Verbal Notifications

Any verbal reports or verbal notifications, if required in Parts I and/or II of this permit, shall be made to both EPA and to MassDEP. This includes verbal reports and notifications which require reporting within 24 hours. (As examples, see Part II.B.4.c. (2), Part II.B.5.c. (3), and Part II.D.1.e.) Verbal reports and verbal notifications shall be made to EPA's Office of Environmental Stewardship at: **617-918-1510**.

PART I.F. STATE PERMIT CONDITIONS

1. This authorization to discharge includes two separate and independent permit authorizations. The two permit authorizations are (i) a federal National Pollutant Discharge Elimination System permit issued by the U.S. Environmental Protection Agency (EPA) pursuant to the Federal Clean Water Act, 33 U.S.C. §§1251 et seq.; and (ii) an identical state surface water discharge permit issued by the Commissioner of the Massachusetts Department of Environmental Protection (MassDEP) pursuant to the Massachusetts Clean Waters Act, M.G.L. c. 21, §§26-53, and 314 CMR 3.00. All of the requirements contained in this authorization, as well as the standard conditions contained in 314 CMR 3.19, are hereby incorporated by reference into this state surface water discharge permit.
2. This authorization also incorporates the state water quality certification issued by MassDEP under §401(a) of the Federal Clean Water Act, 40 CFR 124.53, M.G.L. c. 21, §27 and 314 CMR 3.07. All of the requirements (if any) contained in MassDEP's water quality certification for the permit are hereby incorporated by reference into this state surface water discharge permit as special conditions pursuant to 314 CMR 3.11.
3. Each agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this permit shall be effective only with respect to the agency taking such action, and shall not affect the validity or status of this permit as issued by the other agency, unless and until each agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this permit is declared invalid, illegal or otherwise issued in violation of state law such permit shall remain in full force and effect under federal law as a NPDES permit issued by the U.S. Environmental Protection Agency. In the event this permit is declared invalid, illegal or otherwise issued in violation of federal law, this permit shall remain in full force and effect under state law as a permit issued by the Commonwealth of Massachusetts.
4. The permittee shall ensure that sweepings collected at its facility are reused or disposed in a manner consistent with MassDEP's Policy #BWP-94-092: Reuse and Disposal of Street Sweepings.

USEPA REGION 1 FRESHWATER ACUTE TOXICITY TEST PROCEDURE AND PROTOCOL

I. GENERAL REQUIREMENTS

The permittee shall conduct acceptable acute toxicity tests in accordance with the appropriate test protocols described below:

- **Daphnid (Ceriodaphnia dubia) definitive 48 hour test.**
- **Fathead Minnow (Pimephales promelas) definitive 48 hour test.**

Acute toxicity test data shall be reported as outlined in Section VIII.

II. METHODS

The permittee shall use 40 CFR Part 136 methods. Methods and guidance may be found at:

http://water.epa.gov/scitech/methods/cwa/wet/disk2_index.cfm

The permittee shall also meet the sampling, analysis and reporting requirements included in this protocol. This protocol defines more specific requirements while still being consistent with the Part 136 methods. If, due to modifications of Part 136, there are conflicting requirements between the Part 136 method and this protocol, the permittee shall comply with the requirements of the Part 136 method.

III. SAMPLE COLLECTION

A discharge sample shall be collected. Aliquots shall be split from the sample, containerized and preserved (as per 40 CFR Part 136) for chemical and physical analyses required. The remaining sample shall be measured for total residual chlorine and dechlorinated (if detected) in the laboratory using sodium thiosulfate for subsequent toxicity testing. (Note that EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection.) Grab samples must be used for pH, temperature, and total residual chlorine (as per 40 CFR Part 122.21).

Standard Methods for the Examination of Water and Wastewater describes dechlorination of samples (APHA, 1992). Dechlorination can be achieved using a ratio of 6.7 mg/L anhydrous sodium thiosulfate to reduce 1.0 mg/L chlorine. If dechlorination is necessary, a thiosulfate control (maximum amount of thiosulfate in lab control or receiving water) must also be run in the WET test.

All samples held overnight shall be refrigerated at 1- 6°C.

IV. DILUTION WATER

A grab sample of dilution water used for acute toxicity testing shall be collected from the receiving water at a point immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location. Avoid collection near areas of obvious road or agricultural runoff, storm sewers or other point source discharges and areas where stagnant conditions exist. In the case where an alternate dilution water has been agreed upon an additional receiving water control (0% effluent) must also be tested.

If the receiving water diluent is found to be, or suspected to be toxic or unreliable, an alternate standard dilution water of known quality with a hardness, pH, conductivity, alkalinity, organic carbon, and total suspended solids similar to that of the receiving water may be substituted **AFTER RECEIVING WRITTEN APPROVAL FROM THE PERMIT ISSUING AGENCY(S)**. Written requests for use of an alternate dilution water should be mailed with supporting documentation to the following address:

Director
Office of Ecosystem Protection (CAA)
U.S. Environmental Protection Agency-New England
5 Post Office Sq., Suite 100 (OEP06-5)
Boston, MA 02109-3912

and

Manager
Water Technical Unit (SEW)
U.S. Environmental Protection Agency
5 Post Office Sq., Suite 100 (OES04-4)
Boston, MA 02109-3912

Note: USEPA Region 1 retains the right to modify any part of the alternate dilution water policy stated in this protocol at any time. Any changes to this policy will be documented in the annual DMR posting.

See the most current annual DMR instructions which can be found on the EPA Region 1 website at <http://www.epa.gov/region1/enforcement/water/dmr.html> for further important details on alternate dilution water substitution requests.

It may prove beneficial to have the proposed dilution water source screened for suitability prior to toxicity testing. EPA strongly urges that screening be done prior to set up of a full definitive toxicity test any time there is question about the dilution water's ability to support acceptable performance as outlined in the 'test acceptability' section of the protocol.

V. TEST CONDITIONS

The following tables summarize the accepted daphnid and fathead minnow toxicity test conditions and test acceptability criteria:

EPA NEW ENGLAND EFFLUENT TOXICITY TEST CONDITIONS FOR THE DAPHNID, CERIODAPHNIA DUBIA 48 HOUR ACUTE TESTS¹

1.	Test type	Static, non-renewal
2.	Temperature (°C)	20 ± 1°C or 25 ± 1°C
3.	Light quality	Ambient laboratory illumination
4.	Photoperiod	16 hour light, 8 hour dark
5.	Test chamber size	Minimum 30 ml
6.	Test solution volume	Minimum 15 ml
7.	Age of test organisms	1-24 hours (neonates)
8.	No. of daphnids per test chamber	5
9.	No. of replicate test chambers per treatment	4
10.	Total no. daphnids per test concentration	20
11.	Feeding regime	As per manual, lightly feed YCT and <u>Selenastrum</u> to newly released organisms while holding prior to initiating test
12.	Aeration	None
13.	Dilution water ²	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q ^R or equivalent deionized water and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14.	Dilution series	≥ 0.5, must bracket the permitted RWC
15.	Number of dilutions	5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution

series.

- | | | |
|-----|------------------------|--|
| 16. | Effect measured | Mortality-no movement of body
or appendages on gentle prodding |
| 17. | Test acceptability | 90% or greater survival of test organisms in
dilution water control solution |
| 18. | Sampling requirements | For on-site tests, samples must be used
within 24 hours of the time that they are
removed from the sampling device. For off-
site tests, samples must first be used within
36 hours of collection. |
| 19. | Sample volume required | Minimum 1 liter |

Footnotes:

1. Adapted from EPA-821-R-02-012.
2. Standard prepared dilution water must have hardness requirements to generally reflect the characteristics of the receiving water.

**EPA NEW ENGLAND TEST CONDITIONS FOR THE FATHEAD MINNOW
(PIMEPHALES PROMELAS) 48 HOUR ACUTE TEST¹**

1. Test Type	Static, non-renewal
2. Temperature (°C)	20 ± 1 ° C or 25 ± 1°C
3. Light quality	Ambient laboratory illumination
4. Photoperiod	16 hr light, 8 hr dark
5. Size of test vessels	250 mL minimum
6. Volume of test solution	Minimum 200 mL/replicate
7. Age of fish	1-14 days old and age within 24 hrs of each other
8. No. of fish per chamber	10
9. No. of replicate test vessels per treatment	4
10. Total no. organisms per concentration	40
11. Feeding regime	As per manual, lightly feed test age larvae using concentrated brine shrimp nauplii while holding prior to initiating test
12. Aeration	None, unless dissolved oxygen (D.O.) concentration falls below 4.0 mg/L, at which time gentle single bubble aeration should be started at a rate of less than 100 bubbles/min. (Routine D.O. check is recommended.)
13. dilution water ²	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q ^R or equivalent deionized and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14. Dilution series	≥ 0.5, must bracket the permitted RWC

15. Number of dilutions	5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution series.
16. Effect measured	Mortality-no movement on gentle prodding
17. Test acceptability	90% or greater survival of test organisms in dilution water control solution
18. Sampling requirements	For on-site tests, samples must be used within 24 hours of the time that they are removed from the sampling device. For off-site tests, samples are used within 36 hours of collection.
19. Sample volume required	Minimum 2 liters

Footnotes:

1. Adapted from EPA-821-R-02-012
2. Standard dilution water must have hardness requirements to generally reflect characteristics of the receiving water.

VI. CHEMICAL ANALYSIS

At the beginning of a static acute toxicity test, pH, conductivity, total residual chlorine, oxygen, hardness, alkalinity and temperature must be measured in the highest effluent concentration and the dilution water. Dissolved oxygen, pH and temperature are also measured at 24 and 48 hour intervals in all dilutions. The following chemical analyses shall be performed on the 100 percent effluent sample and the upstream water sample for each sampling event.

<u>Parameter</u>	<u>Effluent</u>	<u>Receiving Water</u>	<u>ML (mg/l)</u>
Hardness ¹	x	x	0.5
Total Residual Chlorine (TRC) ^{2, 3}	x		0.02
Alkalinity	x	x	2.0
pH	x	x	--
Specific Conductance	x	x	--
Total Solids	x		--
Total Dissolved Solids	x		--
Ammonia	x	x	0.1
Total Organic Carbon	x	x	0.5
Total Metals			
Cd	x	x	0.0005
Pb	x	x	0.0005
Cu	x	x	0.003
Zn	x	x	0.005
Ni	x	x	0.005
Al	x	x	0.02
Other as permit requires			

Notes:

- Hardness may be determined by:
 - APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 2340B (hardness by calculation)
 - Method 2340C (titration)
- Total Residual Chlorine may be performed using any of the following methods provided the required minimum limit (ML) is met.
 - APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 4500-CL E Low Level Amperometric Titration
 - Method 4500-CL G DPD Colorimetric Method
- Required to be performed on the sample used for WET testing prior to its use for toxicity testing.

VII. TOXICITY TEST DATA ANALYSIS

LC50 Median Lethal Concentration (Determined at 48 Hours)

Methods of Estimation:

- Probit Method
- Spearman-Kärber
- Trimmed Spearman-Kärber
- Graphical

See the flow chart in Figure 6 on p. 73 of EPA-821-R-02-012 for appropriate method to use on a given data set.

No Observed Acute Effect Level (NOAEL)

See the flow chart in Figure 13 on p. 87 of EPA-821-R-02-012.

VIII. TOXICITY TEST REPORTING

A report of the results will include the following:

- Description of sample collection procedures, site description
- Names of individuals collecting and transporting samples, times and dates of sample collection and analysis on chain-of-custody
- General description of tests: age of test organisms, origin, dates and results of standard toxicant tests; light and temperature regime; other information on test conditions if different than procedures recommended. Reference toxicant test data should be included.
- All chemical/physical data generated. (Include minimum detection levels and minimum quantification levels.)
- Raw data and bench sheets.
- Provide a description of dechlorination procedures (as applicable).
- Any other observations or test conditions affecting test outcome.

FRESHWATER CHRONIC TOXICITY TEST PROCEDURE AND PROTOCOL

USEPA Region 1

I. GENERAL REQUIREMENTS

The permittee shall be responsible for the conduct of acceptable chronic toxicity tests using three fresh samples collected during each test period. The following tests shall be performed as prescribed in Part 1 of the NPDES discharge permit in accordance with the appropriate test protocols described below. (Note: the permittee and testing laboratory should review the applicable permit to determine whether testing of one or both species is required).

- **Daphnid (Ceriodaphnia dubia) Survival and Reproduction Test.**
- **Fathead Minnow (Pimephales promelas) Larval Growth and Survival Test.**

Chronic toxicity data shall be reported as outlined in Section VIII.

II. METHODS

Methods to follow are those recommended by EPA in: Short Term Methods For Estimating The Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, Fourth Edition, October 2002. United States Environmental Protection Agency. Office of Water, Washington, D.C., EPA 821-R-02-013. The methods are available on-line at <http://www.epa.gov/waterscience/WET/> . Exceptions and clarification are stated herein.

III. SAMPLE COLLECTION AND USE

A total of three fresh samples of effluent and receiving water are required for initiation and subsequent renewals of a freshwater, chronic, toxicity test. The receiving water control sample must be collected immediately upstream of the permitted discharge's zone of influence. Fresh samples are recommended for use on test days 1, 3, and 5. However, provided a total of three samples are used for testing over the test period, an alternate sampling schedule is acceptable. The acceptable holding times until initial use of a sample are 24 and 36 hours for on-site and off-site testing, respectively. A written waiver is required from the regulating authority for any hold time extension. All test samples collected may be used for 24, 48 and 72 hour renewals after initial use. All samples held for use beyond the day of sampling shall be refrigerated and maintained at a temperature range of 0-6° C.

All samples submitted for chemical and physical analyses will be analyzed according to Section VI of this protocol.

Sampling guidance dictates that, where appropriate, aliquots for the analysis required in this protocol shall be split from the samples, containerized and immediately preserved, or analyzed as per 40 CFR Part 136. EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection. Testing for the presence of total residual chlorine (TRC) must be analyzed immediately or as soon as possible, for all effluent samples, prior to WET testing. TRC analysis may be performed on-site or by the toxicity testing laboratory and the samples must be dechlorinated, as necessary, using sodium thiosulfate prior to sample use for toxicity testing.

If any of the renewal samples are of sufficient potency to cause lethality to 50 percent or more of the test organisms in any of the test treatments for either species or, if the test fails to meet its permit limits, then chemical analysis for total metals (originally required for the initial sample only in Section VI) will be required on the renewal sample(s) as well.

IV. DILUTION WATER

Samples of receiving water must be collected from a location in the receiving water body immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location. Avoid collection near areas of obvious road or agricultural runoff, storm sewers or other point source discharges and areas where stagnant conditions exist. EPA strongly urges that screening for toxicity be performed prior to the set up of a full, definitive toxicity test any time there is a question about the test dilution water's ability to achieve test acceptability criteria (TAC) as indicated in Section V of this protocol. The test dilution water control response will be used in the statistical analysis of the toxicity test data. All other control(s) required to be run in the test will be reported as specified in the Discharge Monitoring Report (DMR) Instructions, Attachment F, page 2, Test Results & Permit Limits.

The test dilution water must be used to determine whether the test met the applicable TAC. When receiving water is used for test dilution, an additional control made up of standard laboratory water (0% effluent) is required. This control will be used to verify the health of the test organisms and evaluate to what extent, if any, the receiving water itself is responsible for any toxic response observed.

If dechlorination of a sample by the toxicity testing laboratory is necessary a "sodium thiosulfate" control, representing the concentration of sodium thiosulfate used to adequately dechlorinate the sample prior to toxicity testing, must be included in the test.

If the use of an alternate dilution water (ADW) is authorized, in addition to the ADW test control, the testing laboratory must, for the purpose of monitoring the receiving water, also run a receiving water control.

If the receiving water diluent is found to be, or suspected to be toxic or unreliable an ADW of known quality with hardness similar to that of the receiving water may be substituted. Substitution is species specific meaning that the decision to use ADW is made for each species and is based on the toxic response of that particular species. Substitution to an ADW is authorized in two cases. The first is the case where repeating a test due to toxicity in the site dilution water requires an **immediate decision** for ADW use be made by the permittee and toxicity testing laboratory. The second is in the case where two of the most recent documented incidents of unacceptable site dilution water toxicity requires ADW use in future WET testing.

For the second case, written notification from the permittee requesting ADW use **and** written authorization from the permit issuing agency(s) is required **prior to** switching to a long-term use of ADW for the duration of the permit.

Written requests for use of ADW must be mailed with supporting documentation to the following addresses:

Director
Office of Ecosystem Protection (CAA)
U.S. Environmental Protection Agency, Region 1
Five Post Office Square, Suite 100
Mail Code OEP06-5
Boston, MA 02109-3912

and

Manager
Water Technical Unit (SEW)
U.S. Environmental Protection Agency
Five Post Office Square, Suite 100
Mail Code OES04-4
Boston, MA 02109-3912

Note: USEPA Region 1 retains the right to modify any part of the alternate dilution water policy stated in this protocol at any time. Any changes to this policy will be documented in the annual DMR posting.

See the most current annual DMR instructions which can be found on the EPA Region 1 website at <http://www.epa.gov/region1/enforcementandassistance/dmr.html> for further important details on alternate dilution water substitution requests.

V. TEST CONDITIONS AND TEST ACCEPTABILITY CRITERIA

Method specific test conditions and TAC are to be followed and adhered to as specified in the method guidance document, EPA 821-R-02-013. If a test does not meet TAC the test must be repeated with fresh samples within 30 days of the initial test completion date.

V.1. Use of Reference Toxicity Testing

Reference toxicity test results and applicable control charts must be included in the toxicity testing report.

If reference toxicity test results fall outside the control limits established by the laboratory for a specific test endpoint, a reason or reasons for this excursion must be evaluated, correction made and reference toxicity tests rerun as necessary.

If a test endpoint value exceeds the control limits at a frequency of more than one out of twenty then causes for the reference toxicity test failure must be examined and if problems are identified corrective action taken. The reference toxicity test must be repeated during the same month in which the exceedance occurred.

If two consecutive reference toxicity tests fall outside control limits, the possible cause(s) for the exceedance must be examined, corrective actions taken and a repeat of the reference toxicity test must take place immediately. Actions taken to resolve the problem must be reported.

V.1.a. Use of Concurrent Reference Toxicity Testing

In the case where concurrent reference toxicity testing is required due to a low frequency of testing with a particular method, if the reference toxicity test results fall slightly outside of laboratory established control limits, but the primary test met the TAC, the results of the primary test will be considered acceptable. However, if the results of the concurrent test fall well outside the established **upper** control limits i.e. ≥ 3 standard deviations for IC25 values and \geq two concentration intervals for NOECs, and even though the primary test meets TAC, the primary test will be considered unacceptable and must be repeated.

V.2. For the *C. dubia* test, the determination of TAC and formal statistical analyses must be performed using only the first three broods produced.

V.3. Test treatments must include 5 effluent concentrations and a dilution water control. An additional test treatment, at the permitted effluent concentration (% effluent), is required if it is not included in the dilution series.

VI. CHEMICAL ANALYSIS

As part of each toxicity test's daily renewal procedure, pH, specific conductance, dissolved oxygen (DO) and temperature must be measured at the beginning and end of each 24-hour period in each test treatment and the control(s).

The additional analysis that must be performed under this protocol is as specified and noted in the table below.

<u>Parameter</u>	Effluent	Receiving Water	ML (mg/l)
Hardness ^{1, 4}	x	x	0.5
Total Residual Chlorine (TRC) ^{2, 3, 4}	x		0.02
Alkalinity ⁴	x	x	2.0
pH ⁴	x	x	--
Specific Conductance ⁴	x	x	--
Total Solids ⁶	x		--
Total Dissolved Solids ⁶	x		--
Ammonia ⁴	x	x	0.1
Total Organic Carbon ⁶	x	x	0.5
Total Metals ⁵			
Cd	x	x	0.0005
Pb	x	x	0.0005
Cu	x	x	0.003
Zn	x	x	0.005
Ni	x	x	0.005
Al	x	x	0.02

Other as permit requires

Notes:

1. Hardness may be determined by:

- APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 2340B (hardness by calculation)
 - Method 2340C (titration)
2. Total Residual Chlorine may be performed using any of the following methods provided the required minimum limit (ML) is met.
- APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 4500-CL E Low Level Amperometric Titration
 - Method 4500-CL G DPD Colorimetric Method
 - USEPA 1983. Manual of Methods Analysis of Water and Wastes
 - Method 330.5
3. Required to be performed on the sample used for WET testing prior to its use for toxicity testing
4. Analysis is to be performed on samples and/or receiving water, as designated in the table above, from all three sampling events.
5. Analysis is to be performed on the initial sample(s) only unless the situation arises as stated in Section III, paragraph 4
6. Analysis to be performed on initial samples only

VII. TOXICITY TEST DATA ANALYSIS AND REVIEW

A. Test Review

1. Concentration / Response Relationship

A concentration/response relationship evaluation is required for test endpoint determinations from both Hypothesis Testing and Point Estimate techniques. The test report is to include documentation of this evaluation in support of the endpoint values reported. The dose-response review must be performed as required in Section 10.2.6 of EPA-821-R-02-013. Guidance for this review can be found at <http://water.epa.gov/scitech/methods/cwa/> . In most cases, the review will result in one of the following three conclusions: (1) Results are reliable and reportable; (2) Results are anomalous and require explanation; or (3) Results are inconclusive and a retest with fresh samples is required.

2. Test Variability (Test Sensitivity)

This review step is separate from the determination of whether a test meets or does not meet TAC. Within test variability is to be examined for the purpose of evaluating test sensitivity. This evaluation is to be performed for the sub-lethal hypothesis testing endpoints reproduction and growth as required by the permit. The test report is to include documentation of this evaluation to support that the endpoint values reported resulted from a toxicity test of adequate sensitivity. This evaluation must be performed as required in Section 10.2.8 of EPA-821-R-02-013.

To determine the adequacy of test sensitivity, USEPA requires the calculation of test percent minimum significant difference (PMSD) values. In cases where NOEC determinations are made based on a non-parametric technique, calculation of a test PMSD value, for the sole purpose of assessing test sensitivity, shall be calculated using a comparable parametric statistical analysis technique. The calculated test PMSD is then compared to the upper and lower PMSD bounds shown for freshwater tests in Section 10.2.8.3, p. 52, Table 6 of EPA-821-R-02-013. The comparison will yield one of the following determinations.

- The test PMSD exceeds the PMSD upper bound test variability criterion in Table 6, the test results are considered highly variable and the test may not be sensitive enough to determine the presence of toxicity at the permit limit concentration (PLC). If the test results indicate that the discharge is not toxic at the PLC, then the test is considered insufficiently sensitive and must be repeated within 30 days of the initial test completion using fresh samples. If the test results indicate that the discharge is toxic at the PLC, the test is considered acceptable and does not have to be repeated.
- The test PMSD falls below the PMSD lower bound test variability criterion in Table 6, the test is determined to be very sensitive. In order to determine which treatment(s) are statistically significant and which are not, for the purpose of reporting a NOEC, the relative percent difference (RPD) between the control and each treatment must be calculated and compared to the lower PMSD boundary. See *Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the NPDES Program*, EPA 833-R-00-003, June 2002, Section 6.4.2. The following link: [Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the NPDES Program](#) can be used to locate the USEPA website containing this document. If the RPD for a treatment falls below the PMSD lower bound, the difference is considered statistically insignificant. If the RPD for a treatment is greater than the PMSD lower bound, then the treatment is considered statistically significant.
- The test PMSD falls within the PMSD upper and lower bounds in Table 6, the sub-lethal test endpoint values shall be reported as is.

B. Statistical Analysis

1. General - Recommended Statistical Analysis Method

Refer to general data analysis flowchart, EPA 821-R-02-013, page 43

For discussion on Hypothesis Testing, refer to EPA 821-R-02-013, Section 9.6

For discussion on Point Estimation Techniques, refer to EPA 821-R-02-013, Section 9.7

2. *Pimephales promelas*

Refer to survival hypothesis testing analysis flowchart, EPA 821-R-02-013, page 79

Refer to survival point estimate techniques flowchart, EPA 821-R-02-013, page 80

Refer to growth data statistical analysis flowchart, EPA 821-R-02-013, page 92

3. *Ceriodaphnia dubia*

Refer to survival data testing flowchart, EPA 821-R-02-013, page 168

Refer to reproduction data testing flowchart, EPA 821-R-02-013, page 173

VIII. TOXICITY TEST REPORTING

A report of results must include the following:

- Test summary sheets (2007 DMR Attachment F) which includes:
 - Facility name
 - NPDES permit number
 - Outfall number
 - Sample type
 - Sampling method
 - Effluent TRC concentration
 - Dilution water used
 - Receiving water name and sampling location
 - Test type and species
 - Test start date
 - Effluent concentrations tested (%) and permit limit concentration
 - Applicable reference toxicity test date and whether acceptable or not
 - Age, age range and source of test organisms used for testing
 - Results of TAC review for all applicable controls
 - Test sensitivity evaluation results (test PMSD for growth and reproduction)
 - Permit limit and toxicity test results
 - Summary of test sensitivity and concentration response evaluation

In addition to the summary sheets the report must include:

- A brief description of sample collection procedures
- Chain of custody documentation including names of individuals collecting samples, times and dates of sample collection, sample locations, requested analysis and lab receipt with time and date received, lab receipt personnel and condition of samples upon receipt at the lab(s)
- Reference toxicity test control charts
- All sample chemical/physical data generated, including minimum limits (MLs) and analytical methods used
- All toxicity test raw data including daily ambient test conditions, toxicity test chemistry, sample dechlorination details as necessary, bench sheets and statistical analysis
- A discussion of any deviations from test conditions
- Any further discussion of reported test results, statistical analysis and concentration-response relationship and test sensitivity review per species per endpoint

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)¹

TABLE OF CONTENTS

A. GENERAL CONDITIONS	Page
1. <u>Duty to Comply</u>	2
2. <u>Permit Actions</u>	3
3. <u>Duty to Provide Information</u>	4
4. <u>Oil and Hazardous Substance Liability</u>	4
5. <u>Property Rights</u>	4
6. <u>Confidentiality of Information</u>	4
7. <u>Duty to Reapply</u>	4
8. <u>State Authorities</u>	4
9. <u>Other laws</u>	5
B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS	
1. <u>Proper Operation and Maintenance</u>	5
2. <u>Need to Halt or Reduce Not a Defense</u>	5
3. <u>Duty to Mitigate</u>	5
4. <u>Bypass</u>	5
5. <u>Upset</u>	6
C. MONITORING AND RECORDS	
1. <u>Monitoring and Records</u>	7
2. <u>Inspection and Entry</u>	8
D. REPORTING REQUIREMENTS	
1. <u>Reporting Requirements</u>	8
a. Planned changes	8
b. Anticipated noncompliance	8
c. Transfers	9
d. Monitoring reports	9
e. Twenty-four hour reporting	9
f. Compliance schedules	10
g. Other noncompliance	10
h. Other information	10
i. Identification of the initial recipient for NPDES electronic reporting data	11
2. <u>Signatory Requirement</u>	11
3. <u>Availability of Reports</u>	11
E. DEFINITIONS AND ABBREVIATIONS	
1. <u>General Definitions</u>	11
2. <u>Commonly Used Abbreviations</u>	20

¹ Updated July 17, 2018 to fix typographical errors.

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

A. GENERAL REQUIREMENTS

1. Duty to Comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA or Act) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- a. The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- b. Penalties for Violations of Permit Conditions: The Director will adjust the civil and administrative penalties listed below in accordance with the Civil Monetary Penalty Inflation Adjustment Rule (83 Fed. Reg. 1190-1194 (January 10, 2018) and the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note. See Pub. L. 114-74, Section 701 (Nov. 2, 2015)). These requirements help ensure that EPA penalties keep pace with inflation. Under the above-cited 2015 amendments to inflationary adjustment law, EPA must review its statutory civil penalties each year and adjust them as necessary.

(1) Criminal Penalties

- (a) *Negligent Violations.* The CWA provides that any person who negligently violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to criminal penalties of not less than \$2,500 nor more than \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation or by imprisonment of not more than 2 years, or both.
- (b) *Knowing Violations.* The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
- (c) *Knowing Endangerment.* The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 303, 306, 307, 308, 318, or 405 of the Act and who knows at that time that he or she is placing another person in imminent danger of death or serious bodily injury shall upon conviction be subject to a fine of not more than \$250,000 or by imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in Section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- (d) *False Statement.* The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- (2) *Civil Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act, the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L.114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).
- (3) *Administrative Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to an administrative penalty as follows:
 - (a) *Class I Penalty.* Not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act, the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L.114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).
 - (b) *Class II Penalty.* Not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L.114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).

2. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)

condition.

3. Duty to Provide Information

The Permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

4. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from responsibilities, liabilities or penalties to which the Permittee is or may be subject under Section 311 of the CWA, or Section 106 of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA).

5. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

6. Confidentiality of Information

a. In accordance with 40 C.F.R. Part 2, any information submitted to EPA pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice. If a claim is asserted, the information will be treated in accordance with the procedures in 40 C.F.R. Part 2 (Public Information).

b. Claims of confidentiality for the following information will be denied:

- (1) The name and address of any permit applicant or Permittee;
- (2) Permit applications, permits, and effluent data.

c. Information required by NPDES application forms provided by the Director under 40 C.F.R. § 122.21 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.

7. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the Permittee must apply for and obtain a new permit. The Permittee shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Director. (The Director shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)

8. State Authorities

Nothing in Parts 122, 123, or 124 precludes more stringent State regulation of any activity

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

covered by the regulations in 40 C.F.R. Parts 122, 123, and 124, whether or not under an approved State program.

9. Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations.

B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

2. Need to Halt or Reduce Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

3. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

4. Bypass

a. Definitions

- (1) *Bypass* means the intentional diversion of waste streams from any portion of a treatment facility.
- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

- b. *Bypass not exceeding limitations.* The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this Section.

c. Notice

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

- (1) *Anticipated bypass.* If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass. As of December 21, 2020 all notices submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or if required to do so by state law.
- (2) *Unanticipated bypass.* The Permittee shall submit notice of an unanticipated bypass as required in paragraph D.1.e. of this part (24-hour notice). As of December 21, 2020 all notices submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or required to do so by law.

d. *Prohibition of bypass.*

- (1) Bypass is prohibited, and the Director may take enforcement action against a Permittee for bypass, unless:
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
 - (c) The Permittee submitted notices as required under paragraph 4.c of this Section.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 4.d of this Section.

5. Upset

- a. *Definition.* *Upset* means an exceptional incident in which there is an unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)

improper operation.

- b. *Effect of an upset.* An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph B.5.c. of this Section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. *Conditions necessary for a demonstration of upset.* A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the Permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated; and
 - (3) The Permittee submitted notice of the upset as required in paragraph D.1.e.2.b. (24-hour notice).
 - (4) The Permittee complied with any remedial measures required under B.3. above.
- d. *Burden of proof.* In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.

C. MONITORING REQUIREMENTS

1. Monitoring and Records

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least 5 years (or longer as required by 40 C.F.R. § 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time.
- c. Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;
 - (2) The individual(s) who performed the sampling or measurements;
 - (3) The date(s) analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.
- d. Monitoring must be conducted according to test procedures approved under 40 C.F.R. § 136 unless another method is required under 40 C.F.R. Subchapters N or O.
- e. The Clean Water Act provides that any person who falsifies, tampers with, or

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

2. Inspection and Entry

The Permittee shall allow the Director, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

D. REPORTING REQUIREMENTS

1. Reporting Requirements

- a. *Planned Changes.* The Permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. § 122.29(b); or
 - (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements at 40 C.F.R. § 122.42(a)(1).
 - (3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. *Anticipated noncompliance.* The Permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

- c. *Transfers.* This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the Clean Water Act. *See* 40 C.F.R. § 122.61; in some cases, modification or revocation and reissuance is mandatory.
- d. *Monitoring reports.* Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices. As of December 21, 2016 all reports and forms submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or if required to do so by State law.
 - (2) If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 C.F.R. § 136, or another method required for an industry-specific waste stream under 40 C.F.R. Subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
 - (3) Calculations for all limitations which require averaging or measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. *Twenty-four hour reporting.*
 - (1) The Permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written report shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances. The written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (combined sewer overflows, sanitary sewer overflows, or bypass events), type of sewer overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volumes untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the sewer overflow event, and whether the noncompliance was related to wet weather. As of December 21, 2020 all

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

reports related to combined sewer overflows, sanitary sewer overflows, or bypass events submitted in compliance with this section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to electronically submit reports related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section by a particular permit or if required to do so by state law. The Director may also require Permittees to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section.

- (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
 - (a) Any unanticipated bypass which exceeds any effluent limitation in the permit. *See* 40 C.F.R. § 122.41(g).
 - (b) Any upset which exceeds any effluent limitation in the permit.
 - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within 24 hours. *See* 40 C.F.R. § 122.44(g).
 - (3) The Director may waive the written report on a case-by-case basis for reports under paragraph D.1.e. of this Section if the oral report has been received within 24 hours.
- f. *Compliance Schedules.* Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- g. *Other noncompliance.* The Permittee shall report all instances of noncompliance not reported under paragraphs D.1.d., D.1.e., and D.1.f. of this Section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph D.1.e. of this Section. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in paragraph D.1.e. and the applicable required data in Appendix A to 40 C.F.R. Part 127. As of December 21, 2020 all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events submitted in compliance with this section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to electronically submit reports related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section by a particular permit or if required to do so by state law. The Director may also require Permittees to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this Section.
- h. *Other information.* Where the Permittee becomes aware that it failed to submit any

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

- i. *Identification of the initial recipient for NPDES electronic reporting data.* The owner, operator, or the duly authorized representative of an NPDES-regulated entity is required to electronically submit the required NPDES information (as specified in Appendix A to 40 C.F.R. Part 127) to the appropriate initial recipient, as determined by EPA, and as defined in 40 C.F.R. § 127.2(b). EPA will identify and publish the list of initial recipients on its Web site and in the FEDERAL REGISTER, by state and by NPDES data group (see 40 C.F.R. § 127.2(c) of this Chapter). EPA will update and maintain this listing.

2. Signatory Requirement

- a. All applications, reports, or information submitted to the Director shall be signed and certified. *See* 40 C.F.R. §122.22.
- b. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

3. Availability of Reports.

Except for data determined to be confidential under paragraph A.6. above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the State water pollution control agency and the Director. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statements on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA.

E. DEFINITIONS AND ABBREVIATIONS

1. General Definitions

For more definitions related to sludge use and disposal requirements, see EPA Region 1's NPDES Permit Sludge Compliance Guidance document (4 November 1999, modified to add regulatory definitions, April 2018).

Administrator means the Administrator of the United States Environmental Protection Agency, or an authorized representative.

Applicable standards and limitations means all, State, interstate, and federal standards and limitations to which a "discharge," a "sewage sludge use or disposal practice," or a related activity is subject under the CWA, including "effluent limitations," water quality standards, standards of performance, toxic effluent standards or prohibitions, "best management practices," pretreatment standards, and "standards for sewage sludge use or disposal" under Sections 301, 302, 303, 304, 306, 307, 308, 403 and 405 of the CWA.

Application means the EPA standard national forms for applying for a permit, including any additions, revisions, or modifications to the forms; or forms approved by EPA for use in

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)

“approved States,” including any approved modifications or revisions.

Approved program or *approved State* means a State or interstate program which has been approved or authorized by EPA under Part 123.

Average monthly discharge limitation means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.

Average weekly discharge limitation means the highest allowable average of “daily discharges” over a calendar week, calculated as the sum of all “daily discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week.

Best Management Practices (“BMPs”) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of “waters of the United States.” BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Bypass see B.4.a.1 above.

C-NOEC or “*Chronic (Long-term Exposure Test) – No Observed Effect Concentration*” means the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specified time of observation.

Class I sludge management facility is any publicly owned treatment works (POTW), as defined in 40 C.F.R. § 501.2, required to have an approved pretreatment program under 40 C.F.R. § 403.8 (a) (including any POTW located in a State that has elected to assume local program responsibilities pursuant to 40 C.F.R. § 403.10 (e)) and any treatment works treating domestic sewage, as defined in 40 C.F.R. § 122.2, classified as a Class I sludge management facility by the EPA Regional Administrator, or, in the case of approved State programs, the Regional Administrator in conjunction with the State Director, because of the potential for its sewage sludge use or disposal practice to affect public health and the environment adversely.

Contiguous zone means the entire zone established by the United States under Article 24 of the Convention on the Territorial Sea and the Contiguous Zone.

Continuous discharge means a “discharge” which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or similar activities.

CWA means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972) Public Law 92-500, as amended by Public Law 95-217, Public Law 95-576, Public Law 96-483 and Public Law 97-117, 33 U.S.C. 1251 *et seq.*

CWA and regulations means the Clean Water Act (CWA) and applicable regulations promulgated thereunder. In the case of an approved State program, it includes State program requirements.

Daily Discharge means the “discharge of a pollutant” measured during a calendar day or any

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

other 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

Direct Discharge means the “discharge of a pollutant.”

Director means the Regional Administrator or an authorized representative. In the case of a permit also issued under Massachusetts’ authority, it also refers to the Director of the Division of Watershed Management, Department of Environmental Protection, Commonwealth of Massachusetts.

Discharge

- (a) When used without qualification, *discharge* means the “discharge of a pollutant.”
- (b) As used in the definitions for “interference” and “pass through,” *discharge* means the introduction of pollutants into a POTW from any non-domestic source regulated under Section 307(b), (c) or (d) of the Act.

Discharge Monitoring Report (“DMR”) means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by Permittees. DMRs must be used by “approved States” as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA’s.

Discharge of a pollutant means:

- (a) Any addition of any “pollutant” or combination of pollutants to “waters of the United States” from any “point source,” or
- (b) Any addition of any pollutant or combination of pollutants to the waters of the “contiguous zone” or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation.

This definition includes additions of pollutants into waters of the United States from: surface runoff which is collected or channeled by man; discharges through pipes, sewers, or other conveyances owned by a State, municipality, or other person which do not lead to a treatment works; and discharges through pipes, sewers, or other conveyances, leading into privately owned treatment works. This term does not include an addition of pollutants by any “indirect discharger.”

Effluent limitation means any restriction imposed by the Director on quantities, discharge rates, and concentrations of “pollutants” which are “discharged” from “point sources” into “waters of the United States,” the waters of the “contiguous zone,” or the ocean.

Effluent limitation guidelines means a regulation published by the Administrator under section 304(b) of CWA to adopt or revise “effluent limitations.”

Environmental Protection Agency (“EPA”) means the United States Environmental Protection

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)

Agency.

Grab Sample means an individual sample collected in a period of less than 15 minutes.

Hazardous substance means any substance designated under 40 C.F.R. Part 116 pursuant to Section 311 of CWA.

Incineration is the combustion of organic matter and inorganic matter in sewage sludge by high temperatures in an enclosed device.

Indirect discharger means a nondomestic discharger introducing “pollutants” to a “publicly owned treatment works.”

Interference means a discharge (see definition above) which, alone or in conjunction with a discharge or discharges from other sources, both:

- (a) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (b) Therefore is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resources Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to Subtitle D of the SDWA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Landfill means an area of land or an excavation in which wastes are placed for permanent disposal, and that is not a land application unit, surface impoundment, injection well, or waste pile.

Land application is the spraying or spreading of sewage sludge onto the land surface; the injection of sewage sludge below the land surface; or the incorporation of sewage sludge into the soil so that the sewage sludge can either condition the soil or fertilize crops or vegetation grown in the soil.

Land application unit means an area where wastes are applied onto or incorporated into the soil surface (excluding manure spreading operations) for agricultural purposes or for treatment and disposal.

LC₅₀ means the concentration of a sample that causes mortality of 50% of the test population at a specific time of observation. The *LC₅₀* = 100% is defined as a sample of undiluted effluent.

Maximum daily discharge limitation means the highest allowable “daily discharge.”

Municipal solid waste landfill (MSWLF) unit means a discrete area of land or an excavation that receives household waste, and that is not a land application unit, surface impoundment, injection well, or waste pile, as those terms are defined under 40 C.F.R. § 257.2. A MSWLF unit also may receive other types of RCRA Subtitle D wastes, such as commercial solid waste, nonhazardous sludge, very small quantity generator waste and industrial solid waste. Such a landfill may be

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

publicly or privately owned. A MSWLF unit may be a new MSWLF unit, an existing MSWLF unit or a lateral expansion. A construction and demolition landfill that receives residential lead-based paint waste and does not receive any other household waste is not a MSWLF unit.

Municipality

- (a) When used without qualification *municipality* means a city, town, borough, county, parish, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under Section 208 of CWA.
- (b) As related to sludge use and disposal, *municipality* means a city, town, borough, county, parish, district, association, or other public body (including an intermunicipal Agency of two or more of the foregoing entities) created by or under State law; an Indian tribe or an authorized Indian tribal organization having jurisdiction over sewage sludge management; or a designated and approved management Agency under Section 208 of the CWA, as amended. The definition includes a special district created under State law, such as a water district, sewer district, sanitary district, utility district, drainage district, or similar entity, or an integrated waste management facility as defined in Section 201 (e) of the CWA, as amended, that has as one of its principal responsibilities the treatment, transport, use or disposal of sewage sludge.

National Pollutant Discharge Elimination System means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318, and 405 of the CWA. The term includes an “approved program.”

New Discharger means any building, structure, facility, or installation:

- (a) From which there is or may be a “discharge of pollutants;”
- (b) That did not commence the “discharge of pollutants” at a particular “site” prior to August 13, 1979;
- (c) Which is not a “new source;” and
- (d) Which has never received a finally effective NPDES permit for discharges at that “site.”

This definition includes an “indirect discharger” which commences discharging into “waters of the United States” after August 13, 1979. It also includes any existing mobile point source (other than an offshore or coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas developmental drilling rig) such as a seafood processing rig, seafood processing vessel, or aggregate plant, that begins discharging at a “site” for which it does not have a permit; and any offshore or coastal mobile oil and gas exploratory drilling rig or coastal mobile oil and gas developmental drilling rig that commences the discharge of pollutants after August 13, 1979, at a “site” under EPA’s permitting jurisdiction for which it is not covered by an individual or general permit and which is located in an area determined by the Director in the issuance of a final permit to be in an area of biological concern. In determining whether an area is an area of biological concern, the Director shall consider the factors specified in 40 C.F.R. §§ 125.122 (a) (1) through (10).

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

An offshore or coastal mobile exploratory drilling rig or coastal mobile developmental drilling rig will be considered a “new discharger” only for the duration of its discharge in an area of biological concern.

New source means any building, structure, facility, or installation from which there is or may be a “discharge of pollutants,” the construction of which commenced:

- (a) After promulgation of standards of performance under Section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with Section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal.

NPDES means “National Pollutant Discharge Elimination System.”

Owner or operator means the owner or operator of any “facility or activity” subject to regulation under the NPDES programs.

Pass through means a Discharge (see definition above) which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation).

Pathogenic organisms are disease-causing organisms. These include, but are not limited to, certain bacteria, protozoa, viruses, and viable helminth ova.

Permit means an authorization, license, or equivalent control document issued by EPA or an “approved State” to implement the requirements of Parts 122, 123, and 124. “Permit” includes an NPDES “general permit” (40 C.F.R. § 122.28). “Permit” does not include any permit which has not yet been the subject of final agency action, such as a “draft permit” or “proposed permit.”

Person means an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

Person who prepares sewage sludge is either the person who generates sewage sludge during the treatment of domestic sewage in a treatment works or the person who derives a material from sewage sludge.

pH means the logarithm of the reciprocal of the hydrogen ion concentration measured at 25° Centigrade or measured at another temperature and then converted to an equivalent value at 25° Centigrade.

Point Source means any discernible, confined, and discrete conveyance, including but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel or other floating craft from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff (see 40 C.F.R. § 122.3).

Pollutant means dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

(except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 *et seq.*)), heat, wrecked or discarded equipment, rock, sand, cellar dirt and industrial, municipal, and agricultural waste discharged into water. It does not mean:

- (a) Sewage from vessels; or
- (b) Water, gas, or other material which is injected into a well to facilitate production of oil or gas, or water derived in association with oil and gas production and disposed of in a well, if the well is used either to facilitate production or for disposal purposes is approved by the authority of the State in which the well is located, and if the State determines that the injection or disposal will not result in the degradation of ground or surface water resources.

Primary industry category means any industry category listed in the NRDC settlement agreement (*Natural Resources Defense Council et al. v. Train*, 8 E.R.C. 2120 (D.D.C. 1976), *modified* 12 E.R.C. 1833 (D.D.C. 1979)); also listed in Appendix A of 40 C.F.R. Part 122.

Privately owned treatment works means any device or system which is (a) used to treat wastes from any facility whose operator is not the operator of the treatment works and (b) not a “POTW.”

Process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

Publicly owned treatment works (POTW) means a treatment works as defined by Section 212 of the Act, which is owned by a State or municipality (as defined by Section 504(4) of the Act). This definition includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality as defined in Section 502(4) of the Act, which has jurisdiction over the indirect discharges to and the discharges from such a treatment works.

Regional Administrator means the Regional Administrator, EPA, Region I, Boston, Massachusetts.

Secondary industry category means any industry which is not a “primary industry category.”

Septage means the liquid and solid material pumped from a septic tank, cesspool, or similar domestic sewage treatment system, or a holding tank when the system is cleaned or maintained.

Sewage Sludge means any solid, semi-solid, or liquid residue removed during the treatment of municipal waste water or domestic sewage. Sewage sludge includes, but is not limited to, solids removed during primary, secondary, or advanced waste water treatment, scum, septage, portable toilet pumpings, type III marine sanitation device pumpings (33 C.F.R. Part 159), and sewage sludge products. Sewage sludge does not include grit or screenings, or ash generated during the incineration of sewage sludge.

Sewage sludge incinerator is an enclosed device in which only sewage sludge and auxiliary fuel are fired.

Sewage sludge unit is land on which only sewage sludge is placed for final disposal. This does

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

not include land on which sewage sludge is either stored or treated. Land does not include waters of the United States, as defined in 40 C.F.R. § 122.2.

Sewage sludge use or disposal practice means the collection, storage, treatment, transportation, processing, monitoring, use, or disposal of sewage sludge.

Significant materials includes, but is not limited to: raw materials; fuels; materials such as solvents, detergents, and plastic pellets; finished materials such as metallic products; raw materials used in food processing or production; hazardous substance designated under Section 101(14) of CERCLA; any chemical the facility is required to report pursuant to Section 313 of title III of SARA; fertilizers; pesticides; and waste products such as ashes, slag and sludge that have the potential to be released with storm water discharges.

Significant spills includes, but is not limited to, releases of oil or hazardous substances in excess of reportable quantities under Section 311 of the CWA (see 40 C.F.R. §§ 110.10 and 117.21) or Section 102 of CERCLA (see 40 C.F.R. § 302.4).

Sludge-only facility means any “treatment works treating domestic sewage” whose methods of sewage sludge use or disposal are subject to regulations promulgated pursuant to section 405(d) of the CWA, and is required to obtain a permit under 40 C.F.R. § 122.1(b)(2).

State means any of the 50 States, the District of Columbia, Guam, the Commonwealth of Puerto Rico, the Virgin Islands, American Samoa, the Commonwealth of the Northern Mariana Islands, the Trust Territory of the Pacific Islands, or an Indian Tribe as defined in the regulations which meets the requirements of 40 C.F.R. § 123.31.

Store or storage of sewage sludge is the placement of sewage sludge on land on which the sewage sludge remains for two years or less. This does not include the placement of sewage sludge on land for treatment.

Storm water means storm water runoff, snow melt runoff, and surface runoff and drainage.

Storm water discharge associated with industrial activity means the discharge from any conveyance that is used for collecting and conveying storm water and that is directly related to manufacturing, processing, or raw materials storage areas at an industrial plant.

Surface disposal site is an area of land that contains one or more active sewage sludge units.

Toxic pollutant means any pollutant listed as toxic under Section 307(a)(1) or, in the case of “sludge use or disposal practices,” any pollutant identified in regulations implementing Section 405(d) of the CWA.

Treatment works treating domestic sewage means a POTW or any other sewage sludge or waste water treatment devices or systems, regardless of ownership (including federal facilities), used in the storage, treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated for the disposal of sewage sludge. This definition does not include septic tanks or similar devices.

For purposes of this definition, “domestic sewage” includes waste and waste water from humans or household operations that are discharged to or otherwise enter a treatment works. In States where there is no approved State sludge management program under Section 405(f) of the CWA, the Director may designate any person subject to the standards for sewage sludge use and

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

disposal in 40 C.F.R. Part 503 as a “treatment works treating domestic sewage,” where he or she finds that there is a potential for adverse effects on public health and the environment from poor sludge quality or poor sludge handling, use or disposal practices, or where he or she finds that such designation is necessary to ensure that such person is in compliance with 40 C.F.R. Part 503.

Upset see B.5.a. above.

Vector attraction is the characteristic of sewage sludge that attracts rodents, flies, mosquitoes, or other organisms capable of transporting infectious agents.

Waste pile or *pile* means any non-containerized accumulation of solid, non-flowing waste that is used for treatment or storage.

Waters of the United States or *waters of the U.S.* means:

- (a) All waters which are currently used, were used in the past, or may be susceptible to use in interstate or foreign commerce, including all waters which are subject to the ebb and flow of the tide;
- (b) All interstate waters, including interstate “wetlands;”
- (c) All other waters such as intrastate lakes, rivers, streams (including intermittent streams), mudflats, sandflats, “wetlands”, sloughs, prairie potholes, wet meadows, playa lakes, or natural ponds the use, degradation, or destruction of which would affect or could affect interstate or foreign commerce including any such waters:
 - (1) Which are or could be used by interstate or foreign travelers for recreational or other purpose;
 - (2) From which fish or shellfish are or could be taken and sold in interstate or foreign commerce; or
 - (3) Which are used or could be used for industrial purposes by industries in interstate commerce;
- (d) All impoundments of waters otherwise defined as waters of the United States under this definition;
- (e) Tributaries of waters identified in paragraphs (a) through (d) of this definition;
- (f) The territorial sea; and
- (g) “Wetlands” adjacent to waters (other than waters that are themselves wetlands) identified in paragraphs (a) through (f) of this definition.

Waste treatment systems, including treatment ponds or lagoons designed to meet the requirements of CWA (other than cooling ponds as defined in 40 C.F.R. § 423.11(m) which also meet the criteria of this definition) are not waters of the United States. This exclusion applies only to manmade bodies of water which neither were originally created in waters of the United States (such as disposal area in wetlands) nor resulted from the impoundment of waters of the United States. Waters of the United States do not include prior converted cropland.

NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

Notwithstanding the determination of an area's status as prior converted cropland by any other federal agency, for the purposes of the Clean Water Act, the final authority regarding Clean Water Act jurisdiction remains with EPA.

Wetlands means those areas that are inundated or saturated by surface or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole Effluent Toxicity (WET) means the aggregate toxic effect of an effluent measured directly by a toxicity test.

Zone of Initial Dilution (ZID) means the region of initial mixing surrounding or adjacent to the end of the outfall pipe or diffuser ports, provided that the ZID may not be larger than allowed by mixing zone restrictions in applicable water quality standards.

2. Commonly Used Abbreviations

BOD	Five-day biochemical oxygen demand unless otherwise specified
CBOD	Carbonaceous BOD
CFS	Cubic feet per second
COD	Chemical oxygen demand
Chlorine	
Cl ₂	Total residual chlorine
TRC	Total residual chlorine which is a combination of free available chlorine (FAC, see below) and combined chlorine (chloramines, etc.)
TRO	Total residual chlorine in marine waters where halogen compounds are present
FAC	Free available chlorine (aqueous molecular chlorine, hypochlorous acid, and hypochlorite ion)
Coliform	
Coliform, Fecal	Total fecal coliform bacteria
Coliform, Total	Total coliform bacteria
Cont.	Continuous recording of the parameter being monitored, i.e. flow, temperature, pH, etc.
Cu. M/day or M ³ /day	Cubic meters per day
DO	Dissolved oxygen

NPDES PART II STANDARD CONDITIONS
(April 26, 2018)

kg/day	Kilograms per day
lbs/day	Pounds per day
mg/L	Milligram(s) per liter
mL/L	Milliliters per liter
MGD	Million gallons per day
Nitrogen	
Total N	Total nitrogen
NH3-N	Ammonia nitrogen as nitrogen
NO3-N	Nitrate as nitrogen
NO2-N	Nitrite as nitrogen
NO3-NO2	Combined nitrate and nitrite nitrogen as nitrogen
TKN	Total Kjeldahl nitrogen as nitrogen
Oil & Grease	Freon extractable material
PCB	Polychlorinated biphenyl
Surfactant	Surface-active agent
Temp. °C	Temperature in degrees Centigrade
Temp. °F	Temperature in degrees Fahrenheit
TOC	Total organic carbon
Total P	Total phosphorus
TSS or NFR	Total suspended solids or total nonfilterable residue
Turb. or Turbidity	Turbidity measured by the Nephelometric Method (NTU)
µg/L	Microgram(s) per liter
WET	“Whole effluent toxicity”
ZID	Zone of Initial Dilution

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
NEW ENGLAND - REGION 1
5 POST OFFICE SQUARE, SUITE 100
BOSTON, MASSACHUSETTS 02109-3912

FACT SHEET SUPPLEMENT

(Supplementing the August 1, 2017 Fact Sheet provided with the August 1, 2017 Draft Permit)

REVISED DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
(NPDES) PERMIT TO DISCHARGE TO WATERS OF THE UNITED STATES
PURSUANT TO THE CLEAN WATER ACT (CWA)

NPDES PERMIT NUMBER: MA0000531

PUBLIC NOTICE START AND END DATES: **March 5, 2019 – April 3, 2019**

NAME AND MAILING ADDRESS OF APPLICANT:

Boston Sand & Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

Boston Sand & Gravel Company
500 Front Street
Charlestown, MA 02129

FACT SHEET SUPPLEMENT

1. Introduction

The Region 1 Office of the United States Environmental Protection Agency (“EPA” or the “Agency”) and the Massachusetts Department of Environmental Protection (“MassDEP”) are exercising their discretion, based on public comments, to provide additional opportunity for comment on certain revisions to the draft permit to further inform the permit proceedings and improve the agencies’ decision making regarding the draft National Pollutant Discharge Elimination System (“NPDES”) permit for Boston Sand & Gravel (referred to herein as the “facility” or “BS&G”) in Charlestown, MA. EPA is in the process of reissuing the NPDES permit under Section 402 of the Clean Water Act (CWA). 33 U.S.C. § 1342. In accordance with 40 C.F.R. § 124.14(c), the comment period for the Draft Permit is not being reopened “across the board”. Rather, as provided in 40 CFR § 124.14(c), any comment filed during this public comment period shall be limited to the following proposed condition in the Draft Permit:

- Revised Maximum Daily Total Recoverable Copper effluent limitation in Part I.A.1.

This issue is discussed in this Fact Sheet Supplement.

2. Background

EPA last issued a new Final NPDES Permit to BS&G on September 28, 2007. The permit expired on August 31, 2012 but was administratively continued as a result of BS&G’s timely application for permit renewal pursuant to 40 C.F.R. § 122.6. EPA published a new Draft Permit for public notice and comment on August 1, 2017 (the “2017 Draft Permit”). EPA Region 1 and MassDEP received written comments from Boston Sand & Gravel dated August 30, 2017. EPA Region 1 and MassDEP did not receive any other public comments. Since the closure of the public notice and comment periods for the 2017 Draft Permit, EPA has been considering the comments submitted by BS&G and is developing the Final Permit.

In its comments on the Draft Permit, BS&G commented that reasonable potential analysis for metals presented in the Fact Sheet and based on discharge monitoring data from 2007 to 2015 did not consider that the facility has been operating with new treatment technology that improves metals removal efficiency since September 2016 (the Hubbard Hall system). BS&G requested that EPA reassess the reasonable potential analysis for metals using discharge monitoring data beginning in September 2016. BS&G also requested that where the revised analysis based on data representative of the new treatment chemistry indicates no reasonable potential, the corresponding WQBELs be removed from the Final Permit.

The WQBELs in the Draft Permit were established on an individual basis via a reasonable potential analysis, as correctly noted by BS&G in its 2017 comments. EPA’s Technical Support

Document for Water Quality-based Toxics Control¹ (“TSD”) provides the methodology for making a reasonable potential analysis determination in accordance with 40 CFR §122.44(d)(1)(ii). EPA, in response to comments and new information provided during the public comment period, may choose to re-evaluate the basis for effluent limitations, including, in some cases, the reasonable potential analysis. In response to BS&G’s comments, and based on the unique facts presented, EPA reconsidered the reasonable potential analysis used for the development of WQBELs for all metals in the Draft Permit using data representative of the new treatment technology used at the facility since September 2016.

In response to this comment, regarding effluent limitations for copper, EPA re-evaluated DMR data recorded from October 2016 through the end of May 2018 to determine if there was reasonable potential to cause or contribute to a violation of water quality standards for metals. EPA concluded that the facility’s discharge did not have reasonable potential to cause or contribute to a violation of applicable acute copper criterion: 26.8 µg/L (see Attachment A). EPA determined that, based on this analysis, removing the maximum daily WQBEL for copper is appropriate.

Having determined that WQBELs were not required for copper, EPA examined what an appropriate technology-based effluent limitation (“TBEL”) would be. *See* CWA § 301(b). *See also* 40 C.F.R. § 125.3. As discussed in the 2017 Fact Sheet, TBELs represent the minimum level of control that must be imposed under Sections 301(b) and 402 of the CWA to meet best practicable control technology currently available (BPT) for conventional pollutants and some metals, and best available technology economically available (BAT) for toxic and non-conventional pollutants. EPA has not promulgated effluent limitation guidelines (“ELGs”) for copper at Ready-Mix Concrete facilities. In the absence of published technology-based ELGs, the permit writer establishes appropriate technology-based effluent limitations on a case-by-case basis under CWA § 402(a)(1)(B) using best professional judgment (“BPJ”). *See* 40 C.F.R. § 125.3. Because copper is a toxic pollutant, developing a BAT TBEL for copper based on BPJ is appropriate for this facility.

When establishing TBELs on a case-by-case basis using BPJ, EPA considers specific factors that track those specified in the statute for EPA’s consideration in the development of national effluent limitation guidelines (NELGs). *See* 33 U.S.C. § 1314(b). In establishing a BAT TBEL for copper, EPA requires limits based on use of the most effective pollution control technologies that are technologically and economically achievable, and that will result in reasonable progress toward eliminating discharges of the toxic pollutant.

EPA considers the following six specific factors in determining the BAT: (i) age of the equipment and facilities involved; (ii) process employed; (iii) engineering aspects of the application of various types of control techniques; (iv) process changes; (v) the cost of achieving such effluent reductions; and (vi) non-water quality environmental impacts (including energy requirements). *See* CWA § 304(b)(2) and 40 C.F.R. § 125.3(d)(3). Ultimately, when setting BAT limits, EPA’s consideration of the required factors is governed by a reasonableness standard. *BP Exploration & Oil, Inc. v. EPA*, 66 F.3d 784, 796 (6th Cir. 1995), citing *American Iron & Steel*

¹ See EPA’s Technical Support Document for Water Quality-based Toxics Control: EPA/505/2-90-001, pages 49-65 (1991).

Institute v. EPA, 526 F.2d 1027, 1051 (3d Cir. 1975), modified in other part, 560 F.2d 589 (3d Cir. 1977), cert. denied, 435 U.S. 914 (1978); *Chemical Manufacturers Ass’n v. U.S. Environmental Protection Agency*, 870 F.2d 177, 250 n. 320 (5th Cir. 1989) (citing Congressional Research Service, A Legislative History of the Water Pollution Control Act Amendments of 1972 (1973), at 170) (in determining BAT, “[t]he Administrator will be bound by a test of reasonableness.”). As one court summarized it, “[s]o long as the required technology reduces the discharge of pollutants, our inquiry will be limited to whether the Agency considered the cost of technology, along with other statutory factors, and whether its conclusion is reasonable.” *Ass’n of Pacific Fisheries v. EPA*, 615 F.2d 794, 818 (9th Cir. 1980).

According to 40 C.F.R. § 125.3(c)(2), in determining BAT requirements, EPA should consider the “appropriate technology for the category of point sources of which the applicant is a member, based on all available information,” and also “any unique factors relating to the applicant.” EPA is not aware of any unique factors applicable to the facility that would impact the selection of the BAT in this case.

EPA has taken into account site-specific factors in the course of discussing the six BAT considerations below.

(i) Age of the equipment and facilities involved

BS&G began using new treatment chemistry, which replaces the hydroxide precipitation with sulfide precipitation, in September 2016. According to BS&G, the change in chemicals is applied to the block house treatment system (Lagoon 7 effluent) in addition to the existing coagulant and polymer. The use of the new technology is a recent addition to the existing system and represents an improvement in the treatment efficiency for metals as compared to the old treatment chemistry. There is nothing about the age of the equipment and facilities involved that would prevent the ongoing use of the same or similar treatment chemistry to treat the wastestream at the facility.

(ii) Process(es) employed

BS&G is a Ready-Mix Concrete facility that produces various concrete products. Continuing to treat the wastestream with the new treatment technology will not prevent the permittee from maintaining its primary production processes (Ready-Mix Concrete) as the facility selected and voluntarily installed the new treatment technology independent of the permit issuance process. The facility has continued to operate since the new treatment technology was installed.

(iii) Engineering aspects of the application of various types of control techniques

Treatment processes for toxic pollutants typically include pH adjustment, coagulation and solids removal. In combination, these three processes are a fairly straightforward, standard technology applied to treat many types of wastewaters containing metals. The wastewater at this facility is treated using settling, pH adjustment and chemical additives where the wastewater is routed through a combination of settling lagoons and mixing tanks in the block house prior to discharge. All treatment processes at the facility were in place at least since the permit was last issued in

2007. The new treatment technology was installed in September 2016 to enhance the treatment efficacy of the chemical additives, and the settling and pH adjustment processes. From an engineering standpoint, BS&G is expected to achieve the effluent limitation for copper in the final permit simply by maintaining the current performance of the treatment technology.

(iv) Process changes

As discussed above, BS&G's wastewater is treated using an existing treatment system. The treatment technology, installed in September 2016, does not appear to interfere with the production of concrete products at the facility and EPA believes that BS&G would not have independently selected and voluntarily installed this treatment technology if it interfered with the production of concrete products.

(v) Cost of achieving effluent reductions

As discussed above, EPA considers the cost of technological alternatives when determining the BAT and associated NPDES permit requirements. Where the BAT standard applies, CWA §§ 301(b)(2) and 304(b)(2) require "EPA to set discharge limits that reflect the amount of pollutant that would be discharged by a point source employing the best available technology that the EPA determines to be economically feasible" *Texas Oil and Gas v. EPA*, 161 F.3d 923, 928 (5th Cir. 1998). To be an "available" technology, the option in question must be "economically achievable." See *Chemical Manufacturers*, 870 F.2d at 250 (citing 33 U.S.C. § 1311(b)(2)(A)). The United States Supreme Court has interpreted the CWA to mean that the BAT should "represent a commitment of the maximum resources economically possible to the ultimate goal of eliminating all polluting discharges." *Crushed Stone*, 449 U.S. at 74.

Neither the CWA nor EPA regulations dictate precisely how the Agency should go about considering costs in its technology standards determinations, but the courts have made clear that only a reasonable consideration of cost is necessary and precise cost estimates are not required. See *BP Exploration*, 66 F.3d at 803; *NRDC v. EPA*, 863 F.2d 1420, 1426 (9th Cir. 1988) (EPA need "develop no more than a rough idea of the costs the industry would incur"). Moreover, the BAT standard does not call for consideration of a comparison of costs to benefits. See, e.g., *Crushed Stone*, 449 U.S. at 74; *Texas Oil*, 161 F.3d at 936.

BS&G's implemented the new treatment technology in September 2016 and continues to operate it. As such, EPA expects that there are no additional capital costs and minimal operating costs associated with continuing to operate and maintain the new treatment technology. To the extent BS&G incurs additional costs due to the operation of the new treatment technology, EPA assumes from the fact that BS&G has been doing so for several years indicates such treatment is "economically achievable."

(vi) Non-water quality environmental impacts (including energy requirements)

Finally, EPA considers the non-water quality environmental impacts associated with the treatment of wastewater, including energy consumption, air emissions, noise, and visual impacts. The Permittee has operated the new treatment technology since September 2016 and did not

comment that the new technology results in an increase in energy usage, air emissions and noise as compared to the existing system prior to September 2016. The new technology consists of new treatment chemistry in the block house, which would not be expected to have any visual impacts on the existing lagoons, mixing tanks, and the block house that contains the mixing tanks. EPA also does not expect any non-water quality environmental impacts associated with continuing to operate and maintain the new treatment chemistry. Furthermore, any impacts of treatment equipment are dwarfed by active vehicles and concrete production machinery and used throughout the rest of the site and it is assumed that the energy usage, air emissions, and noise generated by the equipment will be negligible in considering the operations of the entire facility.

Technology-based controls in NPDES permits are performance-based measures. Based on analysis of the appropriate factors and its best professional judgment, EPA concludes that the performance of the “Hubbard Hall” treatment system represents the BAT for the discharge of copper from this facility. Therefore, EPA developed a numeric TBEL for copper based on the performance of this technology as measured by permittee and submitted to the DMR after the new treatment technology was installed. DMR data from October 2016 through the end of May 2018 was used to assess the long-term treatment performance of the BAT technology used by BS&G to remove copper. A numeric TBEL was developed by estimating the 95th percentile of representative performance data. The 95th percentile of the monthly Total Recoverable Copper performance data was found to be 26.3 µg/L. TBELs must be met end-of-pipe. Therefore, the daily maximum effluent limitation for Total Recoverable Copper is 26.3 µg/L.

EPA and MassDEP agree that the basis for the maximum daily Total Recoverable Copper TBEL based on BAT differs from the basis for the water quality-based effluent limitation (“WQBEL”) that was proposed in the 2017 Draft Permit. This limit is more stringent than otherwise would be imposed to meet water quality, as the applicable criterion is 26.8 µg/L Total Recoverable Copper. As a result of this change, based on analysis performed in response to comments received on the Draft Permit, EPA is issuing a revised Draft Permit to invite comment on the proposed technology-based maximum daily effluent limitation. EPA expects that the facility can meet this effluent limitation as the facility has consistently achieved it since it implemented the new treatment technology. Inclusion of the numeric effluent limitation for this parameter will provide an incentive to maintain and operate the new treatment technology.

2018 Fact Sheet Supplement Attachment A

Reasonable Potential Analysis for Copper:

October 2016 – May 2018 DMR data, 18 data points

DMR data for months where there was no discharge were not used to determine reasonable potential. The applicable acute criterion for copper is 26.8 µg/L Total Recoverable Copper. As discussed previously, there is no reasonable potential for the discharge to cause or contribute to a violation of copper criteria based on the projected 95th percentile Total Recoverable Copper concentration. The BAT TBEL for copper is also based on the projected 95th percentile Total Recoverable Copper concentration in the table below.

Copper - Lognormal distribution, no ND	
Estimated Daily Maximum Effluent Concentration	
k = number of daily samples =	18
u _y = Avg of Nat. Log of daily Discharge =	1.80
s _y = Std Dev. of Nat Log of daily discharge =	0.89
95th Percentile Daily Max Estimate = $\exp(u_y + 1.645*s_y)$	
Estimated Daily Max including Dilution Factor =	26.3 µg/L

MASSACHUSETTS DEPARTMENT OF
ENVIRONMENTAL PROTECTION
COMMONWEALTH OF MASSACHUSETTS
1 WINTER STREET
BOSTON, MASSACHUSETTS 02108

UNITED STATES ENVIRONMENTAL
PROTECTION AGENCY – REGION 1
OFFICE OF ECOSYSTEM PROTECTION
5 POST OFFICE SQUARE
BOSTON, MASSACHUSETTS 02109

**JOINT PUBLIC NOTICE OF A REVISED DRAFT NATIONAL POLLUTANT
DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT TO DISCHARGE INTO
WATERS OF THE UNITED STATES UNDER SECTIONS 301 AND 402 OF THE CLEAN
WATER ACT, AS AMENDED, AND SECTIONS 27 AND 43 OF THE MASSACHUSETTS
CLEAN WATERS ACT, AS AMENDED, AND REQUEST FOR STATE CERTIFICATION
UNDER SECTION 401 OF THE CLEAN WATER ACT.**

DATE OF ORIGINAL PUBLIC NOTICE: 08/01/2017 - 08/30/2017

DATE OF PUBLIC NOTICE: **March 5, 2019 – April 3, 2019**

PERMIT NUMBER: **MA0000531**

PUBLIC NOTICE NUMBER: **MA-006-19**

NAME AND MAILING ADDRESS OF APPLICANT:

Boston Sand & Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114

NAME AND ADDRESS OF THE FACILITY WHERE DISCHARGE OCCURS:

Boston Sand & Gravel Company
500 Front Street
Charlestown, MA 02129

RECEIVING WATER: Unnamed Tributary to the Charles River (“Millers River”, Outfall 001)

PREPARATION OF THE REVISED DRAFT PERMIT:

The U.S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (“MassDEP”) have cooperated in the development of a revised Draft Permit for Boston Sand & Gravel’s Charlestown facility, which discharges commingled process water and stormwater. The effluent limits and permit conditions imposed have been drafted to assure that State Water Quality Standards and provisions of the Clean Water Act will be met. EPA has requested that the State certify this revised Draft Permit pursuant to Section 401 of the Clean Water Act and expects that the revised Draft Permit will be certified.

INFORMATION ABOUT THE REVISED DRAFT PERMIT:

A draft NPDES permit was released for public comment on August 1, 2017 (“2017 Draft Permit”). EPA received comments from Boston Sand & Gravel on the 2017 Draft Permit, including a request to review DMR data collected after a new treatment technology was installed to more effectively remove metals in the discharge. EPA Region 1 and the Massachusetts Department of Environmental Protection (“MassDEP”) reviewed the DMR data and determined that a technology-based effluent limitation rather than a water quality-based effluent limitation, as in the 2017 Draft Permit, was appropriate for copper. The effluent limitations in this revised Draft Permit are imposed to protect water quality in the Unnamed Tributary of the Charles River.

A fact sheet supplement (which includes the basis for the revised draft permit conditions; and significant factual, legal and policy questions considered in preparing this revised draft permit) may be obtained at no cost at http://www.epa.gov/region1/npdes/draft_permits_listing_ma.html or by contacting:

Undine Kipka
U.S. Environmental Protection Agency – Region 1
5 Post Office Square, Suite 100 (OEP06-1)
Boston, MA 02109-3912
Telephone: (617) 918-1335
kipka.undine@epa.gov

The administrative record containing all documents relating to this revised Draft Permit including all data submitted by the applicant may be inspected at the EPA Boston office mentioned above between 9:00 a.m. and 5:00 p.m., Monday through Friday, except holidays.

FINAL PERMIT DECISION AND APPEALS:

Following the close of the comment period, and after a public hearing, if such hearing is held, the Regional Administrator will issue a final permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice. Within 30 days following the notice of the final permit decision any interested person may submit a request for a formal hearing to reconsider or contest the final decision.

LEALDON LANGLEY, DIRECTOR
DIVISION OF WATERSHED
MANAGEMENT
MASSACHUSETTS DEPARTMENT
OF ENVIRONMENTAL PROTECTION

KEN MORAFF, DIRECTOR
OFFICE OF ECOSYSTEM PROTECTION
UNITED STATES ENVIRONMENTAL
PROTECTION AGENCY - REGION 1

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA", and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Boston Sand and Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114**

is authorized to discharge from a facility located at

**500 Front Street
Charlestown, MA 02129**

to receiving a water named

Unnamed Tributary to the Charles River ("Millers River", Outfall 001)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the first day of the calendar month following sixty (60) days after signature if comments are received.*

This permit and the authorization to discharge expire at midnight, five (5) years from the last day of the month preceding the effective date.

This permit supersedes the permit issued on September 28, 2007.

This permit consists of 18 pages in Part I including effluent limitations and monitoring requirements, 15 pages in Attachments A (USEPA Region 1 Freshwater Acute Toxicity Procedure and Protocol, February 2011) and B (USEPA Region 1 Freshwater Chronic Toxicity Procedure and Protocol, March 2013), and 25 pages in Part II, the Standard Conditions.

Signed this day of , 2017

Arthur V. Johnson III, Acting Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Douglas E. Fine, Assistant Commissioner
Bureau of Water Resources
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

* Pursuant to 40 CFR 124.15(b)(3), if no comments requesting a change to the draft permit are received, the permit will become effective upon the date of signature.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge treated process water and stormwater through **Outfall Serial Number 001** to the Unnamed Tributary to the Charles River (“Millers River”)^{1,2}.

Effluent characteristic	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Flow	GPD	Report	Report	Continuous	Recorder
pH ⁵	S.U.	--	6.5 to 8.3	1/Month	Grab
Total Suspended Solids (TSS)	mg/L	20	45	1/Week	Grab
Turbidity	NTU	25	Report	1/Month	Grab
Total Sulfate	mg/L	250	Report	1/Month	Grab
Oil & Grease	mg/L	--	15	1/Month	Grab
Total Petroleum Hydrocarbons (TPH)	mg/L	--	Report	1/Month	Grab
Total Recoverable Copper	µg/L	18	29	1/Month	Grab
Dissolved Chromium (VI)	µg/L	11	16	1/Month	Grab
Total Recoverable Chromium	µg/L	--	Report	1/Month	Grab
Total Recoverable Aluminum	µg/L	87	750	1/Month	Grab
Hardness of Effluent	mg/L as CaCO ₃	--	Report	1/Month	Grab
Hardness of Receiving Water	mg/L as CaCO ₃	--	Report	1/Month	Grab
Total Phosphorus	mg/L	--	Report	1/Month	Grab
<i>E. Coli</i>	cfu/100mL	--	Report	1/Month	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity (WET) Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁶⁻⁹	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Acute LC50	%	LC50 ≥ 100%		1/Quarter	Grab
Chronic C-NOEC	%	NOEC ≥ 100%		1/Quarter	Grab
Effluent Chemistry					
Hardness	mg/L	Report		1/Quarter	Grab
Alkalinity	mg/L	Report		1/Quarter	Grab
pH	S.U.	Report		1/Quarter	Grab
Specific Conductance	µmhos/cm	Report		1/Quarter	Grab
Total Solids	mg/L	Report		1/Quarter	Grab
Total Dissolved Solids	mg/L	Report		1/Quarter	Grab
Total Ammonia Nitrogen	mg/L	Report		1/Quarter	Grab
Total Organic Carbon	mg/L	Report		1/Quarter	Grab
Total Residual Chlorine	mg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	mg/L	Report		1/Quarter	Grab
Total Recoverable Lead	mg/L	Report		1/Quarter	Grab
Total Recoverable Copper	mg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	mg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	mg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	mg/L	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.For Whole Effluent Toxicity Testing for **Outfall Serial Number 001**:

Whole Effluent Toxicity ⁶⁻⁹	Units	Discharge Limitation		Monitoring Requirements ³	
		Average monthly	Maximum Daily	Measurement Frequency ⁴	Sample Type
Receiving Water Chemistry					
Hardness	mg/L	Report		1/Quarter	Grab
Alkalinity	mg/L	Report		1/Quarter	Grab
pH	S.U.	Report		1/Quarter	Grab
Specific Conductance	µmhos/cm	Report		1/Quarter	Grab
Total Solids	mg/L	Report		1/Quarter	Grab
Total Dissolved Solids	mg/L	Report		1/Quarter	Grab
Total Ammonia Nitrogen	mg/L	Report		1/Quarter	Grab
Total Organic Carbon	mg/L	Report		1/Quarter	Grab
Total Residual Chlorine	mg/L	Report		1/Quarter	Grab
Total Recoverable Cadmium	mg/L	Report		1/Quarter	Grab
Total Recoverable Lead	mg/L	Report		1/Quarter	Grab
Total Recoverable Copper	mg/L	Report		1/Quarter	Grab
Total Recoverable Zinc	mg/L	Report		1/Quarter	Grab
Total Recoverable Nickel	mg/L	Report		1/Quarter	Grab
Total Recoverable Aluminum	mg/L	Report		1/Quarter	Grab

See footnotes on pages 5 and 6.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.**Footnotes for monitoring at Outfall 001:**

1. Such discharge shall: 1) be limited and monitored by the permittee as specified below; and 2) not cause a violation of the State Surface Water Quality Standards (314 CMR 4.00) of the receiving water.
2. Effluent samples shall be representative of the discharge and shall be taken from Lagoon 9, as close as practicable to the overflow, during the discharge of effluent to the designated receiving water. Changes in sampling location must be approved in writing by the U.S. Environmental Protection Agency (EPA). Sampling discharges from the facility must yield data representative of the discharge under authority of CWA Section 308(a) and in accordance with 40 Code of Federal Regulations (CFR) §122.41(j), §122.44(i), and §122.48. Samples shall be taken when discharging. During months when no tests are performed or required, NODI (no discharge) code 9 shall be entered for that month.
3. In accordance with 40 CFR §122.44(i)(1)(iv), the permittee shall use sufficiently sensitive test procedures (i.e., methods) approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O, for the analysis of pollutants or pollutant parameters limited in this permit (except for WET limits). A method is considered “sufficiently sensitive” when either: (1) the method minimum level (ML) is at or below the level of the effluent limit established in this permit for the measured pollutant or pollutant parameter; or (2) the method has the lowest ML of the analytical methods approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O for the measured pollutant or pollutant parameter. The ML is not the minimum level of detection, but rather the lowest level at which the test equipment produces a recognizable signal and acceptable calibration point for a pollutant or pollutant parameter, representative of the lowest concentration at which a pollutant or pollutant parameter can be measured with a known level of confidence. For the purposes of this permit, the detection limit is the lowest concentration that can be reliably measured within specified limits of precision and accuracy for a specific laboratory analytical method during routine laboratory operating conditions (i.e., the level above which an actual value is reported for an analyte, and the level below which an analyte is reported as non-detect).
4. Sampling frequency of once per week is defined as the sampling of one (1) discharge event in each calendar week, when discharge occurs. Sampling frequency of once per month is defined as the sampling of one (1) discharge event in each calendar month, when discharge occurs. Sampling frequency of 1/quarter is defined as the sampling of four (4) discharge events in each calendar year, when discharge occurs. Quarters are defined as the interval of time between the months of: January through March, inclusive; April through June, inclusive; July through September, inclusive; and October through December, inclusive. Quarterly sampling shall be performed concurrently with the monthly monitoring event. The permittee shall submit the results to EPA of any additional testing done to that required herein, if it is conducted in accordance with EPA approved methods consistent with the provisions of 40 CFR §122.41(l)(4)(ii).
5. Requirement for State Certification. The pH of the effluent shall not be less than 6.5 standard units (SU), nor greater than 8.3 SU at any time, unless these values are exceeded due to natural causes. The pH shall be no more than 0.5 units outside the natural background range.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

6. WET test samples shall be collected quarterly during the months of January, April, July, and October. The test results shall be submitted by the last day of the month following the completion of the test. The permittee shall conduct acute and chronic WET tests specified in the WET test protocols can be found in Attachments A and B of the permit. The permittee shall test the daphnid, *Ceriodaphnia dubia*.
7. LC50 (lethal concentration to 50 percent) is the concentration of wastewater causing mortality to 50% of the test organisms. The C-NOEC (chronic no observed effect concentration) is the highest effluent concentration at which there is no statistically-significant adverse effect on the survival of the test organisms when compared with the diluent control survival at the time of observation.
8. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall either follow procedures outlined in Attachment A (Toxicity Test Procedure and Protocol) Section IV., DILUTION WATER in order to obtain an individual approval for use of an alternate dilution water, or the permittee shall follow the Self-Implementing Alternative Dilution Water Guidance, which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water (see page 4 in <https://www3.epa.gov/region1/npdes/permits/generic/Alternatedilutionwaterguidance.pdf>).
9. The permittee shall conduct the analyses specified in Attachments A and B, Part VI. CHEMICAL ANALYSIS, of this permit. Even where an alternate dilution water is permitted, the receiving water control (0% effluent) must still be analyzed. MLs and methods are specified in Attachments A and B, Part VI: CHEMICAL ANALYSIS. Sampling for any parameter required for WET may be used to satisfy any duplicative sampling required for that parameter in this permit, so long as the sampling requirement for WET is equivalent with the sampling requirements otherwise established for that parameter in this permit.

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

2. The discharge shall not cause a violation of the water quality standards of the receiving waters.
3. The pH of the effluent shall not be less than 6.5 or greater than 8.3 at any time.
4. The discharge shall not cause objectionable discoloration of the receiving waters.
5. The effluent shall not contain a visible oil sheen, foam, or floating solids at any time.
6. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
7. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.
8. All existing manufacturing, commercial, mining and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge, on a routine basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. One hundred micrograms per liter (100 µg/l);
 - ii. Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7); or
 - iv. Any other notification level established by the Director in accordance with 40 CFR §122.44(f).
 - b. That any activity has occurred or will occur which would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
 - i. Five hundred micrograms per liter (500 µg/l);
 - ii. One milligram per liter (1 mg/l) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR §122.21(g)(7).
 - iv. Any other notification level established by the Director in accordance with 40 CFR §122.44(f).

PART I.A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, cont'd.

c. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant which was not reported in the permit application.

9. The results of sampling for any parameter done in accordance with EPA approved methods above its required frequency must also be reported in accordance with 40 CFR §122.41(l)(4)(ii).

PART I.B. STORMWATER POLLUTION PREVENTION PLAN

1. The permittee shall maintain a Stormwater Pollution Prevention Plan (SWPPP) designed to reduce, or prevent, the discharge of pollutants in stormwater to the receiving waters identified in this permit. The SWPPP shall be a written document and consistent with the terms of this permit. The permittee shall comply with the terms of its SWPPP.
2. The SWPPP, including the SWPPP site map, shall be updated and signed by the permittee within ninety (90) days after the effective date of this permit. The permittee shall certify that the SWPPP has been completed or updated and that it meets the requirements of the permit. The certification shall be signed in accordance with the requirements identified in 40 CFR §122.22. A copy of this certification and a hardcopy of the SWPPP shall be sent to EPA and MassDEP within thirty (30) days after the certification date.
3. The SWPPP shall be consistent with the general provisions for SWPPPs included in the most current version of the Multi-Sector General Permits for Stormwater Discharges Associated with Industrial Activities (MSGP). (The current MSGP was effective June 4, 2015 – see https://www.epa.gov/sites/production/files/2015-10/documents/msgp2015_finalpermit.pdf). However, where any provision that applies to outfalls authorized under this permit differs from the requirements of a SWPPP prepared to meet the requirements of the MSGP, the requirements in this permit shall take precedence.
4. The SWPPP shall be prepared in accordance with good engineering practices, identify potential sources of pollution that may reasonably be expected to affect the quality of the stormwater discharges, and describe and ensure implementation of practices which will be used to reduce the pollutants and assure compliance with this permit. Specifically, the SWPPP shall contain the elements listed below:
 - a. A pollution prevention team responsible for developing, implementing, maintaining, revising and ensuring compliance with the SWPPP.
 - b. A site description which includes a list of activities at the facility; a site map showing drainage areas and direction of stormwater flows; receiving waters and outfall location; the location of industrial activities, storage, disposal, material handling; and all structural controls.
 - c. A summary of all pollutant sources which includes all areas where spills have occurred or could occur. For each source, identify the expected drainage and the corresponding pollutant.
 - d. A description of all stormwater controls, both structural and non-structural. All BMPs shall be properly maintained and be in effective operating conditions. BMPs must be selected and implemented as non-numeric technology-based effluent limitations. BMPs must include good housekeeping measures, preventative maintenance programs, spill and leak prevention and response procedures, erosion and sediment controls, and runoff management practices. The SWPPP shall describe how the BMPs are appropriate for the facility.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

e. A record of the following information for all chemical products that could potentially have an impact to stormwater associated with industrial activity as defined in §122.26(b)(14)(i)-(ix),(xi):

- i. Product name, chemical formula, and manufacturer;
- ii. Purpose or use of the chemical;
- iii. Safety Data Sheet (SDS) and Chemical Abstracts Service (CAS) Registry number for each chemical;
- iv. The frequency (e.g., hourly, daily), duration (e.g., hours, days), quantity (e.g., maximum and average), and method of application for the chemical; and
- v. The vendor's reported aquatic toxicity (NOAEL and/or LC50 in percent for aquatic organism(s)), when available.

f. A description of the training to be provided for employees to assure they understand the goals, objectives, and procedures of the SWPPP, the requirements of the NPDES permit, and their individual responsibilities for complying with the goals and objectives of the SWPPP and the NPDES permit.

g. Minimum documentation requirements are as follows:

- i. Records of operational and preventive maintenance activities, equipment inspections, procedure audits, and personnel training;
- ii. Records of the collection and analysis of samples, including, but not limited to, sample location, any calculations done at the time of sampling, any sampling or analytical methods used for samples analyzed on site, and sample results;
- iii. Any records of the collection and analysis of samples, the evaluation of design standards and operational changes, the selection, design, installation, and implementation of control measures, and/or evaluations, identifications, examinations and/or explanations documented in support of the residuals management BMP and/or environmental monitoring program requirement, below; and
- iv. All documentation of SWPPP activities shall be kept at the facility for at least three years and provided to EPA or MassDEP upon request.

5. All areas identified in the SWPPP shall be inspected, at least on a quarterly basis. Inspections shall occur beginning the 1st quarter after the effective date of the permit. EPA considers quarters as follows: January to March; April to June; July to September; and October to December.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

6. The permittee shall amend and update the SWPPP within 14 days for any changes at the facility affecting the SWPPP. Changes which may affect the SWPPP include, but are not limited to, the following activities: a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to the waters of the United States; a release of a reportable quantity of pollutants as described in 40 CFR §302; or a determination by the permittee or EPA that the SWPPP appears to be ineffective in achieving the general objective of controlling pollutants in stormwater discharges associated with industrial activity. Any amended or new versions of the SWPPP shall be re-certified by the permittee. Such re-certifications also shall be signed in accordance with the requirements identified in 40 CFR §122.22.

7. The permittee shall certify at least annually that the previous year's inspections and maintenance activities were conducted, results were recorded, records were maintained, and that the facility is in compliance with the SWPPP. If the facility is not in compliance with any aspect of the SWPPP, the annual certification shall state the non-compliance and the remedies which are being undertaken. Such annual certifications also shall be signed in accordance with the requirements identified in 40 CFR §122.22. The permittee shall keep a copy of the current SWPPP and all SWPPP certifications (the initial certification, recertifications, and annual certifications) signed during the effective period of this permit at the facility and shall make them available for inspection by EPA and MassDEP.

8. The SWPPP shall include best management practices (BMPs) for on-site activities that will minimize the discharge of pollutants in stormwater to waters of the United States. The permittee shall develop and implement site-specific BMPs; including BMPs to achieve the following:

- a. Store materials and equipment indoors such that contact with stormwater is limited and avoided whenever possible.
- b. Protect material stockpiles and equipment not stored indoors with weather-resistant covers to minimize exposure to rain and wind.
- c. Ensure stormwater not discharged through Outfall 001 remains on-site.
- d. Undertake reasonable efforts to control or reduce stormwater runoff volume to allow for proper operation of the WWTF.
- e. Ensure for proper cleanup of chemical spills that may come in contact with stormwater.
- f. Use vacuum equipment to sweep all paved or impervious areas of its property draining to Outfall 001 where solids deposition may occur, including roads, driveways, parking areas, sidewalks, and loading areas.

PART I.B. STORMWATER POLLUTION PREVENTION PLAN, cont'd.

- g. Inspect onsite pollution control measures more frequently following severe weather events or natural disasters when these conditions may result in increased pollutant discharges to the Unnamed Tributary.

Additionally, the permittee shall continue to implement site specific BMPs that are required for Sector E (Glass, Clay, Cement, Concrete, and Gypsum Products) of the current MSGP.

PART I.C. PHOSPHORUS CONTROL PLAN (PCP)

The PCP shall be developed and fully implemented during the permit term to meet the 62% phosphorus load reduction waste load allocation (WLA) set forth in the Lower Charles River TMDL. The permittee is required to develop and implement the following site-specific PCP:

- Within two (2) years of the effective date of the permit, in order to establish baseline conditions, the permittee shall:
 - complete the estimation of the average annual phosphorus load to the permitted outfall using influent and effluent phosphorus data, and
 - complete an evaluation of any additional structural or non-structural BMPs that reduce the phosphorus load to the Unnamed Tributary.
- Within three-and-a-half (3.5) years of the effective date of the permit, the permittee shall:
 - begin construction or implementation of BMPs designed to reduce phosphorus loads, and
 - monitor the effectiveness of those BMPs.
- Within five (5) years of the effective date of the permit, provide to EPA a report including:
 - a summary of phosphorus data analysis and phosphorus load estimation,
 - a description of the evaluation of additional phosphorus reduction BMPs beyond the WWTF (if applicable),
 - an operation, maintenance, and inspection plan of additional phosphorus reduction BMPs (if applicable),
 - a demonstration of the capacity of the entire facility to meet the 62% phosphorus WLA-based reduction target.

PART I.D. SOURCE IDENTIFICATION AND REDUCTION PLAN (SIRP)Metals

The permittee shall continue to implement the Source Identification and Reduction Plan (SIRP) for copper, chromium (VI), and aluminum. In addition, the permittee shall

- attempt to eliminate, or reduce to the maximum extent possible, the discharge of these pollutants from the facility,
- take additional samples to characterize the concentration and variability of each of the metals in onsite source streams using sufficiently sensitive analytical methods,
- develop BMPs to significantly reduce or eliminate the pollutant loading(s) to the receiving water in the event the source(s) of these metals cannot be eliminated, and evaluate whether site-specific stormwater BMPs can be used in conjunction with commingled stormwater and process water treatment options (e.g. pH adjustment, flocculation, and/or coagulation in the Wastewater Treatment Facility) to reduce metals identified as contributing to or causing an excursion of water quality standards in the receiving water (including but not limited to copper, chromium(VI), and aluminum), and
- update or amend the SIRP with any BMPs resulting from the evaluation within one (1) year after the effective date of the permit.

Pathogens

The permittee shall develop and implement a Source Identification and Reduction Plan (SIRP) in order to

- eliminate or reduce the discharge of bacteria through the facility's stormwater system, e.g. identifying and eliminating illicit sewer connections to the facility's drainage system, and
- significantly reduce or eliminate the bacteria loading to the receiving water via the development of BMPs in the event the source(s) of bacteria cannot be eliminated.

PART I.E. MONITORING AND REPORTING

The monitoring program in the permit specifies sampling and analysis, which will provide continuous information on compliance and the reliability and effectiveness of the installed pollution abatement equipment. The approved analytical procedures found in 40 CFR Part 136 are required unless other procedures are explicitly required in the permit. The permittee is obligated to monitor and report sampling results to EPA and the MassDEP within the time specified within the permit. Unless otherwise specified in this permit, the permittee shall submit reports, requests, and information and provide notices in the manner described in this section.

1. Submittal of Reports as NetDMR Attachments

As the permittee is already using NetDMR, the permittee shall electronically submit all reports to EPA as NetDMR attachments rather than as hard copies, unless otherwise specified in this permit. Permittees shall continue to send hard copies of reports other than DMRs to MassDEP until further notice from MassDEP. (See Part I.E.5 for more information on state reporting.) Because the due dates for reports described in this permit may not coincide with the due date for submitting DMRs (which is no later than the 15th day of the month), a report submitted electronically as a NetDMR attachment shall be considered timely if it is electronically submitted to EPA using NetDMR with the next DMR due following the particular report due date specified in this permit.

2. Submittal of Requests and Reports to EPA/OEP

The following requests, reports, and information described in this permit shall be submitted to the EPA/OEP NPDES Applications Coordinator in the EPA Office Ecosystem Protection (OEP).

- a. Transfer of permit notice
- b. Request for changes in sampling location
- c. Request for reduction in WET testing requirement
- d. Report on unacceptable dilution water / request for alternative dilution water for WET testing
- e. Notification of proposal to add or replace chemicals, including chemical additives

3. Submittal of Requests and Reports to EPA/OEP

These reports, information, and requests shall be submitted to EPA/OEP electronically at R1NPDES.Notices.OEP@epa.gov.

PART I.E. MONITORING AND REPORTING, cont'd.**4. Submittal of Reports in Hard Copy Form**

The following notifications and reports shall be submitted as hard copy with a cover letter describing the submission. These reports shall be signed and dated originals submitted to EPA.

- a. Written notifications required under Part II
- b. Notice of unauthorized discharges
- c. Reports and DMRs submitted prior to the use of NetDMR

This information shall be submitted to EPA/OES and MassDEP at the following addresses:

U.S. Environmental Protection Agency
Office of Environmental Stewardship (OES)
Water Technical Unit
5 Post Office Square, Suite 100 (OES04-4)
Boston, MA 02109-3912

Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, MA 01887

5. State Reporting

Transfer or termination of permit notices shall also specifically be submitted to:

Massachusetts Department of Environmental Protection
Bureau of Water Resources
Wastewater Management Program
1 Winter Street, 5th Floor
Boston, MA 02108

PART I.E. MONITORING AND REPORTING, cont'd.

Unless otherwise specified in this permit, duplicate signed copies of all reports, information, requests or notifications described in this permit, including the reports, information, requests or notifications described in Parts I.E.2, I.E.3, and I.E.4 also shall be submitted to the State at the following address:

Massachusetts Department of Environmental Protection
Northeast Regional Office
Bureau of Air and Waste
205B Lowell Street
Wilmington, Massachusetts 01887

Hard copies of Whole Effluent Toxicity tests and reports only shall be submitted to:

Massachusetts Department of Environmental Protection
Watershed Planning Program
8 New Bond Street
Worcester, MA 01606

7. Verbal Reports and Verbal Notifications

Any verbal reports or verbal notifications, if required in Parts I and/or II of this permit, shall be made to both EPA and to MassDEP. This includes verbal reports and notifications which require reporting within 24 hours. (As examples, see Part II.B.4.c. (2), Part II.B.5.c. (3), and Part II.D.1.e.) Verbal reports and verbal notifications shall be made to EPA's Office of Environmental Stewardship at: **617-918-1510**.

PART I.F. STATE PERMIT CONDITIONS

1. This authorization to discharge includes two separate and independent permit authorizations. The two permit authorizations are (i) a federal National Pollutant Discharge Elimination System permit issued by the U.S. Environmental Protection Agency (EPA) pursuant to the Federal Clean Water Act, 33 U.S.C. §§1251 et seq.; and (ii) an identical state surface water discharge permit issued by the Commissioner of the Massachusetts Department of Environmental Protection (MassDEP) pursuant to the Massachusetts Clean Waters Act, M.G.L. c. 21, §§26-53, and 314 CMR 3.00. All of the requirements contained in this authorization, as well as the standard conditions contained in 314 CMR 3.19, are hereby incorporated by reference into this state surface water discharge permit.
2. This authorization also incorporates the state water quality certification issued by MassDEP under §401(a) of the Federal Clean Water Act, 40 CFR 124.53, M.G.L. c. 21, §27 and 314 CMR 3.07. All of the requirements (if any) contained in MassDEP's water quality certification for the permit are hereby incorporated by reference into this state surface water discharge permit as special conditions pursuant to 314 CMR 3.11.
3. Each agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this permit shall be effective only with respect to the agency taking such action, and shall not affect the validity or status of this permit as issued by the other agency, unless and until each agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this permit is declared invalid, illegal or otherwise issued in violation of state law such permit shall remain in full force and effect under federal law as a NPDES permit issued by the U.S. Environmental Protection Agency. In the event this permit is declared invalid, illegal or otherwise issued in violation of federal law, this permit shall remain in full force and effect under state law as a permit issued by the Commonwealth of Massachusetts.
4. The permittee shall ensure that sweepings collected at its facility are reused or disposed in a manner consistent with MassDEP's Policy #BWP-94-092: Reuse and Disposal of Street Sweepings.

USEPA REGION 1 FRESHWATER ACUTE TOXICITY TEST PROCEDURE AND PROTOCOL

I. GENERAL REQUIREMENTS

The permittee shall conduct acceptable acute toxicity tests in accordance with the appropriate test protocols described below:

- **Daphnid (Ceriodaphnia dubia) definitive 48 hour test.**
- **Fathead Minnow (Pimephales promelas) definitive 48 hour test.**

Acute toxicity test data shall be reported as outlined in Section VIII.

II. METHODS

The permittee shall use 40 CFR Part 136 methods. Methods and guidance may be found at:

http://water.epa.gov/scitech/methods/cwa/wet/disk2_index.cfm

The permittee shall also meet the sampling, analysis and reporting requirements included in this protocol. This protocol defines more specific requirements while still being consistent with the Part 136 methods. If, due to modifications of Part 136, there are conflicting requirements between the Part 136 method and this protocol, the permittee shall comply with the requirements of the Part 136 method.

III. SAMPLE COLLECTION

A discharge sample shall be collected. Aliquots shall be split from the sample, containerized and preserved (as per 40 CFR Part 136) for chemical and physical analyses required. The remaining sample shall be measured for total residual chlorine and dechlorinated (if detected) in the laboratory using sodium thiosulfate for subsequent toxicity testing. (Note that EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection.) Grab samples must be used for pH, temperature, and total residual chlorine (as per 40 CFR Part 122.21).

Standard Methods for the Examination of Water and Wastewater describes dechlorination of samples (APHA, 1992). Dechlorination can be achieved using a ratio of 6.7 mg/L anhydrous sodium thiosulfate to reduce 1.0 mg/L chlorine. If dechlorination is necessary, a thiosulfate control (maximum amount of thiosulfate in lab control or receiving water) must also be run in the WET test.

All samples held overnight shall be refrigerated at 1- 6°C.

IV. DILUTION WATER

A grab sample of dilution water used for acute toxicity testing shall be collected from the receiving water at a point immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location. Avoid collection near areas of obvious road or agricultural runoff, storm sewers or other point source discharges and areas where stagnant conditions exist. In the case where an alternate dilution water has been agreed upon an additional receiving water control (0% effluent) must also be tested.

If the receiving water diluent is found to be, or suspected to be toxic or unreliable, an alternate standard dilution water of known quality with a hardness, pH, conductivity, alkalinity, organic carbon, and total suspended solids similar to that of the receiving water may be substituted **AFTER RECEIVING WRITTEN APPROVAL FROM THE PERMIT ISSUING AGENCY(S)**. Written requests for use of an alternate dilution water should be mailed with supporting documentation to the following address:

Director
Office of Ecosystem Protection (CAA)
U.S. Environmental Protection Agency-New England
5 Post Office Sq., Suite 100 (OEP06-5)
Boston, MA 02109-3912

and

Manager
Water Technical Unit (SEW)
U.S. Environmental Protection Agency
5 Post Office Sq., Suite 100 (OES04-4)
Boston, MA 02109-3912

Note: USEPA Region 1 retains the right to modify any part of the alternate dilution water policy stated in this protocol at any time. Any changes to this policy will be documented in the annual DMR posting.

See the most current annual DMR instructions which can be found on the EPA Region 1 website at <http://www.epa.gov/region1/enforcement/water/dmr.html> for further important details on alternate dilution water substitution requests.

It may prove beneficial to have the proposed dilution water source screened for suitability prior to toxicity testing. EPA strongly urges that screening be done prior to set up of a full definitive toxicity test any time there is question about the dilution water's ability to support acceptable performance as outlined in the 'test acceptability' section of the protocol.

V. TEST CONDITIONS

The following tables summarize the accepted daphnid and fathead minnow toxicity test conditions and test acceptability criteria:

EPA NEW ENGLAND EFFLUENT TOXICITY TEST CONDITIONS FOR THE DAPHNID, CERIODAPHNIA DUBIA 48 HOUR ACUTE TESTS¹

1.	Test type	Static, non-renewal
2.	Temperature (°C)	20 ± 1°C or 25 ± 1°C
3.	Light quality	Ambient laboratory illumination
4.	Photoperiod	16 hour light, 8 hour dark
5.	Test chamber size	Minimum 30 ml
6.	Test solution volume	Minimum 15 ml
7.	Age of test organisms	1-24 hours (neonates)
8.	No. of daphnids per test chamber	5
9.	No. of replicate test chambers per treatment	4
10.	Total no. daphnids per test concentration	20
11.	Feeding regime	As per manual, lightly feed YCT and <u>Selenastrum</u> to newly released organisms while holding prior to initiating test
12.	Aeration	None
13.	Dilution water ²	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q ^R or equivalent deionized water and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14.	Dilution series	≥ 0.5, must bracket the permitted RWC
15.	Number of dilutions	5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution

series.

- | | |
|----------------------------|---|
| 16. Effect measured | Mortality-no movement of body or appendages on gentle prodding |
| 17. Test acceptability | 90% or greater survival of test organisms in dilution water control solution |
| 18. Sampling requirements | For on-site tests, samples must be used within 24 hours of the time that they are removed from the sampling device. For off-site tests, samples must first be used within 36 hours of collection. |
| 19. Sample volume required | Minimum 1 liter |

Footnotes:

1. Adapted from EPA-821-R-02-012.
2. Standard prepared dilution water must have hardness requirements to generally reflect the characteristics of the receiving water.

**EPA NEW ENGLAND TEST CONDITIONS FOR THE FATHEAD MINNOW
(PIMEPHALES PROMELAS) 48 HOUR ACUTE TEST¹**

1. Test Type	Static, non-renewal
2. Temperature (°C)	$20 \pm 1^{\circ} \text{C}$ or $25 \pm 1^{\circ} \text{C}$
3. Light quality	Ambient laboratory illumination
4. Photoperiod	16 hr light, 8 hr dark
5. Size of test vessels	250 mL minimum
6. Volume of test solution	Minimum 200 mL/replicate
7. Age of fish	1-14 days old and age within 24 hrs of each other
8. No. of fish per chamber	10
9. No. of replicate test vessels per treatment	4
10. Total no. organisms per concentration	40
11. Feeding regime	As per manual, lightly feed test age larvae using concentrated brine shrimp nauplii while holding prior to initiating test
12. Aeration	None, unless dissolved oxygen (D.O.) concentration falls below 4.0 mg/L, at which time gentle single bubble aeration should be started at a rate of less than 100 bubbles/min. (Routine D.O. check is recommended.)
13. dilution water ²	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q ^R or equivalent deionized and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14. Dilution series	≥ 0.5 , must bracket the permitted RWC

15. Number of dilutions	5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution series.
16. Effect measured	Mortality-no movement on gentle prodding
17. Test acceptability	90% or greater survival of test organisms in dilution water control solution
18. Sampling requirements	For on-site tests, samples must be used within 24 hours of the time that they are removed from the sampling device. For off-site tests, samples are used within 36 hours of collection.
19. Sample volume required	Minimum 2 liters

Footnotes:

1. Adapted from EPA-821-R-02-012
2. Standard dilution water must have hardness requirements to generally reflect characteristics of the receiving water.

VI. CHEMICAL ANALYSIS

At the beginning of a static acute toxicity test, pH, conductivity, total residual chlorine, oxygen, hardness, alkalinity and temperature must be measured in the highest effluent concentration and the dilution water. Dissolved oxygen, pH and temperature are also measured at 24 and 48 hour intervals in all dilutions. The following chemical analyses shall be performed on the 100 percent effluent sample and the upstream water sample for each sampling event.

<u>Parameter</u>	Effluent	Receiving Water	ML (mg/l)
Hardness ¹	x	x	0.5
Total Residual Chlorine (TRC) ^{2, 3}	x		0.02
Alkalinity	x	x	2.0
pH	x	x	--
Specific Conductance	x	x	--
Total Solids	x		--
Total Dissolved Solids	x		--
Ammonia	x	x	0.1
Total Organic Carbon	x	x	0.5
Total Metals			
Cd	x	x	0.0005
Pb	x	x	0.0005
Cu	x	x	0.003
Zn	x	x	0.005
Ni	x	x	0.005
Al	x	x	0.02
Other as permit requires			

Notes:

- Hardness may be determined by:
 - APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 2340B (hardness by calculation)
 - Method 2340C (titration)
- Total Residual Chlorine may be performed using any of the following methods provided the required minimum limit (ML) is met.
 - APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 4500-CL E Low Level Amperometric Titration
 - Method 4500-CL G DPD Colorimetric Method
- Required to be performed on the sample used for WET testing prior to its use for toxicity testing.

VII. TOXICITY TEST DATA ANALYSIS

LC50 Median Lethal Concentration (Determined at 48 Hours)

Methods of Estimation:

- Probit Method
- Spearman-Kärber
- Trimmed Spearman-Kärber
- Graphical

See the flow chart in Figure 6 on p. 73 of EPA-821-R-02-012 for appropriate method to use on a given data set.

No Observed Acute Effect Level (NOAEL)

See the flow chart in Figure 13 on p. 87 of EPA-821-R-02-012.

VIII. TOXICITY TEST REPORTING

A report of the results will include the following:

- Description of sample collection procedures, site description
- Names of individuals collecting and transporting samples, times and dates of sample collection and analysis on chain-of-custody
- General description of tests: age of test organisms, origin, dates and results of standard toxicant tests; light and temperature regime; other information on test conditions if different than procedures recommended. Reference toxicant test data should be included.
- All chemical/physical data generated. (Include minimum detection levels and minimum quantification levels.)
- Raw data and bench sheets.
- Provide a description of dechlorination procedures (as applicable).
- Any other observations or test conditions affecting test outcome.

FRESHWATER CHRONIC TOXICITY TEST PROCEDURE AND PROTOCOL

USEPA Region 1

I. GENERAL REQUIREMENTS

The permittee shall be responsible for the conduct of acceptable chronic toxicity tests using three fresh samples collected during each test period. The following tests shall be performed as prescribed in Part 1 of the NPDES discharge permit in accordance with the appropriate test protocols described below. (Note: the permittee and testing laboratory should review the applicable permit to determine whether testing of one or both species is required).

- **Daphnid (Ceriodaphnia dubia) Survival and Reproduction Test.**
- **Fathead Minnow (Pimephales promelas) Larval Growth and Survival Test.**

Chronic toxicity data shall be reported as outlined in Section VIII.

II. METHODS

Methods to follow are those recommended by EPA in: Short Term Methods For Estimating The Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, Fourth Edition, October 2002. United States Environmental Protection Agency. Office of Water, Washington, D.C., EPA 821-R-02-013. The methods are available on-line at <http://www.epa.gov/waterscience/WET/> . Exceptions and clarification are stated herein.

III. SAMPLE COLLECTION AND USE

A total of three fresh samples of effluent and receiving water are required for initiation and subsequent renewals of a freshwater, chronic, toxicity test. The receiving water control sample must be collected immediately upstream of the permitted discharge's zone of influence. Fresh samples are recommended for use on test days 1, 3, and 5. However, provided a total of three samples are used for testing over the test period, an alternate sampling schedule is acceptable. The acceptable holding times until initial use of a sample are 24 and 36 hours for on-site and off-site testing, respectively. A written waiver is required from the regulating authority for any hold time extension. All test samples collected may be used for 24, 48 and 72 hour renewals after initial use. All samples held for use beyond the day of sampling shall be refrigerated and maintained at a temperature range of 0-6° C.

All samples submitted for chemical and physical analyses will be analyzed according to Section VI of this protocol.

Sampling guidance dictates that, where appropriate, aliquots for the analysis required in this protocol shall be split from the samples, containerized and immediately preserved, or analyzed as per 40 CFR Part 136. EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection. Testing for the presence of total residual chlorine (TRC) must be analyzed immediately or as soon as possible, for all effluent samples, prior to WET testing. TRC analysis may be performed on-site or by the toxicity testing laboratory and the samples must be dechlorinated, as necessary, using sodium thiosulfate prior to sample use for toxicity testing.

If any of the renewal samples are of sufficient potency to cause lethality to 50 percent or more of the test organisms in any of the test treatments for either species or, if the test fails to meet its permit limits, then chemical analysis for total metals (originally required for the initial sample only in Section VI) will be required on the renewal sample(s) as well.

IV. DILUTION WATER

Samples of receiving water must be collected from a location in the receiving water body immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location. Avoid collection near areas of obvious road or agricultural runoff, storm sewers or other point source discharges and areas where stagnant conditions exist. EPA strongly urges that screening for toxicity be performed prior to the set up of a full, definitive toxicity test any time there is a question about the test dilution water's ability to achieve test acceptability criteria (TAC) as indicated in Section V of this protocol. The test dilution water control response will be used in the statistical analysis of the toxicity test data. All other control(s) required to be run in the test will be reported as specified in the Discharge Monitoring Report (DMR) Instructions, Attachment F, page 2, Test Results & Permit Limits.

The test dilution water must be used to determine whether the test met the applicable TAC. When receiving water is used for test dilution, an additional control made up of standard laboratory water (0% effluent) is required. This control will be used to verify the health of the test organisms and evaluate to what extent, if any, the receiving water itself is responsible for any toxic response observed.

If dechlorination of a sample by the toxicity testing laboratory is necessary a "sodium thiosulfate" control, representing the concentration of sodium thiosulfate used to adequately dechlorinate the sample prior to toxicity testing, must be included in the test.

If the use of an alternate dilution water (ADW) is authorized, in addition to the ADW test control, the testing laboratory must, for the purpose of monitoring the receiving water, also run a receiving water control.

If the receiving water diluent is found to be, or suspected to be toxic or unreliable an ADW of known quality with hardness similar to that of the receiving water may be substituted. Substitution is species specific meaning that the decision to use ADW is made for each species and is based on the toxic response of that particular species. Substitution to an ADW is authorized in two cases. The first is the case where repeating a test due to toxicity in the site dilution water requires an **immediate decision** for ADW use be made by the permittee and toxicity testing laboratory. The second is in the case where two of the most recent documented incidents of unacceptable site dilution water toxicity requires ADW use in future WET testing.

For the second case, written notification from the permittee requesting ADW use **and** written authorization from the permit issuing agency(s) is required **prior to** switching to a long-term use of ADW for the duration of the permit.

Written requests for use of ADW must be mailed with supporting documentation to the following addresses:

Director
Office of Ecosystem Protection (CAA)
U.S. Environmental Protection Agency, Region 1
Five Post Office Square, Suite 100
Mail Code OEP06-5
Boston, MA 02109-3912

and

Manager
Water Technical Unit (SEW)
U.S. Environmental Protection Agency
Five Post Office Square, Suite 100
Mail Code OES04-4
Boston, MA 02109-3912

Note: USEPA Region 1 retains the right to modify any part of the alternate dilution water policy stated in this protocol at any time. Any changes to this policy will be documented in the annual DMR posting.

See the most current annual DMR instructions which can be found on the EPA Region 1 website at <http://www.epa.gov/region1/enforcementandassistance/dmr.html> for further important details on alternate dilution water substitution requests.

V. TEST CONDITIONS AND TEST ACCEPTABILITY CRITERIA

Method specific test conditions and TAC are to be followed and adhered to as specified in the method guidance document, EPA 821-R-02-013. If a test does not meet TAC the test must be repeated with fresh samples within 30 days of the initial test completion date.

V.1. Use of Reference Toxicity Testing

Reference toxicity test results and applicable control charts must be included in the toxicity testing report.

If reference toxicity test results fall outside the control limits established by the laboratory for a specific test endpoint, a reason or reasons for this excursion must be evaluated, correction made and reference toxicity tests rerun as necessary.

If a test endpoint value exceeds the control limits at a frequency of more than one out of twenty then causes for the reference toxicity test failure must be examined and if problems are identified corrective action taken. The reference toxicity test must be repeated during the same month in which the exceedance occurred.

If two consecutive reference toxicity tests fall outside control limits, the possible cause(s) for the exceedance must be examined, corrective actions taken and a repeat of the reference toxicity test must take place immediately. Actions taken to resolve the problem must be reported.

V.1.a. Use of Concurrent Reference Toxicity Testing

In the case where concurrent reference toxicity testing is required due to a low frequency of testing with a particular method, if the reference toxicity test results fall slightly outside of laboratory established control limits, but the primary test met the TAC, the results of the primary test will be considered acceptable. However, if the results of the concurrent test fall well outside the established **upper** control limits i.e. ≥ 3 standard deviations for IC25 values and \geq two concentration intervals for NOECs, and even though the primary test meets TAC, the primary test will be considered unacceptable and must be repeated.

V.2. For the *C. dubia* test, the determination of TAC and formal statistical analyses must be performed using only the first three broods produced.

V.3. Test treatments must include 5 effluent concentrations and a dilution water control. An additional test treatment, at the permitted effluent concentration (% effluent), is required if it is not included in the dilution series.

VI. CHEMICAL ANALYSIS

As part of each toxicity test's daily renewal procedure, pH, specific conductance, dissolved oxygen (DO) and temperature must be measured at the beginning and end of each 24-hour period in each test treatment and the control(s).

The additional analysis that must be performed under this protocol is as specified and noted in the table below.

<u>Parameter</u>	Effluent	Receiving Water	ML (mg/l)
Hardness ^{1, 4}	x	x	0.5
Total Residual Chlorine (TRC) ^{2, 3, 4}	x		0.02
Alkalinity ⁴	x	x	2.0
pH ⁴	x	x	--
Specific Conductance ⁴	x	x	--
Total Solids ⁶	x		--
Total Dissolved Solids ⁶	x		--
Ammonia ⁴	x	x	0.1
Total Organic Carbon ⁶	x	x	0.5
Total Metals ⁵			
Cd	x	x	0.0005
Pb	x	x	0.0005
Cu	x	x	0.003
Zn	x	x	0.005
Ni	x	x	0.005
Al	x	x	0.02

Other as permit requires

Notes:

1. Hardness may be determined by:

- APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 2340B (hardness by calculation)
 - Method 2340C (titration)
2. Total Residual Chlorine may be performed using any of the following methods provided the required minimum limit (ML) is met.
- APHA Standard Methods for the Examination of Water and Wastewater , 21st Edition
 - Method 4500-CL E Low Level Amperometric Titration
 - Method 4500-CL G DPD Colorimetric Method
 - USEPA 1983. Manual of Methods Analysis of Water and Wastes
 - Method 330.5
3. Required to be performed on the sample used for WET testing prior to its use for toxicity testing
4. Analysis is to be performed on samples and/or receiving water, as designated in the table above, from all three sampling events.
5. Analysis is to be performed on the initial sample(s) only unless the situation arises as stated in Section III, paragraph 4
6. Analysis to be performed on initial samples only

VII. TOXICITY TEST DATA ANALYSIS AND REVIEW

A. Test Review

1. Concentration / Response Relationship

A concentration/response relationship evaluation is required for test endpoint determinations from both Hypothesis Testing and Point Estimate techniques. The test report is to include documentation of this evaluation in support of the endpoint values reported. The dose-response review must be performed as required in Section 10.2.6 of EPA-821-R-02-013. Guidance for this review can be found at <http://water.epa.gov/scitech/methods/cwa/> . In most cases, the review will result in one of the following three conclusions: (1) Results are reliable and reportable; (2) Results are anomalous and require explanation; or (3) Results are inconclusive and a retest with fresh samples is required.

2. Test Variability (Test Sensitivity)

This review step is separate from the determination of whether a test meets or does not meet TAC. Within test variability is to be examined for the purpose of evaluating test sensitivity. This evaluation is to be performed for the sub-lethal hypothesis testing endpoints reproduction and growth as required by the permit. The test report is to include documentation of this evaluation to support that the endpoint values reported resulted from a toxicity test of adequate sensitivity. This evaluation must be performed as required in Section 10.2.8 of EPA-821-R-02-013.

To determine the adequacy of test sensitivity, USEPA requires the calculation of test percent minimum significant difference (PMSD) values. In cases where NOEC determinations are made based on a non-parametric technique, calculation of a test PMSD value, for the sole purpose of assessing test sensitivity, shall be calculated using a comparable parametric statistical analysis technique. The calculated test PMSD is then compared to the upper and lower PMSD bounds shown for freshwater tests in Section 10.2.8.3, p. 52, Table 6 of EPA-821-R-02-013. The comparison will yield one of the following determinations.

- The test PMSD exceeds the PMSD upper bound test variability criterion in Table 6, the test results are considered highly variable and the test may not be sensitive enough to determine the presence of toxicity at the permit limit concentration (PLC). If the test results indicate that the discharge is not toxic at the PLC, then the test is considered insufficiently sensitive and must be repeated within 30 days of the initial test completion using fresh samples. If the test results indicate that the discharge is toxic at the PLC, the test is considered acceptable and does not have to be repeated.
- The test PMSD falls below the PMSD lower bound test variability criterion in Table 6, the test is determined to be very sensitive. In order to determine which treatment(s) are statistically significant and which are not, for the purpose of reporting a NOEC, the relative percent difference (RPD) between the control and each treatment must be calculated and compared to the lower PMSD boundary. See *Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the NPDES Program*, EPA 833-R-00-003, June 2002, Section 6.4.2. The following link: [Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications Under the NPDES Program](#) can be used to locate the USEPA website containing this document. If the RPD for a treatment falls below the PMSD lower bound, the difference is considered statistically insignificant. If the RPD for a treatment is greater than the PMSD lower bound, then the treatment is considered statistically significant.
- The test PMSD falls within the PMSD upper and lower bounds in Table 6, the sub-lethal test endpoint values shall be reported as is.

B. Statistical Analysis

1. General - Recommended Statistical Analysis Method

Refer to general data analysis flowchart, EPA 821-R-02-013, page 43

For discussion on Hypothesis Testing, refer to EPA 821-R-02-013, Section 9.6

For discussion on Point Estimation Techniques, refer to EPA 821-R-02-013, Section 9.7

2. *Pimephales promelas*

Refer to survival hypothesis testing analysis flowchart, EPA 821-R-02-013, page 79

Refer to survival point estimate techniques flowchart, EPA 821-R-02-013, page 80

Refer to growth data statistical analysis flowchart, EPA 821-R-02-013, page 92

3. *Ceriodaphnia dubia*

Refer to survival data testing flowchart, EPA 821-R-02-013, page 168

Refer to reproduction data testing flowchart, EPA 821-R-02-013, page 173

VIII. TOXICITY TEST REPORTING

A report of results must include the following:

- Test summary sheets (2007 DMR Attachment F) which includes:
 - Facility name
 - NPDES permit number
 - Outfall number
 - Sample type
 - Sampling method
 - Effluent TRC concentration
 - Dilution water used
 - Receiving water name and sampling location
 - Test type and species
 - Test start date
 - Effluent concentrations tested (%) and permit limit concentration
 - Applicable reference toxicity test date and whether acceptable or not
 - Age, age range and source of test organisms used for testing
 - Results of TAC review for all applicable controls
 - Test sensitivity evaluation results (test PMSD for growth and reproduction)
 - Permit limit and toxicity test results
 - Summary of test sensitivity and concentration response evaluation

In addition to the summary sheets the report must include:

- A brief description of sample collection procedures
- Chain of custody documentation including names of individuals collecting samples, times and dates of sample collection, sample locations, requested analysis and lab receipt with time and date received, lab receipt personnel and condition of samples upon receipt at the lab(s)
- Reference toxicity test control charts
- All sample chemical/physical data generated, including minimum limits (MLs) and analytical methods used
- All toxicity test raw data including daily ambient test conditions, toxicity test chemistry, sample dechlorination details as necessary, bench sheets and statistical analysis
- A discussion of any deviations from test conditions
- Any further discussion of reported test results, statistical analysis and concentration-response relationship and test sensitivity review per species per endpoint

NPDES PART II STANDARD CONDITIONS
(January, 2007)

TABLE OF CONTENTS

A. GENERAL CONDITIONS	Page
1. <u>Duty to Comply</u>	2
2. <u>Permit Actions</u>	2
3. <u>Duty to Provide Information</u>	2
4. <u>Reopener Clause</u>	3
5. <u>Oil and Hazardous Substance Liability</u>	3
6. <u>Property Rights</u>	3
7. <u>Confidentiality of Information</u>	3
8. <u>Duty to Reapply</u>	4
9. <u>State Authorities</u>	4
10. <u>Other laws</u>	4
B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS	
1. <u>Proper Operation and Maintenance</u>	4
2. <u>Need to Halt or Reduce Not a Defense</u>	4
3. <u>Duty to Mitigate</u>	4
4. <u>Bypass</u>	4
5. <u>Upset</u>	5
C. MONITORING AND RECORDS	
1. <u>Monitoring and Records</u>	6
2. <u>Inspection and Entry</u>	7
D. REPORTING REQUIREMENTS	
1. <u>Reporting Requirements</u>	7
a. Planned changes	7
b. Anticipated noncompliance	7
c. Transfers	7
d. Monitoring reports	8
e. Twenty-four hour reporting	8
f. Compliance schedules	9
g. Other noncompliance	9
h. Other information	9
2. <u>Signatory Requirement</u>	9
3. <u>Availability of Reports</u>	9
E. DEFINITIONS AND ABBREVIATIONS	
1. <u>Definitions for Individual NPDES Permits including Storm Water Requirements</u>	9
2. <u>Definitions for NPDES Permit Sludge Use and Disposal Requirements</u>	17
3. <u>Commonly Used Abbreviations</u>	23

NPDES PART II STANDARD CONDITIONS

(January, 2007)

PART II. A. GENERAL REQUIREMENTS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

- a. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirements.
- b. The CWA provides that any person who violates Section 301, 302, 306, 307, 308, 318, or 405 of the CWA or any permit condition or limitation implementing any of such sections in a permit issued under Section 402, or any requirement imposed in a pretreatment program approved under Section 402 (a)(3) or 402 (b)(8) of the CWA is subject to a civil penalty not to exceed \$25,000 per day for each violation. Any person who negligently violates such requirements is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than 1 year, or both. Any person who knowingly violates such requirements is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both.
- c. Any person may be assessed an administrative penalty by the Administrator for violating Section 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any permit condition or limitation implementing any of such sections in a permit issued under Section 402 of the CWA. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.

Note: See 40 CFR §122.41(a)(2) for complete “Duty to Comply” regulations.

2. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or notifications of planned changes or anticipated noncompliance does not stay any permit condition.

3. Duty to Provide Information

The permittee shall furnish to the Regional Administrator, within a reasonable time, any information which the Regional Administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Regional Administrator, upon request, copies of records required to be kept by this permit.

NPDES PART II STANDARD CONDITIONS
(January, 2007)

4. Reopener Clause

The Regional Administrator reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the CWA in order to bring all discharges into compliance with the CWA.

For any permit issued to a treatment works treating domestic sewage (including “sludge-only facilities”), the Regional Administrator or Director shall include a reopener clause to incorporate any applicable standard for sewage sludge use or disposal promulgated under Section 405 (d) of the CWA. The Regional Administrator or Director may promptly modify or revoke and reissue any permit containing the reopener clause required by this paragraph if the standard for sewage sludge use or disposal is more stringent than any requirements for sludge use or disposal in the permit, or contains a pollutant or practice not limited in the permit.

Federal regulations pertaining to permit modification, revocation and reissuance, and termination are found at 40 CFR §122.62, 122.63, 122.64, and 124.5.

5. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the CWA, or Section 106 of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA).

6. Property Rights

The issuance of this permit does not convey any property rights of any sort, nor any exclusive privileges.

7. Confidentiality of Information

- a. In accordance with 40 CFR Part 2, any information submitted to EPA pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words “confidential business information” on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR Part 2 (Public Information).
- b. Claims of confidentiality for the following information will be denied:
 - (1) The name and address of any permit applicant or permittee;
 - (2) Permit applications, permits, and effluent data as defined in 40 CFR §2.302(a)(2).
- c. Information required by NPDES application forms provided by the Regional Administrator under 40 CFR §122.21 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.

NPDES PART II STANDARD CONDITIONS
(January, 2007)

8. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee must apply for and obtain a new permit. The permittee shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Regional Administrator. (The Regional Administrator shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)

9. State Authorities

Nothing in Part 122, 123, or 124 precludes more stringent State regulation of any activity covered by these regulations, whether or not under an approved State program.

10. Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, nor does it relieve the permittee of its obligation to comply with any other applicable Federal, State, or local laws and regulations.

PART II. B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit and with the requirements of storm water pollution prevention plans. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of the permit.

2. Need to Halt or Reduce Not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

4. Bypass

a. Definitions

- (1) *Bypass* means the intentional diversion of waste streams from any portion of a treatment facility.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can be reasonably expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

b. Bypass not exceeding limitations

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of Paragraphs B.4.c. and 4.d. of this section.

c. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D.1.e. of this part (Twenty-four hour reporting).

d. Prohibition of bypass

Bypass is prohibited, and the Regional Administrator may take enforcement action against a permittee for bypass, unless:

- (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
- (3) i) The permittee submitted notices as required under Paragraph 4.c. of this section.
ii) The Regional Administrator may approve an anticipated bypass, after considering its adverse effects, if the Regional Administrator determines that it will meet the three conditions listed above in paragraph 4.d. of this section.

5. Upset

- a. Definition. *Upset* means an exceptional incident in which there is an unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph B.5.c. of this section are met. No determination made during

NPDES PART II STANDARD CONDITIONS

(January, 2007)

administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in paragraphs D.1.a. and 1.e. (Twenty-four hour notice); and
 - (4) The permittee complied with any remedial measures required under B.3. above.
- d. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

PART II. C. MONITORING REQUIREMENTS

1. Monitoring and Records

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Except for records for monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application except for the information concerning storm water discharges which must be retained for a total of 6 years. This retention period may be extended by request of the Regional Administrator at any time.
- c. Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;
 - (2) The individual(s) who performed the sampling or measurements;
 - (3) The date(s) analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.
- d. Monitoring results must be conducted according to test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, unless other test procedures have been specified in the permit.
- e. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by

NPDES PART II STANDARD CONDITIONS

(January, 2007)

imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

2. Inspection and Entry

The permittee shall allow the Regional Administrator or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the CWA, any substances or parameters at any location.

PART II. D. REPORTING REQUIREMENTS

1. Reporting Requirements

- a. **Planned Changes.** The permittee shall give notice to the Regional Administrator as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:
 - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR§122.29(b); or
 - (2) The alteration or addition could significantly change the nature or increase the quantities of the pollutants discharged. This notification applies to pollutants which are subject neither to the effluent limitations in the permit, nor to the notification requirements at 40 CFR§122.42(a)(1).
 - (3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition or change may justify the application of permit conditions different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. **Anticipated noncompliance.** The permittee shall give advance notice to the Regional Administrator of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- c. **Transfers.** This permit is not transferable to any person except after notice to the Regional Administrator. The Regional Administrator may require modification or revocation and reissuance of the permit to change the name of the permittee and

NPDES PART II STANDARD CONDITIONS
(January, 2007)

incorporate such other requirements as may be necessary under the CWA. (See 40 CFR Part 122.61; in some cases, modification or revocation and reissuance is mandatory.)

- d. Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.
 - (2) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of the monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
 - (3) Calculations for all limitations which require averaging or measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. Twenty-four hour reporting.
 - (1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances.

A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
 - (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
 - (a) Any unanticipated bypass which exceeds any effluent limitation in the permit. (See 40 CFR §122.41(g).)
 - (b) Any upset which exceeds any effluent limitation in the permit.
 - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Regional Administrator in the permit to be reported within 24 hours. (See 40 CFR §122.44(g).)
 - (3) The Regional Administrator may waive the written report on a case-by-case basis for reports under Paragraph D.1.e. if the oral report has been received within 24 hours.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

- f. Compliance Schedules. Reports of compliance or noncompliance with, any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
 - g. Other noncompliance. The permittee shall report all instances of noncompliance not reported under Paragraphs D.1.d., D.1.e., and D.1.f. of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in Paragraph D.1.e. of this section.
 - h. Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Administrator, it shall promptly submit such facts or information.
2. Signatory Requirement
- a. All applications, reports, or information submitted to the Regional Administrator shall be signed and certified. (See 40 CFR §122.22)
 - b. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 2 years per violation, or by both.
3. Availability of Reports.

Except for data determined to be confidential under Paragraph A.8. above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the State water pollution control agency and the Regional Administrator. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statements on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA.

PART II. E. DEFINITIONS AND ABBREVIATIONS

1. Definitions for Individual NPDES Permits including Storm Water Requirements

Administrator means the Administrator of the United States Environmental Protection Agency, or an authorized representative.

Applicable standards and limitations means all, State, interstate, and Federal standards and limitations to which a “discharge”, a “sewage sludge use or disposal practice”, or a related activity is subject to, including “effluent limitations”, water quality standards, standards of performance, toxic effluent standards or prohibitions, “best management practices”, pretreatment standards, and “standards for sewage sludge use and disposal” under Sections 301, 302, 303, 304, 306, 307, 308, 403, and 405 of the CWA.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

Application means the EPA standard national forms for applying for a permit, including any additions, revisions, or modifications to the forms; or forms approved by EPA for use in “approved States”, including any approved modifications or revisions.

Average means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For total and/or fecal coliforms and Escherichia coli, the average shall be the geometric mean.

Average monthly discharge limitation means the highest allowable average of “daily discharges” over a calendar month calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.

Average weekly discharge limitation means the highest allowable average of “daily discharges” measured during the calendar week divided by the number of “daily discharges” measured during the week.

Best Management Practices (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of “waters of the United States.” BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Best Professional Judgment (BPJ) means a case-by-case determination of Best Practicable Treatment (BPT), Best Available Treatment (BAT), or other appropriate technology-based standard based on an evaluation of the available technology to achieve a particular pollutant reduction and other factors set forth in 40 CFR §125.3 (d).

Coal Pile Runoff means the rainfall runoff from or through any coal storage pile.

Composite Sample means a sample consisting of a minimum of eight grab samples of equal volume collected at equal intervals during a 24-hour period (or lesser period as specified in the section on Monitoring and Reporting) and combined proportional to flow, or a sample consisting of the same number of grab samples, or greater, collected proportionally to flow over that same time period.

Construction Activities - The following definitions apply to construction activities:

- (a) Commencement of Construction is the initial disturbance of soils associated with clearing, grading, or excavating activities or other construction activities.
- (b) Dedicated portable asphalt plant is a portable asphalt plant located on or contiguous to a construction site and that provides asphalt only to the construction site that the plant is located on or adjacent to. The term dedicated portable asphalt plant does not include facilities that are subject to the asphalt emulsion effluent limitation guideline at 40 CFR Part 443.
- (c) Dedicated portable concrete plant is a portable concrete plant located on or contiguous to a construction site and that provides concrete only to the construction site that the plant is located on or adjacent to.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

- (d) Final Stabilization means that all soil disturbing activities at the site have been complete, and that a uniform perennial vegetative cover with a density of 70% of the cover for unpaved areas and areas not covered by permanent structures has been established or equivalent permanent stabilization measures (such as the use of riprap, gabions, or geotextiles) have been employed.
- (e) Runoff coefficient means the fraction of total rainfall that will appear at the conveyance as runoff.

Contiguous zone means the entire zone established by the United States under Article 24 of the Convention on the Territorial Sea and the Contiguous Zone.

Continuous discharge means a “discharge” which occurs without interruption throughout the operating hours of the facility except for infrequent shutdowns for maintenance, process changes, or similar activities.

CWA means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972) Pub. L. 92-500, as amended by Pub. L. 95-217, Pub. L. 95-576, Pub. L. 96-483, and Pub. L. 97-117; 33 USC §§1251 et seq.

Daily Discharge means the discharge of a pollutant measured during the calendar day or any other 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

Director normally means the person authorized to sign NPDES permits by EPA or the State or an authorized representative. Conversely, it also could mean the Regional Administrator or the State Director as the context requires.

Discharge Monitoring Report Form (DMR) means the EPA standard national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by “approved States” as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA’s.

Discharge of a pollutant means:

- (a) Any addition of any “pollutant” or combination of pollutants to “waters of the United States” from any “point source”, or
- (b) Any addition of any pollutant or combination of pollutants to the waters of the “contiguous zone” or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation (See “Point Source” definition).

This definition includes additions of pollutants into waters of the United States from: surface runoff which is collected or channeled by man; discharges through pipes, sewers, or other conveyances owned by a State, municipality, or other person which do not lead

NPDES PART II STANDARD CONDITIONS

(January, 2007)

to a treatment works; and discharges through pipes, sewers, or other conveyances leading into privately owned treatment works.

This term does not include an addition of pollutants by any “indirect discharger.”

Effluent limitation means any restriction imposed by the Regional Administrator on quantities, discharge rates, and concentrations of “pollutants” which are “discharged” from “point sources” into “waters of the United States”, the waters of the “contiguous zone”, or the ocean.

Effluent limitation guidelines means a regulation published by the Administrator under Section 304(b) of CWA to adopt or revise “effluent limitations”.

EPA means the United States “Environmental Protection Agency”.

Flow-weighted composite sample means a composite sample consisting of a mixture of aliquots where the volume of each aliquot is proportional to the flow rate of the discharge.

Grab Sample – An individual sample collected in a period of less than 15 minutes.

Hazardous Substance means any substance designated under 40 CFR Part 116 pursuant to Section 311 of the CWA.

Indirect Discharger means a non-domestic discharger introducing pollutants to a publicly owned treatment works.

Interference means a discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (a) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (b) Therefore is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act (CWA), the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resources Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to Subtitle D of the SDWA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection Research and Sanctuaries Act.

Landfill means an area of land or an excavation in which wastes are placed for permanent disposal, and which is not a land application unit, surface impoundment, injection well, or waste pile.

Land application unit means an area where wastes are applied onto or incorporated into the soil surface (excluding manure spreading operations) for treatment or disposal.

Large and Medium municipal separate storm sewer system means all municipal separate storm sewers that are either: (i) located in an incorporated place (city) with a population of 100,000 or more as determined by the latest Decennial Census by the Bureau of Census (these cities are listed in Appendices F and 40 CFR Part 122); or (ii) located in the counties with unincorporated urbanized

NPDES PART II STANDARD CONDITIONS

(January, 2007)

populations of 100,000 or more, except municipal separate storm sewers that are located in the incorporated places, townships, or towns within such counties (these counties are listed in Appendices H and I of 40 CFR 122); or (iii) owned or operated by a municipality other than those described in Paragraph (i) or (ii) and that are designated by the Regional Administrator as part of the large or medium municipal separate storm sewer system.

Maximum daily discharge limitation means the highest allowable “daily discharge” concentration that occurs only during a normal day (24-hour duration).

Maximum daily discharge limitation (as defined for the Steam Electric Power Plants only) when applied to Total Residual Chlorine (TRC) or Total Residual Oxidant (TRO) is defined as “maximum concentration” or “Instantaneous Maximum Concentration” during the two hours of a chlorination cycle (or fraction thereof) prescribed in the Steam Electric Guidelines, 40 CFR Part 423. These three synonymous terms all mean “a value that shall not be exceeded” during the two-hour chlorination cycle. This interpretation differs from the specified NPDES Permit requirement, 40 CFR § 122.2, where the two terms of “Maximum Daily Discharge” and “Average Daily Discharge” concentrations are specifically limited to the daily (24-hour duration) values.

Municipality means a city, town, borough, county, parish, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian tribe organization, or a designated and approved management agency under Section 208 of the CWA.

National Pollutant Discharge Elimination System means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318, and 405 of the CWA. The term includes an “approved program”.

New Discharger means any building, structure, facility, or installation:

- (a) From which there is or may be a “discharge of pollutants”;
- (b) That did not commence the “discharge of pollutants” at a particular “site” prior to August 13, 1979;
- (c) Which is not a “new source”; and
- (d) Which has never received a finally effective NPDES permit for discharges at that “site”.

This definition includes an “indirect discharger” which commences discharging into “waters of the United States” after August 13, 1979. It also includes any existing mobile point source (other than an offshore or coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas developmental drilling rig) such as a seafood processing rig, seafood processing vessel, or aggregate plant, that begins discharging at a “site” for which it does not have a permit; and any offshore rig or coastal mobile oil and gas exploratory drilling rig or coastal mobile oil and gas developmental drilling rig that commences the discharge of pollutants after August 13, 1979, at a “site” under EPA’s permitting jurisdiction for which it is not covered by an individual or general permit and which is located in an area determined by the Regional Administrator in the issuance of a final permit to be in an area of biological concern. In determining whether an area is an area of biological concern, the Regional Administrator shall consider the factors specified in 40 CFR §§125.122 (a) (1) through (10).

NPDES PART II STANDARD CONDITIONS (January, 2007)

An offshore or coastal mobile exploratory drilling rig or coastal mobile developmental drilling rig will be considered a “new discharger” only for the duration of its discharge in an area of biological concern.

New source means any building, structure, facility, or installation from which there is or may be a “discharge of pollutants”, the construction of which commenced:

- (a) After promulgation of standards of performance under Section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with Section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal.

NPDES means “National Pollutant Discharge Elimination System”.

Owner or operator means the owner or operator of any “facility or activity” subject to regulation under the NPDES programs.

Pass through means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation).

Permit means an authorization, license, or equivalent control document issued by EPA or an “approved” State.

Person means an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

Point Source means any discernible, confined, and discrete conveyance, including but not limited to any pipe ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel, or other floating craft, from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff (see 40 CFR §122.2).

Pollutant means dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials (except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. §§2011 et seq.)), heat, wrecked or discarded equipment, rock, sand, cellar dirt and industrial, municipal, and agricultural waste discharged into water. It does not mean:

- (a) Sewage from vessels; or
- (b) Water, gas, or other material which is injected into a well to facilitate production of oil or gas, or water derived in association with oil and gas production and disposed of in a well, if the well is used either to facilitate production or for disposal purposes is approved by the authority of the State in which the well is located, and if the State determines that the injection or disposal will not result in the degradation of ground or surface water resources.

NPDES PART II STANDARD CONDITIONS
(January, 2007)

Primary industry category means any industry category listed in the NRDC settlement agreement (Natural Resources Defense Council et al. v. Train, 8 E.R.C. 2120 (D.D.C. 1976), modified 12 E.R.C. 1833 (D. D.C. 1979)); also listed in Appendix A of 40 CFR Part 122.

Privately owned treatment works means any device or system which is (a) used to treat wastes from any facility whose operation is not the operator of the treatment works or (b) not a “POTW”.

Process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

Publicly Owned Treatment Works (POTW) means any facility or system used in the treatment (including recycling and reclamation) of municipal sewage or industrial wastes of a liquid nature which is owned by a “State” or “municipality”.

This definition includes sewers, pipes, or other conveyances only if they convey wastewater to a POTW providing treatment.

Regional Administrator means the Regional Administrator, EPA, Region I, Boston, Massachusetts.

Secondary Industry Category means any industry which is not a “primary industry category”.

Section 313 water priority chemical means a chemical or chemical category which:

- (1) is listed at 40 CFR §372.65 pursuant to Section 313 of the Emergency Planning and Community Right-To-Know Act (EPCRA) (also known as Title III of the Superfund Amendments and Reauthorization Act (SARA) of 1986);
- (2) is present at or above threshold levels at a facility subject to EPCRA Section 313 reporting requirements; and
- (3) satisfies at least one of the following criteria:
 - (i) are listed in Appendix D of 40 CFR Part 122 on either Table II (organic priority pollutants), Table III (certain metals, cyanides, and phenols), or Table V (certain toxic pollutants and hazardous substances);
 - (ii) are listed as a hazardous substance pursuant to Section 311(b)(2)(A) of the CWA at 40 CFR §116.4; or
 - (iii) are pollutants for which EPA has published acute or chronic water quality criteria.

Septage means the liquid and solid material pumped from a septic tank, cesspool, or similar domestic sewage treatment system, or a holding tank when the system is cleaned or maintained.

Sewage Sludge means any solid, semisolid, or liquid residue removed during the treatment of municipal wastewater or domestic sewage. Sewage sludge includes, but is not limited to, solids removed during primary, secondary, or advanced wastewater treatment, scum, septage, portable toilet pumpings, Type III Marine Sanitation Device pumpings (33 CFR Part 159), and sewage sludge products. Sewage sludge does not include grit or screenings, or ash generated during the incineration of sewage sludge.

NPDES PART II STANDARD CONDITIONS
(January, 2007)

Sewage sludge use or disposal practice means the collection, storage, treatment, transportation, processing, monitoring, use, or disposal of sewage sludge.

Significant materials includes, but is not limited to: raw materials, fuels, materials such as solvents, detergents, and plastic pellets, raw materials used in food processing or production, hazardous substance designated under section 101(14) of CERCLA, any chemical the facility is required to report pursuant to EPCRA Section 313, fertilizers, pesticides, and waste products such as ashes, slag, and sludge that have the potential to be released with storm water discharges.

Significant spills includes, but is not limited to, releases of oil or hazardous substances in excess of reportable quantities under Section 311 of the CWA (see 40 CFR §110.10 and §117.21) or Section 102 of CERCLA (see 40 CFR § 302.4).

Sludge-only facility means any “treatment works treating domestic sewage” whose methods of sewage sludge use or disposal are subject to regulations promulgated pursuant to Section 405(d) of the CWA, and is required to obtain a permit under 40 CFR §122.1(b)(3).

State means any of the 50 States, the District of Columbia, Guam, the Commonwealth of Puerto Rico, the Virgin Islands, American Samoa, the Trust Territory of the Pacific Islands.

Storm Water means storm water runoff, snow melt runoff, and surface runoff and drainage.

Storm water discharge associated with industrial activity means the discharge from any conveyance which is used for collecting and conveying storm water and which is directly related to manufacturing, processing, or raw materials storage areas at an industrial plant. (See 40 CFR §122.26 (b)(14) for specifics of this definition.

Time-weighted composite means a composite sample consisting of a mixture of equal volume aliquots collected at a constant time interval.

Toxic pollutants means any pollutant listed as toxic under Section 307 (a)(1) or, in the case of “sludge use or disposal practices” any pollutant identified in regulations implementing Section 405(d) of the CWA.

Treatment works treating domestic sewage means a POTW or any other sewage sludge or wastewater treatment devices or systems, regardless of ownership (including federal facilities), used in the storage, treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated for the disposal of sewage sludge. This definition does not include septic tanks or similar devices.

For purposes of this definition, “domestic sewage” includes waste and wastewater from humans or household operations that are discharged to or otherwise enter a treatment works. In States where there is no approved State sludge management program under Section 405(f) of the CWA, the Regional Administrator may designate any person subject to the standards for sewage sludge use and disposal in 40 CFR Part 503 as a “treatment works treating domestic sewage”, where he or she finds that there is a potential for adverse effects on public health and the environment from poor sludge quality or poor sludge handling, use or disposal practices, or where he or she finds that such designation is necessary to ensure that such person is in compliance with 40 CFR Part 503.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

Waste Pile means any non-containerized accumulation of solid, non-flowing waste that is used for treatment or storage.

Waters of the United States means:

- (a) All waters which are currently used, were used in the past, or may be susceptible to use in interstate or foreign commerce, including all waters which are subject to the ebb and flow of tide;
- (b) All interstate waters, including interstate “wetlands”;
- (c) All other waters such as intrastate lakes, rivers, streams (including intermittent streams), mudflats, sandflats, “wetlands”, sloughs, prairie potholes, wet meadows, playa lakes, or natural ponds the use, degradation, or destruction of which would affect or could affect interstate or foreign commerce including any such waters:
 - (1) Which are or could be used by interstate or foreign travelers for recreational or other purpose;
 - (2) From which fish or shellfish are or could be taken and sold in interstate or foreign commerce; or
 - (3) Which are used or could be used for industrial purposes by industries in interstate commerce;
- (d) All impoundments of waters otherwise defined as waters of the United States under this definition;
- (e) Tributaries of waters identified in Paragraphs (a) through (d) of this definition;
- (f) The territorial sea; and
- (g) “Wetlands” adjacent to waters (other than waters that are themselves wetlands) identified in Paragraphs (a) through (f) of this definition.

Waste treatment systems, including treatment ponds or lagoons designed to meet the requirements of the CWA (other than cooling ponds as defined in 40 CFR §423.11(m) which also meet the criteria of this definition) are not waters of the United States.

Wetlands means those areas that are inundated or saturated by surface or ground water at a frequency and duration to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole Effluent Toxicity (WET) means the aggregate toxic effect of an effluent measured directly by a toxicity test. (See Abbreviations Section, following, for additional information.)

2. Definitions for NPDES Permit Sludge Use and Disposal Requirements.

Active sewage sludge unit is a sewage sludge unit that has not closed.

NPDES PART II STANDARD CONDITIONS

(January, 2007)

Aerobic Digestion is the biochemical decomposition of organic matter in sewage sludge into carbon dioxide and water by microorganisms in the presence of air.

Agricultural Land is land on which a food crop, a feed crop, or a fiber crop is grown. This includes range land and land used as pasture.

Agronomic rate is the whole sludge application rate (dry weight basis) designed:

- (1) To provide the amount of nitrogen needed by the food crop, feed crop, fiber crop, cover crop, or vegetation grown on the land; and
- (2) To minimize the amount of nitrogen in the sewage sludge that passes below the root zone of the crop or vegetation grown on the land to the ground water.

Air pollution control device is one or more processes used to treat the exit gas from a sewage sludge incinerator stack.

Anaerobic digestion is the biochemical decomposition of organic matter in sewage sludge into methane gas and carbon dioxide by microorganisms in the absence of air.

Annual pollutant loading rate is the maximum amount of a pollutant that can be applied to a unit area of land during a 365 day period.

Annual whole sludge application rate is the maximum amount of sewage sludge (dry weight basis) that can be applied to a unit area of land during a 365 day period.

Apply sewage sludge or sewage sludge applied to the land means land application of sewage sludge.

Aquifer is a geologic formation, group of geologic formations, or a portion of a geologic formation capable of yielding ground water to wells or springs.

Auxiliary fuel is fuel used to augment the fuel value of sewage sludge. This includes, but is not limited to, natural gas, fuel oil, coal, gas generated during anaerobic digestion of sewage sludge, and municipal solid waste (not to exceed 30 percent of the dry weight of the sewage sludge and auxiliary fuel together). Hazardous wastes are not auxiliary fuel.

Base flood is a flood that has a one percent chance of occurring in any given year (i.e. a flood with a magnitude equaled once in 100 years).

Bulk sewage sludge is sewage sludge that is not sold or given away in a bag or other container for application to the land.

Contaminate an aquifer means to introduce a substance that causes the maximum contaminant level for nitrate in 40 CFR §141.11 to be exceeded in ground water or that causes the existing concentration of nitrate in the ground water to increase when the existing concentration of nitrate in the ground water exceeds the maximum contaminant level for nitrate in 40 CFR §141.11.

Class I sludge management facility is any publicly owned treatment works (POTW), as defined in 40 CFR §501.2, required to have an approved pretreatment program under 40 CFR §403.8 (a) (including any POTW located in a state that has elected to assume local program responsibilities pursuant to 40 CFR §403.10 (e) and any treatment works treating domestic sewage, as defined in 40 CFR § 122.2,

NPDES PART II STANDARD CONDITIONS

(January, 2007)

classified as a Class I sludge management facility by the EPA Regional Administrator, or, in the case of approved state programs, the Regional Administrator in conjunction with the State Director, because of the potential for sewage sludge use or disposal practice to affect public health and the environment adversely.

Control efficiency is the mass of a pollutant in the sewage sludge fed to an incinerator minus the mass of that pollutant in the exit gas from the incinerator stack divided by the mass of the pollutant in the sewage sludge fed to the incinerator.

Cover is soil or other material used to cover sewage sludge placed on an active sewage sludge unit.

Cover crop is a small grain crop, such as oats, wheat, or barley, not grown for harvest.

Cumulative pollutant loading rate is the maximum amount of inorganic pollutant that can be applied to an area of land.

Density of microorganisms is the number of microorganisms per unit mass of total solids (dry weight) in the sewage sludge.

Dispersion factor is the ratio of the increase in the ground level ambient air concentration for a pollutant at or beyond the property line of the site where the sewage sludge incinerator is located to the mass emission rate for the pollutant from the incinerator stack.

Displacement is the relative movement of any two sides of a fault measured in any direction.

Domestic septage is either liquid or solid material removed from a septic tank, cesspool, portable toilet, Type III marine sanitation device, or similar treatment works that receives only domestic sewage. Domestic septage does not include liquid or solid material removed from a septic tank, cesspool, or similar treatment works that receives either commercial wastewater or industrial wastewater and does not include grease removed from a grease trap at a restaurant.

Domestic sewage is waste and wastewater from humans or household operations that is discharged to or otherwise enters a treatment works.

Dry weight basis means calculated on the basis of having been dried at 105 degrees Celsius (°C) until reaching a constant mass (i.e. essentially 100 percent solids content).

Fault is a fracture or zone of fractures in any materials along which strata on one side are displaced with respect to the strata on the other side.

Feed crops are crops produced primarily for consumption by animals.

Fiber crops are crops such as flax and cotton.

Final cover is the last layer of soil or other material placed on a sewage sludge unit at closure.

Fluidized bed incinerator is an enclosed device in which organic matter and inorganic matter in sewage sludge are combusted in a bed of particles suspended in the combustion chamber gas.

Food crops are crops consumed by humans. These include, but are not limited to, fruits, vegetables, and tobacco.

NPDES PART II STANDARD CONDITIONS
(January, 2007)

Forest is a tract of land thick with trees and underbrush.

Ground water is water below the land surface in the saturated zone.

Holocene time is the most recent epoch of the Quaternary period, extending from the end of the Pleistocene epoch to the present.

Hourly average is the arithmetic mean of all the measurements taken during an hour. At least two measurements must be taken during the hour.

Incineration is the combustion of organic matter and inorganic matter in sewage sludge by high temperatures in an enclosed device.

Industrial wastewater is wastewater generated in a commercial or industrial process.

Land application is the spraying or spreading of sewage sludge onto the land surface; the injection of sewage sludge below the land surface; or the incorporation of sewage sludge into the soil so that the sewage sludge can either condition the soil or fertilize crops or vegetation grown in the soil.

Land with a high potential for public exposure is land that the public uses frequently. This includes, but is not limited to, a public contact site and reclamation site located in a populated area (e.g., a construction site located in a city).

Land with low potential for public exposure is land that the public uses infrequently. This includes, but is not limited to, agricultural land, forest and a reclamation site located in an unpopulated area (e.g., a strip mine located in a rural area).

Leachate collection system is a system or device installed immediately above a liner that is designed, constructed, maintained, and operated to collect and remove leachate from a sewage sludge unit.

Liner is soil or synthetic material that has a hydraulic conductivity of 1×10^{-7} centimeters per second or less.

Lower explosive limit for methane gas is the lowest percentage of methane gas in air, by volume, that propagates a flame at 25 degrees Celsius and atmospheric pressure.

Monthly average (Incineration) is the arithmetic mean of the hourly averages for the hours a sewage sludge incinerator operates during the month.

Monthly average (Land Application) is the arithmetic mean of all measurements taken during the month.

Municipality means a city, town, borough, county, parish, district, association, or other public body (including an intermunicipal agency of two or more of the foregoing entities) created by or under State law; an Indian tribe or an authorized Indian tribal organization having jurisdiction over sewage sludge management; or a designated and approved management agency under section 208 of the CWA, as amended. The definition includes a special district created under state law, such as a water district, sewer district, sanitary district, utility district, drainage district, or similar entity, or an integrated waste management facility as defined in section 201 (e) of the CWA, as amended, that has as one of its principal responsibilities the treatment, transport, use or disposal of sewage sludge.

NPDES PART II STANDARD CONDITIONS (January, 2007)

Other container is either an open or closed receptacle. This includes, but is not limited to, a bucket, a box, a carton, and a vehicle or trailer with a load capacity of one metric ton or less.

Pasture is land on which animals feed directly on feed crops such as legumes, grasses, grain stubble, or stover.

Pathogenic organisms are disease-causing organisms. These include, but are not limited to, certain bacteria, protozoa, viruses, and viable helminth ova.

Permitting authority is either EPA or a State with an EPA-approved sludge management program.

Person is an individual, association, partnership, corporation, municipality, State or Federal Agency, or an agent or employee thereof.

Person who prepares sewage sludge is either the person who generates sewage sludge during the treatment of domestic sewage in a treatment works or the person who derives a material from sewage sludge.

pH means the logarithm of the reciprocal of the hydrogen ion concentration; a measure of the acidity or alkalinity of a liquid or solid material.

Place sewage sludge or sewage sludge placed means disposal of sewage sludge on a surface disposal site.

Pollutant (as defined in sludge disposal requirements) is an organic substance, an inorganic substance, a combination of organic and inorganic substances, or pathogenic organism that, after discharge and upon exposure, ingestion, inhalation, or assimilation into an organism either directly from the environment or indirectly by ingestion through the food chain, could on the basis of information available to the Administrator of EPA, cause death, disease, behavioral abnormalities, cancer, genetic mutations, physiological malfunctions (including malfunction in reproduction) or physical deformations in either organisms or offspring of the organisms.

Pollutant limit (for sludge disposal requirements) is a numerical value that describes the amount of a pollutant allowed per unit amount of sewage sludge (e.g., milligrams per kilogram of total solids); the amount of pollutant that can be applied to a unit of land (e.g., kilograms per hectare); or the volume of the material that can be applied to the land (e.g., gallons per acre).

Public contact site is a land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.

Qualified ground water scientist is an individual with a baccalaureate or post-graduate degree in the natural sciences or engineering who has sufficient training and experience in ground water hydrology and related fields, as may be demonstrated by State registration, professional certification, or completion of accredited university programs, to make sound professional judgments regarding ground water monitoring, pollutant fate and transport, and corrective action.

Range land is open land with indigenous vegetation.

Reclamation site is drastically disturbed land that is reclaimed using sewage sludge. This includes, but is not limited to, strip mines and construction sites.

NPDES PART II STANDARD CONDITIONS (January, 2007)

Risk specific concentration is the allowable increase in the average daily ground level ambient air concentration for a pollutant from the incineration of sewage sludge at or beyond the property line of a site where the sewage sludge incinerator is located.

Runoff is rainwater, leachate, or other liquid that drains overland on any part of a land surface and runs off the land surface.

Seismic impact zone is an area that has 10 percent or greater probability that the horizontal ground level acceleration to the rock in the area exceeds 0.10 gravity once in 250 years.

Sewage sludge is a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works. Sewage sludge includes, but is not limited to: domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment processes; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in treatment works.

Sewage sludge feed rate is either the average daily amount of sewage sludge fired in all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located for the number of days in a 365 day period that each sewage sludge incinerator operates, or the average daily design capacity for all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located.

Sewage sludge incinerator is an enclosed device in which only sewage sludge and auxiliary fuel are fired.

Sewage sludge unit is land on which only sewage sludge is placed for final disposal. This does not include land on which sewage sludge is either stored or treated. Land does not include waters of the United States, as defined in 40 CFR §122.2.

Sewage sludge unit boundary is the outermost perimeter of an active sewage sludge unit.

Specific oxygen uptake rate (SOUR) is the mass of oxygen consumed per unit time per unit mass of total solids (dry weight basis) in sewage sludge.

Stack height is the difference between the elevation of the top of a sewage sludge incinerator stack and the elevation of the ground at the base of the stack when the difference is equal to or less than 65 meters. When the difference is greater than 65 meters, stack height is the creditable stack height determined in accordance with 40 CFR §51.100 (ii).

State is one of the United States of America, the District of Columbia, the Commonwealth of Puerto Rico, the Virgin Islands, Guam, American Samoa, the Trust Territory of the Pacific Islands, the Commonwealth of the Northern Mariana Islands, and an Indian tribe eligible for treatment as a State pursuant to regulations promulgated under the authority of section 518(e) of the CWA.

Store or storage of sewage sludge is the placement of sewage sludge on land on which the sewage sludge remains for two years or less. This does not include the placement of sewage sludge on land for treatment.

Surface disposal site is an area of land that contains one or more active sewage sludge units.

NPDES PART II STANDARD CONDITIONS (January, 2007)

Total hydrocarbons means the organic compounds in the exit gas from a sewage sludge incinerator stack measured using a flame ionization detection instrument referenced to propane.

Total solids are the materials in sewage sludge that remain as residue when the sewage sludge is dried at 103 to 105 degrees Celsius.

Treat or treatment of sewage sludge is the preparation of sewage sludge for final use or disposal. This includes, but is not limited to, thickening, stabilization, and dewatering of sewage sludge. This does not include storage of sewage sludge.

Treatment works is either a federally owned, publicly owned, or privately owned device or system used to treat (including recycle and reclaim) either domestic sewage or a combination of domestic sewage and industrial waste of a liquid nature.

Unstable area is land subject to natural or human-induced forces that may damage the structural components of an active sewage sludge unit. This includes, but is not limited to, land on which the soils are subject to mass movement.

Unstabilized solids are organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Vector attraction is the characteristic of sewage sludge that attracts rodents, flies, mosquitoes, or other organisms capable of transporting infectious agents.

Volatile solids is the amount of the total solids in sewage sludge lost when the sewage sludge is combusted at 550 degrees Celsius in the presence of excess air.

Wet electrostatic precipitator is an air pollution control device that uses both electrical forces and water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

Wet scrubber is an air pollution control device that uses water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

3. Commonly Used Abbreviations

BOD	Five-day biochemical oxygen demand unless otherwise specified
CBOD	Carbonaceous BOD
CFS	Cubic feet per second
COD	Chemical oxygen demand
Chlorine	
Cl ₂	Total residual chlorine
TRC	Total residual chlorine which is a combination of free available chlorine (FAC, see below) and combined chlorine (chloramines, etc.)

NPDES PART II STANDARD CONDITIONS
(January, 2007)

TRO	Total residual chlorine in marine waters where halogen compounds are present
FAC	Free available chlorine (aqueous molecular chlorine, hypochlorous acid, and hypochlorite ion)
Coliform	
Coliform, Fecal	Total fecal coliform bacteria
Coliform, Total	Total coliform bacteria
Cont. (Continuous)	Continuous recording of the parameter being monitored, i.e. flow, temperature, pH, etc.
Cu. M/day or M ³ /day	Cubic meters per day
DO	Dissolved oxygen
kg/day	Kilograms per day
lbs/day	Pounds per day
mg/l	Milligram(s) per liter
ml/l	Milliliters per liter
MGD	Million gallons per day
Nitrogen	
Total N	Total nitrogen
NH ₃ -N	Ammonia nitrogen as nitrogen
NO ₃ -N	Nitrate as nitrogen
NO ₂ -N	Nitrite as nitrogen
NO ₃ -NO ₂	Combined nitrate and nitrite nitrogen as nitrogen
TKN	Total Kjeldahl nitrogen as nitrogen
Oil & Grease	Freon extractable material
PCB	Polychlorinated biphenyl
pH	A measure of the hydrogen ion concentration. A measure of the acidity or alkalinity of a liquid or material
Surfactant	Surface-active agent

NPDES PART II STANDARD CONDITIONS
(January, 2007)

Temp. °C	Temperature in degrees Centigrade
Temp. °F	Temperature in degrees Fahrenheit
TOC	Total organic carbon
Total P	Total phosphorus
TSS or NFR	Total suspended solids or total nonfilterable residue
Turb. or Turbidity	Turbidity measured by the Nephelometric Method (NTU)
ug/l	Microgram(s) per liter
WET	“Whole effluent toxicity” is the total effect of an effluent measured directly with a toxicity test.
C-NOEC	“Chronic (Long-term Exposure Test) – No Observed Effect Concentration”. The highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specified time of observation.
A-NOEC	“Acute (Short-term Exposure Test) – No Observed Effect Concentration” (see C-NOEC definition).
LC ₅₀	LC ₅₀ is the concentration of a sample that causes mortality of 50% of the test population at a specific time of observation. The LC ₅₀ = 100% is defined as a sample of undiluted effluent.
ZID	Zone of Initial Dilution means the region of initial mixing surrounding or adjacent to the end of the outfall pipe or diffuser ports.

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
NEW ENGLAND - REGION I
5 POST OFFICE SQUARE, SUITE 100
BOSTON, MASSACHUSETTS 02109-3912**

FACT SHEET

DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
PERMIT TO DISCHARGE TO WATERS OF THE UNITED STATES PURSUANT TO THE
CLEAN WATER ACT (CWA)

NPDES PERMIT NUMBER: **MA0000531**

PUBLIC NOTICE START AND END DATES: August 1, 2017 – August 30, 2017

NAME AND MAILING ADDRESS OF APPLICANT:

**Boston Sand & Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114**

ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

**500 Front Street
Charlestown, MA 02129**

RECEIVING WATER: Unnamed Tributary to the Charles River (“Millers River”, Outfall 001)

CLASSIFICATION: Class B

SIC CODE: 3273 (Ready-Mix Concrete)

Table of Contents

1.0	PROPOSED ACTION, TYPE OF FACILITY AND DISCHARGE LOCATION	5
1.1	Proposed Action.....	5
1.2	Type of Facility and Discharge Location.....	5
1.2.1	On-site Water Management	6
1.2.2	Wastewater Treatment	7
1.2.3	Raw Material Storage.....	8
1.2.4	Concrete Production.....	9
1.2.5	Truck Wash-Out and Wash-Off.....	10
1.2.6	Returned Concrete.....	10
1.2.7	Vehicle Fueling	11
1.2.8	Extreme Weather Management.....	11
2.0	RECEIVING WATER DESCRIPTION	12
2.1	Classification.....	12
2.2	Water Quality Assessment.....	12
3.0	PERMIT BASIS: STATUTORY AND REGULATORY AUTHORITY	15
3.1	General Background	15
3.2	Technology-Based Requirements	15
3.3	Water Quality-Based Requirements.....	16
3.3.1	Reasonable Potential Analysis	16
3.3.2	Antidegradation.....	16
3.4	Antibacksliding	17
4.0	DESCRIPTION OF OUTFALLS	17
4.1	Outfall 001	17
4.2	Internal Outfall 002.....	18
5.0	PROPOSED EFFLUENT LIMITATIONS, CONDITIONS	18
5.1	Outfall 001	18
5.1.1	Flow	18
5.1.2	pH.....	18
5.1.3	Total Suspended Solids (TSS)	19
5.1.4	Turbidity	20
5.1.5	Oil & Grease	20
5.1.6	Sulfate	21

5.1.7	Copper.....	21
5.1.8	Chromium VI.....	24
5.1.9	Aluminum	25
5.1.10	Phosphorus.....	25
5.1.11	<i>E. Coli</i>	27
5.1.12	Whole Effluent Toxicity (WET) Testing	27
5.1.13	Other Pollutants of Potential Concern.....	29
5.2	Internal Outfall 002.....	30
5.2.1	Oil & Grease	30
5.2.2	Removal of the Internal Outfall	30
5.3	Special Conditions	30
5.3.1	Stormwater Pollution Prevention Plan (SWPPP).....	30
5.3.2	Phosphorus Control Plan.....	31
5.3.3	Source Identification and Reduction Plan.....	32
5.4	Compliance Schedules	32
6.0	MONITORING AND REPORTING.....	33
7.0	OTHER LEGAL REQUIREMENTS	33
7.1	Essential Fish Habitat	33
7.2	Endangered Species Act.....	35
7.3	State Certification Requirements	36
7.4	Public Comment Period, Public Hearing Requests, and Procedures for Final Decision	36
8.0	EPA AND MASS DEP CONTACTS.....	37

LIST OF ATTACHMENTS

- A – Aerial Photo of Facility
- B – Process Diagram
- C – Facility Drainage Areas
- D – Chemical and Chemical Additive Summary
- E – Summary of DMR Data
- F – WET Limit Calculation
- G – EFH Species for Area that Includes Boston Inner Harbor

1.0 PROPOSED ACTION, TYPE OF FACILITY AND DISCHARGE LOCATION

1.1 Proposed Action

The above named applicant has applied to the U.S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) for the re-issuance of a National Pollutant Discharge Elimination System (NPDES) permit to discharge stormwater and process water into the designated receiving water. The permit last issued to Boston Sand and Gravel became effective on September 28, 2007 and expired on August 31, 2012. EPA received a permit renewal application from Boston Sand and Gravel on March 1, 2012. Since the permit renewal application was deemed timely and complete by EPA, the permit has been administratively continued.

1.2 Type of Facility and Discharge Location

Boston Sand and Gravel Company (BS&G) operates two facilities in Charlestown, Massachusetts: a Ready-Mix Concrete Plant (“the Concrete Plant”) located at 500 Front Street and a vehicle maintenance garage located at 40 Bunker Hill Industrial Park Drive. Although the Concrete Plant’s address is in Charlestown, a majority of the site area is located in Cambridge, Massachusetts. An aerial photograph of the facility is located in Attachment A.

Ready-mix concrete batching operations which occur at the Concrete Plant involve raw material storage, concrete production, truck wash-off and drum wash-out, waste disposal and recycling, vehicle fueling, water recycling, and wastewater treatment operations as described below and provided in the facility’s Process Diagram (Attachment B).

Process water commingled with stormwater is treated by settling, chemical treatment and clarification at the Concrete Plant’s wastewater treatment facility (WWTF), prior to final discharge to the Unnamed Tributary (known locally as “Millers River”). Activities at the maintenance garage are conducted within an enclosed facility such that there is no exposure of industrial activities and related pollution to stormwater at the garage. Inside the garage building, any water from the vehicles flows to internal floor drains which connect to an oil/water separator. The separator then discharges to the MWRA wastewater system. The separator is inspected by BS&G employees on a monthly basis and these inspection reports are included in an oil/water separator database as part of MWRA’s Toxic Reduction and Control program (TRAC). Since the garage is a separate, non-contiguous facility with no outdoor activities that could result in exposure of stormwater to industrial activities, BS&G submitted a no exposure certification for the garage. Stormwater and process water permitting requirements for other areas of the site where industrial activities are occurring will be addressed under this individual NPDES permit.

The majority of the land at the site is covered by overhead highways (Interstate 93) which capture the majority of the stormwater that would otherwise fall on the site beneath. The

stormwater runoff which falls on the overhead structures is conveyed through the stormwater management system for the highways. However, during large storms, stormwater from the overhead highway overflows onto the site below. The site is comprised of primarily impervious surface areas and is divided into seven drainage areas as delineated in Attachment C. Dust control is performed throughout the site.

The site is bordered on the northwestern edge by a chain link fence adjacent to the Massachusetts Bay Transportation Authority (MBTA) commuter rail tracks. The MBTA Commuter Rail Maintenance Facility (CRMF) is also covered by a NPDES permit (MA0003590) and also discharges to the same Unnamed Tributary of the Charles River as Boston Sand & Gravel's facility. At the time of the March 2016 site visit, approximately one half-acre of the Boston Sand & Gravel site was used for MBTA Green Line Extension project activities. Green Line Extension project activity in the surrounding areas was halted in October 2016 due to funding issues. Construction is scheduled to resume in 2018 but this date is subject to change. The approximately 0.5 acre temporary construction area was fenced off but stormwater runoff appeared to pond and discharge underneath a chain link fence that surrounded it. This non-BS&G discharge could have commingled with stormwater and process water from the facility. Maintenance for Interstate 93 highway viaducts, performed as necessary by MassDOT, occasionally also occurs on-site. There were no current maintenance activities occurring at the time of the site visit in late March, 2016. Ducts from the above highway are routed to grates and connected underground conveyances that discharge to the Unnamed Tributary.

Discharges of stormwater and process water at the Concrete Plant will be covered under this individual permit. BS&G previously obtained a Multi-Sector General Permit (MSGP) for stormwater discharge from the Concrete Plant, however this MSGP coverage was terminated in 2009.

1.2.1 On-site Water Management

Stormwater and process water commingle on-site. Impervious surface is graded so that water flows to three "Low Points". Most of the site area is impervious, except for the area around the rail tracks on the northwestern border, the area surrounding bulk storage of aggregate materials (i.e. sand and stone), and a northeasterly portion of the site that includes storage of concrete blocks and employee parking. These three pervious areas are designed for infiltration.

Water that collects in Low Points is pumped and/or recycled through a series of treatment lagoons, and then routed to the WWTF for final treatment. Refer to Attachment B for the Process Diagram and the location of the three Low Points.

Low Point #1 (LP1) is located on an access road bisecting the site underneath Interstate 93. A process/stormwater collection sump, a process/stormwater recycle tank (the Recycle Tank), and a sweeper sediment collection bin are in the vicinity of LP1. Water collected at LP1 is pumped either to the Recycle Tank or the truck washoff areas. Low Point #2 (LP2) is located nearby the Clearwater Pit in the northwestern portion of the site, which includes the truck washout area, the solids drying area, a truck washoff area, the rail lines, and the truck fueling area. Commingled process and stormwater can be pumped from LP2 to the other two low points if desired. Any

stormwater and process water that trickles into the conveyor belt tunnel at the Concrete Plant is also directed to LP2. Low Point #3 (LP3) is located adjacent to a Wastewater Treatment Facility (WWTF) that includes a block house building containing chemical mixing and treatment tanks and three exterior settling lagoons). A second truck washoff area is located by the Concrete Plant and the WWTF.

Recycling of on-site water is performed using the Clearwater Pit and the Recycle Tank. The Recycle Tank is also used in truck drum washout and concrete products manufacturing. Settling of solids occurs during water recycling and partially contributes to treatment of solids prior to the WWTF.

The Clearwater Pit is a concrete holding tank containing water from wash-off of residue from mixer trucks. The trucks are rinsed off over an impervious area and the wash water flows, along with any stormwater collected over the impervious area, through shallow tanks where solids settle, to the Clearwater Pit. The water from both pits may be reused as truck washout water. Water is pumped from the Clearwater pit to the Recycle Tank. The Recycle Tank acts as a holding vessel prior to pumping the recycled water into the manufacturing process. Recycle Tank water is pumped to the Concrete Plant as needed. Any excess water in the Recycle Tank may be pumped directly to LP3 to begin treatment in Lagoon 7. Potable water is used when there is insufficient recycled process water and stormwater necessary for operations.

Locations of drainage areas on the site, potential pollutants and risks associated with these drainage areas, and MSGP recommendations that apply to the facility operations are discussed in the SWPPP as required by Part I.C of the permit and Section 5.3.1. of this fact sheet. See Attachment C for the location of site drainage areas.

1.2.2 Wastewater Treatment

The WWTF consists of three settling basins (Lagoons 7, 8, and 9) and a block house building containing pumps, piping, a 2-chamber 1,800 gallon mixing tank, and treatment chemicals. Process water and commingled stormwater are treated at the block house building by the process of settling, chemical treatment, and clarification (for suspended solids and turbidity control), and pH neutralization. A certified WWTP operator (257 CMR 2.00) operates the wastewater treatment system and pumps are inspected daily.

The influent to the WWTF consists of water pumped from two low points, LP1 and LP2, which combines with the water from LP3 located near the WWTF. Boiler blowdown occurs in a building adjacent to the QA/QC lab and is discharged to LP1, is pumped into the recycle system at the Clearwater Pit (LP2) and eventually directed to the WWTF. Boiler blowdown is a minimal contribution to the final discharge.

Wastewater from LP3 is conveyed to Lagoon 7 where both flow equalization and primary solids settling is accomplished. The maximum holding capacity of Lagoon 7 is 14,300 gallons. A minimal amount of water dripping from mobile ice trucks is also directed to Lagoon 7. The water from Lagoon 7 is pumped to a 2-chamber 1,800 gallon tank inside the block house building where chemical addition (ferric chloride coagulant, hydrochloric acid, and polymer) promotes

the flocculation of suspended solids. The wastewater transfer pump is controlled by an automatic float system which activates the pump when the water in Lagoon 7 reaches a set level (approximately 3,000 – 4,000 gallons per pump cycle). Coagulant and polymer injection pumps turn on automatically when the wastewater transfer pump starts. The coagulant and polymer pumps are set to deliver doses established during wastewater treatability studies, but may be manually adjusted to handle changes in solids loading. Additionally, a pump connected to a pH controller injects acid to neutralize the wastewater whenever the controller set point is reached. Hydrochloric acid is stored in a 1,500 gallon tank outside the block house building and is delivered twice annually. A permanent employee at the facility, who is a licensed operator, performs manual adjustments and manages the efficiency of batch treatment and improvements for the WWTF.

The maximum holding capacity of Lagoon 8 is 17,900 gallons. Flocculated solids settle in Lagoon 8. When the water reaches a set level in Lagoon 8, it is pumped back through the block house building and into Lagoon 9, where additional settling of any solids occurs. A pH probe in the block house building is connected to a controller that activates an alarm and shuts off the pump if the pH measures outside of the prescribed limits. Flow between Lagoons 8 and 9, in addition to pH, is continuously monitored within the block house building. Lagoon 9 holds 4,100 gallons and discharges by gravity through a 12” ductile iron pipe to the Unnamed Tributary.

Settled solids are periodically removed from Lagoons 7, 8, and 9 and recycled for use in road base or other products.

Treated wastewater discharged for all of 2015 totaled 983,000 gallons and 1,140,000 gallons for 2016. An average 1.9 million gallons was discharged per year from 2007 to 2016 and the discharge for 2017 is expected to be similar. Concrete production in 2015 totaled 595,000 tons and 603,000 tons in 2016. Total concrete production is projected to be 715,000 tons for 2017, and water use for 2017 is expected to be 19 million gallons based upon production forecasts. Approximately 7% of water used at the site (1.1 million gallons) is recycled based on estimates for 2015 and 2016.

Sanitary wastewater from the dispatch building is contained in a septic tank equipped with a high level alarm. The tank is regularly pumped out by a commercial septic service provider and the wastewater is trucked off-site.

1.2.3 Raw Material Storage

Raw materials used in the production of ready-mix concrete at the facility include a variety of fine and coarse aggregate, Portland cement, other cementitious materials such as fly ash and ground granulated blast furnace slag, and concrete additives.

Coarse and fine aggregate are received at the facility by truck or rail car and offloaded and stockpiled at the southern portion of the site at the aggregate material storage area. A conveyor belt runs in a tunnel underneath the stockpiled materials. A gate is opened to allow the materials to fall onto the conveyor for transport to enclosed hoppers, where the dry material is stored until it is metered into a ready-mix concrete batch. The portions of the stockpile that are located under

Interstate 93 are not exposed to stormwater, whereas the remaining portions are exposed to stormwater. Since the aggregate material storage area is pervious, most stormwater is absorbed by the stockpiled materials. The minimal amount of stormwater that enters the conveyor tunnel through the gate is pumped to LP3 at the WWTF. Any stormwater runoff from the stockpile areas is also directed to the WWTF. Concrete walls constructed of pre-cast concrete blocks surround the stockpile perimeter and are used to separate different grades of aggregate material.

Portland cement, fly ash, and slag are received at the facility by tanker truck and stored in silos until the material is metered into a ready-mix concrete batch. Concrete additives such as water-reducing agents, air-entraining agents, and/or setting agents may be added to a ready-mix batch to enhance the concrete properties. Liquid concrete additives are stored in aboveground tanks on the ground and second floor in the Concrete Plant. Solid additives such as polymeric fibers are delivered in smaller bags which are stored in a covered area and not exposed to stormwater. BS&G uses enclosed silos and bins to store these materials. Bulk deliveries utilize enclosed transport vehicles which offload by pneumatic conveying. Dust entrained in the air exhaust is cleaned by baghouse-type dust collectors. A summary of chemicals and chemical additives used for cement product and process and stormwater treatment are included in Attachment D.

The Plant's use of cement and fly ash in concrete production also triggers the EPCRA (Emergency Planning and Community Right-to-Know Act) Section 313 thresholds for persistent bioaccumulative toxins (PBTs), namely lead and mercury. Muriatic acid (hydrochloric acid) is subject to state reporting only. These materials are stored and used in drainage areas 2, 3, and 7 (Attachment C).

Ice chips prepared from potable water for use in ready-mix concrete production are stored in mobile trailers outside the Plant dispatch area. A dumpster for general refuse is also located in a northwestern corner of the site and is not exposed to stormwater as it is located underneath the highway.

1.2.4 Concrete Production

The facility produces ready-mixed concrete (hereafter referred to as concrete). Basic components of concrete are coarse aggregate, fine aggregate, cement, and water. The aggregate functions as a filler material and is bound together by hardened cement paste formed by the hydration of cement. In addition to these basic components, supplementary cementitious materials and chemical admixtures are often used to enhance or modify properties of the fresh or hardened concrete.

Ready-mix batches are prepared based on industry standards for varying classifications of concrete. Additives to delay setting of the final concrete product may be combined with raw materials. Raw materials for each batch are metered into a central mix drum above the truck awaiting loading at the filling location nearby the Concrete Plant. The materials are mixed inside a central mix drum and poured into the hopper of the mixer truck drum for delivery.

The Concrete Plant and the two associated aggregate conveyors are located in the southwestern portion of the site. Aggregate storage bins with concrete retention walls contain sand and gravel

at the southernmost portion of the site. A dielectric transformer maintained by Eversource is located next the shipping office adjacent to the Concrete Plant. The outdoor transformer is staged on a concrete pad.

Concrete is batched to the mixer trucks at the Concrete Plant northwest of the WWTF and nearby the aggregate storage bins.

1.2.5 Truck Wash-Out and Wash-Off

Wastewater from truck washing is generated in two process operations: external truck wash-off prior to delivery and internal drum wash-out upon the return of the truck from the job site. The primary designated truck wash area is located adjacent to LP2 and the Clearwater Pit. The area has an impervious surface with a bermed area to collect truck wash-out and chute wash-off. The area is sloped such that exterior truck wash-off collects and flows to LP2 or a ramp adjacent to LP1 which is then pumped to either LP2 or LP3. A secondary exterior truck rinsing area is located adjacent to the WWTF at LP3. Wastewater generated at the designated truck wash area is collected in a settling basin at LP2 and either recycled (used for mixer truck drum wash-out and as available, used in concrete production) or transferred to the influent lagoon at the WWTF. Rinsing conducted at LP3 flows by gravity to Lagoon 7 for subsequent treatment at the WWTF.

After a ready-mix batch has been added to the truck drum and prior to shipment to the job site, the truck exterior is rinsed at the designated truck wash area or at the wash rack located at LP3 adjacent to the WWTF. Exterior rinsing of the truck is performed to remove residual materials from the outside of the truck's drum and chute. The rinsing prevents adherence of the residuals to the truck and drum, as well as release to the environment outside of the facility. Although no surfactants are used in the rinsing, acid wash may be used, which is applied to the truck exterior with a spray bottle and rinsed off with water.

At the end of the work day (and occasionally between certain concrete loads) the drum of the mixer truck is rinsed out. The truck exterior rinsing and interior drum wash-out occurs in the designated truck wash area located adjacent to LP2 in the northwestern portion of the site. Recycled process water from the Clearwater Pit at LP2 is added to the truck drum while it is rotating in order to remove the residual concrete inside the drum. No surfactants are used for drum wash-out.

1.2.6 Returned Concrete

Upon return of the truck to the Plant, unused concrete may be reused to manufacture pre-cast retaining blocks or recycled by ribbon feed drying the concrete. Pre-cast retaining blocks are either sold, or used at the facility to construct partitions for the separation of materials and to erect semi-permanent walls for the protection of site features from truck traffic. Ribbon feed drying involves discharge of the concrete in narrow rows, also referred to as "ribbons," onto the ground in a designated area for drying. When the ribbons are partially dry, a front-end loader is used to break the material into small pieces which are stockpiled and then shipped off-site for further sizing to prepare the material for off-site use such as road base.

1.2.7 Vehicle Fueling

Two 10,000 gallon underground storage tanks (USTs) are in use at the facility, one for gasoline and the other for diesel fuel. They are located, along with the fueling equipment, between the boiler room/QC building and the Clearwater Pit (LP2). Filling and fueling of all vehicles occurs on impervious surfaces. Spill response equipment is located throughout the site. A Spill Pollution Control Plan (SPCC) detailing fuel spill pollution control procedures for the facility is kept, along with a Stormwater Pollution Prevention Plan (SWPPP), at the office building on the non-contiguous maintenance facility lot. Vehicle storage, maintenance, and cleaning occurs at the maintenance facility and associated discharges are not covered under this permit.

1.2.8 Extreme Weather Management

Sheetflow only occurs during extreme precipitation or in case of frozen ground. In the event of extreme stormy or icy weather, concrete production is shut down and discharges from the WWTF are ceased. The WWTF operator is responsible for severe event preparation and impacts on process and stormwater discharge. Site managers plan for severe weather events, and if necessary, a licensed operator of the WWTF comes on-site in order to treat commingled stormwater and process water during and after extreme weather events regardless of whether production has ceased. Generally, wastewater treatment is necessary with greater than approximately one half inch of precipitation (the “first flush” of stormwater) and more treatment is required with heavier flows. There is sufficient holding capacity in both the treatment lagoons and the site (drainage areas 1 and 5 in Attachment C) in order to manage additional volume from a 100-year storm event. Frac tanks for additional water storage will be brought to the facility when on-site water storage capacity is expected to be exceeded. Removal of solids from treatment lagoons (Lagoons 7, 8, and 9) during maintenance is performed only in dry weather. Ice on the rail tracks due to cold weather can derail cars transporting raw materials to the facility. Propane flame torches are used for deicing to prevent derailment and associated material spills.

2.0 RECEIVING WATER DESCRIPTION

2.1 Classification

The receiving water for Outfall 001, the Unnamed Tributary (locally known as “Millers River”), is designated as Class B. Class B waters are designated as a habitat for fish, other aquatic life, and wildlife, including for their reproduction, migration, growth and other critical functions, and for primary and secondary contact recreation. Class B waters must also maintain “consistently good aesthetic value”, according to 314 CMR 4.05(3)(b).

Section 303(d) of the Clean Water Act (CWA) requires states to identify those waterbodies that are not expected to meet surface water quality standards after the implementation of technology-based controls and, as such, require the development of total maximum daily loads (TMDL). According to the *Final Massachusetts Year 2014 Integrated List of Waters*, the Unnamed Tributary (segment ID MA72-31) is classified as a water requiring a TMDL¹. The river segment is defined from the emergence near Route 93, Cambridge/Boston, to the confluence with the Charles River in Cambridge. It is approximately 0.207 miles long. The impairment causes are foam/flocs/scum/oil slicks, petroleum hydrocarbons, polychlorinated biphenyls, polycyclic aromatic hydrocarbons, sedimentation/siltation, and taste and odor, as well as other causes designated as “Other” (“Other” causes include unspecified metals). Non-pollutant impairments to bottom deposits and stream habitat are also listed for this water, but these impairments do not trigger a TMDL requirement.

2.2 Water Quality Assessment

The 2002-2006 Massachusetts Water Quality Assessment report for the Unnamed Tributary to the Charles River Watershed notes that urban stormwater runoff, the NPDES discharges, and discharges from municipal separate storm sewer systems are likely sources of pollution to the water². According to the same report, withdrawals and discharges include those from the MBTA Commuter Rail facility (NPDES permit MA0003590), this facility (Boston Sand and Gravel Company (NPDES permit MA0000531)), and the Boston Water and Sewer Commission (NPDES stormwater permit MAS010001). A use assessment was also performed as part of the 2002-2006 water quality assessment, and the assessment was primarily based on information from the earlier 2000 water quality assessment³. Aquatic life, primary and secondary contact recreation, and aesthetic uses were assessed as impaired due to degraded habitat, sediment quality, and aesthetic conditions. Ongoing stormwater runoff, urban runoff, and discharges from local permitted facilities are cited as contributing to these conditions. No fish were found during 2002 electrofishing during the data collection effort for the report and fish consumption use specifically for this waterbody was not assessed at the time of the report. However, state-wide safe eating guidelines from the Massachusetts Department of Public Health include the

¹ MassDEP. 2016. <http://www.mass.gov/eea/docs/dep/water/resources/07v5/14list2.pdf>

² MassDEP. 2008. Charles River Watershed 2002-2006 Water Quality Assessment Report.

³ Fiorentino, J.F., L.E. Kennedy, and M.J. Weinstein. 2000. Charles River Watershed 1997/1998 Water Quality Assessment Report. Massachusetts Department of Environmental Protection, Division of Watershed Management. Worcester, MA.

recommendation that pregnant women, women who may become pregnant, nursing mothers and children under 12 years old should not eat freshwater fish caught in any streams, rivers, lakes, and ponds in Massachusetts (including the Unnamed Tributary).

A Final Phosphorus TMDL for the Lower Charles River Basin⁴ and a Final Pathogen TMDL for the Charles River Watershed⁵ have been completed. For the watershed areas that discharge to tributaries of the Lower Charles, all water segments, except the upper watershed above the Watertown dam and combined sewer areas not slated for sewer separation, are subject to a Waste Load Allocation (WLA) of a 62% reduction in phosphorus. The Final Pathogen TMDL requires that facilities that discharge to the Charles River, including to tributaries of the Charles, take an iterative approach to identifying and eliminating illicit discharge connections.

The Boston Water and Sewer Commission's annual reports submitted as part of the requirements of the 1999 City of Boston Municipal Separate Storm Sewer System (MS4) permit provide an example of the iterative approach to reducing water pollutants. The annual reports summarize progress made in reducing stormwater pollutant loads through BMPs and specifically through illicit discharge elimination. The area just upstream of the Unnamed Tributary is included as a sub-catchment area in the 2015 annual report. The following two tables are excerpts from the 2015 annual report and summarize the estimated 2015 annual loads as well as the 2012-2013 estimated loads reduced for pollutants including Total Phosphorus and *E. Coli* for the Unnamed Tributary (Millers River).

⁴ <http://www.mass.gov/eea/docs/dep/water/resources/a-thru-m/charlesp.pdf>

⁵ <http://www.mass.gov/eea/docs/dep/water/resources/a-thru-m/charles1.pdf>

**Table 1. BWSC 2012 Stormwater Model:
2015 Mean Annual Pollutant Loads for the Unnamed Tributary⁶**

Drainage Area	Mean Flow (annual)	BOD5	COD	TKN	Nitrate-Nitrite as N	Ammonia as N	Total Phosphorus
Acres	cfs	lb/year					
208	1.57	15,716	65,888	1,891	3,732	575	383

Ortho-phosphate as P	Total Copper	Total Zinc	TSS	E. Coli	Enterococcus	Fecal Coliform
lb/year				10 ⁹ cfu/year		
60	18	76	29,967	119,979	88,372	95,414

Table 2. Annual Load Reduction for the Unnamed Tributary Based on Illicit Discharge Removal in 2012 and 2013⁷

Drainage Area	Number of Illicits Removed	Flow Removed	Total Phosphorus Removed	E. Coli Removed	Enterococcus Removed	Fecal Coliform Removed
Acres		GPD	lb/year	10 ⁹ cfu/year		
208	1	27	1	316	32	607

⁶ Excerpt from Table 7-1 in Boston Water and Sewer Commission. 2015. 2015 Annual Stormwater Management Report (for MS4 NPDES permit compliance).

⁷ Estimates based on 2007-2009 precipitation using BWSC precipitation gage network; no illicit discharges removed for the Unnamed Tributary in 2014 and 2015; excerpt from Table 7-2 in Boston Water and Sewer Commission. 2015. 2015 Annual Stormwater Management Report (for MS4 NPDES permit compliance).

3.0 PERMIT BASIS: STATUTORY AND REGULATORY AUTHORITY

3.1 General Background

The CWA prohibits the discharge of pollutants to waters of the United States without a NPDES permit unless such a discharge is otherwise authorized by the CWA. The NPDES permit is the mechanism used to implement technology-based effluent limitations (TBELs), water quality-based effluent limitations (WQBELs) and other requirements including monitoring and reporting. The draft permit was developed in accordance with various statutory and regulatory requirements established pursuant to the CWA and applicable State regulations. During development, EPA considered the most recent technology-based treatment requirements and water quality-based requirements. The regulations governing the EPA NPDES permit program are generally found at 40 CFR Parts 122, 124, 125, and 136. The general conditions of the draft permit are based on 40 CFR §122.41 and consist primarily of management requirements common to all permits. The effluent monitoring requirements have been established to yield data representative of the discharge under authority of Section 308(a) of the CWA in accordance with 40 CFR §122.41(j), §122.44(i), and §122.48.

3.2 Technology-Based Requirements

Subpart A of 40 CFR §125 establishes criteria and standards for the imposition of technology-based treatment requirements in permits under Section 301(b) of the CWA, including the application of EPA promulgated effluent limitations and case-by-case determinations of effluent limitations under Section 402(a)(1) of the CWA.

Technology-based treatment requirements represent the minimum level of control that must be imposed under Sections 301(b) and 402 of the CWA (see 40 CFR §125 Subpart A) to meet best practicable control technology currently available (BPT) for conventional pollutants and some metals, best conventional control technology (BCT) for conventional pollutants, and best available technology economically available (BAT) for toxic and non-conventional pollutants. In general, technology-based effluent guidelines for non-POTW facilities must have been complied with as expeditiously as practicable but in no case later than three years after the date such limitations are established and in no case later than March 31, 1989. *See* 40 CFR §125.3(a)(2). Compliance schedules and deadlines not in accordance with the statutory provisions of the CWA cannot be authorized by a NPDES permit.

EPA has promulgated technology-based National Effluent Limitation Guidelines (ELGs) for wastewater from certain mineral mining and processing facilities under 40 CFR §436. Sand and gravel operations at facilities like Boston Sand & Gravel fall under the subcategory C of this Part (construction sand and gravel). The ELG limits the effluent pH of process wastewaters and mine dewatering discharges to a range of 6.0 to 9.0 SU. pH is the only pollutant in the applicable ELG. Additionally, 40 CFR §436.32(b) states that “any overflow from facilities governed by this subpart shall not be subject to the limitations of paragraph (a) [pH] of this section if the facilities

are designed, constructed and maintained to contain or treat the volume of waste water which would result from a 10-year 24-hour precipitation event.”

3.3 Water Quality-Based Requirements

Section 301(b)(1)(C) of the CWA requires that effluent limitations based on water quality considerations be established for point source discharges when such limitations are necessary to meet state or federal water quality standards that are applicable to the designated receiving water. This is necessary when technology-based limitations would interfere with the attainment or maintenance of water quality in the receiving water. Under Section 301(b)(1)(C) of the CWA and EPA regulations, NPDES permits must contain effluent limits more stringent than technology-based limits where more stringent limits are necessary to maintain or achieve state or federal water quality standards.

Water quality standards consist of three parts: (1) beneficial designated uses for a waterbody or a segment of a waterbody; (2) numeric and/or narrative water quality criteria sufficient to protect the assigned designated use(s); and (3) antidegradation requirements to ensure that once a use is attained it will not be degraded. The Massachusetts Surface Water Quality Standards, found at 314 CMR 4.00, include these elements. The state will limit or prohibit discharges of pollutants to surface waters to assure that surface water quality standards of the receiving waters are protected and maintained or attained. These standards also include requirements for the regulation and control of toxic constituents and require that EPA criteria, established pursuant to Section 304(a) of the CWA, shall be used unless a site specific criterion is established.

3.3.1 Reasonable Potential Analysis

The draft permit must limit any pollutant or pollutant parameter (conventional, non-conventional, and toxic) that is or may be discharged at a level that causes or has the “reasonable potential” to cause or contribute to an excursion above any water quality standard. *See* 40 CFR §122.44(d). An excursion occurs if the projected or actual in-stream concentration exceeds an applicable water quality criterion. In determining “reasonable potential”, EPA considers: (1) existing controls on point and non-point sources of pollution; (2) pollutant concentration and variability in the effluent and receiving water as determined from the permit's re-issuance application, monthly discharge monitoring reports (DMRs), and State and Federal Water Quality Reports; (3) sensitivity of the indicator species used in toxicity testing; (4) known water quality impacts of processes on waste waters; and (5) where appropriate, dilution of the effluent in the receiving water.

3.3.2 Antidegradation

Federal regulations found at 40 CFR §131.12 require states to develop and adopt a statewide antidegradation policy which maintains and protects existing instream water uses and the level of water quality necessary to protect the existing uses, and maintains the quality of waters which exceed levels necessary to support propagation of fish, shellfish, and wildlife and to support recreation in and on the water. The Massachusetts Antidegradation Regulations, found at 314 CMR 4.04, apply to any new or increased activity that would lower water quality or affect

existing or designated uses, including increased loadings to a waterbody from an existing activity. All existing instream uses and the level of water quality necessary to protect the existing uses of the receiving waters shall be maintained and protected.

No new or increased discharges have been proposed by the permittee. This draft permit is being reissued with allowable effluent limits as stringent or more stringent than the previous permit and accordingly will continue to protect the existing uses of the Unnamed Tributary (Millers River). Therefore, MassDEP is not required to conduct an antidegradation review as part of this permit reissuance.

3.4 Antibacksliding

A permit may not be renewed, reissued or modified with less stringent limitations or conditions than those contained in the previous permit unless in compliance with the anti-backsliding requirements of the CWA [see Sections 402(o) and 303(d)(4) of the CWA and 40 CFR §122.44(l)(1 and 2)]. EPA's antibacksliding provisions prohibit the relaxation of permit limits, standards, and conditions except under certain circumstances. Effluent limits based on BPJ, water quality, and state certification requirements must also meet the antibacksliding provisions found at Section 402(o) and 303(d)(4) of the CWA. All proposed permit conditions are at least as stringent as those found in the current permit. Therefore, the draft permit complies with the antibacksliding requirements of the CWA.

4.0 DESCRIPTION OF OUTFALLS

4.1 Outfall 001

The discharge from Outfall 001 consists of a combination of stormwater runoff, road sweeping water, and truck wash-off and wash-out water. All stormwater and process water is either treated at the WWTF prior to discharge to the Unnamed Tributary, or recycled on-site for use in making concrete and flowable fill.

The drainage at the site is such that the process water and stormwater combine and collect at three water accumulation areas or Low Points (LP1, LP2, and LP3), as shown in Attachment B. The water from LP1 and LP2 is pumped to LP3, near the WWTF, for subsequent treatment prior to discharge.

Process water and commingled stormwater are treated at the WWTF prior to final discharge to the Unnamed Tributary. Treated wastewater is discharged as overflow from Lagoon 9 via Outfall 001 when the pump from Lagoon 8 to Lagoon 9 turns on and the effective capacity of Lagoon 9 is exceeded. With the exception of flow monitoring, the discharge is sampled for permit parameters in Lagoon 9 after previous treatment, as close as practicable to the overflow, but prior to the overflow discharge to the Unnamed Tributary. The location in Lagoon 9, as close as practicable to the overflow, was chosen as the Outfall 001 sampling location because the discharge point to the Unnamed Tributary is not easily accessible and is considered unsafe for

routine sampling. The flow from Lagoon 8 to 9 is monitored by a continuous flow monitor inside the block house building.

4.2 Internal Outfall 002

The internal sampling location was deemed to be representative of boiler blowdown water and was associated with an Oil & Grease monthly monitoring requirement in the current permit. The monitoring requirement has been removed from the draft permit (See Section 5.2).

5.0 PROPOSED EFFLUENT LIMITATIONS, CONDITIONS

A monitoring data summary report for Outfall 001 is included in Attachment E. Regular water quality monitoring for Outfall 001 is identified by outfall code 001A and WET test results at Outfall 001 are identified by DMR outfall code 001T. Monthly hardness measurements for the receiving water are identified by DMR outfall code 001 – Receiving Water.

5.1 Outfall 001

Outfall 001 effluent contains both process water and stormwater as these commingle on-site.

5.1.1 Flow

The maximum daily flow from 2007 to 2015 was 280,000 GPD. Mean flow for the same time period was 5573 GPD (calculated as the mean of all reported average monthly flows). There were 2 recorded instances of no discharge in February 2012 and February 2015. The requirement to report daily maximum flow and report monthly average flow has been retained in this permit.

5.1.2 pH

The Massachusetts Surface Water Quality Standards [MA SWQS; 314 CMR 4.05 (3)(b)3] require that the pH of the receiving water be in the range of 6.5 to 8.3 standard units (SU) and no more than 0.5 units outside the background range (the applicable ELG-based limitation of pH of 6.0 to 9.0 is less stringent). Additionally, the State standards require that there shall be no change from background conditions that would impair any use assigned to this Class. The water quality criteria have been adopted as discharge limitations based on certification requirements under Section 401(a)(1) of the CWA, as described in 40 CFR §124.53 and §124.55. Therefore, the pH range limit of 6.0 to 8.5 SU contained in the existing permit is replaced with the more stringent range of 6.5 to 8.3, with the requirement that pH should be no more than 0.5 SU outside the background range.

Review of the DMR data reveals that the monthly effluent pH did not violate the permitted pH range of 6.0 to 8.5 SU, or the more stringent range of 6.5 to 8.3 by more than 0.5 units. Based on these data, the monitoring frequency is retained at once per month.

5.1.3 Total Suspended Solids (TSS)

In the absence of published technology-based effluent limitation guidelines (ELG) or if an ELG exists but it doesn't address and didn't consider a pollutant of concern in its development, the permit writer is authorized under CWA §402(a)(1)(B) to establish effluent limitations on a case-by-case basis using best professional judgment (BPJ). EPA conducted a site-specific BPJ analysis to determine the appropriate technology-based effluent limit (TBEL) for the permit as there is no applicable ELG for TSS⁸ for the discharge (§125.3(c)(2)). The current permit includes a maximum daily TSS limit of 45 mg/L and a monthly average TSS limit of 20 mg/L.

Review of the DMR data reveals that the TSS effluent limitations were exceeded twice and generally were far below the daily maximum and monthly average limits. In December 2013, the highest TSS values of 21 mg/L for the monthly average and 48 mg/L for the daily maximum, respectively, were recorded.

An effective influent concentration of 100 mg/L of TSS to the series of settling ponds and the WWTF at the facility (the "current treatment system") can be assumed based on the National Urban Runoff Program median concentration often cited in the MSGP. Stormwater BMPs are expected to achieve at least 80% effectiveness⁹. Using the assumed influent concentration of 100 mg/L, combined with the monthly average discharge concentrations recorded in the DMR from October 2007 to December 2015, an average TSS treatment efficiency of 96% in the commingled stormwater and process water effluent is calculated. Therefore, the current treatment system for TSS at the facility is considered sufficient to meet the current maximum daily limit of 45 mg/L.

EPA's Quality Criteria for Water, 1986 (the Gold Book¹⁰) cites many potential problems associated with high suspended solids and turbidity in a waterbody, including harm to pelagic and benthic organisms; reduced primary production and ecosystem health; and safety issues for swimming and other recreational uses of the waterbody. In addition, pollutants such as toxic metals and phosphorus are likely to be adsorbed onto sediment particles. National as well as state water quality criteria are narrative for solids and turbidity. The Massachusetts water quality standards for Class B waters at 314 CMR 4.05(3)(b)5 require that:

[t]hese waters shall be free from floating, suspended, and settleable solids in concentrations and combinations that would impair any use assigned to this Class, that would cause aesthetically objectionable conditions, or that would impair the benthic biota or degrade the chemical composition of the bottom.

⁸ Federal Register notice of the Mineral Mining and Processing Point Source Category: Revocation of BPT Regulations and the final amendment to the rule is available at

https://www.epa.gov/sites/production/files/2015-09/documents/mineral-mining_bpt_44-fr-76793_12-28-1979.pdf

⁹ EPA Office of Water. 1999. Preliminary Data Summary of Urban Storm Water Best Management Practices. EPA-821-R-99-012.

¹⁰ Available at:

http://water.epa.gov/scitech/swguidance/standards/criteria/aqlife/upload/2009_01_13_criteria_goldbook.pdf

The Gold Book proposes the same criteria for solids as EPA's 1972 Water Quality Criteria report¹¹. Prescriptive requirements for recreation and aesthetics recommend managing solids with reference to waterbody historical/baseline data. In order to provide a high level of protection to aquatic organisms, EPA recommends a suspended solids level of 25 mg/L. A high level of protection is appropriate for the discharge based on the receiving waterbody impairments. Thus a monthly average TSS limit of 25 mg/L or less is sufficient to ensure the discharge does not cause or contribute to a water quality standards violation.

Based on the facility's ability to treat solids in their discharge with their current technology and to avoid backsliding, the monthly average TSS limit shall be retained at 20 mg/L, and the daily maximum limit shall be retained at 45 mg/L, with a weekly monitoring requirement.

5.1.4 Turbidity

The Massachusetts Surface Water Quality Standards (MA SWQS) under 314 CMR 4.05(3)(b)(6) require that Class B waters shall be free from turbidity in concentrations or combinations that are aesthetically objectionable or would impair any use assigned to this Class. Turbidity of water is related to the amount of suspended and colloidal material present in the water column. Aside from the aesthetic problems of color that a turbid discharge can create, turbidity reduces water clarity; therefore, the penetration of light into that water column is reduced, negatively impacting the growth and life cycles of various aquatic species (plants and animals). In order to minimize this turbidity, an average monthly limit 25 NTU is retained from the existing permit in the draft permit, as well as a requirement to report the maximum daily turbidity. Similar limits (20 – 25 NTU) have been required in permits for sand and gravel operations. Maintaining this limit is also in accordance with the anti-backsliding requirements found in 40 CFR §122.44(l).

Review of the DMR data reveals that the 25 NTU average monthly turbidity limit was not exceeded during the last decade. Therefore, EPA has determined that sampling frequency for turbidity shall be reduced in this permit from once per week to once per month.

5.1.5 Oil & Grease

Petroleum hydrocarbons are associated with fuel leaks and spills that may occur at the facility. Thus, there is reasonable potential for petroleum hydrocarbons to be present in the discharge. The impairment causes for the Unnamed Tributary also include oil slicks and petroleum hydrocarbons.

¹¹ The National Academy of Science (NAS) and the National Academy of Engineering (NAE), who prepared this report, appointed a Committee on Water Quality Criteria, six Panels, and an Environmental Studies Board. This document is available at:
<http://nepis.epa.gov/Exe/ZyNET.exe/2000XOYT.TXT?ZyActionD=ZyDocument&Client=EPA&Index=Prior+to+1976&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C70thru75%5CTxt%5C00000003%5C2000XOYT.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=p%7Cf&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL>

Historically, Oil & Grease was the primary petroleum related parameter used in many of EPA Region 1's individual NPDES permits and is a common parameter in many of EPA's promulgated industrial effluent guidelines. Daily maximum Oil & Grease is frequently limited to 15 mg/L in order to be protective of Class B narrative MA SWQS.

EPA reviewed Oil & Grease monitoring data from December 2007 through December 2015 from this facility. Oil & Grease was detected only once, at a value of 4.6 mg/L (September 2008). The remaining monitoring results (32 samples) were recorded below the detection limit. Therefore, the Oil & Grease parameter is included in this draft permit with a maximum daily limit of 15 mg/L. EPA establishes this TBEL using BPJ-based performance information from this facility. The BPJ limit of 15 mg/L is also protective of water quality standards.

In addition, Total Petroleum Hydrocarbons (TPH) shall be monitored monthly in order to evaluate the petroleum content of the Oil & Grease monitored at this facility. Massachusetts test methods for volatile petroleum hydrocarbons (VPH) and extractable petroleum hydrocarbons (EPH) may not be used for TPH analysis as they are not approved CWA methods.

5.1.6 Sulfate

The current permit continued a Total Sulfate limit of 250 mg/L. There are no current Effluent Limit Guidelines that apply to this facility with regards to Total Sulfate. However, sulfate is present in this facility's discharge as it is inherent in the Ready-Mix Concrete product formulations. Controlling sulfate in the discharge may assist with reducing copper concentrations as there is some evidence that copper may be associated with sulfate during wastewater treatment at the facility (See Section 5.1.7). The Secondary Maximum Contaminant Level (SMCL) for Total Sulfate is also 250 mg/L. The SMCL is used as a guideline for public water systems in managing aesthetic considerations for drinking water and a concentration at or above 250 mg/L of Total Sulfate is known to induce a salty taste¹².

Review of the DMR data reveals that the previous average monthly Total Sulfate limit of 250 mg/L was exceeded 1 time in June 2009. Therefore, the Total Sulfate limit shall be retained at 250 mg/L to avoid backsliding. The monitoring and reporting frequency shall also be continued at monthly. As the Unnamed Tributary is impaired for taste and odor, retaining the Total Sulfate limit at 250 mg/L would also ensure that MA SWQS continue to be met.

5.1.7 Copper

Boston Sand & Gravel analyzed the Pearson correlation coefficients of metals and other monitored parameters as part of the Metals Reduction study included in the 2012 NPDES permit reapplication. Copper was not correlated with TSS but weakly correlated to hardness and was inversely correlated with temperature. Copper is also somewhat correlated with Total Sulfate (with a Pearson correlation coefficient of 0.324). Boston Sand & Gravel expects interaction of metals and metal binding agents in the treatment system to potentially impact further metals removal efforts. According to the source analysis testing performed on stormwater from loop

¹² <https://www.epa.gov/dwstandardsregulations/secondary-drinking-water-standards-guidance-nuisance-chemicals>

overflow (highway runoff), lightweight product, pea stone product, and tap water in August 2011, concentrations of copper were found to be 38.8 µg/L, 2.9 µg/L, 3.4 µg/L, and 42.7 µg/L respectively. Recycle water tested at a concentration of 17.6 µg/L in September 2011. Based on this limited set of data, the source of copper in the effluent is expected to be predominantly external based on the relatively high concentrations of copper found in tap water and highway runoff relative to product leachate.

Nine BMPs for the reduction of metals, including copper, were considered by the permittee since the issuance of the current permit (see Table 3). The current permit required the development BMPs as TBELs as there was no reasonable potential to cause or contribute to a violation of MA SWQS at the time. These BMPs are included in attachments to the permit application from 2012. The first eight BMPs have been implemented and are part of a continuous improvement cycle. A plan to seal plumbing leaks and install a fill-stop to prevent overflows of hot water during cold months (BMP #2) was specifically expected to reduce copper concentrations. BMP #9, a plan to install a float switch and timer to increase hold time and improve the efficiency of treatment, has not been implemented to date. Copper concentrations in the DMR monitoring data range from 2.3 µg/L to 153 µg/L and have not markedly decreased over time.

Table 3 – Permittee’s Metals Reduction BMPs to Date

BMP Number	Metal Affected	BMP Description	Implementation Date
1	Aluminum	Convert treatment coagulant from polyaluminum chloride to ferric chloride	October 2007
2	Copper	Seal plumbing leaks, install fill-stop to prevent overflows of hot water during cold months	Ongoing
3	All metals	Install variable frequency drives on treatment plant motors to obtain better slow-flow treatment control and improve floc settling	October 2008
4	All metals	Install pump inlet chamber to reduce particulate uptake into the treatment process	August 2010
5	All metals	Hold treatment pH at high end of permit range (8 - 8.5) to improve precipitation of metals	2012
6	All metals	Raise the height of the float set points to lengthen holding time	2012
7	All metals	Increase treatment plant settled solids removal frequency	2012
8	All metals	Schedule treatment for hours when primary settling has been undisturbed	2012
9	All metals	Install float switch and timer to increase hold time and improve efficiency of treatment	automation recommended, will improve control over BMP 8

The reported metals concentrations are expressed as total recoverable fraction in the water column. However, the National Recommended Water Quality Criteria for Copper is expressed as total dissolved fraction in the water column. In order to directly compare the National Recommended Water Quality Criteria for Copper to the measured values in the DMR, the National Recommended Water Quality Criteria must be converted to total recoverable fraction in the water column. Pollutant specific conversion factors are used for converting a metal criterion expressed as the dissolved fraction in the water column to a criterion expressed as the total recoverable fraction in the water column. The equations and constants for determining the water quality criteria for each metal and the conversion factors and equation parameters are listed in EPA's *National Recommended Water Quality Criteria* as published in the Federal Register on December 10, 1998 (63 FR 68354) and updated November 2002 (USEPA 2002).

Review of the DMR data reveals that the receiving water hardness from the DMR data ranged from 37 mg/L to 480 mg/L and the median hardness was 160 mg/L. The total recoverable copper freshwater chronic criterion was calculated as 18.4 µg/L and the total recoverable acute criterion was calculated as 28.8 µg/L using a representative hardness of 160 mg/L and a conversion factor of 0.96¹³, as follows:

$$WQC_{\text{metal}} = \exp[a * \ln(H) + b]$$

Metal-specific constants *a* and *b* are defined as part of the water quality criterion WQC_{metal} and *H* is the representative hardness. For copper in freshwater systems, the constants *a* and *b* are:

Table 4 – Water Quality Copper Criteria Constants

Copper	<i>a</i>	<i>B</i>
Chronic Criteria (µg/L)	0.8545	-1.465
Acute Criteria (µg/L)	0.9422	-1.464

The conversion factor of 0.96 converts the dissolved water quality criterion WQC_{metal} to a total recoverable copper limit.

EPA considers the available dilution when determining reasonable potential and water quality based limitations (WQBELs) in a NPDES permit. The low flow of the Unnamed Tributary would afford very little dilution to this discharge. Therefore, EPA is assuming zero dilution for the Unnamed Tributary receiving water for this facility and the daily maximum WQBEL will be set at the acute criterion value. With the non-intermittent discharge of commingled process water and stormwater, the monthly average WQBEL is also set at the chronic criterion value.

The chronic criterion was exceeded 57 times and the acute criterion was exceeded 33 times, and there is reasonable potential for copper to cause or contribute to an excursion of water quality standards. Therefore, monitoring shall be retained at monthly, the monthly average Total Recoverable Copper limit shall be 18 µg/L, and the daily maximum limit shall be 29 µg/L.

¹³ Dissolved vs. total recoverable metal calculations based on The Metals Translator: Guidance for Calculating a Total Recoverable Permit Limit from Dissolved Criterion. USEPA, 1996.

Additionally, the permittee shall review new and existing BMPs that could reduce the amount of Total Recoverable Copper in the effluent as part of the Source Identification and Reduction Plan (See Section 5.3.3).

In establishing a monthly average limit for copper, as well as chromium (VI) and aluminum as described below, EPA considered the frequency and nature of the Outfall 001 discharge and the associated aquatic life exposures. EPA recognizes that storm events varying in intensity and duration can impact the water quality and volume of the discharge at this facility. Acute exposures of the effluent are typically considered for intermittent industrial stormwater discharges, whereas both acute and chronic exposures are considered for continuous discharges. The data recorded in the DMR and EPA's current understanding of water management processes at the facility is insufficient to classify the discharge at this facility as intermittent. Therefore, in this draft permit, EPA has considered the discharge at Outfall 001 to be non-intermittent for the purposes of deriving effluent limitations for copper, chromium (VI), aluminum, and chronic Whole Effluent Toxicity (WET). EPA invites comment on the nature of the discharge in order to better characterize chronic exposures of any toxic pollutants discharged from this facility, including copper, chromium (VI), and aluminum.

5.1.8 Chromium VI

Chromium (VI) is a known human carcinogen¹⁴. However, a current federal drinking water standard of 100 µg/L only exists for Total Chromium. Total Chromium includes all forms of chromium, including Chromium (VI). The current drinking water standard is based on potential adverse dermatological effects in humans, such as allergic dermatitis, from continued exposure. The criterion equivalent to the drinking water standard is protective against the ingestion of contaminated water and aquatic organisms. The National Recommended Aquatic Life Criteria for Chromium (VI) are expressed as the dissolved fraction in the water column. The chronic Chromium (VI) criterion is 11 µg/L and the acute criterion is 16 µg/L. Since the human health criterion is higher than the aquatic life criteria, the more stringent aquatic life criteria will be used to determine reasonable potential for Chromium (VI) to cause or contribute to a violation of MA SWQS.

According to the source analysis testing performed on stormwater from loop overflow (highway runoff), lightweight product, pea stone product, and tap water in August 2011 as part of the metals study, the concentration of Chromium (VI) was non-detect for all individual source samples. An effluent and a receiving water sample from the 2012 permit re-application revealed a Total Chromium concentration of 136 µg/L and 52 µg/L (with a reporting limit of 5 µg/L).

The low flow of the Unnamed Tributary would afford very little dilution to this discharge. EPA is assuming zero dilution for the Unnamed Tributary receiving water for this facility and the discharge is considered non-intermittent. Therefore, water quality-based effluent limits (WQBELs) are set at criteria values. Review of the DMR data reveals that the Chromium (VI) chronic criterion was exceeded 80 out of 97 times and acute criterion was exceeded 79 out of 97

¹⁴ Agency for Toxic Substances and Disease Control (ATSDR). ToxFAQs for Chromium. February 2001.

times (there were 97 results and two instances of no discharge) and there is reasonable potential for Chromium (VI) in the discharge to cause or contribute to an excursion of MA SWQS.

Therefore, monitoring shall be continued at a monthly frequency, the dissolved Chromium VI limit is established at 11 µg/L for average monthly results, and the daily maximum limit is established at 16 µg/L. Additionally, Total Recoverable Chromium monitoring, as a companion to the dissolved Chromium VI, shall be established at a frequency of once per month to assess the control of all species of this metal.

40 CFR 122.45(c)(3) allows for developing effluent limits for dissolved metals if all the approved methods are for the dissolved fraction instead of the total recoverable metal. Chromium VI (hexavalent chromium) is highlighted as an example of that exception in the regulations. The monthly average and daily maximum effluent limitations are therefore expressed in terms of dissolved Chromium (VI). The permittee shall continue to report dissolved Chromium (VI) to the DMR.

Additionally, the permittee shall review new and existing BMPs that could reduce the amount of Chromium (VI) in the effluent as part of the Source Identification and Reduction Plan (See Section 5.3.3).

5.1.9 Aluminum

Aluminum is present in the discharge due to leaching from pea stone and other product stockpiles. As part of the metals study submitted with the 2012 permit reapplication, the permittee switched the polyaluminum chloride coagulant used in the WWTF to ferric chloride in October 2007 (BMP #1, see Table 3). The low flow of the Unnamed Tributary would afford very little dilution to this discharge. EPA is assuming zero dilution for the Unnamed Tributary receiving water for this facility, and since the discharge is considered non-intermittent, water quality-based effluent limits (WQBELs) would be set at criteria values. Review of the DMR data since 2007 reveals that the daily maximum Total Aluminum concentration, reported monthly has exceeded the acute criterion of 750 µg/L 6 times and the chronic criterion 81 times. Based on the reported data there is reasonable potential to cause or contribute to an excursion of the acute and chronic water quality criteria for Total Aluminum. Therefore, the monthly average limit is established at 87 µg/L and the daily maximum limit at 750 µg/L. The monitoring frequency shall continue at monthly and both the daily maximum and average monthly Total Aluminum value shall be reported.

Additionally, the permittee shall review new and existing BMPs that could reduce the amount of Aluminum in the effluent as part of the Source Identification and Reduction Plan (See Section 5.3.3).

5.1.10 Phosphorus

Phosphorus is an essential nutrient for plant growth but excessive amounts of phosphorus in a water body have the potential to accelerate stream eutrophication, which is characterized by

excessive plant growth, low dissolved oxygen, and large diurnal swings in dissolved oxygen in the waterbody. MA SWQS do not include numeric criteria for phosphorus. The standards include narrative criteria, including, in 314 CMR 4.05(5)(c) that state “Unless naturally occurring, all surface waters shall be free from nutrients in concentrations that would cause or contribute to impairment of existing or designated uses and shall not exceed the site specific criteria developed in a TMDL or as otherwise established by the Department pursuant to 314 CMR 4.00”. Any existing point source discharge containing nutrients in concentrations that would cause or contribute to cultural eutrophication, including the excessive growth of aquatic plants or algae, in any surface water shall be provided with the most appropriate treatment as determined by the Department, including, where necessary, highest and best practical treatment (HBPT) for POTWs and BAT for non-POTWs, to remove such nutrients to ensure protection of existing and designated uses.”

Phosphorus is prevalent in the developed environment and is included in sources such as dust and dirt, organic debris such as pollen and leaf litter, vehicle emissions especially from diesel engines and from both dry and wet weather atmospheric deposition. These sources may be deposited directly on the site or may be carried on from adjacent land areas by wind and traffic. Such sources result in the accumulation of phosphorus on land surfaces where it then becomes available for wash-off during precipitation events as part of stormwater runoff. This is especially true for impervious surfaces that offer little capacity to capture phosphorus through storage or filtering. Consequently, phosphorus from these common sources that are ubiquitous in the built-up environment may result in phosphorus loads being discharged from the impervious surfaces at the Boston Sand & Gravel site.

In the absence of numeric criteria or a TMDL, EPA would interpret the narrative criteria using the procedures found at 40 CFR Part 122.44(d)(1)(vi), including the use of available guidance and other relevant information. For example, the 1986 EPA Gold Book cites that “a desired goal for the prevention of plant nuisances in streams or other flowing waters not discharging directly to lakes or impoundments is 100 µg/L Total Phosphorus” (Mackenthun, 1973).

However, a Phosphorus TMDL for the Lower Charles River Basin was completed in 2007. There is no numerical waste load allocation (WLA) for this facility in the TMDL. However, the TMDL provides a % phosphorus reduction goal of 62% for “other drainage areas”, which apply to this facility’s drainage area, as a basis for the WLA. The development of a phosphorus control plan (PCP) is required to achieve the WLA of the TMDL.

There are no available phosphorus monitoring data for the facility’s effluent to date. Phosphorus impacts from a minor tributary to the Charles River are expected, and therefore the draft permit requires the permittee to develop and implement a PCP. The goal of the PCP would reduce the phosphorus discharges from this site by at least 62% over the term of a permit (see Section 5.3.2 of this fact sheet). The on-site WWTF’s phosphorus treatment efficiency, by itself or in combination with other BMPs at the permittee’s discretion, may be used to demonstrate that the facility achieves the WLA. The permit shall require monthly monitoring for effluent phosphorus, but additional monitoring of representative influent phosphorus may be necessary to establish a baseline condition and demonstrate the required reduction.

5.1.11 *E. Coli*

Coliform bacteria indicator parameters include total coliforms, fecal coliform, and *Escherichia coli* (*E. coli*). When coliform bacteria are found to be present in surface water, it may indicate the improper discharge of sewage. For Class B surface waters such as the Unnamed Tributary, the MA SWQS require that the geometric mean of all *E. coli* samples taken within the most recent six months shall not exceed 126 cfu per 100 mL typically based on a minimum of five samples and no single sample shall exceed 235 cfu per 100 mL.

The current permit does not require monitoring for pathogen indicators such as *E. coli*. However, a Pathogen TMDL for the Charles River was completed in 2007 in which stormwater sources of pathogens, such as from this facility, were identified as potential significant contributors of pathogen pollution. During rain events, fecal matter from domestic animals and wildlife is readily transported to surface waters via the stormwater drainage systems and/or overland flow. The natural filtering capacity provided by vegetative cover and soils is dramatically reduced as urbanization occurs because of the increase in impervious areas (i.e., streets, parking lots, etc.) and stream channelization in the watershed¹⁵. Current recommended pathogen TMDL implementation measures include identification and elimination of prohibited sources such as leaky or improperly connected sanitary sewer flows and best management practices (BMPs) to mitigate stormwater runoff volume.

Therefore, the draft permit requires that the permittee implement a Source Identification and Reduction Plan (SIRP) to identify and minimize the discharge of bacteria through the facility's stormwater system. The mitigation of stormwater runoff volume is addressed in the existing SWPPP. More details of the SIRP may be found in Section 5.3.3 of this fact sheet and Part I.C of the permit. The permit also requires the permittee to sample for *E. coli* on a monthly basis.

5.1.12 Whole Effluent Toxicity (WET) Testing

Whole effluent toxicity (WET) testing is conducted to assess whether certain effluents are discharged in a combination which produces a toxic amount of pollutants in the receiving water. Toxicity testing is used in conjunction with pollutant specific control procedures to control the discharge of toxic pollutants. Sections 402(a)(2) and 308(a) of the CWA provide EPA and States with the authority to require toxicity testing. Section 308 specifically describes biological monitoring methods as techniques that may be used to carry out objectives of the CWA.

Under Section 301(b)(1)(C) of the CWA, discharges are subject to effluent limitations based on water quality standards. The Massachusetts Surface Water Quality Standards include the following narrative statement (314 CMR 4.05(5)(e)) and requires that EPA criteria established pursuant to Section 304(a)(1) of the CWA be used as guidance for interpretation of the following narrative criteria:

¹⁵ Final Pathogen TMDL for the Charles River Watershed, January 2007.

All surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife.

EPA Region 1 typically includes toxicity testing requirements where a combination of toxic constituents may be toxic to humans, aquatic life, or wildlife. Section 101(a)(3) of the CWA specifically prohibits the discharge of toxic pollutants in toxic amounts. Additionally, NPDES regulations under 40 CFR §122.44(d)(1)(iv) and (v) require WET effluent limits in a permit when the permitting authority determines that a discharge causes, has the reasonable potential to cause, or contributes to an in-stream excursion above a State's narrative or numeric criterion within an applicable State water quality standard for toxicity.

The permittee has conducted annual freshwater acute and chronic WET tests for the daphnid, *Ceriodaphnia dubia*, and fathead minnow, *Pimephales promelas*. The end point measured by the acute test is the LC₅₀ or the concentration that is lethal to 50% of the test organisms. An LC₅₀ value, measured in percent, represents the degree of toxicity on an inverse logarithmic scale. The C-NOEC (chronic no observed effect concentration) is defined as the highest effluent concentration at which there is no statistically significant adverse effect on the survival of the test organisms when compared with the diluent control survival at the time of observation.

In order to assure that this limit is met within a short distance of the effluent pipe MassDEP has established an end-of-pipe limit of 1.0 TU (LC₅₀ = 100%) for dilution factors less than or equal to 100 (Boston Sand & Gravel's discharge to the Unnamed Tributary offers no dilution, i.e. a dilution factor of 1). However, at dilution factors of less than 10, the Unnamed Tributary is considered water quality limited in that the effluent limit of 1.0 TU may not be stringent enough to protect receiving waters. MassDEP requires both acute and chronic end points to be reported. Two limits apply to the effluent when the dilution factor is less than 10: (1) the chronic WET test should result in a No Observed Effect Concentration greater than or equal to the Receiving Water Concentration (NOEC > RWC) and (2) the acute level should be less than or equal to 1.0 TU (an LC₅₀ ≥ 100%). Because the dilution factor is 1, this requires NOEC > 100%, or a TU of less than or equal to 1.0.

Review of the DMR data reveals that for the daphnid, 6 of 7 valid acute WET results exceed a TU of 1 and all 7 of 7 valid chronic WET results exceed a TU of 1 and the discharge has the reasonable potential to cause or contribute to a violation of MA SWQS. (See Attachment F for the daphnid DMR WET data converted to TUs and more information on the reasonable potential calculation.) WET results for the fathead minnow do not demonstrate a reasonable potential for this species.

Therefore, two limits apply to the effluent: (1) the acute level should be LC₅₀ ≥ 100%, and (2) the chronic WET test should result in a C-NOEC greater than or equal to the instream Receiving Water Concentration of the discharge (C-NOEC ≥ RWC) at critical low flow conditions. The C-NOEC limit is established using the instream waste concentration (IWC) of the effluent. The IWC is the inverse of the dilution factor (DF) and since it is assumed there is no dilution available to the effluent, or a dilution ratio of 1.0, the inverse would also be 1.0, resulting in the 100% limit.

The frequency of WET testing shall be increased to quarterly for the daphnid, *Ceriodaphnia dubia* (once every three months, at the beginning of the quarter, as specified in the footnotes to the effluent limitation table for Outfall 001 in the permit). WET testing requirements have been eliminated for the fathead minnow, *Pimephales promelas*, as the daphnid is the more sensitive species and the recorded WET results have not demonstrated toxicity of the effluent to the fathead minnow.

In order to determine the cause of the toxicity to the daphnid, the facility may conduct a TIE/TRE study (Toxicity Identification Evaluation/Toxicity Reduction Evaluation). More information on how a TIE/TRE study for industrial facilities is conducted can be found online¹⁶. EPA welcomes comments on the implementation of a TIE/TRE study and a compliance schedule during the public comment period.

5.1.13 Other Pollutants of Potential Concern

5.1.13.1 Iron

Sector E of the MSGP for SIC Code 3273 (Glass Clay, Cement, Concrete, and Gypsum Products) contains a benchmark monitoring cutoff concentration of 1.0 mg/L for Total Recoverable Iron. Previous monitoring for iron has consistently been below this benchmark monitoring concentration (an effluent sample from the 2012 permit application of 0.34 mg/L and three samples from the former permit fact sheet ranging from 0.28-0.31 mg/L). However, if future monitoring required in the permit re-application shows that this benchmark monitoring cutoff concentration is exceeded, the facility may be required to sample for iron, and/or develop BMPs, pursuant to the SWPPP, to reduce the level of iron in the discharge from the facility. The draft permit does not require monitoring for iron at this time.

5.1.13.2 Chlorine

Effluent sampling for the 2012 permit reapplication for Total Residual Chlorine (TRC) resulted in two non-detect readings, with a reporting limit of 20 µg/L. Out of eight (8) effluent water quality analyses conducted as part of the permittee's annual WET tests, seven of these were non-detect for TRC and one was recorded at 240 µg/L for September 2011. The current applicable aquatic life acute criterion for Total Residual Chlorine is 19 µg/L and the chronic criterion is 11 µg/L. The 240 µg/L measurement is not representative of the effluent and no limit is needed at this time. A monitoring requirement for Total Residual Chlorine will be included in the quarterly analytical chemistry testing performed with the WET tests.

¹⁶

<http://nepis.epa.gov/Exe/ZyNET.exe/30000H2L.TXT?ZyActionD=ZyDocument&Client=EPA&Index=1986+Thru+1990&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C86thru90%5CTxt%5C00000002%5C30000H2L.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=p%7Cf&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL>

5.2 Internal Outfall 002

5.2.1 Oil & Grease

A monitoring and reporting requirement for Oil & Grease was previously included for an internal outfall representative of boiler blowdown water. Potential Oil & Grease limits were also previously considered based on a BPJ analysis using the Steam Electric Power Generating Effluent Guidelines. The boiler at the facility is run on natural gas. Due to a recommendation from MassDEP, starting in 2012 the permittee sampled for Oil & Grease at the same location as Outfall 001 in Lagoon 9. The BPJ analysis is not considered appropriate based on the single natural gas-powered boiler at the facility resulting in a minimal wastestream of boiler blowdown. The 2015 Steam Electric Power Generating Effluent Point Source Category: Final Detailed Study Report¹⁷ notes the following about minimal wastewater streams (wastewater streams including boiler blowdown water) at facilities such as Boston Sand & Gravel:

“The information collected during the detailed study [for non-power generating facilities in developing the 2015 Steam Electric Power Generating Guidelines] indicates that most industrial plants commingle the wastewaters associated with the electric generating units with the other plant process wastewaters. Because the wastewaters are commingled, they may be treated in the plant’s wastewater treatment system. These commingled wastewaters typically have permit limits based on the industry-specific effluent guidelines; the Steam Electric Power Generating effluent guidelines limits are typically not used to set BPJ-based limits.”

Therefore, EPA determined that it is appropriate to establish an Oil & Grease limit at Outfall 001.

5.2.2 Removal of the Internal Outfall

Internal Outfall 002 has been removed from the permit. Due to the removal of monitoring requirements at the internal outfall, reporting at this outfall is no longer required.

5.3 Special Conditions

5.3.1 Stormwater Pollution Prevention Plan (SWPPP)

This facility engages in activities which could result in the discharge of pollutants to waters of the United States either directly or indirectly through stormwater runoff. These operations include at least one of the following in an area potentially exposed to precipitation or stormwater: material storage, in-facility transfer, material processing, material handling, or loading and unloading. To control the activities/operations, which could contribute pollutants to

¹⁷ https://www.epa.gov/sites/production/files/2015-06/documents/steam-electric_detailed_study_report_2009.pdf

waters of the United States, potentially violating MA SQWS, the draft permit requires the facility to develop, implement, and maintain a Stormwater Pollution Prevention Plan (SWPPP) containing best management practices (BMPs) appropriate for this specific facility (See Sections 304(e) and 402(a)(1) of the CWA and 40 CFR §125.103(b)). Specifically, at this facility, aggregate storage is an example of a material storage operation, cement and aggregate processing is an example of a processing operation, and transporting of stone and cement materials throughout the site, as well as fueling, are examples of handling operations that shall continue to be included in the SWPPP.

The goal of the SWPPP is to reduce, or prevent, the discharge of pollutants through the stormwater drainage system. The SWPPP requirements in the draft permit are intended to provide a systematic approach by which the permittee shall at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of the permit. The SWPPP shall be prepared in accordance with good engineering practices and identify potential sources of pollutants, which may reasonably be expected to affect the quality of stormwater discharges associated with industrial activity from the facility. The SWPPP, upon implementation, becomes a supporting element to any numeric effluent limitations in the draft permit. Consequently, the SWPPP is as equally enforceable as the numeric limits.

Implementation of the SWPPP involves the following five main steps:

- 1) Forming a team of qualified facility personnel who will be responsible for developing and updating the SWPPP and assisting the plant manager in its implementation;
- 2) Assessing the potential stormwater pollution sources;
- 3) Selecting and implementing appropriate management practices and controls for these potential pollution sources; and
- 4) Reevaluating, periodically, the effectiveness of the SWPPP in preventing stormwater contamination and in complying with the various terms and conditions of the draft permit.
- 5) Development and implementation of site specific BMPs, including BMPs consistent with the sector specific BMPs in Sector E (Glass, Clay, Cement, Concrete, and Gypsum Products) of the MSGP.

5.3.2 Phosphorus Control Plan

On October 17, 2007, EPA approved the Final TMDL for Nutrients in the Lower Charles River Basin (Lower Charles TMDL). The following phosphorus reduction requirements are consistent with the percentage load phosphorus reductions for stormwater drainages systems within the lower Charles River watershed. To address the discharge of phosphorus from this facility and consistent with the TMDL requirements, the permittee shall develop a Phosphorus Control Plan

(PCP) designed to reduce the amount of phosphorus in stormwater discharges in terms of average annual load from its storm drainage system to the Charles River via the Unnamed Tributary. The PCP shall be completed in phases as detailed in the permit. The PCP shall be developed and fully implemented during the permit term to meet the 62% phosphorus load reduction WLA set forth in the TMDL for stormwater discharges that ultimately drain to the lower Charles River. The permittee is required to develop and implement the following site-specific PCP (see also permit Part I.C.).

5.3.3 Source Identification and Reduction Plan

Metals

Site-specific BMPs to address metals loading to the receiving water as part of a Source Identification and Reduction Plan (SIRP), in addition to numeric effluent limitations discussed in Section 5.1.7 through Section 5.1.9, are required in this permit. The permittee shall continue to develop and implement the study to determine the source of metals, including aluminum, chromium (VI) and copper, and continue to develop and implement subsequent treatment methods and/or stormwater BMPs to reduce the level of metals in the discharge. The permittee may build on the existing metals BMP study that was submitted as part of the 2012 permit reapplication.

Pathogens

Immediate effects of pathogen contamination to the Charles River from stormwater sources discharging to its tributaries (like this facility) are expected. Therefore, in addition to monthly monitoring for *E. Coli*, the implementation of BMPs are required as part of the SIRP for this permit. Examples of methods for identifying and eliminating illicit sewer connections in a facility's drainage system and pathogen reduction tracking are available in BWSC annual reports required as part of MS4 NPDES permit no. MAS010001.

5.4 Compliance Schedules

EPA recognizes that the permittee may not be able to meet the numeric chromium (VI), copper, aluminum, and acute and chronic WET effluent limits upon the effective date of the permit. In these situations, EPA would typically issue an Administrative Order to the Permittee with a schedule for compliance with these new effluent limitations. Also, the MA SWQS at 314 CMR 4.03(1)(b) authorize the use of compliance schedules in NPDES permits and may include interim effluent limits. EPA invites comment on a reasonable compliance schedule, and the means for specifying a compliance schedule through an Administrative Order or in the final permit.

6.0 MONITORING AND REPORTING

The permit's monitoring requirements have been established to yield data representative of the facility's pollutant discharges under the authority of Sections 308(a) and 402(a)(2) of the CWA and consistent with 40 CFR §§ 122.41 (j), 122.43(a), 122.44(i) and 122.48. The monitoring program in the permit specifies routine sampling and analysis which will provide ongoing, representative information on the levels of regulated constituents in the wastewater discharge streams. The approved analytical procedures are found in 40 CFR §136 unless other procedures are explicitly required in the permit.

The draft permit requires the permittee to continue to electronically report monitoring results obtained during each calendar month as Discharge Monitoring Report (DMRs) to EPA and the state using NetDMR no later than the 15th day of the month following the completed reporting period.

NetDMR is a national web-based tool for regulated CWA permittees to submit DMRs electronically via a secure internet application to U.S. EPA through the Environmental Information Exchange Network. NetDMR allows participants to discontinue mailing in hard copy forms under 40 CFR §122.41 and §403.12. NetDMR is accessed from the following url: <http://www.epa.gov/netdmr>. Further information about NetDMR can be found on the EPA Region 1 NetDMR website located at <http://www.epa.gov/region1/npdes/netdmr/index.html>.

In most cases, reports required under the permit shall be submitted to EPA as an electronic attachment through NetDMR. Certain exceptions are provided in the permit such as for providing written notifications required under the Part II Standard Permit Conditions. With the use of NetDMR to report DMRs and reports, the permittee is no longer be required to submit hard copies of DMRs or other reports to EPA and is no longer be required to submit hard copies of DMRs to MassDEP. However, permittees must continue to send hard copies of reports other than DMRs to MassDEP until further notice from MassDEP. State reporting requirements are further explained in the draft permit.

7.0 OTHER LEGAL REQUIREMENTS

7.1 Essential Fish Habitat

Under the 1996 Amendments (PL 104-267) to the Magnuson-Stevens Fishery Conservation and Management Act (16 U.S.C. § 1801 et seq. (1998)), EPA is required to consult with the National Marine Fisheries Services (NOAA Fisheries) if EPA's action or proposed actions that it funds, permits, or undertakes, may adversely impact any essential fish habitat such as: waters and substrate necessary to fish for spawning, breeding, feeding, or growth to maturity (16 U.S.C. § 1802 (10)). Adverse impact means any impact which reduces the quality and/or quantity of EFH (50 CFR § 600.910 (a)). Adverse effects may include direct (e.g., contamination or physical disruption), indirect (e.g., loss of prey, reduction in species' fecundity), site-specific or habitat-wide impacts, including individual, cumulative, or synergistic consequences of actions.

In this case, the federal action being considered is the renewal of the NPDES permit for the Boston Sand and Gravel facility (BS&G), which ultimately discharges to the Charles River.

Essential fish habitat is only designated for species for which federal fisheries management plans exist (16 U.S.C. § 1855(b) (1) (A)). EFH designations for New England were approved by the U.S. Department of Commerce on March 3, 1999. For this federal action, a summary of EFH designations identified from inner Boston Harbor near the mouth of the Charles River was consulted. This area of Boston Harbor is the habitat for 21 EFH species. The list of the species, including the applicable lifestage(s) present for each species, was taken from the NOAA Habitat Conservation EFH Mapper Website:

<http://www.habitat.noaa.gov/protection/efh/efhmapper/index.html>. The list is included as Attachment G in this fact sheet.

A review of the 21 species revealed that the life stages of concern are present in the seawater salinity zone (salinity > 25.0 parts per thousand) or the mixing water /brackish salinity zone (0.5 < salinity < 25.0 parts per thousand) only. No life stage is identified as inhabiting the tidal freshwater salinity zone. The freshwater of the Charles River does not experience appreciable mixing with the saline Boston Harbor water, due to the location and operation of the New Charles River Dam and Locks at the mouth of the river. This dam highly regulates the river level and flow of the Charles River, resulting in the river possessing the characteristics of a freshwater salinity zone. Therefore, no EFH species are expected to inhabit the Charles River in the vicinity of the BS&G discharge.

This determination is further supported by data collected as part of a four year adult and juvenile fish sampling program and an extensive ichthyoplankton collection program in the Charles River (Mirant Kendall Generating Station NPDES Monitoring Reports; 1999, 2000, 2002 and 2003). During this study, none of the 21 species listed in Attachment G were collected in the Charles River.

Based on the freshwater characteristic of the receiving water and the absence of any of the species listed in Attachment G, EPA has determined that the outfall from BS&G does not have the potential to come in contact with or directly affect the EFH species of concern.

However, EPA recognizes that the outfall has the potential to indirectly cause adverse effects to EFH species in Boston Harbor or Massachusetts Bay. The BS&G outfall is discharged to an Unnamed Tributary (known locally as “Miller’s River”). The mouth of this tributary meets the Charles River on the Cambridge side of the river, approximately one-third of a mile upstream of the New Charles River Dam and Locks. Anadromous species that enter the Charles River and move past the mouth of Miller’s River to spawn upstream have the potential to encounter the diluted discharge from the outfall. These species - blueback herring and alewife - while not identified as EFH species, may be selected as prey by EFH species. If these prey species are affected by the BS&G outfall, this has the potential to indirectly affect EFH species through loss of prey.

Based on the available information, EPA has determined that the limitations and conditions in the draft permit will minimize any indirect adverse impacts to EFH for the following reasons:

- This permit action does not constitute a new source of pollutants. It is the reissuance of an existing NPDES permit;
- The facility withdraws no water from the Charles River or the Unnamed Tributary, so no life stages of EFH prey species are vulnerable to impingement or entrainment from this facility;
- The draft permit contains water quality-based numeric limits for pH, total suspended solids, oil & grease, copper, aluminum, chromium (VI), and turbidity;
- The draft permit prohibits the discharge of pollutants or combinations of pollutants in toxic amounts; and
- Acute and chronic toxicity testing for *Ceriodaphnia dubia* has been increased to four times per year from annually and acute and chronic WET limits have been established;
- The effluent limitations and conditions in the draft permit were developed to be protective of all aquatic life, including anadromous prey species of EFH species; and
- The draft permit prohibits violations of the state water quality standards.

EPA believes that the conditions and limitations contained within the draft permit adequately protect all aquatic life, including the ichthyoplankton and fish preyed upon by EFH species, and that further mitigation is not warranted. Should adverse impacts to EFH be detected as a result of this permit action, or if new information is received that changes the basis for EPA's conclusions, NMFS will be contacted and an EFH consultation will be initiated.

7.2 Endangered Species Act

Section 7(a) of the Endangered Species Act (ESA) of 1973, as amended (the "Act"), grants authority to and imposes requirements upon federal agencies regarding endangered or threatened species of fish, wildlife, or plants ("listed species") and the habitats of such species that have been designated as critical ("critical habitat"). The NMFS administers Section 7 consultations for marine species and anadromous fish. The United States Fish and Wildlife Service (USFWS) administers Section 7 consultations for freshwater species. In consultation with and with the assistance of the Secretary of the Interior, Section 7(a)(2) of the Act requires every federal agency ensure that any action it authorizes, funds, or carries out, in the United States or upon the high seas, will not jeopardize the continued existence of any listed species or result in the destruction or adverse modification of critical habitat.

In this case, the federal action being considered is the renewal of the NPDES permit for the Boston Sand and Gravel facility (BS&G), which ultimately discharges to the Charles River.

EPA does not consider the area influenced by the facility's discharge (the action area) to be suitable habitat for the protected species listed for Massachusetts Bay and Boston Harbor. Based on the normal distribution of these species, it is extremely unlikely that there would be any NMFS listed species in the vicinity of the area influenced by the BS&G outfall. EPA has made the determination that no protected species are present in the area influenced by the discharge.

Therefore, EPA has made the assessment that consultation is not required for these protected species under Section 7 of the ESA.

Consultation will take place: (a) if new information reveals effects of the action that may affect listed species or critical habitat in a manner or to an extent not previously considered in the consultation; (b) if the identified action is subsequently modified in a manner that causes an effect to the listed species or critical habitat that was not considered in the consultation; or (c) if a new species is listed or critical habitat is designated that may be affected by the identified action.

7.3 State Certification Requirements

EPA may not issue a permit unless the Massachusetts Department of Environmental Protection (MassDEP) either certifies that the effluent limitations contained in the permit are stringent enough to assure that the discharge will not cause the receiving water to violate State Water Quality Standards or it is deemed that the state has waived its right to such certification. Regulations governing state certification are set forth in 40 CFR §124.53 and §124.55. EPA has requested permit certification by the State pursuant to 40 CFR §124.53 and expects that the draft permit will be certified.

7.4 Public Comment Period, Public Hearing Requests, and Procedures for Final Decision

All persons, including applicants, who believe any condition of the draft permit is inappropriate must raise all issues and submit all available arguments and all supporting material for their arguments in full by the close of the public comment period, to Undine Kipka, U.S. EPA, Office of Ecosystem Protection, Industrial Permits Section, 5 Post Office Square, Suite 100, Boston, Massachusetts 02109-3912. Any person, prior to such date, may submit a request in writing for a public hearing to consider the draft permit to EPA and the State Agency. Such requests shall state the nature of the issues proposed to be raised in the hearing. A public meeting may be held if the criteria stated in 40 CFR §124.12 are satisfied. In reaching a final decision on the draft permit, the EPA will respond to all significant comments and make these responses available to the public at EPA's Boston office.

Following the close of the comment period, and after any public hearings, if such hearings are held, the EPA will issue a final permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice. Within 30 days following the notice of the final permit decision, any interested person may submit a petition for review of the permit to EPA's Environmental Appeals Board consistent with 40 CFR §124.19 and/or submit a request for an adjudicatory hearing to MassDEP's Office of Appeals and Dispute Resolution consistent with 310 CMR 1.00.

8.0 EPA AND MASS DEP CONTACTS

Additional information concerning the Draft Permit may be obtained between the hours of 9:00 a.m. and 5:00 p.m., Monday through Friday, excluding holidays, from the EPA and MassDEP contacts below:

Undine Kipka
U.S. Environmental Protection Agency
5 Post Office Square, Suite 100 (OEP 06-01)
Boston, Massachusetts 02109-3912
kipka.undine@epa.gov
(617) 918-1335

Cathy Vakalopoulos
Massachusetts Department of Environmental Protection
Bureau of Water Resources
1 Winter Street
Boston, Massachusetts 02108
catherine.vakalopoulos@state.ma.us
Telephone: (617) 348-4026
Fax: (617) 292-5696

July 25, 2017

Date

Arthur Johnson III, Acting Director
Office of Ecosystem Protection
US Environmental Protection Agency

Attachment A: Site Map


Boston Sand & Gravel Charlestown facility




Image courtesy of USGS Earthstar Geographics. 90 © 2016 Microsoft Corporation © 2010 NAVTEQ © AND

© 2016 Microsoft Corporation, © 2010 NAVTEQ, © AND

Attachment B: Facility Process Diagram



Attachment C: Facility SWPPP Drainage Areas



FOR PERMIT APPROVAL
Not for Construction

DR	Permit Approval	CDC	WCH	2010-10
TA	Permit Approval	TA	RSO	2010-10
TA	Permit Approval	TA	RSO	2010-10
TA	Permit Approval	TA	RSO	2010-10

Figure 4 - Site Drainage Plan

SUBJECT:
 Boston Sand & Gravel
JOB LOCATION:
 Charlestown, MA

SIGNATURE

 Capacchio Environmental Engineering, Inc.
 201 Boston Post Road, 2nd Floor
 Boston, MA 02126
 "Working Hard and Fast to Make Your Project"

DATE: 10/10/10
SCALE: 1" = 50'
TITLE: D
SHEET: Figure 4

Attachment D: Facility Product Safety Data Sheet Summary

Product	MSDS Date	CAS No.	Ingredient Name	%	SG/Density	lb/gal
<i>Liquid Admix</i>						
MasterAir AE 200 (Micro Air)	1/22/2016				1.01 g/cm3	8.43
		68439-57-6	Sulfonic acids, C14-16-alkaline hydroxy and C14-16-alkene, sodium salts	>=1.0 - <3.0 %		
		1310-58-3	Potassium hydroxide	>=0.0 - <5.0%		
		8050-09-7	Rosin	>=0.0 - <1.0%		
MasterGlenium 7500 (Glenium 7500)	1/8/2016				1.05 g/cm3	8.76
		64-19-7	Acetic acid	1.0 - 7.0 %		
		9014-85-1	Poly(oxy-1,2-ethanediyl), .alpha.,.alpha.'-[1,4-dimethyl-1,4-bis(2-methylpropyl)-2-butyne-1,4-diyl]bis[.omega.-hydroxy-	>= 0.3 - < 3.0%		
		126-71-6	triisobutyl phosphate	>= 0.1 - < 0.2%		
MasterLife CI 30 (Rheocrete CNI 30)	6/1/2015				1.29 g/cm3	10.76
		10124-37-5	Calcium nitrate	>= 1.0 - <= 7.0 %		
MasterLife SRA 20 (Master Life)	1/20/2015				1.01 g/cm3	8.43
MasterPolyheed 1025 (Polyheed 1025)	1/11/2016				1.065 g/cm3	8.89
		64-19-7	Acetic acid	5.0 - 10.0 %		
		140-07-8	Ethanol, 2,2',2'',2'''-(1,2-ethanediyl)dinitrilo)tetrakis-	>= 1.0 - < 7.0%		
		126-71-6	triisobutyl phosphate	>= 1.0 - < 3.0%		
		112-18-5	dodecyldimethylamine	>= 0.1 - < 0.3%		
		2634-33-5	1,2-benzisothiazol-3(2H)-one	>= 0.0 - < 0.1%		
MasterPozzolith 700 (Pozzolith 700)	5/14/2015				1.1136 g/cm3	9.46
		102-71-6	2,2',2''-nitridetriethanol	>= 3.0 - <= 5.0 %		
		15733-22-9	Phenol, 4-chloro-3-methyl-, sodium salt	>= 0.2 - < 1.0 %		
		111-42-2	2,2'-iminodiethanol	>= 0.0 - < 1.0 %		
MasterSet AC 122 (Pozzolith 122HE)	5/27/2015				1.301 -	10.85

		10043-52-4	Calcium chloride	$\geq 5.0 - \leq 15.0$ %	1.36 g/cm3	11.35
		7789-41-5	Calcium bromide (CaBr2)	$\geq 0.3 - < 1.0\%$		
		111-42-2	2,2'-iminodiethanol	$\geq 0.0 - < 0.2\%$		
MasterSet AC 534 (Pozzoloth NC 534)	4/9/2015				1.399 g/cm3	11.67
		10124-37-5	Calcium nitrate	$\geq 25.0 - < 75.0$ %		
		540-72-7	Sodium thiocyanate	$\geq 5.0 - < 15.0$ %		
		102-71-6	2,2',2"-nitrilotriethanol	$\geq 0.0 - < 3.0$ %		
		111-42-2	2,2'-iminodiethanol	$\geq 0.0 - < 0.3$ %		
MasterSet FP 20 (Pozzutec 20+)	6/8/2016				1.35 g/cm3	11.26
		10124-37-5	Calcium nitrate	$\geq 0.0 - \leq 75.0$ %		
		540-72-7	Sodium thiocyanate	$\geq 0.0 - \leq 7.0$ %		
		5395-50-6	tetramethylolacethylenediurea	$\geq 0.0 - < 3.0\%$		
		50-00-0	Formaldehyde	$\geq 0.0 - < 0.2\%$		
MasterSet Delvo (Delvo Stabilizer)	1/21/2016				1.061 - 1.075 g/cm3	8.85 8.97
		6419-19-8	Phosphonic acid, [nitrilotris(methylene)]tris-	$\geq 5.0 - < 15.0\%$		
		1310-73-2	Sodium Hydroxide	$\geq 0.3 - < 3.0\%$		
		13598-36-2	Phosphonic acid	$\geq 0.0 - < 1.0\%$		
		59-50-7	4-chloro-3-methyl phenol	$\geq 0.0 - < 0.2\%$		
MasterSet R 100 (Pozzoloth 100 XR)	3/18/2015				1.15	9.59
MasterSure Z60 (RheoTec Z 60)	8/4/2015				1.043	8.7
Dry Powders						
CEMENT - Lafarge Portland I/II	4/23/2015	65997-15-1	Portland Cement			
		12168-85-3	Tri-calcium silicate (20-70)			
		10034-77-2	Di-calcium silicate (10-60)		3.15	
		12068-35-8	Tetra-calcium- alumino-ferrite (5-15)			
			Calcium sulfate (2-10)			
		12042-78-3	Tri-calcium Aluminate (1-15)			

		1309-48-4	Magnesium oxide (0-4)			
		14808-60-7	Crystalline Silica (Quartz) * (0-1%)			
		18540-29-9	Hexavalent Chromium (measured as chromic acid and chromates)			
WHITE CEMENT - Lehigh	5/21/2015	65997-15-1	Portland Cement	100%	2.3 - 3.1	
CEMENT - LAFARGE BLENDED - SILICA FUME	4/21/2015				3 - 3.2	
FLY ASH - Headwaters	5/18/2015		Aluminosilicate Glass Contains Al, Si, Fe, Ca, Mg, Ti Crystalline Silica Calcium Oxide CaO Iron Mineral Dusts Fe2O3, Fe3O4		2.2 - 2.8	
SLAG - Lafarge	4/14/2015	65996-69-2	Granulated blast-furnace slag			
		7631-86-9	Amorphous silica		2 - 3	
			Crystalline Silica (Quartz)			
Wastewater Treatment Chemicals						
Hydrochloric Acid		7647-01-0	Hydrogen chloride	30 - 40 %	1.2	10
Aries 2093		7705-08-0	Ferric chloride solution	92 - 94 %	1.34 - 1.36	11.3
Coagulant		7647-01-0	Hydrochloric acid	<1 %		
Aries 3610		064742-47-8	Petroleum dustillate hydrotreated light	22 - 25 %		
Flocculant		631-61-8	Ammonium acetate	2 - 10 %	1.03 - 1.06	8.7
		69011-36-5	Poly(oxy-1,2-ethanediyl), .alpha.-tridecyl-.omega.-hydroxy-, branched	<3 %		
Other						
Gasoline -		86290-81-5	Gasoline			
10% Ethanol		71-43-2	Benzene			
		100-41-4	Ethyl benzene			
		91-20-3	Naphthalene			
		64-17-5	Ethanol			
		1634-04-4	Methyl tert-butyl ether (MTBE)			
		994-05-8	Tertiary amyl methyl ether (TAME)			
		637-92-3	Ethyl tert-butyl ether (ETBE)			
Diesel Fuel -		68476-34-6	Diesel Fuel			

<i>Low Sulfur</i>		Nonane, all isomers Mixture
	25551-13-7	Trimethylbenzenes, all isomers
	91-20-3	Naphthalene
	98-82-8	Cumene
	100-41-4	Ethylbenzene

Attachment E - DMR Summary

NPDES Permit Fact Sheet Table

Search Criteria: Monitoring Period Range: 01/01/2007 to 03/31/2016 and NPDES Permit ID: MA0000531

Outfall - Monitoring Location - Limit Set: 001A

	Aluminum, total (as Al) Mon, ug/L	Chromium, hexavalent (as Cr) Mon, ug/L	Copper, total (as Cu) Mon, ug/L	Flow, in conduit or thru treatment plant Mon, gal/d	Mon, gal/d	Hardness, total (as CaCO3) Mon, mg/L	Solids, total suspended 20, mg/L	45, mg/L
Monitoring Period End Date	DAILY MX	DAILY MX	DAILY MX	DAILY MX	MO AVG	DAILY MX	MO AVG	DAILY MX
10/31/2007	2490	38	4.4	41900	5400	190	2	9.9
11/30/2007	277	56	9.8	32600	2700	860	0	0
12/31/2007	410	125	47	46100	2700	960	3.2	6.3
1/31/2008	556	28	14	21000	3200	330	3.3	13
2/29/2008	238	19	28.2	80700	10400	140	9.7	29
3/31/2008	2.39	19	7.2	78500	4800	150	9.3	16
4/30/2008	111	55	1103	12000	700	360	0	0
5/31/2008	99	26	4.7	31100	3100	120	0	0
6/30/2008	750	83	8.1	50900	4900	1200	5.9	6.8
7/31/2008	150	97	10.4	81100	8100	700	2.3	9
8/31/2008	376	150	8.7	126000	9000	470	4.6	8.8
9/30/2008	284	93	4	136300	10300	200	2.7	5.3
10/31/2008	172	173	4.8	29100	3000	810	0	0
11/30/2008	110	84	55.5	38200	7000	530	4	20
12/31/2008	93	45	11.6	89700	9500	230	3.8	15
1/31/2009	54	0	45.8	36900	5000	1500	9.4	20
2/28/2009	2800	0	27.8	42100	3300	1800	2.6	5.1
3/31/2009	654	47	20.8	20200	1800	290	3.9	7.8
4/30/2009	249	55	21	101000	9800	360	2.4	7.3
5/31/2009	159	23	16	40600	3400	170	5.5	11
6/30/2009	498	75	38.1	31800	5000	330	2.5	7.4
7/31/2009	172	37	9.3	68400	11200	450	0	0
8/31/2009	66	67	11	63500	5500	770	2	6
9/30/2009	96	21	6	124000	8200	140	2.5	7.4
10/31/2009	109	0	10.9	40800	6900	450	3.7	7.7
11/30/2009	98	0	75	37800	3500	730	0	0
12/31/2009	0	0	153	78800	8300	840	0	0
1/31/2010	176	99	16.2	31600	4400	850	5	10
2/28/2010	194	140	15	86800	8000	1300	3.7	7.4
3/31/2010	289	0	11.6	280000	27700	430	1.7	5
4/30/2010	934	56	24.9	29500	3100	750	0	0
5/31/2010	273	0	8.5	44300	4200	260	2.8	5.6
6/30/2010	80	71	15.4	64800	6500	820	0	0
7/31/2010	657	78	12.3	84400	6100	440	12.7	28
8/31/2010	308	0	67	50300	7900	410	2.5	7.6
9/30/2010	779	112	13.3	16600	2200	430	10	10
10/31/2010	128	100	10.7	42100	7200	520	2	8
11/30/2010	106	0	46.6	25600	4700	520	2	5.9
12/31/2010	167	174	14.4	48200	2800	970	0	0
1/31/2011	201	143	27.5	29800	2200	450	12	17
2/28/2011	1050	75	18.9	36900	3300	550	20	21
3/31/2011	126	148	8.9	23500	2600	300	6.5	13
4/30/2011	461	179	16.7	38000	5100	260	4.7	7.8
5/31/2011	195	295	16.2	27800	3900	420	3.7	11
6/30/2011	46	247	30.3	53800	6900	1200	3.6	5.6
7/31/2011	376	0	18.8	15800	1500	260	0	0

8/31/2011	161	165	21	158800	15500	460	2.3	5.1
9/30/2011	394	56	2.3	73200	9900	190	0	0
10/31/2011	72	229	22.3	81500	10700	650	1.4	5.7
11/30/2011	176	243	12.8	37000	9960	270	2.2	6.6
12/31/2011	230	215	21.2	55400	6200	450	0	0
1/31/2012	389	223	76.1	34000	3800	350	6.5	13
2/29/2012	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
3/31/2012	0	0	9.7	27400	2200	1300	15.5	18
4/30/2012	232	236	5.03	41200	4100	610	6.6	11
5/31/2012	108	0	5.4	20500	5200	320	3.9	6.3
6/30/2012	65	180	21.1	56000	8600	480	1.6	6.4
7/31/2012	131	12.9	19.4	25800	3700	460	8.3	8.3
8/31/2012	355	183	21.6	17600	1800	350	6.7	8.3
9/30/2012	496	114	13.4	25400	3100	310	6.6	6.9
10/31/2012	360	161	22.5	43400	5700	350	0	0
11/30/2012	23	215	38.3	15200	1800	480	0	0
12/31/2012	131	259	55.6	39700	6050	131	2.9	5.7
1/31/2013	138	167	40.4	23100	2750	450	0	0
2/28/2013	271	134	24.8	37600	9900	370	10.2	17
3/31/2013	349	165	57.1	23100	4900	600	8.5	19
4/30/2013	260	225	134	15200	2000	470	5	10
5/31/2013	57.9	116	121.6	25000	5400	540	0	0
6/30/2013	309	239	46.45	84800	16500	520	0	0
7/31/2013	360	41	23.31	42400	6300	290	3.2	6.3
8/31/2013	220	168	36.65	38300	5300	510	2.8	5.5
9/30/2013	198	65	18.35	28300	3600	350	0	0
10/31/2013	47.6	51	22.5	9.04	530	550	0	0
11/30/2013	20	0	68.01	32700	4150	1500	9.2	12
12/31/2013	802	265	94.31	74200	8500	570	21	48
1/31/2014	269	233	40.95	71400	7080	530	7.6	7.6
2/28/2014	296	149	68.95	43000	5250	400	0	0
3/31/2014	216	164	43.38	23600	1740	460	0	0
4/30/2014	141	215	49.95	27800	5190	27	2.9	5.7
5/31/2014	242	238	42.12	28300	6390	390	2.3	7
6/30/2014	135	0	26	28900	7270	920	0	0
7/31/2014	212	259	56.37	39500	8500	370	0	0
8/31/2014	327	294	68.09	31700	2440	540	0	0
9/30/2014	228	257	28.96	17900	2230	360	12	12
10/31/2014	383	105	49.1	40600	9800	340	3.5	5.4
11/30/2014	168	201	13.24	26000	5140	350	0	0
12/31/2014	194	153	24.1	108000	12300	66	0	0
1/31/2015	133	92	78.5	14900	1200	1100	0	0
2/28/2015	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
3/31/2015	64	294	36.5	48400	7200	1100	12	13
4/30/2015	87	0	52	18500	2900	1100	0	0
5/31/2015	140	56	20.6	23100	2040	1000	0	0
6/30/2015	0	84	11	38600	4980	1900	0	0
7/31/2015	198	0	18.1	15900	1200	600	0	0
8/31/2015	249	79	24.4	20600	2200	410	0	0
9/30/2015	100	0	13	43600	3800	580	0	0
10/31/2015	732	79	26.25	24600	2300	320	0	0
11/30/2015	117	348	35.04	20000	2400	900	4.3	8.5
12/31/2015	487	132	27.3	27100	1900	660	0	0
Min	0	0	2.3	9.04	530	27	0	0
Max	2800	348	1103	280000	27700	1900	21	48
Average	300	112	41.8	47110	5573	562	3.58	6.8

Monitoring Period	Sulfate, total (as SO4)		Turbidity		pH	
	250, mg/L	Mon, mg/L	25, NTU	Mon, NTU	6, SU	8.5, SU
	MO AVG	DAILY MX	MO AVG	DAILY MX	MINIMUM	MAXIMUM
10/31/2007	39	39	3.6	6.6	7.2	8.3
11/30/2007	120	120	1.1	1.1	7.5	7.5
12/31/2007	100	100	2.2	2.5	6.4	7.6
1/31/2008	71	71	3.1	7.5	7.6	7.6
2/29/2008	25	25	12.4	35	7	7.2
3/31/2008	41	41	6.4	12	7	7
4/30/2008	80	80	1.3	1.3	7.5	7.5
5/31/2008	34	34	1.3	1.3	7.3	7.3
6/30/2008	31	31	0.86	0.96	7.3	7.3
7/31/2008	84	84	2.4	5.2	7.2	7.2
8/31/2008	67	67	2.1	2.7	6.5	6.5
9/30/2008	71	71	1.2	1.5	6.8	6.8
10/31/2008	120	120	1.6	1.6	7.1	7.1
11/30/2008	140	140	4.6	18	6.6	6.6
12/31/2008	34	34	2.8	7.3	7.2	7.2
1/31/2009	200	200	5.3	11	7.1	7.1
2/28/2009	170	170	1.4	1.4	6.6	6.6
3/31/2009	49	49	2.4	2.6	7.2	7.2
4/30/2009	48	48	1.8	2.5	7.2	7.2
5/31/2009	37	37	8	14	6.5	6.5
6/30/2009	260	260	3.7	7	7.3	7.3
7/31/2009	67	67	1.1	1.6	7.8	7.8
8/31/2009	55	55	1.6	2	6.9	6.9
9/30/2009	34	34	0.79	1	7.7	7.7
10/31/2009	120	120	1.5	2	7	7
11/30/2009	130	130	0.62	0.92	7.9	7.9
12/31/2009	120	120	2.4	4.3	7.3	7.3
1/31/2010	72	72	1.9	2.1	7.9	7.9
2/28/2010	130	130	2.4	3	8.2	8.2
3/31/2010	23	23	1.5	2.8	7.8	7.8
4/30/2010	170	170	1.4	2	6.4	6.4
5/31/2010	73	73	3.2	4.7	7.7	7.7
6/30/2010	170	170	1.2	2	7.7	7.7
7/31/2010	75	75	4.1	9.7	7.8	7.8
8/31/2010	59	59	3.8	8	7.1	7.1
9/30/2010	120	120	4.4	4.5	7.3	7.3
10/31/2010	58	58	2.9	7	7.3	7.3
11/30/2010	130	130	1	1.4	7	7
12/31/2010	59	59	1.3	2.2	6.5	6.5
1/31/2011	89	89	13	24	7	7
2/28/2011	97	97	21	25	6.9	6.9
3/31/2011	45	45	7.7	14	6.5	6.5
4/30/2011	67	67	3.2	4.9	6.2	6.2
5/31/2011	89	89	1.1	1.9	6.2	6.2
6/30/2011	160	160	1.4	2.4	7.4	7.4
7/31/2011	51	51	1	1	6.5	6.5
8/31/2011	100	100	4.1	9.1	7	7
9/30/2011	21	21	0.95	1.5	8	8
10/31/2011	45	45	1	1.8	7.5	7.5
11/30/2011	38	38	3.8	6.3	6.8	6.8
12/31/2011	40	40	0.9	1.4	7.6	7.6
1/31/2012	29	29	3	4.8	8.4	8.4
2/29/2012	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
3/31/2012	180	180	8.8	16	7.9	7.9
4/30/2012	130	130	3	4.8	7.2	7.2
5/31/2012	78	78	3.5	5.5	7.9	7.9

6/30/2012	72	72	2.1	3.4	7	7
7/31/2012	46	46	3.5	5.5	7.2	7.2
8/31/2012	77	77	4.5	5.7	7.8	7.8
9/30/2012	60	60	4.3	5.3	8.2	8.2
10/31/2012	54	54	2.4	2.5	7.5	7.5
11/30/2012	40	40	11.2	2.2	7	7
12/31/2012	29	29	1.8	2	6.9	6.9
1/31/2013	22	22	1.7	1.7	8.4	8.4
2/28/2013	27	27	1.6	2.8	6.9	6.9
3/31/2013	49	49	2.5	3.2	7.3	7.3
4/30/2013	62	62	1	1.1	8.1	8.1
5/31/2013	26	26	0.93	0.93	7.6	7.6
6/30/2013	28	28	2.4	3.3	7.1	7.1
7/31/2013	41	41	1.7	2.7	7.1	7.1
8/31/2013	76	76	0.86	1.1	7.3	7.3
9/30/2013	32	32	0.91	1.3	7.1	7.1
10/31/2013	58	58	0.47	0.47	7.5	7.5
11/30/2013	54	54	1.4	2.2	7.5	7.5
12/31/2013	18	18	2.6	3.5	7.9	7.9
1/31/2014	27	27	2.3	2.3	8.1	8.1
2/28/2014	26	26	3.7	3.7	8	8
3/31/2014	16	16	1.9	1.9	7.8	7.8
4/30/2014	24	24	0.92	1.3	7	7
5/31/2014	19	19	2.3	3.4	8.3	8.3
6/30/2014	31	31	1.4	1.9	7.6	7.6
7/31/2014	130	130	1.2	1.6	7.3	7.3
8/31/2014	71	71	2.6	4.3	8.2	8.2
9/30/2014	90	90	3.5	3.5	6.9	6.9
10/31/2014	28	28	2.3	3	7	7
11/30/2014	36	36	0.93	2	7	7
12/31/2014	46	46	1.2	1.8	6.9	6.9
1/31/2015	17	17	0.84	0.84	7.8	7.8
2/28/2015	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
3/31/2015	44	44	1.5	1.7	8.2	8.2
4/30/2015	16	16	1.9	3.1	8.4	8.4
5/31/2015	56	56	1	1.1	6.8	6.8
6/30/2015	60	60	5.5	7.6	7.4	7.4
7/31/2015	41	41	4.8	4.8	6.8	6.8
8/31/2015	54	54	3	4.3	7	7
9/30/2015	23	23	1	1	7.2	7.2
10/31/2015	30	30	2.2	3.1	7.8	7.8
11/30/2015	92	92	1.7	1.8	7.8	7.8
12/31/2015	18	18	4.5	4.5	8.2	8.2
Minimum	16	16	0.47	0.47	6.2	6.2
Maximum	260	260	21	35	8.4	8.4
Average	68	68	3	5	7	7

Outfall - Monitoring Location - Limit Set: 001T

	Alkalinity, total (as CaCO3) Mon, mg/L	Aluminum, total (as Al) Mon, mg/L	Ammonia (as N) + unionized ammonia Mon, mg/L	Cadmium, total (as Cd) Mon, mg/L	Calcium, total (as Ca) Mon, mg/L	Carbon, tot organic (TOC) Mon, mg/L	Chlorine, total residual Mon, mg/L	Chromium, total (as Cr) Mon, mg/L
Monitoring Period End Date	DAILY MX	DAILY MX	DAILY MX	DAILY MX	DAILY MX	DAILY MX	DAILY MX	DAILY MX
12/31/2007	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2008	33	0.41	0.638	0	380	33	0	0.09
9/30/2009	25	0.11	0.914	0	210	10	0	0.1952
9/30/2010	26	0	0.761	0	340	7.3	0	0.0439
9/30/2011	36	0.128	0.467	0	210	7.7	0.24	0.0975
9/30/2012	25	0.176	0	0	110	10	0	0.1362
9/30/2013	37.5	0.0476	1.08	0	220	4.18	0	0.1346
9/30/2014	40.1	0.168	0.099	0	140	6	0	0.1217
9/30/2015	58	0	2.06	0	730	8.86	0	0.0216
Minimum	25	0	0	0	110	4.18	0	0.0216
Maximum	58	0.41	2.06	0	730	33	0.24	0.1952
Average	35	0.130	0.752	0	293	11	0.03	0.1051

	Copper, total (as Cu) Mon, mg/L	Hardness, total (as CaCO3) Mon, mg/L	LC50 Static 48Hr Acute Ceriodaphnia Mon, %	LC50 Static 48Hr Acute Pimephales Mon, %	Lead, total (as Pb) Mon, mg/L	Magnesium, total (as Mg) Mon, mg/L	Nickel, total (as Ni) Mon, mg/L	Noel Static 7Day Chronic Ceriodaphnia Mon, %
Monitoring Period End Date	DAILY MX	DAILY MX	MO AV MN	MO AV MN	DAILY MX	DAILY MX	DAILY MX	MO AV MN
12/31/2007	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2008	0.047	960	Not Valid	100	0	1.2	0	Not Valid
9/30/2009	0.0555	530	57.4	100	0	0.51	0.0027	25
9/30/2010	0.153	840	76.1	100	0	0.8	0.0044	25
9/30/2011	0.0107	520	18.9	100	0	0.72	0.0029	6.25
9/30/2012	0.0128	270	100	100	0	0.42	0.0156	50
9/30/2013	0.0225	550	82	100	0	0.58	0.00332	50
9/30/2014	0.01324	350	61.6	100	0	0.48	0.00177	12.5
9/30/2015	0.011	1900	25	100	0	11.1	0.0122	12.5
Minimum	0.0107	270	18.9	100	0	0.42	0	6.25
Maximum	0.153	1900	100	100	0	11.1	0.0156	50
Average	0.0407	740	60	100	0	2	0.0054	26

	Noel Static 7Day Chronic Pimephales Mon, %	Oxygen, dissolved (DO) Mon, mg/L	Solids, total Mon, mg/L	Specific conductance Mon, umho/cm	Zinc, total (as Zn) Mon, mg/L	pH Mon, SU
Monitoring Period End Date	MO AV MN	DAILY MX	DAILY MX	DAILY MX	DAILY MX	DAILY MX
12/31/2007	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9	NODI: 9
9/30/2008	100	9.8	3700	6400	0.099	7.6
9/30/2009	100	7.8	1200	2000	0.0188	7
9/30/2010	100	7.1	2500	4100	0.099	6.4
9/30/2011	100	9.9	920	1600	0.0186	7.3
9/30/2012	100	9.2	810	1300	0.018	6.8
9/30/2013	100	7.8	1200	1900	0.00616	7.5
9/30/2014	100	7.2	760	1100	0.00714	7.7
9/30/2015	100	5.8	3300	5600	0.0073	7.4
Minimum	100	5.8	760	1100	0.00616	6.4
Maximum	100	9.9	3700	6400	0.099	7.7
Average	100	8	1799	3000	0.0343	7.2

Outfall - Monitoring Location - Limit Set: 001A - Receiving Water

Monitoring Period End Date	Hardness, total (as CaCO3) Mon, mg/L	Monitoring Period End Date	Hardness, total (as CaCO3) Mon, mg/L
	DAILY MX		DAILY MX
10/31/2007	150	1/31/2012	270
11/30/2007	480	2/29/2012	NODI: C
12/31/2007	130	3/31/2012	250
1/31/2008	140	4/30/2012	180
2/29/2008	260	5/31/2012	160
3/31/2008	210	6/30/2012	160
4/30/2008	100	7/31/2012	160
5/31/2008	150	8/31/2012	74
6/30/2008	120	9/30/2012	130
7/31/2008	130	10/31/2012	140
8/31/2008	160	11/30/2012	200
9/30/2008	170	12/31/2012	480
10/31/2008	150	1/31/2013	240
11/30/2008	120	2/28/2013	120
12/31/2008	180	3/31/2013	170
1/31/2009	230	4/30/2013	250
2/28/2009	240	5/31/2013	180
3/31/2009	250	6/30/2013	51
4/30/2009	160	7/31/2013	180
5/31/2009	140	8/31/2013	130
6/30/2009	37	9/30/2013	180
7/31/2009	110	10/31/2013	200
8/31/2009	110	11/30/2013	110
9/30/2009	150	12/31/2013	140
10/31/2009	170	1/31/2014	210
11/30/2009	140	2/28/2014	130
12/31/2009	67	3/31/2014	150
1/31/2010	160	4/30/2014	59
2/28/2010	240	5/31/2014	53
3/31/2010	280	6/30/2014	120
4/30/2010	480	7/31/2014	160
5/31/2010	230	8/31/2014	140
6/30/2010	55	9/30/2014	180
7/31/2010	180	10/31/2014	93
8/31/2010	150	11/30/2014	160
9/30/2010	150	12/31/2014	52
10/31/2010	160	1/31/2015	260
11/30/2010	100	2/28/2015	NODI: C
12/31/2010	150	3/31/2015	310
1/31/2011	220	4/30/2015	260
2/28/2011	310	5/31/2015	220
3/31/2011	100	6/30/2015	53
4/30/2011	190	7/31/2015	170
5/31/2011	60	8/31/2015	220
6/30/2011	200	9/30/2015	97
7/31/2011	93	10/31/2015	110
8/31/2011	180	11/30/2015	210
9/30/2011	130	12/31/2015	260
10/31/2011	250	Minimum	37
11/30/2011	230	Maximum	480
12/31/2011	280	Average	174

Outfall - Monitoring Location - Limit Set: 002A

Oil & grease

Monitoring Period End	Mon, mg/L	Mon, mg/L
Date	DAILY MX	MO AVG
12/31/2007	0	0
3/31/2008	0	0
6/30/2008	0	0
9/30/2008	4.6	4.6
12/31/2008	0	0
3/31/2009	0	0
6/30/2009	0	0
9/30/2009	0	0
12/31/2009	0	0
3/31/2010	0	0
6/30/2010	0	0
9/30/2010	0	0
12/31/2010	0	0
3/31/2011	0	0
6/30/2011	0	0
9/30/2011	0	0
12/31/2011	0	0
3/31/2012	0	0
6/30/2012	0	0
9/30/2012	0	0
12/31/2012	0	0
3/31/2013	0	0
6/30/2013	0	0
9/30/2013	0	0
12/31/2013	0	0
3/31/2014	0	0
6/30/2014	0	0
9/30/2014	0	0
12/31/2014	0	0
3/31/2015	0	0
6/30/2015	0	0
9/30/2015	0	0
12/31/2015	0	0
Minimum	0	0
Maximum	4.6	4.6
Average	0.139	0.139

DMR No Data Indicator (NODI) Codes

C: No discharge

9: Conditional monitoring – not required this period

E: Analysis not conducted – no sample

B: Below detection limit/no detection

Attachment F: WET Reasonable Potential Calculation

Massachusetts policy-based WET limit derivation protocol

Dilution Factor for facility: 1 (no assumed dilution)

In order to assure that this limit is met within a short distance of the effluent pipe MassDEP has established an end-of-pipe limit of 1.0 TU ($LC_{50} = 100\%$) for dilution factors less than or equal to 100 (Boston Sand & Gravel's discharge to the Unnamed Tributary offers no dilution, i.e. a dilution factor of 1). However, at dilution factors less than 10, the Unnamed Tributary is considered water quality limited in that the effluent limit of 1.0 TU may not be stringent enough to protect receiving waters. MassDEP requires both acute and chronic end points to be reported.

Two limits apply to the effluent when the dilution factor is less than 10: (1) the chronic WET test should result in a No Observed Effect Concentration greater than or equal to the Receiving Water Concentration ($NOEC \geq RWC$) and (2) the acute level should be less than or equal to 1.0 TU (an $LC_{50} \geq 100\%$). Because the Dilution Factor is 1, this requires $NOEC \geq 100\%$, or a TU of less than or equal to 1.0.

$\frac{100}{NOEC \text{ or } LC_{50}}$ = Toxic Units or TU

Facility WET Test Data for the Daphnid

Monitoring Period End Date	WET Test Date	Species	LC50 Static 48Hr Acute Ceriodaphnia, modified (%)	TU, acute	Noel Static 7Day Chronic Ceriodaphnia (%)	TU, chronic
12/31/2007	N/A	<i>Ceriodaphnia dubia</i>	N/A	N/A	N/A	N/A
9/30/2008	12/17/2007	<i>Ceriodaphnia dubia</i>	Not valid*	N/A	Not valid*	N/A
9/30/2009	11/17/2008	<i>Ceriodaphnia dubia</i>	57.4	1.74	25	4
9/30/2010	12/14/2009	<i>Ceriodaphnia dubia</i>	76	1.32	25	4
9/30/2011	10/25/2010	<i>Ceriodaphnia dubia</i>	18.9	5.29	6.25	16
9/30/2012	11/15/2011	<i>Ceriodaphnia dubia</i>	100	1	50	2
9/30/2013	10/2/2013	<i>Ceriodaphnia dubia</i>	82	1.22	50	2
9/30/2014	10/28/2014	<i>Ceriodaphnia dubia</i>	61.6	1.62	12.5	8
9/30/2015	6/2/2015	<i>Ceriodaphnia dubia</i>	25	4	12.5	8

*Result was invalid because survival of *C.dubia* exposed to the ambient river water (which was used as the diluent in the test) was 0% at 24 hours.

Daphnid chronic toxic - (TU Lognormal distribution assumed)**Estimated Daily Maximum Effluent Concentration**

k = number of daily samples =	7
Max Concentration	16
cv(x)= Coefficient of Variation* =	0.6
99th percentile multiplication factor**	3.6
95th percentile multiplication factor**	2

Daily Max Estimate = Max*99th percentile multiplication factor**

Estimated Daily Max 99th percentile =	57.6	TU,chronic
Estimated Daily Max including Dilution Factor =	57.6	TU,chronic

Daily Max Estimate = Max*95th percentile multiplication factor**

Estimated Daily Max 95th Percentile =	32.0	TU,chronic
Estimated Daily Max including Dilution Factor =	32.0	TU,chronic

Daphnid acute toxicity - (TU Lognormal distribution assumed)**Estimated Daily Maximum Effluent Concentration**

k = number of daily samples =	7
Max Concentration	5.29
cv(x)= Coefficient of Variation* =	0.6
99th percentile multiplication factor**	3.6
95th percentile multiplication factor**	2

Daily Max Estimate = Max*99th percentile multiplication factor**

Estimated Daily Max 99th percentile =	19.0	TU,acute
Estimated Daily Max including Dilution Factor =	19.0	TU,acute

Daily Max Estimate = Max*95th percentile multiplication factor**

Estimated Daily Max 95th Percentile =	10.6	TU,acute
Estimated Daily Max including Dilution Factor =	10.6	TU,acute

*Conservative estimate of CV. See box 3-2 in Technical Support Document for Water Quality Based Toxics Control

**Multiplication factors from Table 3-1 and Table 3-2 in Technical Support Document for Water Quality Based Toxics Control.

The 95th percentiles for daphnid chronic (32 TU) and acute toxicity (10.6 TU) are both higher than 1 and a WET limit is required.

Attachment G: EFH list

The following is a list of the EFH species and applicable lifestage(s) for the area that includes inner Boston Harbor:

Species	Eggs	Larvae	Juveniles	Adults
Atlantic cod (<i>Gadus morhua</i>)	X	X	X	X
haddock (<i>Melanogrammus aeglefinus</i>)	X	X		
pollock (<i>Pollachius virens</i>)	X	X	X	X
silver hake (<i>Merluccius bilinearis</i>)	X	X	X	X
red hake (<i>Urophycis chuss</i>)	X	X	X	X
white hake (<i>Urophycis tenuis</i>)	X	X	X	X
winter flounder (<i>Pseudopleuronectes americanus</i>)	X	X	X	X
yellowtail flounder (<i>Pleuronectes ferruginea</i>)	X	X	X	X
windowpane flounder (<i>Scopthalmus aquosus</i>)	X	X	X	X
American plaice (<i>Hippoglossoides platessoides</i>)	X	X	X	X
ocean pout (<i>Macrozoarces americanus</i>)	X	X	X	X
Atlantic halibut (<i>Hippoglossus hippoglossus</i>)	X	X	X	X
Atlantic herring (<i>Clupea harengus</i>)		X	X	X
white shark (<i>Carcharodon carcharias</i>)	X	X	X	X
Atlantic butterfish (<i>Peprilus triacanthus</i>)	X	X	X	X
Atlantic mackerel (<i>Scomber scombrus</i>)	X	X	X	X
Atlantic wolffish (<i>Anarhichas lupus</i>)	X	X	X	X
bluefish (<i>Pomatomus saltatrix</i>)	X	X	X	X
black sea bass (<i>Centropristus striata</i>)	n/a		X	X
little skate (<i>Leucoraja erinacea</i>)	n/a	n/a	X	X
bluefin tuna (<i>Thunnus thynnus</i>)			X	X

Source: NOAA Habitat Conservation EFH Mapper Website:
<http://www.habitat.noaa.gov/protection/efh/efhmapper/index.html>.

MASSACHUSETTS DEPARTMENT OF
ENVIRONMENTAL PROTECTION
COMMONWEALTH OF MASSACHUSETTS
1 WINTER STREET
BOSTON, MASSACHUSETTS 02108

UNITED STATES ENVIRONMENTAL
PROTECTION AGENCY – REGION 1
OFFICE OF ECOSYSTEM PROTECTION
5 POST OFFICE SQUARE
BOSTON, MASSACHUSETTS 02109

JOINT PUBLIC NOTICE OF A DRAFT NATIONAL POLLUTANT DISCHARGE
ELIMINATION SYSTEM (NPDES) PERMIT TO DISCHARGE INTO WATERS OF THE
UNITED STATES UNDER SECTIONS 301 AND 402 OF THE CLEAN WATER ACT, AS
AMENDED, AND SECTIONS 27 AND 43 OF THE MASSACHUSETTS CLEAN WATERS
ACT, AS AMENDED, AND REQUEST FOR STATE CERTIFICATION UNDER SECTION
401 OF THE CLEAN WATER ACT.

DATE OF NOTICE: August 1, 2017 – August 30, 2017

PERMIT NUMBER: **MA0000531**

PUBLIC NOTICE NUMBER: MA-006-2017

NAME AND MAILING ADDRESS OF APPLICANT:

Boston Sand & Gravel Company
100 N. Washington Street, 2nd Floor
Boston, MA 02114

NAME AND ADDRESS OF THE FACILITY WHERE DISCHARGE OCCURS:

Boston Sand & Gravel Company
500 Front Street
Charlestown, MA 02129

RECEIVING WATER: Unnamed Tributary to the Charles River (“Millers River”, Outfall 001)

The U.S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) have cooperated in the development of a draft permit for Boston Sand & Gravel’s Charlestown facility, which discharges commingled process water and stormwater. The effluent limits and permit conditions imposed have been drafted to assure compliance with the Clean Water Act, 33 U.S.C. sections 1251 et seq., the Massachusetts Clean Waters Act, G.L. c. 21, §§ 26-53, 314 CMR 3.00, and State Surface Water Quality Standards at 314 CMR 4.00. EPA has requested that the State certify this draft permit pursuant to Section 401 of the Clean Water Act and expects that the draft permit will be certified.

INFORMATION ABOUT THE DRAFT PERMIT:

The draft permit and explanatory fact sheet may be obtained at no cost at http://www.epa.gov/region1/npdes/draft_permits_listing_ma.html or by contacting:

Undine Kipka
U.S. Environmental Protection Agency – Region 1
5 Post Office Square, Suite 100 (OEP06-1)
Boston, MA 02109-3912
Telephone: (617) 918-1335
kipka.undine@epa.gov

The administrative record containing all documents relating to this draft permit including all data submitted by the applicant may be inspected at the EPA Boston office mentioned above between 9:00 a.m. and 5:00 p.m., Monday through Friday, except holidays.

PUBLIC COMMENT AND REQUEST FOR PUBLIC HEARING:

All persons, including applicants, who believe any condition of this draft permit is inappropriate, must raise all issues and submit all available arguments and all supporting material for their arguments in full by August 30, 2017, to the address or email address listed above. Any person, prior to such date, may submit a request in writing to EPA and MassDEP for a public hearing to consider this draft permit. Such requests shall state the nature of the issues proposed to be raised in the hearing. A public hearing may be held after at least thirty days public notice whenever the Regional Administrator finds that response to this notice indicates significant public interest. In reaching a final decision on this draft permit, the Regional Administrator will respond to all significant comments and make the responses available to the public at EPA's Boston office.

FINAL PERMIT DECISION:

Following the close of the comment period, and after a public hearing, if such hearing is held, the Regional Administrator will issue a final permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice.

DOUGLAS E. FINE
ASSISTANT COMMISSIONER
BUREAU OF WATER RESOURCES
MASSACHUSETTS DEPARTMENT
OF ENVIRONMENTAL PROTECTION

ARTHUR V. JOHNSON III
ACTING DIRECTOR
OFFICE OF ECOSYSTEM PROTECTION
EPA REGION 1