## AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA"), and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

Town of Erving Board of Selectmen Erving, MA 01344

is authorized to discharge from a facility located at

Erving POTW #2
Erving Center Wastewater Treatment Plant
Route 2
Erving, MA

to a receiving waters named

#### Millers River (MA35-05)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective December 1, 2008.

This permit and the authorization to discharge expire five (5) years from the effective date.

This permit supersedes the permit issued on May 11, 2004 and expired September 30, 2007.

This permit consists of 16 pages in Part I including effluent limitations, monitoring requirements, Attachment A (Freshwater Chronic, Modified Acute WET Protocol), Attachment B (Pretreatment Reassessment Form), Attachment C (Pretreatment Annual Report), Attachment D (Summary of Required Report Submittals) and 25 pages in Part II including General Conditions and Definitions.

Signed this 29<sup>th</sup> day of September, 2008

#### /S/ SIGNATURE ON FILE

Director Office of Ecosystem Protection Environmental Protection Agency Boston, MA Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

#### **PART I**

A.1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge treated effluent from outfall serial number **001** to the Millers River. Such discharge shall be limited and monitored by the permittee as specified below.

EFFLUENT CHARACTERISTIC		EFFLUENT LIMITS						REQUIREMENTS
		Mass Limits Concentration Limits						
PARAMETER	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE <sup>3</sup>
FLOW 1	***	***	***	2.70 MGD	***	Report MGD	CONTINUOUS	RECORDER
FLOW <sup>1</sup>	***	***	***	Report MGD	***	***	CONTINUOUS	RECORDER
BOD <sub>5</sub> <sup>2</sup> (November 1 – March 31)	1700 lbs/Day	***	3400 lbs/Day	Report mg/l	***	Report mg/l	3/WEEK	24-HOUR COMPOSITE
BOD <sub>5</sub> <sup>2</sup> (April 1 – October 31)	900 lbs/Day	***	1800 lbs/Day	Report mg/l	***	Report mg/l	3/WEEK	24-HOUR COMPOSITE
TSS <sup>2</sup> (November 1 – March 31)	2350 lbs/Day	***	4700 lbs/Day	Report mg/l	***	Report mg/l	3/WEEK	24-HOUR COMPOSITE
TSS <sup>2</sup> (April 1 – October 31)	900 lbs/Day	***	1800 lbs/Day	Report mg/l	***	Report mg/l	3/WEEK	24-HOUR COMPOSITE
pH RANGE <sup>4,5</sup>	6.5 - 8.3 SU SE	E PERMIT PAGE	7 OF 16, PARAG	RAPH I.A.2.b.			1/DAY	GRAB
FECAL COLIFORM <sup>4,5</sup> April 1- October 31)	***	***	***	200 cfu/100 ml	***	400 cfu/100 ml	2/WEEK	GRAB
E- coli <sup>· 4,5</sup> (April 1- October 31)	***	***	***	126 cfu/100 ml	***	409 cfu/100 ml	2/WEEK	GRAB
CHLORINE, TOTAL RESIDUAL <sup>6</sup> (April 1- October 31)	***	***	***	0.12 mg/l	***	0.21 mg/l	1/DAY (when in use)	GRAB

#### Part I Continued

PARAMETER	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE <sup>3</sup>
TOTAL COPPER	Report lbs/Day	***	Report lbs/Day	32 ug/l	***	43 ug/l	1/WEEK	24-HOUR COMPOSITE
TOTAL NITROGEN 7	Report lbs/Day	***	Report lbs/Day	Report mg/l	***	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL NITRITE + NITRATE	Report lbs/Day	***	Report lbs/Day	Report mg/l	***	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL KJELDAHL NITROGEN	Report lbs/Day	***	Report lbs/Day	Report mg/l	***	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL AMMONIA AS N	Report lbs/Day	***	Report lbs/Day	Report mg/l	***	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL PHOPHORUS Seasonal April 1-October 31	***	***	***	0.65 mg/l	***	Report mg/l	1/WEEK	24-HOUR COMPOSITE
WHOLE EFFLUENT TOXICITY <sup>8,9,10</sup>	ACUTE LC <sub>50</sub> $\geq$ 100% CHRONIC C-NOEC $\geq$ 9%					4/YEAR	24-HOUR COMPOSITE	

#### Footnotes:

- 1. Report annual average, monthly average, and the maximum daily flow. The limit is an annual average, which shall be reported as a rolling average. The value will be calculated as the arithmetic mean of the monthly average flow for the reporting month and the monthly average flows of the previous eleven months.
- 2. Sampling required for influent and effluent.
- 3. A routine sampling program shall be developed in which samples are taken at the same location, same time and same days of the week each month. Occasional deviations from the routine sampling program are allowed, but the reason for the deviation shall be documented in correspondence appended to the applicable discharge monitoring report.

All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136. All samples shall be 24 hour composites unless specified as a grab sample in 40 CFR §136.

All required effluent samples shall be collected at the point specified herein. Any change					
in sampling location must be reviewed and approved in writing by EPA and MassDEP					
SAMPLE LOCATION					
Recorder in the Parshall Flume					
Manhole after the chlorine contact chamber					
Manhole after the chlorine contact chamber					
last cell of each chlorine contact chamber					
WET Dilution water:					
Millers River Upstream of outfall					
Influent line at Parshall Flume					

24-hour composite samples will consist of at least twenty four (24) grab samples taken during one consecutive 24 hour period, either collected at equal intervals and combined proportional to flow or continuously collected proportionally to flow.

4. Required for State Certification.

5. The fecal coliform limits and monitoring requirements shall end one year after the effective date of this permit.

The Permittee shall monitor for *E. coli* (without limits) for one year from the effective date of the permit. The *E. coli* limits shall go into effect one year after the effective date of this permit.

The average monthly limits for fecal coliform and *E. coli* are expressed as geometric means. Fecal coliform sampling and *E. coli* sampling shall be done concurrently. A total residual chlorine sample (when in use) shall be taken at the same time as *E. coli* and fecal coliform samples.

- 6. Whenever more than one total residual chlorine grab sample is taken per day, the monthly DMR shall include an attachment documenting the individual grab sample results for that day, including the date and time of each sample, and a summary of any operational modifications implemented in response to sample results. All test results shall be used in the calculation and reporting of the monthly average and maximum daily data submitted on the DMR.
- 7. The permittee shall include with the monthly Discharge Monitoring Report, the quantity and form of nitrogen and phosphorus added to the treatment system.
- 8. The permittee shall conduct acute and chronic (modified acute) toxicity tests four (4) times per year using a single species, the daphid, <u>Ceriodaphnia dubia</u>. Toxicity test samples shall be collected during the months specified below. The test results shall be submitted by the last day of the month following the completion of the testes. The permittee shall sample during the same weeks of: January, April, July, and October each year. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Dates	Submit Results By:	Test Species	LC <sub>50</sub> C-NOEC
January	February 28 <sup>th</sup>	Ceriodaphnia dubia	≥ 100%
April	May 31 <sup>st</sup>	(Daphnid)	≥ 9%
July	August 31 <sup>st</sup>	See Attachment A	
October	November 30th	See Attachment A	

After a minimum of four complete and consecutive WET tests, all of which must be valid and demonstrate compliance with the permit limits for whole effluent toxicity, the permittee may submit a written request to the EPA seeking a review of the toxicity test results. If the results of these tests are consistently negative during a one year period, the monitoring frequency and testing may be reduced to not less than one per year by a certified letter from the EPA.

- 9. The  $LC_{50}$  is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent shall cause no more than a 50% mortality rate.
  - C-NOEC (chronic-no observed effect concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life cycle or partial life cycle test which causes no adverse effect on growth, survival, or reproduction at a specific time of observation as determined from hypothesis testing where the test results exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, the permittee must report the lowest concentration where there is no observable effect. The "9% or greater" limit is defined as a sample which is composed of 9% (or greater) effluent, the remainder being dilution water. This is a maximum daily limit derived as a percentage of the inverse of the dilution factor of 11.2.
- 10. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall follow procedures outlined in **Attachment A**, **Section IV**, **DILUTION WATER** in order to obtain permission to use alternate dilution water. In lieu of individual approvals for alternate dilution water required in **Attachment A**, EPANew England has developed a <u>Self-Implementing Alternative Dilution Water Guidance</u> document (called "Guidance Document") which may be used to obtain automatic approval of alternate dilution water, including the appropriate species for use with that water. If this Guidance document is revoked, the permittee shall revert to obtaining approval as outlined in **Attachment A**.

The "Guidance Document" has been sent to all permittees with their annual set of DMRs and Revised Updated Instructions for Completing EPA's Pre-Printed NPDES

Discharge Monitoring Report (DMR) Form 3320-1 and is not intended as a direct attachment to this permit. Any modification or revocation to this "Guidance Document" will be transmitted to the permittees as part of the annual DMR instruction package. However, at any time, the permittee may choose to contact EPA-New England directly using the approach outlined in **Attachment A**.

#### Part I.A.2.

- a. The discharge shall not cause a violation of the water quality standards of the receiving waters.
- b. The pH of the effluent shall not be less than 6.5 nor greater than 8.3 at any time.
- c. The discharge shall not cause objectionable discoloration of the receiving waters.
- d. The effluent shall contain neither visible oil sheen, foam, nor floating solids at any time.
- e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values.
- f. The results of sampling for any parameter done in accordance with EPA approved methods above its required frequency must also be reported.
- g. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.
- h. If the average annual flow in any calendar year exceeds 80% of the facility's design flow, the permittee shall submit a report to MassDEP by March 31 of the following calendar year describing plans for further flow increases and discuss how the permittee will remain in compliance with the effluent limitations in the permit.
- 3. All POTWs must provide adequate notice to the Director of the following:
  - a. Any new introduction of pollutants into that POTW from an indirect discharger in a primary industry category discharging process water; and
  - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
  - c. For purposes of this paragraph, adequate notice shall include information on:
    - (1) the quantity and quality of effluent introduced into the POTW; and

- (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- 4. Prohibitions Concerning Interference and Pass Through:
  - a. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.

#### 5. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.
- 6. Numerical Effluent Limitations for Toxicants

EPA or MassDEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

#### PART B. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from the outfall listed in Part I.A.1. of this permit. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e.(1) of the General Requirements of this permit (Twenty-four hour reporting).

[Note: SSO Reporting Form (which includes MassDEP Regional Office telephone numbers) for submittal of written report to MassDEP is available on-line at http://www.mass.gov/dep/water/approvals/surffms.htm#sso.]

#### PART C. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

#### 1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

#### 2. Preventative Maintenance Program

The permittee shall maintain an ongoing preventative maintenance program to prevent overflows and bypasses caused by malfunctions or failures of the sewer system infrastructure. The program shall include an inspection program designed to identify all potential and actual unauthorized discharges.

#### 3. Infiltration/Inflow Control Plan:

The permittee shall implement a plan to control infiltration and inflow (I/I) to the separate sewer system. The updated plan shall be submitted to EPA and MassDEP within six (6) months of the effective date of this permit (see page 1 of this permit for the effective date) and shall describe the permittee's program for preventing infiltration/inflow related effluent limit violations, and all unauthorized discharges of wastewater, including overflows and by-passes due to excessive infiltration/inflow.

#### The plan shall include:

- An ongoing program to identify and remove sources of infiltration and inflow.
   The program shall include the necessary funding level and the source(s) of funding.
- An inflow identification and control program that focuses on the disconnection and redirection of illegal sump pumps and roof down spouts. Priority should be given to removal of public and private inflow sources that are upstream from, and potentially contribute to, known areas of sewer system backups and/or overflows.
- Identification and prioritization of areas that will provide increased aquifer recharge as the result of reduction/elimination of infiltration and inflow to the system.

• An educational public outreach program for all aspects of I/I control, particularly private inflow.

#### Reporting Requirements:

A summary report of all actions taken to minimize I/I during the previous calendar year shall be submitted to EPA and the MassDEP annually, **by** March 31. The summary report shall, at a minimum, include:

- A map and a description of inspection and maintenance activities conducted and corrective actions taken during the previous year.
- Expenditures for any infiltration/inflow related maintenance activities and corrective actions taken during the previous year.
- A map with areas identified for I/I-related investigation/action in the coming year.
- A calculation of the annual average I/I, the maximum month I/I for the reporting year.
- A report of any infiltration/inflow related corrective actions taken as a result of unauthorized discharges reported pursuant to 314 CMR 3.19(20) and reported pursuant to the <u>Unauthorized Discharges</u> section of this permit.

#### 4. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §403.3(o))

#### PART D. INDUSTRIAL PRETREATMENT PROGRAM

#### 1. Limitations for Industrial Users

The permittee shall develop and enforce specific effluent limits (local limits) for Industrial User(s), and all other users, as appropriate, which together with appropriate changes in the POTW Treatment Plant's Facilities or operation, are necessary to ensure continued compliance with the POTW's NPDES permit or sludge use or disposal practices. Specific local limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond.

Within 120 days of the effective date of this permit, the permittee shall prepare and submit a written technical evaluation to the EPA analyzing the need to revise local limits. As part of this

evaluation, the permittee shall assess how the POTW performs with respect to influent and effluent of pollutants, water quality concerns, sludge quality, sludge processing concerns/inhibition, biomonitoring results, activated sludge inhibition, worker health and safety and collection system concerns.

In preparing this evaluation, the permittee shall complete and submit the attached form (Attachment B) with the technical evaluation to assist in determining whether existing local limits need to be revised. Justifications and conclusions should be based on actual plant data if available and should be included in the report. Should the evaluation reveal the need to revise local limits, the permittee shall complete the revisions within 120 days of notification by EPA and submit the revisions to EPA for approval. The Permittee shall carry out the local limits revisions in accordance with EPA's Local Limit Development Guidance (July 2004).

#### 2. Industrial Pretreatment Program

The permittee shall implement the Industrial Pretreatment Program in accordance with the legal authorities, policies, procedures, and financial provisions described in the permittee's approved Pretreatment Program, and the General Pretreatment Regulations, 40 CFR 403. At a minimum, the permittee must perform the following duties to properly implement the Industrial Pretreatment Program (IPP):

- a. Carry out inspection, surveillance, and monitoring procedures which will determine independent of information supplied by the industrial user, whether the industrial user is in compliance with the Pretreatment Standards. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP but in no case less than once per year. Adequate records of these actions shall be maintained.
- b. Issue or renew all necessary industrial user control mechanisms within 90 days of their expiration date or within 180 days after the industry has been determined to be a significant industrial user.
- c. Obtain appropriate remedies for noncompliance by any industrial user with any pretreatment standard and/or requirement.
- d. Maintain an adequate revenue structure for continued implementation of the Pretreatment Program.
- 3. The permittee shall provide the EPA and MassDEP with an annual report describing the permittee's pretreatment program activities for the twelve month period ending 60 days prior to the due date in accordance with 40 CFR 403.12(i). The annual report shall be consistent with the format described in Attachment C of this permit and shall be submitted no later than March 1 of each year.

- 4. The permittee must obtain approval from EPA prior to making any significant changes to the industrial pretreatment program in accordance with 40 CFR 403.18(c).
- 5. The permittee must assure that applicable National Categorical Pretreatment Standards are met by all categorical industrial users of the POTW. These standards are published in the Federal Regulations at 40 CFR 405 et. seq.
- 6. The permittee must modify its pretreatment program, if applicable, to conform to all changes in the Federal Regulations that pertain to the implementation and enforcement of the industrial pretreatment program. The permittee must provide EPA, in writing, within 180 days of this permit's effective date proposed changes, if applicable, to the permittee's pretreatment program deemed necessary to assure conformity with current Federal Regulations.

At a minimum, the permittee must address in its written submission the following areas: (1) proposed changes to the enforcement response plan and (2) recent revisions to the sewer use ordinances. The permittee will implement these proposed changes pending EPA Region I's approval under 40 CFR 403.18. This submission is separate and distinct from any local limits analysis submission described in Part I.D.1.

- 7. On October 14, 2005 EPA published in the Federal Register final changes to the General Pretreatment Regulations. The final "Pretreatment Streamlining Rule" is designed to reduce the burden to industrial users and provide regulatory flexibility in technical and administrative requirements of industrial users and POTWs.
  - Within 90 days of the effective date of this permit, the permittee must submit to EPA all required modifications of the Streamlining Rule in order to be consistent with the provisions of the newly promulgated Rule. To the extent that the POTW legal authority is not consistent with the required changes, they must be revised and submitted to EPA for review.
- 8. EPA conducted a pretreatment audit in August 2006 and all deficiencies were identified in a March 2007 letter. However, the POTW has not responded to those comments. Therefore, within 30 days, the POTW must submit a response to EPA's March 2007 Pretreatment Audit Findings letter.

#### PART E. SLUDGE CONDITIONS

- 1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
- 2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
- 3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices:
  - a. Land application the use of sewage sludge to condition or fertilize the soil
  - b. Surface disposal the placement of sewage sludge in a sludge-only landfill
  - c. Sewage sludge incineration in a sludge-only incinerator
- 4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (e.g. lagoons, reed beds), or are otherwise excluded under 40 CFR 503.6.
- 5. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements:
  - General requirements
  - Pollutant limitations
  - Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
  - Management practices
  - Record keeping
  - Monitoring
  - Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year:

 Less than 290
 1/ year

 290 to less than 1500
 1 /quarter

 1500 to less than 15000
 6 /year

 15000 +
 1 /month

- 7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR §503.8.
- 8. The permittee shall submit an annual report containing the information specified in the guidance by **February 19.** Reports shall be submitted to the address contained in the reporting section of the permit. Sludge monitoring is not required by the permittee when the permittee is not responsible for the ultimate sludge disposal. The permittee must be assured that any third party contractor is in compliance with appropriate regulatory requirements. In such case, the permittee is required only to submit an annual report by February 19 containing the following information:
  - Name and address of contractor responsible for sludge disposal
  - Quantity of sludge in dry metric tons removed from the facility by the sludge contractor

#### PART F. SPECIAL CONDITION

Within **one year of the effective date of the permit**, the permittee shall complete an evaluation of alternative methods of operating the existing wastewater treatment facility to optimize the removal of nitrogen, and submit a report to EPA and MassDEP documenting this evaluation and presenting a description of recommended operational changes. The permittee shall implement the recommended operational changes in order to maintain the existing mass discharge loading of total nitrogen. Existing mass loadings will be based on the levels monitored by the facility over the first year of the permit term.

The permittee shall also submit an annual report to EPA and MassDEP, **by February 1 each year**, that summarizes activities related to optimizing nitrogen removal efficiencies, documents the annual nitrogen discharge load from the facility, and tracks trends relative to the previous year.

#### PART G. MONITORING AND REPORTING

#### 1. Reporting

Monitoring results obtained during each calendar month shall be summarized and reported on Discharge Monitoring Report Form(s) postmarked no later than the **15th day of the following month.** 

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency Water Technical Unit (SEW) P.O. Box 8127 Boston, Massachusetts 02114

The State Agencies are:

Massachusetts Department of Environmental Protection Western Regional Office - Bureau of Resource Protection 436 Dwight Street Springfield, Massachusetts 01103

and

Massachusetts Department of Environmental Protection Division of Watershed Management Surface Water Discharge Permit Program 627 Main Street, 2nd Floor Worcester, Massachusetts 01608

Any Pretreatment reports required to be submitted in Section D, "Local Limits and Industrial Pretreatment Program" shall be sent to EPA and the State at:

EPA New England Attn: Justin Pimpare One Congress Street Suite 1100 – CMU Boston, MA 02114

Massachusetts Department of Environmental Protection Bureau of Waste Prevention- Industrial Wastewater Section 1 Winter Street Boston, MA 02108

#### PART H. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MassDEP pursuant to M.G.L. Chap. 21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this permit is declared invalid, illegal or otherwise issued in violation of Federal law, this permit shall remain in full force and effect under State law as a permit issued by the Commonwealth of Massachusetts.

# PERMIT ATTACHMENT B REASSESSMENT OF TECHNICALLY BASED LOCAL LIMITS (TBLLs)

POTW Name & Address:							
NPDES PERMIT # :							
Date EPA approved current	TBLLs :						
Date EPA approved current	Sewer Use Ordinance :						
	ITEM I.						
In Column (1) list the condit calculated. In Column (2), POTW.							
	Column (1) EXISTING TBLLs	Column (2) PRESENT CONDITIONS					
POTW Flow (MGD)							
Dilution Ratio or 7Q10 (from NPDES Permit)							
SIU Flow (MGD)							
Safety Factor		N/A					
Biosolids Disposal							

### ITEM II.

	EXISTING TBLLs							
POLLUTANT	NUMERICAL LIMIT (mg/l) or (lb/day)	POLLUTANT	NUMERICAL LIMIT (mg/l) or (lb/day)					

#### ITEM III.

Note how your existing TBLLs, listed in Item II., are allocated to your Significant Industrial Users (SIUs), i.e. uniform concentration, contributory flow, mass proportioning, other. Please specify by circling.

#### ITEM IV.

Has your POT	W experienced a	iny upsets,	inhibition,	interference	or pass-through	from
industrial sourc	es since your ex	sting TBLL	s were cal	culated?		


If yes, explain.

If yes, explain.	
Has your POTW violated any of its NPDES permit limits and/or toxicity test requirement	s?

Using current POTW influent sampling data fill in Column (1). In Column (2), list your Maximum Allowable Industrial Headwork Loading (MAIHL) values used to derive your TBLLs listed in Item II. In addition, please note the Environmental Criteria for which each MAIHL value was established, i.e. water quality, sludge, NPDES etc.

ITEM V.

each MAITE value was established, i.e. water quality, sludge, NPDES etc.					
Pollutant	Column (1) Influent Data And Maximum (lb/day)	alyses Average (lb/day)	Column (2) MAHL Values (lb/day)	Criteria	
Arsenic					
Cadmium					
Chromium					
Copper					
Cyanide					
Lead					
Mercury					
Nickel					
Silver					
Zinc					
Other (List)					

#### ITEM VI.

Using current POTW effluent sampling data, fill in Column (1). In Column (2A) list what the Water Quality Standards (Gold Book Criteria) were at the time your existing TBLLs were developed. List in Column (2B) current Gold Book values multiplied by the dilution ratio used in your new/reissued NPDES permit.

Pollutant	utant Column (1)		Columns (2A) (2B)		
	Effluent Da Maximum (ug/l)	ta Analyses Average (ug/l)	Water Qua (Gold From TBLLs (ug/l)	lity Criteria Book) Today (ug/l)	
Arsenic					
*Cadmium					
*Chromium					
*Copper					
Cyanide					
*Lead					
Mercury					
*Nickel					
Silver					
*Zinc					
Other (List)					

<sup>\*</sup>Hardness Dependent (mg/l - CaCO3)

### ITEM VII.

In Column (1), identify all pollutants limited in your new/reissued NPDES permit. In Column (2), identify all pollutants that were limited in your old/expired NPDES permit.

Column (2), Idonary an pointainto triat word infinited in your claroxpriod in BEO pointin.					
NEW F Pollutants	mn (1) PERMIT Limitations g/l)	Column (2) OLD PERMIT Pollutants Limitations (ug/l)			

#### ITEM VIII.

Using current POTW biosolids data, fill in Column (1). In Column (2A), list the biosolids criteria that was used at the time your existing TBLLs were calculated. If your POTW is planing on managing its biosolids differently, list in Column (2B) what your new biosolids criteria would be and method of disposal.

Column (1) Pollutant Biosolids Data Analyses  Average (mg/kg)		(2A)	umns (2B) Is Criteria New (mg/kg)
Arsenic		, o o,	
Cadmium			
Chromium			
Copper			
Cyanide			
Lead			
Mercury			
Nickel			
Silver			
Zinc			
Molybdenum			
Selenium			
Other (List)			

# ATTACHMENT C NPDES PERMIT REQUIREMENT FOR INDUSTRIAL PRETREATMENT ANNUAL REPORT

The information described below shall be included in the pretreatment program annual reports:

- 1. An updated list of all industrial users by category, as set forth in 40 C.F.R. 403.8(f)(2)(i), indicating compliance or noncompliance with the following:
- baseline monitoring reporting requirements for newly promulgated industries
- compliance status reporting requirements for newly promulgated industries
- periodic (semi-annual) monitoring reporting requirements,
  - categorical standards, and
- local limits;
- 2. A summary of compliance and enforcement activities during the preceding year, including the number of:
- significant industrial users inspected by POTW (include inspection dates for each industrial user),
- significant industrial users sampled by POTW (include sampling dates for each industrial user),
- compliance schedules issued (include list of subject users),
- written notices of violations issued (include list of subject users),
- administrative orders issued (include list of subject users),
- criminal or civil suits filed (include list of subject users) and,
- penalties obtained (include list of subject users and penalty amounts);
- 3. A list of significantly violating industries required to be published in a local newspaper in accordance with 40 C.F.R. 403.8(f)(2)(vii);
- 4. A narrative description of program effectiveness including present and proposed changes to the program, such as funding, staffing, ordinances, regulations, rules and/or statutory authority;

5. A summary of all pollutant analytical results for influent, effluent, sludge and any toxicity or bioassay data from the wastewater treatment facility. The summary shall include a comparison of influent sampling results versus threshold inhibitory concentrations for Erving's Wastewater Treatment System and effluent sampling results versus water quality standards. Such a comparison shall be based on the sampling program described in the paragraph below or any similar sampling program described in this Permit.

At a minimum, annual sampling and analysis of the influent and effluent of the Erving Wastewater Treatment Plant shall be conducted for the following pollutants:

a.) Total Cadmium
b.) Total Chromium
c.) Total Copper
d.) Total Lead
e.) Total Mercury

f.) Total Nickel
g.) Total Silver
h.) Total Zinc
i.) Total Cyanide
.) Total Arsenic

The sampling program shall consist of one 24-hour flow-proportioned composite and at least one grab sample that is representative of the flows received by the POTW. The composite shall consist of hourly flow-proportioned grab samples taken over a 24-hour period if the sample is collected manually or shall consist of a minimum of 48 samples collected at 30 minute intervals if an automated sampler is used. Cyanide shall be taken as a grab sample during the same period as the composite sample. Sampling and preservation shall be consistent with 40 CFR Part 136.

- 6. A detailed description of all interference and pass-through that occurred during the past year;
- 7. A thorough description of all investigations into interference and passthrough during the past year;
- 8. A description of monitoring, sewer inspections and evaluations which were done during the past year to detect interference and pass-through, specifying parameters and frequencies;
- 9. A description of actions being taken to reduce the incidence of significant violations by significant industrial users; and,
- 10. The date of the latest adoption of local limits and an indication as to whether or not the city is under a State or Federal compliance schedule that includes steps to be taken to revise local limits.

## **Summary of Required Report Submittals**

This table is a summary of the reports required to be submitted under this NPDES permit as an aid to the permittee(s). If there are any discrepancies between the permit and this summary, the permittee(s) shall follow the permit requirements

1	2
Environmental Protection Agency	MassDEP
Water Technical Unit (SEW)	Division of Watershed Management
P.O. Box 8127	Surface Water Discharge Permit Program
Boston, MA 02114	627 Main Street, 2nd Floor
	Worcester, MA 01608
3	4
EPA New England	MassDEP
Attn: Justin Pimpare	Western Regional Office - Bureau of Resource
One Congress Street	Protection
Suite 1100 – CMU	436 Dwight Street
Boston, MA 02114	Springfield, Massachusetts 01103
5	
MassDEP	
Bureau of Waste Prevention	
Industrial Wastewater Section	
1 Winter Street	
Boston, MA 02108	

Requirement	<b>Due Date</b>	Addressees
Toxicity test samples shall be	Results shall be submitted by February	1 and 2
collected during the months	28 <sup>th</sup> , May 31 <sup>st</sup> , August 31 <sup>st</sup> , and	
of. January, April, July, and	November 30th of each year	
October [Part I.A.1]		
If the average annual flow in	By March 31 of the following calendar	1, 2 and 3
any calendar year exceeds	year	
80% of the facility's design		
flow, the permittee shall		
submit a report to MassDEP.		
[Part I.A.2.h.]		
Notification of Sanitary Sewer	Within 24 hours of SSO event.	2 and 4
Overflows [Part I.B		
Updated infiltration and	The updated plan shall be submitted to	1, 2, and 4
inflow (I/I) to the separate	EPA and MassDEP within six (6)	
sewer system. [Part I. C.3]	months of the effective date of this	
, , ,	permit	
Annual I/I Summary Report	Annually by March 31	1, 2, and 4
[Part I. C.3]		

The permittee shall prepare	Within 120 days of the effective date of	2, 3, 4 and 5
and submit a written technical	this permit.	
evaluation to the EPA		
analyzing the need to revise		
local limits. [Part I. D.1]		
The permittee shall provide	No later than March 1 of each year	2, 3, 4 and 5
the EPA and MassDEP with		
an annual report describing the		
permittee's pretreatment program activities for the		
twelve month period ending		
60 days prior to the due date in		
accordance with 40 CFR		
403.12(i) [Part I. D.3]		
The permittee must provide	Within 180 days of this permit's	2, 3, 4 and 5
EPA, in writing, proposed	effective date	
changes, if applicable, to		
the permittee's pretreatment		
program deemed necessary		
to assure conformity with		
current Federal Regulations.		
[Part I. D.6]		
Submit to EPA all required	Within 90 days of the effective date of	2, 3, 4 and 5
modifications of the	this permit	_, _,
streamlining Rule in order to	r · · · · · ·	
be consistent with the		
provisions of the newly		
promulgated Rule. [Part I.		
D.7]		
Annual Sludge Report	Annually by February 19	1, 2, and 4
[Part I.E.8]	What can be a see a see a	1.0.14
The permittee shall complete	Within one year of the effective date of	1, 2, and 4
an evaluation of alternative	the permit	
methods of operating the		
existing wastewater treatment facility to optimize the		
removal of nitrogen, and		
submit a report.		
The permittee shall submit a	By February 1 <sup>st</sup> , each year	1, 2, and 4
report that summarizes	, , , , , , , , , , , , , , , , , , ,	, —,
activities related to optimizing		
nitrogen removal efficiencies,		
documents the annual nitrogen		
discharge load from the		
facility, and tracks trends		
relative to the previous year.		
[Part I.F]		

Monitoring results obtained	Postmarked no later than the 15th day of	1, 2, and 4
during each calendar month	the following month.	
shall be summarized and		
reported on Discharge		
Monitoring Report Form(s)		
[Part I.G]		
Submit a response to EPA's	Within 30 days of the effective date of	3 and 5
March 2007 Pretreatment	the permit.	
Audit Findings letter.		

#### MA0101052 ERVING CENTER W W T P #2

001A <u>Monitoring Location = 1</u> 00310 - BOD, 5-day, 20 deg. C (SNC Group = 1 )

			900 lb/d	1800 lb/d	Mon. mg/L	դ. Mon. m
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX	MO AVG	DAILY M
4/30/2006	5/30/2006		753	1108	51	73
5/31/2006	6/23/2006		972	2652	63	159
6/30/2006	7/24/2006		691	1291	46	86
7/31/2006	8/24/2006		147	234	10	15
8/31/2006	9/21/2006		129	438		29
9/30/2006	10/20/2006		150	192		13
10/31/2006	11/27/2006		227	358	16	25
4/30/2007	5/30/2007		631	822	43	
5/31/2007	6/22/2007		517	784	39	58
6/30/2007	7/20/2007		581	743	42	53
7/31/2007	8/21/2007		629	882	46	70
8/31/2007	9/21/2007		608	856	45	63
9/30/2007	10/19/2007		514	776	39	
10/31/2007	11/19/2007		556	718	43	59
		Ave:	507.5	846.71	35.93	58.9286

			3400 lb/d	lon. mg/l	. Mon. m
MP Date	Rec'd Date	NO	DAILY MX	MO AVG	DAILY N
1/31/2006	2/24/2006		1958	89	129
2/28/2006	3/22/2006		3041	107	195
3/31/2006	4/24/2006		1937	99	129
11/30/2006	12/27/2006		549	17	37
12/31/2006	1/22/2006		1286	41	82
1/31/2007	2/20/2007		729	38	53
2/28/2007	3/23/2007		1370	59	104
3/31/2007	4/30/2007		724	37	52
11/30/2007	12/20/2007		1635	58	114
12/31/2007	1/18/2008		2042	75	144
1/31/2008	2/16/2008		1791	88	120
		Ave:	1551.091	64.364	105.36

50060 - Chlorine, total residual (SNC Group = 2)

			.13 mg/L	.22 mg/L
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX
4/30/2006	5/30/2006		0.004	0.03
5/31/2006	6/23/2006		0.039	0.17
6/30/2006	7/24/2006		0.036	0.14
7/31/2006	8/24/2006		0.025	0.1
8/31/2006	9/21/2006		0.024	0.17
9/30/2006	10/20/2006		0.002	0.04
10/31/2006	11/27/2006		0.002	0.03
4/30/2007	5/30/2007		0.047	0.19
5/31/2007	6/22/2007		0.06	0.2
6/30/2007	7/20/2007		0.06	0.19
7/31/2007	8/21/2007		0.01	0.01
8/31/2007	9/21/2007		0.02	0.11
9/30/2007	10/19/2007		0.04	0.08
10/31/2007	11/19/2007		0.03	0.17
		Ave:	0.03	0.12

74055 - Coliform, fecal general

			200 #/100ml
MP Date	Rec'd Date	NOL	MO GEO
4/30/2006	5/30/2006		9
5/31/2006	6/23/2006		3.88
6/30/2006	7/24/2006		2.49
7/31/2006	8/24/2006		2.8
8/31/2006	9/21/2006		6.4
9/30/2006	10/20/2006		1.3
10/31/2006	11/27/2006		0
4/30/2007	5/30/2007		0
5/31/2007	6/22/2007		8.6
6/30/2007	7/20/2007		3.8
7/31/2007	8/21/2007		2
8/31/2007	9/21/2007		2.3
9/30/2007	10/19/2007		6.4
10/31/2007	11/19/2007		8.7
		Ave:	4.12

01042 - Copper, total (as Cu) (SNC Group = 2)

			33 ug/L	44 ug/L
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX
1/31/2006	2/24/2006		9.2	13
2/28/2006	3/22/2006		55.5	150
3/31/2006	4/24/2006		47.75	130
4/30/2006	5/30/2006		0.315	68
5/31/2006	6/23/2006		77.8	180
6/30/2006	7/24/2006		53.6	125
7/31/2006	8/24/2006		14.5	44.5
8/31/2006	9/21/2006		1.83	11
9/30/2006	10/20/2006		18.5	32
10/31/2006	11/27/2006		3.4	16
11/30/2006	12/27/2006		20	42
12/31/2006	1/22/2006		13.25	37
1/31/2007	2/20/2007		22	52
2/28/2007	3/23/2007		51.5	70
3/31/2007	4/30/2007		45.5	59
4/30/2007	5/30/2007		50	76
5/31/2007	6/22/2007		54	69
6/30/2007	7/20/2007		34.25	52
7/31/2007	8/21/2007		31.75	55
8/31/2007	9/21/2007		10.8	21
9/30/2007	10/19/2007		29	60
10/31/2007	11/19/2007		16.2	27
11/30/2007	12/20/2007		20.5	25
12/31/2007	1/18/2008		23.5	26
1/31/2008	2/16/2008		51.4	99
		Ave:	30.24	61.58

50050 - Flow, in conduit or thru treatment plant

			2.7 Mgal/d
MP Date	Rec'd Date	NOL	12MO AVG
1/31/2006	2/24/2006		1.72
2/28/2006	3/22/2006		1.73
3/31/2006	4/24/2006		1.74
4/30/2006	5/30/2006		1.73
5/31/2006	6/23/2006		1.74
6/30/2006	7/24/2006		1.75
7/31/2006	8/24/2006		1.75
8/31/2006	9/21/2006		1.754
9/30/2006	10/20/2006		1.76
10/31/2006	11/27/2006		1.75
11/30/2006	12/27/2006		1.75
12/31/2006	1/22/2006		1.76
1/31/2007	2/20/2007		1.75
2/28/2007	3/23/2007		1.73
3/31/2007	4/30/2007		1.729
4/30/2007	5/30/2007		1.73
5/31/2007	6/22/2007		1.71
6/30/2007	7/20/2007		1.7
7/31/2007	8/21/2007		1.685
8/31/2007	9/21/2007		1.68
9/30/2007	10/19/2007		1.67
10/31/2007	11/19/2007		1.55
11/30/2007	12/20/2007		1.65
12/31/2007	1/18/2008		1.63
1/31/2008	2/16/2008		1.64
		Ave:	1.71

00610 - Nitrogen, ammonia total (as N) (SNC Group = 1 )

			Reg. Mon. lb/d	g. Mon. mc
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX
1/31/2006	2/24/2006		5	0.33
2/28/2006	3/22/2006		1.4	0.1
3/31/2006	4/24/2006		11.6	0.8
4/30/2006	5/30/2006		7.1	0.49
5/31/2006	6/23/2006		10.3	0.67
6/30/2006	7/24/2006		4.5	0.3
7/31/2006	8/24/2006		5.9	0.4
8/31/2006	9/21/2006		6.3	0.44
9/30/2006	10/20/2006		5.5	0.4
10/31/2006	11/27/2006		7.09	0.5
11/30/2006	12/27/2006		2.9	0.2
12/31/2006	1/22/2006		8.5	0.6
1/31/2007	2/20/2007		5.6	0.4
2/28/2007	3/23/2007		14	1
3/31/2007	4/30/2007		5.6	0.4
4/30/2007	5/30/2007		5.9	0.4
5/31/2007	6/22/2007		3	0.23
6/30/2007	7/20/2007		0.69	0.05
7/31/2007	8/21/2007		0.41	0.03
8/31/2007	9/21/2007		0.68	0.05
9/30/2007	10/19/2007		1.1	0.1
10/31/2007	11/19/2007		1.29	0.1
11/30/2007	12/20/2007		2.2	0.16
12/31/2007	1/18/2008		2.9	0.23
1/31/2008	2/16/2008		1.03	0.07
		Ave:	4.82	0.34

<u>00400 - pH</u>

			6.5 SU
MP Date	Rec'd Date	NOD	
1/31/2006	2/24/2006		6.9
2/28/2006	3/22/2006		6.7
3/31/2006	4/24/2006		6.8
4/30/2006	5/30/2006		6.9
5/31/2006	6/23/2006		6.7
6/30/2006	7/24/2006		6.7
7/31/2006	8/24/2006		7
8/31/2006	9/21/2006		7
9/30/2006	10/20/2006		7.1
10/31/2006	11/27/2006		7
11/30/2006	12/27/2006		6.8
12/31/2006	1/22/2006		7
1/31/2007	2/20/2007		7
2/28/2007	3/23/2007		6.9
3/31/2007	4/30/2007		7
4/30/2007	5/30/2007		6.9
5/31/2007	6/22/2007		6.8
6/30/2007	7/20/2007		6.7
7/31/2007	8/21/2007		6.8
8/31/2007	9/21/2007		6.9
9/30/2007	10/19/2007		6.9
10/31/2007	11/19/2007		7
11/30/2007	12/20/2007		7
12/31/2007	1/18/2008		6.9
1/31/2008	2/16/2008		7
		Ave:	6.90

00665 - Phosphorus, total (as P) (SNC Group = 1 )

				eq. Mon. mg
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX
1/31/2006	2/24/2006		0	0
2/28/2006	3/22/2006		0	0
3/31/2006	4/24/2006		0	0
4/30/2006	5/30/2006		0	0
5/31/2006	6/23/2006		0.205	0.24
6/30/2006	7/24/2006		0.236	0.44
7/31/2006	8/24/2006		0.1	0.16
8/31/2006	9/21/2006		0.275	0.48
9/30/2006	10/20/2006		0.22	0.29
10/31/2006	11/27/2006		0.23	0.37
11/30/2006	12/27/2006		0	0
12/31/2006	1/22/2006		0	0
1/31/2007	2/20/2007		0	
1/31/2007				
2/28/2007	3/23/2007		0	0
3/31/2007				
4/30/2007	5/30/2007		0	0
5/31/2007	6/22/2007		0.3	0.6
6/30/2007	7/20/2007		0.08	0.14
7/31/2007	8/21/2007		0.023	0.09
8/31/2007	9/21/2007		0.18	0.21
9/30/2007	10/19/2007		0.28	0.46
10/31/2007	11/19/2007		0.37	0.78
11/30/2007	12/20/2007		0	0
12/31/2007	1/18/2008		0	0
1/31/2008	2/16/2008		0	0
		Ave:	0.10	0.19

00011 - Temperature, water deg. fahrenheit

			Reg. Mon. deg F
MP Date	Rec'd Date	NOD	DAILY MX
1/31/2006			62.06
2/28/2006	3/22/2006		62.6
3/31/2006	4/24/2006		69.4
4/30/2006	5/30/2006		69.8
5/31/2006	6/23/2006		80.6
6/30/2006	7/24/2006		83.48
7/31/2006	8/24/2006		84.9
8/31/2006	9/21/2006		87.08
9/30/2006	10/20/2006		76.8
10/31/2006	11/27/2006		72
11/30/2006	12/27/2006		72.1
12/31/2006	1/22/2006		68.72
1/31/2007	2/20/2007		67.1
2/28/2007	3/23/2007		60.08
3/31/2007	4/30/2007		66.2
4/30/2007	5/30/2007		71.8
5/31/2007	6/22/2007		79.5
6/30/2007	7/20/2007		85.8
7/31/2007	8/21/2007		86.18
8/31/2007	9/21/2007		86.2
9/30/2007	10/19/2007		84.6
10/31/2007	11/19/2007		81.9
11/30/2007	12/20/2007		67.5
12/31/2007	1/18/2008		61.34
1/31/2008	2/16/2008		65.48
		Ave:	74.13

00530 - Solids, total suspended (SNC Group = 1 )

			900 lb/d	1800 lb/d	a. Mon. m	a. Mon. m
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX	MO AVG	DAILY M
4/30/2006	5/30/2006		812	1765	55	115
5/31/2006	6/23/2006		478	834	31	50
6/30/2006	7/24/2006		405	951	27	62
7/31/2006	8/24/2006		264	555	18	37
8/31/2006	9/21/2006		402	721	28	47
9/30/2006	10/20/2006		356	576	26	40
10/31/2006	11/27/2006		425	1224	30	82
4/30/2007	5/30/2007		558		38	81
5/31/2007	6/22/2007		438	746	33	59
6/30/2007	7/20/2007		388	803	28	57
7/31/2007	8/21/2007		506		37	74
8/31/2007	9/21/2007		459	789	34	56
9/30/2007	10/19/2007		469	1158		89
10/31/2007	11/19/2007		414	974	32	80
		Ave:	455.2857143	955.5	32.3571	66.3571
			<u> </u>			
			2350 lb/d	4700 lb/d	g. Mon. m	q. Mon. m
MP Date	Rec'd Date	NODI	MO AVG	DAILY MX	MO AVG	DAILY M
1/31/2006	2/24/2006		1457	2553	96	157
2/28/2006	3/22/2006		1453	4353	95	290
3/31/2006	4/24/2006		1001	2265	69	157
11/30/2006	12/27/2006		616		42	91
12/31/2006	1/22/2006		680	2651	48	170
1/31/2007	2/20/2007		417	1022	30	70
2/28/2007	3/23/2007		648	1606	46	116
3/31/2007	4/30/2007		634	1169	45	81
11/30/2007	12/20/2007		619		45	100
12/31/2007	1/18/2008		1179	2995	93	220
1/31/2008	2/16/2008		1240	2060	84	143
		Ave:	904	2124.818	63	145

Monitoring Location = G 00310 - BOD, 5-day, 20 deg. C (SNC Group = 1 )

			Req. Mon. lb/d	
MP Date	Rec'd Date	NODI	MO AVG	MO AV MN
1/31/2006	2/24/2006		22692	1495
2/28/2006	3/22/2006		20632	1430
3/31/2006	4/24/2006		19271	1328
4/30/2006	5/30/2006		17611	1193
5/31/2006	6/23/2006		20736	1344
6/30/2006	7/24/2006		16618	1107
7/31/2006	8/24/2006		15163	1033
8/31/2006	9/21/2006		15794	1101
9/30/2006	10/20/2006		18861	1379
10/31/2006	11/27/2006		18275	1289
11/30/2006	12/27/2006		19728	344
12/31/2006	1/22/2006		20501	1446
1/31/2007	2/20/2007		18900	1357
2/28/2007	3/23/2007		19338	1372
3/31/2007	4/30/2007		17816	1264
4/30/2007	5/30/2007		18730	1276
5/31/2007	6/22/2007		16271	1227
6/30/2007	7/20/2007		17029	1230
7/31/2007	8/21/2007		17480	1278
8/31/2007	9/21/2007		16281	1205
9/30/2007	10/19/2007		16431	1247
10/31/2007	11/19/2007		16870	1305
11/30/2007	12/20/2007		19037	1403
12/31/2007	1/18/2008		14832	1170
1/31/2008	2/16/2008		18482	1252
		Ave:	18135.16	1243

00530 - Solids, total suspended (SNC Group = 1 )

			Reg. Mon. lb/d	
MP Date	Rec'd Date	NODI	MO AVG	MO AV MN
1/31/2006			91316	6016
2/28/2006	3/22/2006		84717	5539
3/31/2006	4/24/2006		72195	4975
4/30/2006			74547	5050
5/31/2006	6/23/2006		59279	3842
6/30/2006			55154	3674
7/31/2006	8/24/2006		60093	4094
8/31/2006	9/21/2006		68267	4759
9/30/2006	10/20/2006		49826	3643
10/31/2006	11/27/2006		65559	4624
11/30/2006	12/27/2006		68122	4641
12/31/2006	1/22/2006		70407	4966
1/31/2007	2/20/2007		72884	5233
2/28/2007	3/23/2007		73376	5206
3/31/2007	4/30/2007		76675	5440
4/30/2007	5/30/2007		68710	4681
5/31/2007	6/22/2007		78622	5929
6/30/2007	7/20/2007		61774	4462
7/31/2007	8/21/2007		665584	4785
8/31/2007	9/21/2007		67095	4966
9/30/2007	10/19/2007		68534	5201
10/31/2007	11/19/2007		92506	7156
11/30/2007	12/20/2007		97634	7095
12/31/2007	1/18/2008		84478	6664
1/31/2008	2/16/2008		99362	6731
		Ave:	97068.64	5174.88

Monitoring Location = K 81010 - BOD, 5-day, percent removal (SNC Group = 1 )

			85 %
MP Date		NODI	DAILY MN
1/31/2006	2/24/2006		91.9
2/28/2006	3/22/2006		88.7
3/31/2006	4/24/2006		87.7
4/30/2006	5/30/2006		91.6
5/31/2006	6/23/2006		87.4
6/30/2006	7/24/2006		93.7
7/31/2006	8/24/2006		98.8
8/31/2006	9/21/2006		99.2
9/30/2006	10/20/2006		98.7
10/31/2006	11/27/2006		97.9
11/30/2006	12/27/2006		96.8
12/31/2006	1/22/2006		97.2
1/31/2007	2/20/2007		95.3
2/28/2007	3/23/2007		89.4
3/31/2007	4/30/2007		95.6
4/30/2007	5/30/2007		96.6
5/31/2007	6/22/2007		93.6
6/30/2007	7/20/2007		96.6
7/31/2007	8/21/2007		96.4
8/31/2007	9/21/2007		93.5
9/30/2007	10/19/2007		96.8
10/31/2007	11/19/2007		96.7
11/30/2007	12/20/2007		95.9
12/31/2007	1/18/2008		93.6
1/31/2008	2/16/2008		93
		Ave:	94.50

81011 - Solids, suspended percent removal (SNC Group = 1 )

			85 %
MP Date	Rec'd Date	NO	DAILY MN
1/31/2006			95.4
2/28/2006	3/22/2006		92.2
3/31/2006	4/24/2006		95.5
4/30/2006	5/30/2006		97.2
5/31/2006	6/23/2006		98.4
6/30/2006	7/24/2006		97.9
7/31/2006	8/24/2006		99.1
8/31/2006	9/21/2006		99.4
9/30/2006	10/20/2006		98.5
10/31/2006	11/27/2006		98
11/30/2006	12/27/2006		98
12/31/2006	1/22/2006		99
1/31/2007	2/20/2007		98
2/28/2007	3/23/2007		97.6
3/31/2007	4/30/2007		98.5
4/30/2007	5/30/2007		99.1
5/31/2007	6/22/2007		99.1
6/30/2007	7/20/2007		99.3
7/31/2007	8/21/2007		99.2
8/31/2007	9/21/2007		98.3
9/30/2007	10/19/2007		99.3
10/31/2007	11/19/2007		99.5
11/30/2007	12/20/2007		99.3
12/31/2007	1/18/2008		98.6
1/31/2008	2/16/2008		98.8
		Ave:	98.13

001Q Monitoring Location = 1 51087 - Nitrogen, Kjeldahl, total (TKN) (water)

			Req. Mon. mg/l
MP Date		NODI	DAILY MX
1/31/2006			2.8
4/30/2006			5.8
7/31/2006			
10/31/2006			
1/31/2007			
4/30/2007	5/30/2007		3.5
7/31/2007	8/21/2007		0
10/31/2007	11/19/2007		2.8
1/31/2008	2/16/2008		4.2
		Ave:	3.18

#### 00615 - Nitrogen, nitrite total (as N) (SNC Group = 1 )

			<u>Reg. Mon. mg/L</u>
		NODI	DAILY MX
1/31/2006	2/24/2006		0
4/30/2006	6/23/2006		0.53
7/31/2006			
10/31/2006			
1/31/2007			
4/30/2007	5/30/2007		0
7/31/2007	8/21/2007		2
10/31/2007	11/19/2007		0
1/31/2008	2/16/2008		0
		Ave:	0.42

#### 00620 - Nitrogen, nitrate total (as N) (SNC Group = 1 )

			Req. Mon. mg/L
MP Date	Rec'd Date	NOL	DAILY MX
1/31/2006	2/24/2006		0.066
4/30/2006	6/23/2006		0.53
7/31/2006			
10/31/2006			
1/31/2007			
4/30/2007	5/30/2007		0
7/31/2007	8/21/2007		0
10/31/2007	11/19/2007		0
1/31/2008	2/16/2008		0
		Ave:	0.10

TAA3B - LC50 Static 48Hr Acute Ceriodaphnia

			100 %
MP Date	Rec'd Date	NOI	DAILY MN
1/31/2006	4/24/2006		100
4/30/2006	7/24/2006		100
7/31/2006	8/24/2006		100
10/31/2006	12/27/2006		100
1/31/2007	2/20/2007		100
4/30/2007	6/29/2007		100
7/31/2007	9/21/2007		100
10/31/2007	1/28/2008		100
1/31/2008			
		Ave:	100

TBP3B - Noel Statre 7Day Chronic Ceriodaphnia

			9 %
		NODI	DAILY MN
1/31/2006	4/24/2006		12.5
4/30/2006	7/24/2006		25
7/31/2006	8/24/2006		50
10/31/2006	12/27/2006		100
1/31/2007	2/20/2007		100
4/30/2007	6/29/2007		100
7/31/2007	9/21/2007		100
10/31/2007	1/28/2008		100
1/31/2008			
		Ave:	73.44