

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA", and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

Sandwich Public Schools

is authorized to discharge from the facility located at

**Henry T. Wing School
Route 130, Water Street
Sandwich, MA 02563**

to receiving water named

Dock Creek to Cape Cod Bay

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on February 12, 2002.

This permit and the authorization to discharge expire at midnight, five (5) years from the effective date.

This permit supersedes the permit issued on September 15, 1987.

This permit consists of 8 pages in Part I including effluent limitations, monitoring requirements, Attachment A, Marine Chronic Toxicity Test Procedure & Protocol, and 35 pages in Part II including General Conditions and Definitions.

Signed this 12th day of February, 2002

/Signature on File/

Linda M. Murphy
Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge treated effluent from outfall serial number 001. Such discharge shall be limited and monitored by the permittee as specified below.

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>			<u>Monitoring Requirement</u>	
		<u>Average Monthly</u>	<u>Average Weekly</u>	<u>Maximum Daily</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow	MGD	0.0144	----	Report	Continuous ¹	Recorder
BOD ₅	mg/l	5	7	Report	1/Week ²	8-Hour Composite ³
	lbs/day	0.6	0.84	Report		
TSS	mg/l	10	15	Report	1/Week ²	8-Hour Composite ³
	lbs/day	1.2	1.8	Report		
pH		(See Condition I.A.1.b. on Page 5)			5/Week	Grab
Fecal Coliform Bacteria ⁵	mpn/100 ml	14	----	43	1/Week	Grab
Total Residual Chlorine ⁶	ug/l	7.5	----	13	5/Week	Grab
Total Ammonia Nitrogen, as N	mg/l	6	----	10	1/Week	8-Hour Composite ³
Copper, Total ⁷	ug/l	----	----	Report	1/Month	8-Hour Composite ³
Whole Effluent Toxicity ^{8,9}	%		LC ₅₀ ≥ 100		4/year	8-Hour Composite ³
Whole Effluent Toxicity ^{8,10}	%		Chronic C-NOEC ≥ 100		4/year	8-Hour Composite ³

Footnotes:

1. For flow, report total flow for each operating date. Flow should be measured at the weir in the chlorine contact chamber using meter with totalizer. The permit limit is an annual average.
2. All required effluent samples shall be collected at the weir located downstream of the sand filter, adjacent to Early Learning Center play yard. Any change in sampling location must be reviewed and approved in writing by EPA and MADEP. All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136. All samples shall be 24 hour composites unless specified as a grab sample in 40 CFR §136.
3. Sampling required for influent and effluent.
4. A 8-hour composite sample will consist of at least eight (8) grab samples taken during one working day.
5. Fecal coliform monitoring will be conducted year round. This is also a State certification requirement. Fecal coliform discharges shall not exceed a monthly geometric mean of 14 colony forming units per 100 ml, nor shall they exceed 43 cfu per 100 ml as a daily maximum. This monitoring shall be conducted concurrently with the TRC sampling described below.
6. The minimum level (ML) for total residual chlorine is defined as 50 ug/l. This value is the minimum level for chlorine using EPA approved methods found in the most currently approved version of Standard Methods for the Examination of Water and Wastes, 18th Edition, Method 4500 CL-E and G, or United States Environmental Protection Agency Manual of Methods of Analysis of Water and Wastes, Method 330.5. One of these methods must be used to determine total residual chlorine. For effluent limitations less than 50 ug/l, compliance/non-compliance will be determined based on the ML. Sample results of 50 ug/l or less shall be reported as zero on the discharge monitoring report.
7. The minimum level (ML) for copper is defined as 5 ug/l. This value is the minimum level for copper using the Furnace Atomic Absorption analytical method (EPA Method 220.2 or Standard Methods 3113b). For effluent limitations less than 5 ug/l, compliance/non-compliance will be determined based on the ML. Sample results of 5 ug/l or less shall be reported as zero on the Discharge Monitoring Report.
8. The permittee shall conduct chronic (and modified acute) toxicity tests four times per year. The chronic test may be used to calculate the acute LC₅₀ at the 48 hour exposure interval. The permittee shall test ARBACIA, MYSID SHRIMP, SILVERSIDE. Toxicity test samples shall be collected during the second week of the months of February, May, August and November. The test results shall be submitted by the last day of the month following the completion of the test. The results are due March 30th, June 30th, September 30th and December 30th, respectively. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Dates Second Tuesday in	Submit Results By:	Test Species	Acute Limit LC ₅₀	Chronic Limit C-NOEC
February May August November	March 30 th June 30 th September 30 th December 30 th	<u>ARBACIA, MYSID</u> <u>SHRIMP,</u> <u>SILVERSIDE</u> See Attachment A	≥ 100%	≥ 100%

After submitting four consecutive sets of WET test results, all of which demonstrate compliance with the WET permit limits, the permittee may request a reduction in the frequency of required WET testing. The permittee is required to continue testing at the frequency specified in the permit until notice is received by certified mail from the EPA that the WET testing requirement has been changed.

9. The LC₅₀ is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
10. C-NOEC (chronic-no observed effect concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life cycle or partial life cycle test which causes no adverse effect on growth, survival, or reproduction at a specific time of observation as determined from hypothesis testing where the test results exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, the permittee must report the lowest concentration where there is no observable effect. The "100% or greater" limit is defined as a sample which is composed of 100% (or greater) effluent, the remainder being dilution water. This is a maximum daily limit derived as the result of little or no dilution.

Part I.A.1. (Continued)

- a. The discharge shall not cause a violation of the water quality standards of the receiving waters.
- b. The pH of the effluent shall not be less than 6.5 nor greater than 8.5 at any time, unless these values are exceeded due to natural causes or as a result of the approved treatment processes.
- c. The discharge shall not cause objectionable discoloration of the receiving waters.
- d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
- e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values.
- f. When the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the designed flow, the permittee shall submit to the permitting authorities a projection of loadings up to the time when the design capacity of the treatment facility will be

reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.

- g. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.

2. All POTWs must provide adequate notice to the Director of the following:

- a. Any new introduction of pollutants into that POTW from an indirect discharger in a primary industry category discharging process water; and
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For purposes of this paragraph, adequate notice shall include information on:
 - (1) the quantity and quality of effluent introduced into the POTW; and
 - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

3. Prohibitions Concerning Interference and Pass-Through:

- a. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.
- b. If, within 30 days after notice of an interference or pass through violation has been sent by EPA to the POTW, and to persons or groups who have requested such notice, the POTW fails to commence appropriate enforcement action to correct the violation, EPA may take appropriate enforcement action.

4. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.

5. Numerical Effluent Limitations for Toxicants

EPA or DEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

B. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from outfalls listed in Part I A.1. of this permit. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e. (1) of the General Requirements of this permit (Twenty-four hour reporting).

C. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

3. Chlorination System Report

Within 6 months of the effective date of the permit, the permittee will submit a report documenting the effectiveness of the chlorination and dechlorination systems. The report will specifically address how flow variability and chlorine demand variability affect compliance with the TRC and fecal coliform limits at all times. Sampling data shall be provided to support conclusions on how hourly and daily flow and chlorine demand variability affects permit compliance. The report will include a description of the chlorination and dechlorination systems and the methods for dosage control. The report will identify all changes necessary to ensure compliance with the TRC and fecal coliform limits at all times, including equipment modifications and upgrades, operational procedures (including calibration procedures and alarm/response procedures), and sampling protocols. The report will include a schedule for implementing all of the necessary changes. An annual report shall be submitted on February 28 of each year summarizing all exceedances of the TRC and fecal coliform effluent limits during the previous year, the estimated or measured fecal coliform and chlorine discharge levels during the exceedance, and measures taken to fix the problem and to prevent future occurrences.

D. SLUDGE CONDITIONS

1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
 - a. Land application - the use of sewage sludge to condition or fertilize the soil

- b. Surface disposal - the placement of sewage sludge in a sludge only landfill
 - c. Sewage sludge incineration in a sludge only incinerator
4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.
 5. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements.
 - General requirements
 - Pollutant limitations
 - Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
 - Management practices
 - Record keeping
 - Monitoring
 - Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month

7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8
8. The permittee shall submit an annual report containing the information specified in the guidance. Reports are due annually by February 19. Reports shall be submitted to the address contained in the reporting section of the permit.

F. MONITORING AND REPORTING

1. Reporting

Monitoring results obtained during each calendar month shall be summarized and reported on Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the following month.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency
Water Technical Unit (SEW)

P.O. Box 8127
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02347

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection
Division of Watershed Management
Surface Water Discharge Permit Program
627 Main Street, 2nd Floor
Worcester, Massachusetts 01608

G. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MA DEP pursuant to M.G.L. Chap.21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.