### DISCLAIMER

The full text of certain NPDES permits and the associated fact sheets has been made available to provide online access to this public information. EPA is making permits and fact sheets available electronically to provide convenient access for interested public parties and as a reference for permit writers. The ownership of these documents lies with the permitting authority, typically a State with an authorized NPDES program.

While EPA makes every effort to ensure that this web site remains current and contains the final version of the active permit, we cannot guarantee it is so. For example, there may be some delay in posting modifications made after a permit is issued. Also note that not all active permits are currently available electronically. Only permits and fact sheets for which the full text has been provided to Headquarters by the permitting authority may be made available. Headquarters has requested the full text only for permits as they are issued or reissued, beginning November 1, 2002.

Please contact the appropriate permitting authority (either a State or EPA Regional office) prior to acting on this information to ensure you have the most up-to-date permit and/or fact sheet. EPA recognizes the official version of a permit or fact sheet to be the version designated as such and appropriately stored by the respective permitting authority.

The documents are gathered from all permitting authorities, and all documents thus obtained are made available electronically, with no screening for completeness or quality. Thus, availability on the website does not constitute endorsement by EPA.

JOHN ELIAS BALDACCI GOVERNOR July 21, 2003

DAWN R. GALLAGHER

Mr. Ross Parker Camden Water Pollution Control Facility P.O. Box 1207 Camden, ME. 04843

RE: Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME0100137 Maine Waste Discharge License Application #W002592-5L-E-M Final Permit/License Modification/Renewal

Dear Mr. Parker:

Enclosed please find a copy of your **final** MEPDES permit and Maine WDL **modification/renewal** which was approved by the Department of Environmental Protection. Please read the permit/license and its attached conditions carefully. You must follow the conditions in the order to satisfy the requirements of law. Any discharge not receiving adequate treatment is in violation of State Law and is subject to enforcement action.

Any interested person aggrieved by a Department determination made pursuant to applicable regulations, may appeal the decision following the procedures described in the attached DEP FACT SHEET entitled "Appealing a Commissioner's Licensing Decision."

We would like to make you aware of the fact that your monthly Discharge Monitoring Reports (DMR) may not reflect the revisions in this permitting action for several months. However, you are required to report applicable test results for parameters required by this permitting action that do not appear on the DMR. Please see the attached April 2003 O&M Newsletter article regarding this matter.

If you have any questions regarding this matter, please feel free to call me at 287-7693.

Sincere

Gregg Wood Division of Water Resource Regulation Bureau of Land and Water Quality

Enc.

cc: Denise Behr, DEP/CMRO

AUGUSTA 17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017 (207) 287-7688 RAY BLDG., HOSPITAL ST.

BANGOR 106 HOGAN ROAD BANGOR, MAINE 04401 (207) 941-4570 FAX: (207) 941-4584 PORTLAND 312 CANCO ROAD PORTLAND, MAINE 04103 (207) 822-6300 FAX: (207) 822-6303 PRESQUE ISLE 1235 CENTRAL DRIVE, SKYWAY PARK PRESQUE ISLE, MAINE 04769-2094 (207) 764-0477 FAX: (207) 764-1507

### **DMR** Lag

When the Department renews discharge permits, the parameter limits may change or parameters may be added or deleted. In some cases, it is merely the replacement of the federally issued NPDES permit with a state-issued MEPDES permit that results in different limits. When the new permit is finalized, a copy of the permit is passed to our data entry staff for coding into EPA's Permits Compliance System (PCS) database. PCS was developed in the 1970's and is not user-friendly. Entering or changing parameters can take weeks or even months.

This can create a lag between the time your new permit becomes effective and the new permit limits appearing on your DMRs. If you are faced with this, it can create three different situations that have to be dealt with in different ways.

 If the parameter was included on previous DMRs, but only the limit was changed, there will be a space for the data. Please go ahead and enter it. When the changes are made to PCS, the program will have the data and compare it to the new limit.

2. When a parameter is eliminated from monitoring in your new permit, but there is a delay in changing the DMR, you will have a space on the DMR that needs to be filled. For a parameter that has been eliminated, please enter the space on the DMR for that parameter only with "NODI-9" (No Discharge Indicator Code #9). This code means monitoring is conditional or not required this monitoring period.

 When your new permit includes parameters for which monitoring was not previously required, and coding has

not caught up on the DMRs, there will not be any space on the DMR identified for those parameters. In that case, please fill out an extra sheet of paper with the facility name and permit number, along with all of the information normally required for each parameter (parameter code, data, frequency of analysis, sample type, and number of exceedances). Each data point should be identified as monthly average, weekly average, daily max, etc. and the units of measurement such as mg/L or lb/day. Staple the extra sheet to the DMR so that the extra data stays with the DMR form. Our data entry staff cannot enter the data for the new parameters until the PCS coding catches up. When the PCS coding does catch up, our data entry staff will have the data right at hand to do the entry without having to take the extra time to seek it from your inspector or from you.

EPA is planning significant improvements for the PCS system that will be implemented in the next few years. These improvements should allow us to issue modified permits and DMRs concurrently. Until then we appreciate your assistance and patience in this effort.

### Phil Garwood



### STATE OF MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION STATE HOUSE STATION 17 AUGUSTA, MAINE 04333

### DEPARTMENT ORDER

### IN THE MATTER OF

TOWN OF CAMDEN	
PUBLICLY OWNED TREATMENT WORKS	S
CAMDEN, KNOX COUNTY, MAINE	•
ME0100137	۰.
W002592-5L-E-M APPROVAL	

# ) MAINE POLLUTANT DISCHARGE ) ELIMINATION SYSTEM PERMIT ) AND ) WASTE DISCHARGE LICENSE ) MODIFICATION/RENEWAL

Pursuant to the provisions of the Federal Water Pollution Control Act, Title 33 USC, Section 1251, et. seq. and Maine Law 38 M.R.S.A., Section 414-A et seq., and applicable regulations, the Department of Environmental Protection (the Department) has considered the application of the TOWN OF CAMDEN (Town), with its supportive data, agency review comments, and other related material on file and finds the following facts:

### APPLICATION SUMMARY

The applicant has applied to the Department for modification of Department Waste Discharge License (WDL) #W002592-5L-D-R which was issued on September 28, 1999 and is due to expire on September 28, 2004. The 9/28/99 WDL authorized the discharge of up to a monthly average flow of 1.21 million gallons per day (MGD) of secondary treated sanitary waste waters from a publicly owned treatment works facility to the Camden Harbor, Class SB, in Camden, Maine.

On January 12, 2001, the Department received authorization from the U.S. Environmental Protection Agency (EPA) to administer the National Pollutant Discharge Elimination System (NPDES) permit program in Maine. From this point forward, the program will be referenced as the Maine Pollutant Discharge Elimination System (MEPDES) permit program and permit #ME0100137 (same as NPDES permit number) will be utilized as the primary reference number.

### MODIFICATIONS REQUESTED

The permittee has requested the Department incorporate the terms and conditions of the MEPDES permitting program as the NPDES permit last issued by the USEPA on September 26, 1997, contains a number of limitations and monitoring requirements associated with tannery waste waters that are no longer received at the Town's waste water treatment facility.

It is noted the Department is processing the application as a combination modification/renewal due to the relatively short time frame between issuance of this modification and the expiration date of the previous licensing action (September 2004) and the effort involved in processing the modification.

### PERMIT

### ME0100137 W002592-5L-E-M

### PERMIT SUMMARY

This permitting action is carrying forward all the terms and conditions of the 9/28/99 WDL action with the following exceptions:

- 1. Eliminating the monthly average and daily maximum water quality based mass and concentration limits for cyanide.
- 2. Eliminating the whole effluent toxicity (WET) limit for the sea urchin (Arbacia punctulata).
- 3. Establishing daily maximum water quality based mass and concentration limits for copper and requiring the submission of a toxicity reduction evaluation (TRE).
- 4. Requiring the permittee to develop a Wet Weather Management Plan for the waste water treatment facility.
- 5. Requiring the permittee to annually review and or update the Operations and Maintenance (O&M) manual for the treatment facility and appurtenant facilities.
- 6. Requiring the town to make provisions to monitor five pump stations to determine the frequency and quantity (via measurement or estimation) of waste water discharged from the bypass structures. The permit requires the town to install a flow estimation system at the Bay View Street pump station as part of the pump station upgrade.
- 7. Incorporating the terms and conditions of the federal pretreatment program as previously required via the 9/30/97 NPDES permit.

### CONCLUSIONS

BASED on the findings in the attached Fact Sheet dated June 18, 2003 and subject to the Conditions listed below, the Department makes the following CONCLUSIONS:

- 1. The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
- 2. The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
- 3. The provisions of the State's antidegradation policy, 38 MRSA Section 464(4)(F), will be met, in that:
  - a. Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
  - b. Where high quality waters of the State constitute an outstanding national resource, that water quality will be maintained and protected;
  - c. The standards of classification of the receiving water body are met or, where the standards of classification of the receiving water body are not met, the discharge will not cause or contribute to the failure of the water body to meet the standards of classification;
  - d. Where the actual quality of any classified receiving water body exceeds the minimum standards of the next highest classification, that higher water quality will be maintained and protected; and
  - e. Where a discharge will result in lowering the existing quality of any water body, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
- 4. The discharge will be subject to effluent limitations that require application of best practicable treatment.

### PERMIT

. 2003.

### ME0100137 W002592-5L-E-M

### ACTION

THEREFORE, the Department APPROVES the application of the TOWN OF CAMDEN, to discharge up to a monthly average flow of 1.21 million gallons per day of secondary treated sanitary waste waters to Camden Harbor, Class SB, subject to the attached conditions and all applicable standards and regulations:

- 1. "Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable To All Permits," revised July 1, 2002, copy attached.
- 2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
- 3. This permit expires five (5) years from the date of signature below.

DONE AND DATED AT AUGUSTA, MAINE, THIS \_/B" DAY OF fully

COMMISSIONER OF ENVIRONMENTAL PROTECTION

BY:

Dawn Gallagher, COMMISSIONER

### PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application \_\_\_\_\_ May 1, 2003

Date of application acceptance \_

May 5, 2003



Date filed with Board of Environmental Protection .

This Order prepared by GREGG WOOD, BUREAU OF LAND & WATER QUALITY W25925le 7/10/03

SPECIAL CONDITIONS ME0100137 W002592-5L-E-M

PERMIT

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

permittee as specified below:

Page 5 of 15

# 1. During the period beginning the effective date of the permit and lasting through permit expiration, the permittee is authorized to discharge secondary treated sanitary waste waters from **OUTFALL #001** to the Camden Harbor. Such discharges shall be limited and monitored by the

Effluent Characteristic		Discharge	Discharge Limitations				Monitoring Requirements	uirements
	Monthly <u>Average</u> Ib/day	Weekly <u>Average</u> Ib/day	Daily <u>Maximum</u> Ib/day	Monthly <u>Average</u> as specified	Weekly Average as specified	Daily <u>Maximum</u> as specified	Measurement Frequency as specified	Sample <u>Type</u> as specified
Flow	1.21 MGD [03]	9 3 5	Report MGD	a a a	I	1	Continuous 199/991	Recorder [RC]
Biochemical Oxygen Demand (BOD <sub>s</sub> ) 100310]	303 #/day [26]	454 #/day [ <sup>26]</sup>	505 #/day <sup>[26]</sup>	30 mg/L [19]	45 mg/L [19]	50 mg/L. [ <sup>19]</sup>	Z/Week [02/07]	Composite [24]
BOD <sub>5</sub> % Removal <sup>(1)</sup> (81010)	E G D	8	8	85% [19]	1	-	1/Month [01/30]	Calculate [CA]
Total Suspended Solids	303 #/day <sup>[26]</sup>	454 #/day [26]	505 #/day <sup>[26]</sup>	30 mg/L /19/	45 mg/L [19]	50 mg/L [19]	2/Week [02/07]	Composite <sup>[24]</sup>
TSS % Removal <sup>(1)</sup> [ator1]	1	8		85% [19]	ł		1/Month [01/30]	Calculate (ca)
Settleable Solids		3		I		0.3 ml/L <sup>[25]</sup>	1/Day [01/01]	Grab [GH]
Fecal Colitorm Bacteria (May 15 - September 30) [31616]	1	ł	1	15/100 ml <sup>(2)</sup>		50/100 ml [13]	2/Week [02/07]	Grab [GR]
Total Residual Chlorine (May 15 - September 30) [50060]	l	1	ł	0.1 mg/L [19]		0.3 mg/L 119	1/Day [01/01]	Grab <sub>(GRI</sub>

SPECIAL CONDITIONS W002592-5L-E-M ME0100137

Page 6 of 15

PERMIT

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS - OUTFALL #001 (cont'd)

Effluent Characteristic	ristic	;	Discharge Limi	Eimitations				Monitoring Requirements	uirements
		Monthly	Weekly	Daily	Monthly	Weekly	Daily	Measurement	Sample
	- <sup>-</sup>	Average Ih/dav	Average Ih/dav	<u>Maximum</u> Ib/dav	Average as specified	Average as specified	<u>Maximum</u> as specified	<u>Frequency</u> as specified	as specified
		(nn m	lan in						
Conner (Total)				0.79 #/Day		1	124 ug/I-	1/Year	Composite
	•			[26]	•		[19]	[01/YR]	[24]
nH (Std 1 Init)							0.0-0.9	1/Day	Grab
		-	l	1	1	1	[12]	[01/01]	(GR)

Beginning twelve months prior to permit expiration and lasting through permit expiration SCREENING LEVEL - Beginning September 2003 and lasting through September 2004 and

Composite/Grab 1241 **Monitoring Requirements** Composite 1241 Composite 1241 Composite 1241 Composite 1241 Sample Type 1/Quarter 101/901 Measurement 2/Year 102/YRI 2/Year lozyri 2/Year 102/rsi Frequency 2/Year lo2/YR Daily <u>Maximum</u> Report % 1231 Report % [23] Report % 1231 Report % [23] **Discharge Limitations** Monthly Average Maximum Daily Monthly **Average** Effluent Characteristic Arbacia punctulata (TBH3A) Menidia beryllina <sub>(TDM6B)</sub> Whole Effluent Toxicity(3) Menidia beryllina <sub>(TBP6B)</sub> Mysidopsis bahia (TDM3E) Chronic - NOEL (Inland Silverside) (Inland Silverside) <u>Acute – NOEL</u> (Mysid Shrimp) (Sea urchin)

Report ug/L (28)

Chemical Specific (4) 1500081

### PERMIT

### ME0100137 W002592-5L-E-M

### SPECIAL CONDITIONS

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) Footnotes:

**Sampling** – Sampling for all parameters (with the exception of total residual chlorine and fecal coliform bacteria) is to be conducted after the parshall flume. Seasonal sampling for total residual chlorine and fecal coliform bacteria is to be conducted at the last manhole in the discharge line located in the town parking area adjacent to the harbor. Any change in sampling location must be approved by the Department in writing. Sampling and analysis must be conducted in accordance with; a) methods approved by 40 Code of Federal Regulations (CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, c) as otherwise specified by the Department. Samples that are sent out for analysis shall be analyzed by a laboratory certified by the State of Maine's Department of Human Services.

- 1. **Percent Removal** The treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand for all flows receiving secondary treatment. The percent removal shall be based on monthly average influent and effluent concentration values. The percent removal shall be waived when the monthly average influent concentration is less than 200 mg/L. When this occurs, the permittee shall report a "*NODI-9*" code in the applicable space on the monthly DMR.
- 2. Fecal coliform bacteria The monthly average limitation is a geometric mean limitation and results shall be calculated and reported as such.
- 3. Whole effluent toxicity (WET) testing Definitive WET testing is a multiconcentration testing event (a minimum of five dilutions bracketing the critical acute and chronic dilution of 3.7% and 2.0% respectively), which provides a point estimate of toxicity in terms of No Observed Effect Level, commonly referred to as NOEL or NOEC. A-NOEL is defined as the acute no observed effect level with survival as the end point. C-NOEL is defined as the chronic no observed effect level with survival, reproduction and growth as the end points.

Between September 2003 and September 2004 and again beginning twelve months prior to the expiration date of the permit, the permittee shall conduct screening level WET testing at a frequency of 2/Year. Acute tests shall be conducted on the mysid shrimp (<u>Mysidopsis bahia</u>) and the inland silverside (<u>Menidia berrylina</u>). Chronic tests shall be conducted on the inland silverside (<u>Menidia berrylina</u>) and on the sea urchin (<u>Arbacia punctulta</u>). Results shall be reported to the Department within 30 days of the permittee receiving the test results from the laboratory conducting the testing.

The permittee is also required to analyze the effluent for the parameters specified in the analytic chemistry on the form in Attachment A of this permit every time a WET test is performed.

### SPECIAL CONDITIONS

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

### Footnotes:

Toxicity tests must be conducted by an experienced laboratory approved by the Department. The laboratory must follow procedures as described in the following U.S.E.P.A. methods manuals.

- a. <u>Short Term Methods for Estimating the Chronic Toxicity of Effluent and</u> <u>Receiving Water to Marine and Estuarine Organisms</u>, Fifth Edition, October 2002, EPA-821-R-02-014.
- Methods for Measuring the Acute Toxicity of Effluent and Receiving Waters to Freshwater and Marine Organisms, Third Edition, October 2002, EPA-821-R-02-012.
- Priority pollutant (chemical specific testing pursuant to Department rule Chapter 530.5) testing are those parameters listed by the USEPA pursuant to Section 307(a) of the Clean Water Act and published a 40 CFR Part 122, Appendix D, Tables II and III.

Between September 2003 and September 2004 and again beginning twelve months prior to the expiration date of the permit, screening level chemical specific testing shall be conducted at a frequency of four per year (four consecutive calendar quarters). Chemical specific testing shall be conducted on samples collected at the same time as those collected for whole effluent toxicity tests, where applicable. Chemical specific testing shall be conducted using methods that permit detection of a pollutant at existing levels in the effluent or that achieve minimum reporting levels of detection as specified by the Department. Results shall be submitted to the Department within thirty (30) days of the permittee receiving the data report from the laboratory conducting the testing. For the purposes of Discharge Monitoring Report (DMR) reporting, enter a "1" for yes, testing done this monitoring period or "NODI-9" monitoring not required this period.

All mercury sampling shall be conducted in accordance with EPA's "clean sampling techniques" found in EPA Method 1669, <u>Sampling Ambient Water For Trace Metals At EPA Water Quality Criteria Levels</u>. All mercury analysis shall be conducted in accordance with EPA Method 1631, <u>Determination of Mercury in Water by Oxidation</u>, <u>Purge and Trap, and Cold Vapor Fluorescence Spectrometry</u>.

### SPECIAL CONDITIONS

### **B. NARRATIVE EFFLUENT LIMITATIONS**

- 1. The effluent shall not contain a visible oil sheen, foam or floating solids at any time which would impair the usages designated by the classification of the receiving waters.
- 2. The effluent shall not contain materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the usages designated by the classification of the receiving waters.
- 3. The discharges shall not cause visible discoloration or turbidity in the receiving waters which would impair the usages designated by the classification of the receiving waters.
- 4. Notwithstanding specific conditions of this permit the effluent must not lower the quality of any classified body of water below such classification, or lower the existing quality of any body of water if the existing quality is higher than the classification.

### C. DISINFECTION

If chlorination is used as a means of disinfection, an approved chlorine contact structure providing the proper detention time consistent with good engineering practice must be utilized, followed by a dechlorination system if the Total Residual Chlorine (TRC) cannot be met by dissipation in the detention tank. The total residual chlorine in the effluent shall at no time cause any demonstrable harm to aquatic life in the receiving waters. The dose of chlorine applied shall be sufficient to leave a TRC concentration that will effectively reduce bacteria to levels below those specified in Special Condition A, "Effluent Limitations and Monitoring Requirements", above.

### D. TREATMENT PLANT OPERATOR

The treatment facility must be operated by a person holding a **Grade III**, certificate pursuant to Title 32 M.R.S.A., Section 4171 et seq. All proposed contracts for facility operation by any person must be approved by the Department before the permittee may engage the services of the contract operator.

### E. LIMITATIONS FOR INDUSTRIAL USERS

Pollutants introduced into the waste water collection and treatment system by a non-domestic source (user) shall not pass through or interfere with the operation of the treatment system.

### SPECIAL CONDITIONS

### F. MONITORING AND REPORTING

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report (DMR) forms provided by the Department. The DMR's shall be **postmarked on or before the thirteenth** (13<sup>th</sup>) day of the **month or hand-delivered to a Department Regional Office such that the DMR's are received by the Department on or before the fifteenth** (15<sup>th</sup>) day of the month following the completed reporting period. A signed copy of the DMR and all other reports required herein shall be submitted to the following address:

> Department of Environmental Protection Central Maine Regional Office Bureau of Land and Water Quality Division of Compliance, Engineering & Technical Assistance State House Station #17 Augusta, Maine 04333

### G. NOTIFICATION REQUIREMENT

In accordance with Standard Condition D, the permittee shall notify the Department of the following.

- 1. Any introduction of pollutants into the waste water collection and treatment system from an indirect discharger in a primary industrial category discharging process waste water; and
- 2. Any substantial change in the volume or character of pollutants being introduced into the waste water collection and treatment system by a source introducing pollutants into the system at the time of permit issuance. For the purposes of this section, notice regarding substantial change shall include information on:
  - (a) the quality and quantity of waste water introduced to the waste water collection and treatment system; and
  - (b) any anticipated impact caused by the change in the quantity or quality of the waste water to be discharged from the treatment system.

### H. TOXICITY REDUCTION EVALUATION (TRE)

Within thirty (30) days of the effective date of this permit, (PCS Code 001PA) the permittee shall submit to the Department for review and approval, a TRE plan which outlines a strategy to identify the source(s) and action items to be implemented to mitigate or eliminate exceedence of the acute ambient water quality criteria for copper.

### SPECIAL CONDITIONS

### I. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from Outfall 001. Discharges of waste water from any other point source are not authorized under this permit, but shall be reported in accordance with Standard Condition B(5) (Bypass) of this permit.

### J. PUMP STATION EMERGENCY BYPASSES

Discharges from emergency bypass structures in pump stations are not authorized by this permit. The permittee shall make provisions to monitor the pump stations listed below to determine the frequency and quantity (via measurement or estimation) of waste water discharged from the bypass structures. To determine quantity from the Bay View Street pump station, the permittee shall install an electronic flow estimation system to record frequency, duration and estimation of flow discharged.

Outfall Number	Outfall Location	Receiving Water and Class
002	Bay View Street	Camden Harbor, SB
003	Rawson Avenue	Megunticook River, B
004	Sea Street	Camden Harbor, SB
005	Mount Battie	Megunticook River, B
006	Latie Beach	Camden Harbor, SB

Discharges from the pump stations shall be reported in accordance with Standard Condition B(5) (Bypass) of this permit.

### K. DISPOSAL OF SEPTAGE WASTE IN WASTE WATER TREATMENT FACILITY

During the effective period of this permit, the permittee is authorized to receive and treat up to **1,500 gallons per day** of septage into its waste water treatment facility subject to the following terms and conditions:

- 1. This approval is limited to methods and plans described in the application and supporting documents. Any variations are subject to review and approval prior to implementation.
- 2. At no time shall the addition of septage cause or contribute to effluent quality violations. If such conditions do exist, the introduction of septage into the treatment process or solids handling stream shall be suspended until effluent quality can be maintained.
- 3. The permittee shall maintain records which shall include, as a minimum, the following by date: volume of septage received, source of the septage (name of municipality), the hauler transporting the septage, the dates and volume of septage added to the waste water treatment influent and test results.

### PERMIT

### SPECIAL CONDITIONS

### K. DISPOSAL OF SEPTAGE WASTE IN WASTE WATER TREATMENT FACILITY

- 4. The addition of septage into the treatment process or solids handling stream shall not cause the treatment facilities design capacity to be exceeded. If, for any reason, the treatment process or solids handling facilities become overloaded, introduction of septage into the treatment process or solids handling stream shall be reduced or terminated in order to eliminate the overload condition.
- 5. Septage known to be harmful to the treatment processes shall not be accepted. Wastes which contain heavy metals, toxic chemicals, extreme pH, flammable or corrosive materials in concentrations harmful to the treatment operation shall be refused.
- 6. Holding tank waste water shall not be recorded as septage but should be reported in the treatment facility's influent flow.

### L. WET WEATHER FLOW MANAGEMENT PLAN

The treatment facility staff shall develop and maintain a Wet Weather Management Plan to direct the staff on how to operate the facility effectively during periods of high flow. The Department acknowledges that the existing collection system may deliver flows in excess of the monthly average design capacity of the treatment plant during periods of high infiltration and rainfall.

**On or before September 1, 2003**, (*PCS Code 06799*) the permittee shall submit to the Department for review and approval, a new or revised Wet Weather Management Plan which conforms to Department guidelines for such plans. The revised plan shall include operating procedures for a range of intensities, address solids handling procedures (including septic waste and other high strength wastes if applicable) and provide written operating and maintenance procedures during the events.

Once the Wet Weather Management Plan has been approved, the permittee shall review their plan annually and record any necessary changes to keep the plan up to date.

### M. OPERATION & MAINTENANCE (O&M) PLAN

This facility shall have a current written comprehensive Operation & Maintenance (O&M) Plan. The plan shall provide a systematic approach by which the permittee shall at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. The O&M Plan shall be kept on-site at all times and made available to Department and EPA personnel upon request.

### SPECIAL CONDITIONS

### M. OPERATION & MAINTENANCE (O&M) PLAN (cont'd)

By December 31 of each year, or within 90 days of any process changes or minor equipment upgrades, the permittee shall evaluate and modify the O&M Plan including site plan(s) and schematic(s) for the waste water treatment facility to ensure that it is up-to-date.

Within 90 days of completion of new and or substantial upgrades of the waste water treatment facility, the permittee shall submit the updated O&M Plan to their Department inspector for review and comment.

### N. CHAPTER 530.5(B)(7)(c)(iii) CERTIFICATION

By December 31 of each calendar year (*PCS Code 030MS*), the permittee shall provide the Department with a certification describing any of the following that have occurred since the effective date of this permit:

- 1. Increases in the number, types and flows of industrial, commercial or domestic discharges to the facility that in the judgment of the Department may cause the receiving water to become toxic.
- 2. Changes in the condition or operations of the facility that may increase the toxicity of the discharge.
- 3. Changes in storm water collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge.

4. Increases in the type or volume of hauled wastes accepted by the facility.

5. The Department reserves the right to reinstate annual (surveillance level) testing or other toxicity testing if new information becomes available that indicates the discharge may cause or have a reasonable potential to cause exceedences of ambient water quality criteria/thresholds.

### **O. REOPENING OF PERMIT FOR MODIFICATIONS**

Upon evaluation of the tests results or monitoring requirements specified in Special Conditions of this permitting action, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at anytime and with notice to the permittee, modify this permit to; 1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded, (2) require additional monitoring if results on file are inconclusive; or (3) change monitoring requirements or limitations based on new information.

### SPECIAL CONDITIONS

### P. INDUSTRIAL PRETREATMENT PROGRAM

- 1. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass-through the publicly owned treatment works (POTW) or interfere with the operation or performance of the works.
  - a. The permittee shall develop and enforce specific effluent limits (local limits) for Industrial User(s), and all other users, as appropriate, which together with appropriate changes in the POTW facilities or operation, are necessary to ensure continued compliance with the POTW's MEPDES permit or sludge use or disposal practices. Specific local limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond.

Within 180 days of the effective date of this permit, (PCS Code 08799), the permittee shall prepare and submit a written technical evaluation to the Department analyzing the need to revise local limits. As part of this evaluation, the permittee shall assess how the POTW performs with respect to influent and effluent of pollutants, water quality concerns, sludge quality, sludge processing concerns/inhibition, biomonitoring results, activated sludge inhibition, worker health and safety and collection system concerns. In preparing this evaluation, the permittee shall complete the attached form (Attachment B of this permit) with the technical evaluation to assist in determining whether existing local limits need to be revised. Justifications and conclusions should be based on actual plant data if available and should be included in the report. Should the evaluation reveal the need to revise local limits, the permittee shall complete the revisions within 120 days of notification by the Department and submit the revisions to the Department for approval. The permittee shall carry out the local limits revisions in accordance with EPA's Guidance Manual for the Development and Implementation of Local Discharge Limitations Under the Pretreatment Program (December, 1987).

- 2. The permittee shall implement the Industrial Pretreatment Program in accordance with the legal authorities, policies, procedures, and financial provisions described in the permittee's approved Pretreatment Program, and the General Pretreatment Regulations, found at 40 CFR 403 and Department rule Chapter 528. At a minimum, the permittee must perform the following duties to properly implement the Industrial Pretreatment Program (IPP):
  - a. Carry out inspection, surveillance, and monitoring procedures which will determine, independent of information supplied by the industrial user, whether the industrial user is in compliance with the Pretreatment Standards. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP but in no case less than once per year and maintain adequate records.

### SPECIAL CONDITIONS

### P. INDUSTRIAL PRETREATMENT PROGRAM (cont'd)

- b. Issue or renew all necessary industrial user control mechanisms within 90 days of their expiration date or within 180 days after the industry has been determined to be a significant industrial user.
- c. Obtain appropriate remedies for noncompliance by an industrial user with any pretreatment standard and/or requirement.
- d. Maintain an adequate revenue structure for continued implementation of the Pretreatment Program.
- e. The permittee shall provide the Department with an annual report describing the permittee's pretreatment program activities for the twelve month period ending 60 days prior to the due date in accordance with federal regulation found at 40 CFR 403.12(i) and Department rule Chapter 528(12)(I). The **annual report** shall be consistent with the format described in Attachment C of this permit **and shall be submitted no later than June 1<sup>st</sup> of each calendar year.** (*PCS Code 61012*)
- f. The permittee must obtain approval from the Department prior to making any significant changes to the industrial pretreatment program in accordance with federal regulation found at 40 CFR 403.18(c) and Department rule Chapter 528(18).
- g. The permittee must assure that applicable National Categorical Pretreatment Standards are met by all categorical industrial users of the POTW. These standards are published in the federal regulations found at 40 CFR 405 et. seq.
- h. The permittee must modify its pretreatment program to conform to all changes in the federal regulations and State rules that pertain to the implementation and enforcement of the industrial pretreatment program. Within 180 days of the effective date of this permit, (PCS Code 50999), the permittee must provide the Department in writing, proposed changes (if applicable) to the permittee's pretreatment program deemed necessary to assure conformity with current federal regulations and State rules. At a minimum, the permittee must address in its written submission the following areas:
  (1) Enforcement response plan; (2) revised sewer use ordinances; and (3) slug control evaluations. The permittee will implement these proposed changes pending the Department's approval under federal regulation 40 CFR 403.18 and Department rule Chapter 528(18). This submission is separate and distinct from any local limits analysis submission described in section 1(a) above.

## ATTACHMENT A

### MARINE WHOLE EFFLUENT TOXICITY (WET) TEST REPORT

Facility			DEPLIC	nse No		NPDES permit No
Contact person					-	Telephone No
Date initially sampled		Date tested	1		- :	Chlorinated?
Test type	mm/dd/yy screening		mr surv	dd/yy eillance		Dechlorinated?
Results	Mysid shrimo			erside		Test required by:
LC50	the second secon		344	ci side	1	Receiving Water Concentration
A-NOEL					а.	
C-NOEL					İ	A-NOEL C-NOEL
Data summary	Mysid shrimp	sca urchin	(d) and die (d) official alle alle alle alle alle alle alle a	silver	side	4. 14
	% survival	% fertilized	% su		final wt (mg)	
QC standard	A>90	>70	A>90	C>80	>0.50	
lab control						
receiving water contri						
conc. 1 ( %)						
conc. 2 ( %)						1
conc. 3 ( %)	·		5 .			1
conc. 4 (			1			1
conc. 5 ( %)		1				
conc. 6 ( %)						1
stat test used	· · · · · · · · · · · · · · · · · · ·					1.
	place " next to va	lues statistically	different	form contr	ols	-4
Reference toxicant	Mysid shrimp	Sea urchin : C-NOEL		silver A-NOEL	stde C-NOEL	Adjustment
toxicant /date			1	1	01.000	brine
limits (mg/l)			1			sea salt
results (mg/l)						other
			L			
Comments						
1 A A A A A A A A A A A A A A A A A A A						
		-				
			<u>^</u>			
aboratory Conducting	Tests. To the be	st of my knowle	dge this i	nformatio	n is true, accur	ate, and complete
Ignature			company			-
rinted name		and the second design of the s	address			
el no.				-		
			· · ·	-		

### ANALYTICAL CHEMISTRY RESULTS MARINE WATERS

Date collected

mm/dd/yy

.

Date analyzed

mm/dd/yy

Lab ID No.

Analyte	Report	Results	effluent	Detection level	Method
Ammonia nitrogen	ug/L			µg/L	an a
Salinity	ppt			ppt	
Total residual oxidants	mg/L			mg/L	
Total organic carbon	mg/L		· · · · · · · · ·	mg/L	
Total solids	mg/L			mg/L	
Total suspended solids	mg/L		· · · ·	mg/L	der der der
Total aluminum	µg/L			µg/L	· · ·
Total cadmium	µg/L	•		µg/L	• .
Total chromium	µg/L			µg/L	
Total copper	µg/L			µg/L	
Total lead	Hg/L			µg/L	
Fotal nickel	µg/L	· •	1	µg/L	
Total zinc	µg/L		•	µg/L	
other ( pH )	S.U.			S.U.	
other (		· · ·			

Comments

Laboratory conducting test. To the best of my knowledge this information is true, accurate, and complete

signature.	lab name	
printed name	address	
tel. no.		

### ATTACHMENT B

### RE-ASSESSMENT OF TECHNICALLY BASED INDUSTRIAL DISCHARGE LIMITS

Pursuant to federal regulation 40 CFR §122.21(j)(4) and Department rule Chapter 528, all Publicly Owned Treatment Works (POTWs) with approved Industrial Pretreatment Programs (IPPs) shall provide the Department with a written evaluation of the need to revise local industrial discharge limits under federal regulation 40 CFR §403.5(c)(1) and Department rule Chapter 528(6).

Below is a form designed by the U.S. Environmental Protection Agency (EPA - New England) to assist POTWs with approved IPPs in evaluating whether their existing Technically Based Local Limits (TBLLs) need to be recalculated. The form allows the permittee and Department to evaluate and compare pertinent information used in previous TBLLs calculations against present conditions at the POTW.

Please read the directions below before filling out the attached form.

### ITEM I.

- In Column (1), list what your POTW's influent flow rate was when your existing TBLLs were calculated. In Column (2), list your POTW's present influent flow rate. Your current flow rate should be calculated using the POTW's average daily flow rate from the previous 12 months.
- In Column (1) list what your POTW's SIU flow rate was when your existing TBLLs were calculated. In Column (2), list your POTW's present SIU flow rate.
- In Column (1), list what dilution ratio and/or 7Q10 value was used in your previous NPDES permit. In Column (2), list what dilution ration and/or 7Q10 value is presently being used in your new/reissued MEPDES permit.

The 7Q10 value is the lowest seven day average flow rate, in the river, over a ten year period. The 7Q10 value and/or dilution ratio used by the Department in your MEPDES permit can be found in your MEPDES permit "Fact Sheet."

In Column (1), list the safety factor, if any, that was used when your existing TBLLs were calculated.

In Column (1), note how your bio-solids were managed when your existing TBLLs were calculated. In Column (2), note how your POTW is presently disposing of its biosolids and how your POTW will be disposing of its biosolids in the future.

### ITEM II.

List what your existing TBLLs are - as they appear in your current Sewer Use Ordinance (SUO).

### ITEM III.

Identify how your existing TBLLs are allocated out to your industrial community. Some pollutants may be allocated differently than others, if so please explain.

### ITEM IV.

Since your existing TBLLs were calculated, identify the following in detail:

if your POTW has experienced any upsets, inhibition, interference or pass-through as (1)a result of an industrial discharge.

(2)

if your POTW is presently violating any of its current MEPDES permit limitations include toxicity.

### ITEM V.

Using current sampling data, list in Column (1) the average and maximum amount of pollutants (in pounds per day) received in the POTW's influent. Current sampling data is defined as data obtained over the last 24 month period.

All influent data collected and analyzed must be in accordance with federal regulation 40 CFR §136. Sampling data collected should be analyzed using the lowest possible detection method(s), e.g. graphite furnace.

Based on your existing TBLLs, as presented in Item II., list in Column (2) each Maximum Allowable Industrial Headworks Loading (MAIHL) value corresponding to each of the local limits derived from an applicable environmental criteria or standard, e.g. water quality, sludge, MEPDES, inhibition, etc. For each pollutant, the MAIHL equals the calculated Maximum Allowable Headwork Loading (MAHL) minus the POTW's domestic loading source(s). For more information, please see p.,3-28 in EPA's Guidance Manual on the Development and Implementation of Local Limits Under the Pretreatment Program, 12/87.

### ITEM VI.

Using current sampling data, list in Column (1) the average and maximum amount of pollutants (in micrograms per liter) present your POTW's effluent. Current sampling data is defined as data obtained during the last 24 month period.

All effluent data collected and analyzed must be in accordance with federal regulation 40 CFR §136. Sampling data collected should be analyzed using the lowest possible detection method(s), e.g. graphite furnace.

List in Column (2A) what the Water Quality Standards (WQS) were (in micrograms per liter) when your TBLLs were calculated, please note what hardness value was used at that time. Hardness should be expressed in milligram per liter of Calcium Carbonate.

List in Column (2B) the current WQSs or "Chronic Gold Book" values for each pollutant multiplied by the dilution ratio used in your new/reissued MEPDES permit. For example, with a dilution ratio of 25:1 at a hardness of 20 mg/l - Calcium Carbonate (copper's chronic WQS equals 2.99 ug/l) the chronic MEPDES permit limit for copper would equal 75 ug/l.

### ITEM VII.

In Column (1), list all pollutants (in micrograms per liter) limited in your new/reissued MEPDES permit. In Column (2), list all pollutants limited in your old/expired NPDES permit.

### ITEM VIII.

Using current sampling data, list in Column (1) the average and maximum amount of pollutants in your POTW's biosolids. Current data is defined as data obtained during the last 24 month period. Results are to be expressed as total dry weight.

All biosolids data collected and analyzed must be in accordance with federal 40 CFR §136.

In Column (2A), list current State and/or Federal sludge standards that your facility's biosolids must comply with. Also note how your POTW currently manages the disposal of its biosolids. If your POTW is planing on managing its biosolids differently, list in Column (2B) what your new biosolids criteria will be and method of disposal.

In general, please be sure the units reported are correct and all pertinent information is included in your evaluation. If you have any questions, please contact your pretreatment representative at the Maine Department of Environmental Protection, Bureau of Land & Water Quality, Division of Engineering, Compliance & Technical Assistance, State House Station #17, Augusta, ME. 04333. The telephone number is (207) 287-3901.

### REASSESSMENT OF TECHNICALLY BASED LOCAL LIMITS (TBLLs)

POTW Name & Address : \_\_\_\_\_

MEPDES PERMIT #\_\_\_\_

Date the Department approved current TBLLs : \_\_\_\_\_

Date the Department approved current Sewer Use Ordinance : \_\_\_\_\_

### ITEM I.

In Column (1) list the conditions that existed when your current TBLLs were calculated. In Column (2), list current conditions or expected conditions at your POTW.

	Column (1	)	Colu	ımn (2)	
	EXISTINC	TBLLs	PRE	SENT CONI	DITIONS
POTW Flow (MGD)	· · · · · · · · · · · · · · · · · · ·		<u> </u>	· · · · · · · · · · · · · · · · · · ·	
SIU Flow (MGD)	на страна с на 1970 — Прила Салана 1970 — Прила Салана (Прила)		·		
Dilution Ratio or 7Q10 from the MEPDES Permit					
Safety Factor		· · · · ·		N/A	
Biosolids Disposal		· · ·			

**Biosolids** Dis Method(s)

### ITEM II.

### **EXISTING TBLLs**

POLLUTANT	NUMERICAL LIMIT (mg/l) or (lb/day)	POLLUTANT NUMERICAL LIMIT (mg/l) or (lb/day)
	· · · · · · · · · · · · · · · · · · ·	
	· · · · · · · · · · · · · · · · · · ·	
		·

### ITEM III.

Note how your existing TBLLs, listed in Item II., are allocated to your Significant Industrial Users (SIUs), i.e. uniform concentration, contributory flow, mass proportioning, other. Please specify by circling.

### ITEM IV.

Has your POTW experienced any upsets, inhibition, interference or pass-through from industrial sources since your existing TBLLs were calculated?

If yes, explain.

Has your POTW violated any of its MEPDES permit limits and/or toxicity test requirements?

If yes, explain. \_\_\_\_

### ITEM V.

Using current POTW influent sampling data fill in Column (1). In Column (2), list your Maximum Allowable Industrial Headwork Loading (MAIHL) values used to derive your TBLLs listed in Item II. In addition, please note the environmental criteria for which each MAIHL value was established, i.e. water quality, sludge, MEPDES etc.

Pollutant	<b>Column</b> (1) Influent Data Ar	nalyses	0 <u>1</u>	C <b>olumn (2)</b> MAIHL Values	Crite	ria
	<u>Maximum</u> (lb/day)	<u>Average</u> (lb/day)	(	lb/day)		
Arsenic Cadmium Chromium Copper Cyanide Lead Mercury Nickel Silver Zinc Other (List)						
				······································		· · · · · · · · · · · · · · · · · · ·
			••••••••••••••••••••••••••••••••••••••			
		· · · · · ·				
на на селото на						
		• • •				

### ITEM VI.

Using current POTW effluent sampling data, fill in Column (1). In Column (2A) list what the Water Quality Standards (Gold Book Criteria) were at the time your existing TBLLs were developed. List in Column (2B) current Gold Book values multiplied by the dilution ratio used in your new/reissued MEPDES permit.

		•	Colum	ns	(2)
Column (1) Effluent Data Analyses <u>Maximum</u>	<u>Average</u>		(2A) Water Quality (Gold Book) From TBLLs	Criteria	(2B) a <u>Today</u> (ug/l)
(ug/l)	(ug/l)		(ug/l)		(ug/1)
<u>Pollutant</u>					
Arsenic	<u> </u>	515 - 65 y			
Cadmium*	· <u>· · · · · · · · · · · · · · · · · · </u>	- ·	· · · · · · · · · · · · · · · · · · ·		
Chromium*				· .	· · · · · · · · · · · · · · · · · · ·
Copper*	<u> </u>		· · · · · · · · · · · · · · · · · · ·	1997 - S. 1997 -	
Cyanide		•			
Lead*					
Mercury	· · · · · · · · · · · · · · · · · · ·	<u>.</u>			
Nickel*	·		· · · · · · · · · · · · · · · · · · ·		
Silver	·		- <u></u>		·
Zinc*	<del></del>				
Other (List)			<b></b>		
			<u> </u>		
			· · · · · · · · · · · · · · · · · · ·		

\*Hardness Dependent (mg/l - CaCO3)

### ITEM VII.

In Column (1), identify all pollutants limited in your new/reissued MEPDES permit. In Column (2), identify all pollutants that were limited in your old/expired NPDES permit.

	<b>Column (1)</b> NEW PERMIT		Column ( OLD PER	MIT
Pollutants	<u>Limitations</u> (ug/l)		Pollutants	Limitations (ug/l)
· · · · · · · · · · · · · · · · · · ·				•
		• • •		

### ITEM VIII.

Using current POTW biosolids data, fill in Column (1). In Column (2A), list the biosolids criteria that was used at the time your existing TBLLs were calculated. If your POTW is planing on managing its biosolids differently, list in Column (2B) what your new biosolids criteria would be and method of disposal.

	Columns						
	Column (1) Biosolids Data Ana <u>Average</u> (mg/kg)			(2A) Biosolids Criter From TBLLs (mg/kg)	ia	(2B) New (mg/kg)	
<u>Pollutant</u>							
Arsenic							
Cadmium	·					<u>.</u>	<u> </u>
Chromium				· · · · · · · · · · · · · · · · · · ·		<u>·</u>	<u> </u>
Copper							
Cyanide	· · · · · · · · · · · · · · · · · · ·						<u> </u>
Lead							
Mercury	·		•.			· <u></u>	· · · · · · · · · · · · · · · · · · ·
Nickel					·		· · · · · · · · · · · · · · · · · · ·
Silver	·						
Zinc					<del></del> .		· · ·
Molybdenum				· · · · · · · · · · · · · · · · · · ·	<b></b> ·		
Selenium	· · · · · · · · · · · · · · · · · · ·	•		· · · · · · · · · · · · · · · · · · ·			·····
Other (List)				· · · · · · · · · · · · · · · · · · ·	<u> </u>		

### ATTACHMENT C

### MEPDES PERMIT REQUIREMENT FOR INDUSTRIAL PRETREATMENT ANNUAL REPORT

1. A narrative description (paragraph) of program effectiveness including the following:

- present and proposed changes to the program
- Funding
- Staffing
- Ordinances
- Regulations
- Statutory authority
- Other

Our pretreatment program is very effective as indicated by the SIU compliance rate and the reduction in pollutant loading to the POTW.

The program is adequately funded and staffed to provide for annual training and completion of our regulatory responsibilities.

No changes have been made, or are proposed, to the Town of Camden's Sewer Use Ordinance. The SUO provides adequate statutory authority to enforce in Local, State and Federal courts.

2. The date of the latest adoption of Local Limits and a statement as to whether the municipality is under a State or Federal compliance schedule that includes steps to be taken to revise Local Limits.

If yes, Compliance Schedule; if no, schedule not needed.

\_\_\_\_\_'s Local Limits were last adopted (by local authority) on \_\_\_\_\_\_ and \_\_\_\_\_ is under no State or Federal compliance schedule that includes steps to be taken to revise Local Limits.

3. A description of actions taken to reduce the incidence of violations by SIU's;

A. Example: Inspections – Notifications – Information/Education

4. A description of monitoring, sewer inspections and evaluations which were done during the past year to detect Interference and Pass Through, specifying parameters and frequencies;

Example: Evaluations/investigations as a result of Monitoring, Sewer Inspections, and Evaluations, Influent – Effluent results, Spills, Dumps, Toxicity, or Unusual events.

5. A detailed description of all Interference and Pass Through that occurred during the past year; [statement of:

Event, Parameter, Violation, Cause, IU, POTW action, IU action, Result (see NOV #)].

experienced no events of Interference or Pass- Through in this reporting period. If "Yes" then describe.

6. A thorough description of all investigations into Interference and Pass-Through during the past year;

A paragraph: Violation, Problem, Steps to resolve, Result.

(same as #5 or describe investigations.)

7. An updated list of all industrial users by category (40 CFR 403.8(f)(2)(i), indicating compliance or non- compliance with the following:

- baseline monitoring reporting requirements for newly promulgated industries

- compliance status reporting requirements for newly promulgated industries

- periodic (semi-annual) monitoring reporting requirements - categorical standards, and - local limits

### Example:

SIU New Promulgated BMR/Compliance (Y/N) (Y/N) Cat Limits Compliance (Y/N) Local Limits Compliance (Y/N)

Semi-annual Reports Compliance (Y/N)

8. A summary of compliance and enforcement activities during the preceding year including a:

- list of SIU's inspected by the POTW (dates, compliance status),

- list of SIU's sampled by the POTW (dates, compliance status),

### Example:

SIU Inspected Sampled/self Sampled/POTW Compliance Y/N

- list of SIU's to which compliance schedules were issued,

[SIU] - Violation - Compliance - Schedule

### N/A or schedule plus Progress Reporting Dates]

- summary list of NOV's written to SIU's by name [statement],

- summary list of AO's written to SIU's by name [statement],

- list of criminal and/or civil suits filed by SIU, [usually a simple statement]
- list of penalty amounts obtained (by SIU) [a statement].

9. NOTE: Some items in numbers 9 & 10 may be combined in a chart, or charts. Be sure that any charts are logical, not cluttered, and don't contain an unreasonable amount of information. Any violations should be shown separately, in summary, for each item.

List of violating industries required to be published in a local newspaper (40 CFR 403.8(f)(2)(vii). [Statement]

10. A summary of all pollutant analytical results for:

- Influent	[Annual average – show violations]
- Effluent	[Annual average – show violations]
- Sludge	[Annual average- show violations]
- Toxicity/Bioassay	[Annual Average – show violations]

 comparison of influent sampling results versus threshold inhibitory concentrations for the POTW's wastewater treatment system.

- comparison of effluent sampling results versus water quality standards, considering the permitted dilution factor of the POTW.

**NOTE:** The sampling program shall be as described below OR any similar sampling program described in the MEPDES permit.

- At a minimum, annual sampling and analysis of/ the influent and effluent of the POTW's wastewater treatment plant shall be conducted on the following pollutants:

Example:

Influent

Inhibition Effluent

AWC Acute Chronic

- Total Cadmium
- Total Chromium
- Total Copper

- Total Lead

- Total Mercury (Methods 1669 & 1631)

- Total Nickel
- Total Silver
- Total Zinc
- Total Cyanide
- Total Arsenic

The sampling program shall consist of one 24-hour flow-proportioned composite that is representative of the flow received by the POTW. The composite shall consist of accurately flow-proportioned grab samples taken over a discharge day if the samples are collected manually, or shall consist of a minimum of 48 accurately flow-proportioned samples if an automatic sampler is used. Sampling and preservation shall be according to 40 CFR part 136.