

## STATE OF MAINE

## Department of Environmental Protection

Paul R. Lepage GOVERNOR

February 17, 2015

Mr. Timothy Gormley Superintendent, Milo Water District 146 Park Street Milo, ME. 04463 e-mail: <u>milowater@myfairpoint.net</u>

RE: Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME0100439 Maine Waste Discharge License (WDL) Application #W002753-6**&**-F-R **Final Permit** 

Dear Mr. Gormley:

Enclosed please find a copy of your **final** MEPDES permit and Maine WDL **renewal** which was approved by the Department of Environmental Protection. Please read this permit/license renewal and its attached conditions carefully. You must follow the conditions in the order to satisfy the requirements of law. Any discharge not receiving adequate treatment is in violation of State Law and is subject to enforcement action.

Any interested person aggrieved by a Department determination made pursuant to applicable regulations, may appeal the decision following the procedures described in the attached DEP FACT SHEET entitled "*Appealing a Commissioner's Licensing Decision*."

If you have any questions regarding the matter, please feel free to call me at 287-7693.

Sincerely,

Gregg Wood Division of Water Quality Management Bureau of Land and Water Quality

Enc.

cc: Tanya Hovell, DEP/EMRO Sandy Mojica, USEPA Olga Vergara, USEPA Marelyn Vega, USEPA

AUGUSTA

17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017 (207) 287-3901 FAX: (207) 287-3435 RAY BLDG., HOSPITAL ST.

BANGOR 106 HOGAN ROAD BANGOR, MAINE 04401 (207) 941-4570 FAX: (207) 941-4584 PORTLAND 312 CANCO ROAD PORTLAND, MAINE 04103 (207) 822-6300 FAX: (207) 822-6303 PRESQUE ISLE 1235 CENTRAL DRIVE, SKYWAY PARK PRESQUE ISLE, MAINE 04769-2094 (207) 764-6477 FAX: (207) 764-1507

Patricia W. Aho COMMISSIONER



STATE OF MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION **17 STATE HOUSE STATION** AUGUSTA, ME 04333

## DEPARTMENT ORDER

## IN THE MATTER OF

)

)

)

)

MILO WATER DISTRICT PUBLICLY OWNED TREATMENT WORKS MILO, PISCATAQUIS COUNTY, MAINE ME0100439 W002753-6C-F-R APPROVAL

) MAINE POLLUTANT DISCHARGE **ELIMINATION SYSTEM PERMIT** AND WASTE DISCHARGE LICENSE RENEWAL

Pursuant to the provisions of the Clean Water Act, Title 33 USC, Section 1251, et. seq. and Maine Law 38 M.R.S.A., Section 414-A et seq., and applicable regulations, the Department of Environmental Protection (Department hereinafter) has considered the application of the MILO WATER DISTRICT (MWD/District/permittee hereinafter), with its supportive data, agency review comments, and other related material on file and finds the following facts:

## APPLICATION SUMMARY

The MWD has submitted a timely and complete application to the Department for the renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0100439/ Maine Waste Discharge License (WDL) #W002753-6C-D-R (permit hereinafter) which was issued by the Department on December 4, 2009, for a five-year term. The 12/4/09 permit authorized the discharge of up to a monthly average flow of 0.39 million gallons per day (MGD) of secondary treated sanitary waste waters to the Piscataquis River, Class B, in Milo, Maine.

## PERMIT SUMMARY

This permitting action is carrying forward all the terms and conditions of the previous permit except that this permit is;

- 1. Eliminating the option when calculating percent removal to report the NODI 9 code on the Discharge Monitoring Report (DMR) when the average influent concentration is less than 200 mg/L based on guidance from the U.S. Environmental Protection Agency (EPA).
- 2. Eliminating the monthly average water quality based mass and concentration limits for ammonia as a statistical evaluation on the most current 60 months of test results submitted to the Departnment indicates the discharge no longer exceeds or has a reasonable potential to exceed the chronic ambient water quality criteria (AWQC) for ammonia.

## ME0100439 W002753-6C-F-R

## PERMIT

# PERMIT SUMMARY (cont'd)

- 3. Incorporating previously established average and maximum technology based concentration limits for total mercury so the results can be tracked in the federal Integrated Compliance Information System (ICIS).
- 4. Eliminating Special Condition C, *Disinfection*, from the permit as the Department has reconsidered the necessity of said condition.
- 5. Establishing a seasonal (June 1 September 30) total phosphorus monitoring requirement to obtain up-to-date test results for the discharge to assist the Department in evaluating the impact on ambient water quality in the Piscataquis River.

## ME0100439 W002753-6C-F-R

### PERMIT

# CONCLUSIONS

BASED on the findings in the attached Fact Sheet dated January 13, 2015, and subject to the Conditions listed below, the Department makes the following CONCLUSIONS:

- 1. The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
- 2. The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
- 3. The provisions of the State's antidegradation policy, 38 MRSA Section 464(4)(F), will be met, in that:
  - a. Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
  - b. Where high quality waters of the State constitute an outstanding national resource, that water quality will be maintained and protected;
  - c. Where the standards of classification of the receiving water body are not met, the discharge will not cause or contribute to the failure of the water body to meet the standards of classification;
  - d. Where the actual quality of any classified receiving water body exceeds the minimum standards of the next highest classification, that higher water quality will be maintained and protected; and
  - e. Where a discharge will result in lowering the existing quality of any water body, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
- 4. The discharges will be subject to effluent limitations that require application of best practicable treatment.

# ME0100439

## PERMIT

W002753-6C-F-R

## Page 4 of 17

## ACTION

THEREFORE, the Department APPROVES the application of the MILO WATER DISTRICT, to discharge up to a monthly average flow of 0.39 million gallons per day (MGD) of secondary treated sanitary waste waters to the Piscataquis Rivers, Class B, in the Town of Milo. The discharges shall be subject to the attached conditions and all applicable standards and regulations including:

- 1. "Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable To All Permits," revised July 1, 2002, copy attached.
- 2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
- 3. This permit becomes effective upon the date of signature below and expires at midnight five (5) after that date. If a renewal application is timely submitted and accepted as complete for processing prior to the expiration of this permit, the terms and conditions of this permit and all subsequent modifications and minor revisions thereto remain in effect until a final Department decision on the renewal application becomes effective. [Maine Administrative Procedure Act, 5 M.R.S.A. § 10002 and Rules Concerning the Processing of Applications and Other Administrative Matters, 06-096 CMR 2(21)(A) (effective April 1, 2003)].

DONE AND DATED AT AUGUSTA, MAINE, THIS  $2^{NO}$  DAY OF March , 2015.

COMMISSIONER OF ENVIRONMENTAL PROTECTION

## PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application \_\_\_\_\_ July 28, 2014

Date of application acceptance July 29, 2014

Filed
-------

MAR 0 3 2015

State of Maine Board of Environmental Protection

Date filed with Board of Environmental Protection

This Order prepared by GREGG WOOD, BUREAU OF LAND & WATER QUALITY ME0100439 2015 2/17/15

W002753-6C-F-R

## SPECIAL CONDITIONS

# A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge secondary treated waste waters to the Piscataquis River. Such treated waste water discharges shall be limited and monitored by the permittee as specified below.

Effluent Characteristic		<u> </u>	Minimum Monitoring Requirements					
	Monthly <u>Average</u>	Weekly <u>Average</u>	Daily <u>Maximum</u>	Monthly <u>Average</u>	Weekly <u>Average</u>	Daily <u>Maximum</u>	Measurement <u>Frequency</u>	Sample Type
Flow [50050]	0.39 MGD <sub>[03]</sub>		Report (MGD) <sub>1037</sub>	481,00400			Continuous 199/997	Recorder /RCI
Biochemical Oxygen Demand (BOD <sub>5</sub> ) <sup>(Ia)</sup> [00310]	98 lbs/Day <sub>[26]</sub>	146 lbs/Day	163 lbs/Day <sub>[26]</sub>	30 mg/L [19]	45 mg/L [19]	50 mg/L <sub>[19]</sub>	2/Month [02/30]	Composite [24]
BOD <sub>5</sub> % Removal <sup>(1b)</sup> [81010]	<b></b>			85% <sub>[23]</sub>		- <u>11</u> 10-10	1/Month <sub>[01/30]</sub>	Calculate <sub>[CA]</sub>
Total Suspended Solids (TSS) <sup>(1a)</sup> [00530]	98 lbs/Day <sub>[26]</sub>	146 lbs/Day [26]	163 lbs/Day <sub>[26]</sub>	30 mg/L [19]	45 mg/L. [19]	50 mg/L [19]	2/Month [02/30]	Composite [24]
TSS % Removal (1b) [810] 1]				85% <sub>/237</sub>		94 TH 56	1/Month <sub>/01/301</sub>	Calculate <sub>/CA1</sub>
<u>E. coli Bacteria</u> <sup>(2)</sup> <sub>[31633]</sub> (May 15 – September 30)				64/100 ml <sup>(3)</sup>		236/100 ml	2/Month [02/30]	Grab <sub>[GR]</sub>
Total Residual Chlorine <sup>(4)</sup>						0.16 mg/L //21	1/Day <sub>[01/01]</sub>	Grab <sub>[GR]</sub>
pH (Std. Units) 1004007						6.0 <b>-</b> 9.0 <sup>(5)</sup>	5/Week [05/07]	Grab <sub>[GR]</sub>
<u>Total Phosphorus</u> <sup>(6)</sup> _ <sub>[00665]</sub> (June 1 – September 30)	Report lbs/Day <sub>[26]</sub>		Report lbs/Day <sub>(26)</sub>	Report mg/L		Report mg/L	1/Week <sub>[0]/07]</sub>	Grab <sub>[GR]</sub>
Copper (Total) 1010-121	0.08 lbs/Day		0.13 lbs/Day <sub>[26]</sub>		-		2/Year <sub>[02/YR]</sub>	Composite [24]
Mercury (Total) (7) [71900]				29.1 ng/L		43.7 ng/L	1/Year	Grab

Page 6 of 17

## SPECIAL CONDITIONS

ME0100439

W002753-6C-F-R

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) - OUTFALL #001A

2. SURVEILLANCE LEVEL TESTING –Beginning upon permit issuance and lasting through 24 months prior to permit expiration (Years 1, 2 & 3 of the term of the permit) and commencing again 12 months prior to permit expiration (Year 5 of the term of the permit), the permittee shall conduct surveillance level testing as follows:

Effluent Characteristic		Discharge Limitations					Monitoring Requirements	
	Monthly <u>Average</u>	Weekiy Average	Daily <u>Maximum</u>	Monthly <u>Average</u>	Weekly Average	Daily <u>Maximum</u>	Measurement <u>Frequency</u>	Sample <u>Type</u>
Whole Effluent Toxicity (WET) <sup>(8)</sup> <u>A-NOEL</u> Ceriodaphnia dubia [TDA3B] Salvelinus fontinalis [TDA6F]	- -	·				Report % [23] Report % [23]	1/Year [01/YR] 1/2 Years [01/2Y]	Composite [24] Composite [24]
<u>C-NOEL</u> Ceriodaphnia dubia [тврзв] Salvelinus fontinalis [твq6г]						2.1 % [23] Report % [23]	.1/Year [01/YR] 1/2 Years [01/29]	Composite [24] Composite [24]
Analytical Chemistry <sup>(9,11)</sup> [51477]	with the					Report ug/L [28]	1/2 Years [01/2Y]	Composite/ Grab [24/GR]

Page 7 of 17

## ME0100439 W002753-6C-F-R

## SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) - OUTFALL #001A

3. SCREENING LEVEL TESTING – Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee shall be limited and monitored by the permittee as specified below.

Effluent Characteristic			Monitoring Requirements					
	Monthly Average	Weekly Average	Daily <u>Maximum</u>	Monthly <u>Average</u>	Weekly Average	Daily <u>Maximum</u>	Measurement Frequency	Sample Type
<u>Whole Effluent Toxicity (WET)</u> <sup>(8)</sup> <u>A-NOEL</u> Ceriodaphnia dubia [ПДАЗВ] Salvelinus fontinalis [ПДА6Г]				_		Report % [23] Report % [23]	2/Year [02/YR] 2/Year [02/YR]	Composite [24] Composite [24]
<u>C-NOEL</u> Ceriodaphnia dubia [ТВРЗВ] Salvelinus fontinalis [ТВQ6F]						2.1 % [23] Report % [23]	2/Year [02/YR] 2/Year [02/YR]	Composite [24] Composite [24]
Analytical Chemistry <sup>(9,11)</sup> [51477]	<b></b>	Note the second se				Report ug/L. [28]	1/Quarter [01/90]	Composite/ Grab [24/GR]
Priority Pollutants <sup>(10,11)</sup>		6.19.70			******	Report ug/L.	1/Year 	Composite/ Grab [24/GR]

## SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

## Sampling Locations:

Influent sampling for BOD<sub>5</sub> and TSS shall be sampled between the Ferry Road Pump Station and the first lagoon.

Effluent sampling shall be sampled after the last treatment unit (including dechlorination) on a year-round basis.

Any change in sampling location(s) must be reviewed and approved by the Department in writing.

Sampling – Sampling and analysis must be conducted in accordance with; a) methods approved in 40 Code of Federal Regulations (CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, or c) as otherwise specified by the Department. Samples that are sent out for analysis shall be analyzed by a laboratory certified by the State of Maine's Department of Human Services. Samples that are sent to another POTW licensed pursuant to *Waste discharge licenses*, 38 M.R.S.A. § 413 are subject to the provisions and restrictions of *Maine Comprehensive and Limited Environmental Laboratory Certification Rules*, 10-144 CMR 263 (last amended February 13, 2000). Laboratory facilities that analyze compliance samples in-house are subject to the provisions and restrictions of the *Maine Comprehensive and Limited Laboratory Certification Rules*, 10-144 CMR 263 (last amended February 13, 2000).

#### 1. BOD & TSS

- a. 2/Month There shall be at least ten (10) days between sampling events.
- b. Percent removal The treatment facility shall maintain a minimum of 85 percent removal of both BOD<sub>5</sub> and TSS for all flows receiving secondary treatment during all months that the facility discharges. Compliance with the limitation shall be based on a twelve-month rolling average. Calendar monthly average percent removal values shall be calculated based on influent and effluent concentrations. For the purposes of this permitting action, the twelve-month rolling average calculation is based on the most recent twelve-month period.
- 2. *E. coli* bacteria Limits are seasonal and apply between May 15<sup>th</sup> and September 30<sup>th</sup> of each calendar year. There shall be at least ten (10) days between sampling events. The Department reserves the right to require disinfection on a year-round basis to protect the health and welfare of the public.

## PERMIT

### SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### Footnotes:

- 3. *E. coli* bacteria The monthly average limitation is a geometric mean limitation and shall be calculated and reported as such.
- 4. Total Residual Chlorine (TRC) Limitations and monitoring requirements are applicable whenever elemental chlorine or chlorine based compounds are being used to disinfect the discharge. The permittee shall utilized approved test methods that are capable of bracketing the limitation of 0.16 mg/L.
- 5. **pH Range Limitation** The pH value of the effluent shall not be lower than 6.0 SU nor higher than 9.0 SU at any time unless these limitations are exceeded due to natural causes.
- 6. **Phosphorus (Total)** See Attachment A of this permit for a Department protocol for total phosphorus.
- Mercury All mercury sampling (1/Year) required to determine compliance with interim limitations established pursuant to *Interim Effluent Limitations and Controls for the Discharge* of Mercury, 06-096 CMR 519 (last amended October 6, 2001) shall be conducted in accordance with EPA's "clean sampling techniques" found in EPA Method 1669, <u>Sampling Ambient Water</u> For Trace Metals At EPA Water Quality Criteria Levels. All mercury analyses shall be conducted in accordance with EPA Method 1631E, <u>Determination of Mercury in Water by</u> <u>Oxidation, Purge and Trap, and Cold Vapor Fluorescence Spectrometry.</u> See Attachment B, *Effluent Mercury Test Report*, of this permit for the Department's form for reporting mercury test results.

The limitation in the monthly average column in table Special Condition A of this permit is defined as the arithmetic mean of all the mercury tests ever conducted utilizing sampling Methods 1669 and analysis Method 1631E.

8. Whole effluent toxicity (WET) testing – Definitive WET testing is a multi-concentration testing event (a minimum of five dilutions bracketing the critical acute and chronic thresholds of 11% and 2.1% respectively), which provides a point estimate of toxicity in terms of No Observed Effect Level, commonly referred to as NOEL or NOEC. A-NOEL is defined as the acute no observed effect level with survival as the end point. C-NOEL is defined as the chronic no observed effect level with survival, reproduction and growth as the end points. The critical acute and chronic thresholds were derived as the mathematical inverse of the applicable acute and chronic dilution factors of 8.7:1 and 47:1, respectively. See Attachment C of this permit for a copy of the Department's WET reporting form.

#### SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### Footnotes:

- a. Surveillance level testing Beginning upon permit issuance and lasting through 24 months prior to permit expiration (Years 1, 2 & 3 of the term of the permit) and commencing again 12 months prior to permit expiration (Year 5 of the term of the permit), the permittee shall conduct surveillance level WET testing at a minimum frequency of once per year (1/Year) on the water flea (*Ceriodaphnia dubia*) and once every other year (1/2 Years) on the brook trout (*Salvelinus fontinalis*).
- b. Screening level testing –Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee shall conduct screening level WET testing at a minimum frequency of twice per year (2/Year) for the water flea (*Ceriodaphnia dubia*) and the brook trout (*Salvelinus fontinalis*).

WET test results must be submitted to the Department not later than the next Discharge Monitoring Report (DMR) required by the permit, provided, however, that the permittee may review the toxicity reports for up to 10 business days of their availability before submitting them. The permittee shall evaluate test results being submitted and identify to the Department possible exceedences of the critical acute and chronic water quality thresholds specified above.

Toxicity tests must be conducted by an experienced laboratory approved by the Department. The laboratory must follow procedures as described in the following USEPA methods manuals as modified by Department protocol for the brook trout. See Attachment E of this permit for the Department protocol.

- a. <u>Short Term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Water to</u> <u>Freshwater Organisms</u>, Fourth Edition, October 2002, EPA-821-R-02-013.
- b. <u>Methods for Measuring the Acute Toxicity of Effluent and Receiving Waters to Freshwater</u> and Marine Organisms, Fifth Edition, October 2002, EPA-821-R-02-012.

Each time a WET test is performed, the permittee shall sample and analyze for the parameters in the WET Chemistry and the Analytical Chemistry sections of the Department form entitled, *Maine Department of Environmental Protection, WET and Chemical Specific Data Report Form.* See Attachment D of this permit.

## SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### Footnotes:

- 9. Analytical chemistry Refers to a suite of parameters specified in Attachment D of this permit.
  - a. Surveillance level testing Beginning upon permit issuance and lasting through 24 months prior to permit expiration (Years 1, 2 & 3 of the term of the permit) and commencing again 12 months prior to permit expiration (Year 5 of the term of the permit),, the permittee shall conduct surveillance level analytical chemistry testing at a minimum frequency of once every other year (1/2 Years).
  - b. Screening level testing –Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee shall conduct analytical chemistry testing at a minimum frequency of once per calendar quarter for four consecutive calendar quarters.
- 10. Priority pollutant testing Refers to a suite of parameters specified in Attachment D of this permit.
  - a. Surveillance level testing is not required pursuant to Department rule 06-096 CMR Chapter 530.
  - b. Screening level testing Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement,, the permittee shall conduct screening level priority pollutant testing at a minimum frequency of once per year, except for those analytical chemistry parameter(s) otherwise regulated in this permit.
  - 11. Priority pollutant and analytical chemistry Testing shall be conducted on samples collected at the same time as those collected for whole effluent toxicity tests when applicable. Priority pollutant and analytical chemistry testing shall be conducted using methods that permit detection of a pollutant at existing levels in the effluent or that achieve minimum reporting levels of detection as specified by the Department.

## PERMIT

## SPECIAL CONDITIONS

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### Footnotes:

Test results must be submitted to the Department not later than the next Discharge Monitoring Report (DMR) required by the permit, provided however, that the permittee may review the toxicity reports for up to 10 business days of their availability before submitting them. The permittee shall evaluate test results being submitted and identify to the Department, possible exceedences of the acute, chronic or human health AWQC as established in *Surface Water Quality Criteria for Toxic Pollutants*, 06-096 CMR 584 (effective October 9, 2005). For the purposes of DMR reporting, enter a "1" for <u>yes</u>, testing done this monitoring period or "NODI-9" monitoring <u>not required</u> this period.

## **B. NARRATIVE EFFLUENT LIMITATIONS**

- 1. The effluent shall not contain a visible oil sheen, foam or floating solids at any time which would impair the uses designated for the classification of the receiving waters.
- 2. The effluent shall not contain materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the uses designated for the classification of the receiving waters.
- 3. The discharges shall not cause visible discoloration or turbidity in the receiving waters which would impair the uses designated for the classification of the receiving waters.
- 4. Notwithstanding specific conditions of this permit the effluent must not lower the quality of any classified body of water below such classification, or lower the existing quality of any body of water if the existing quality is higher than the classification.

## C. TREATMENT PLANT OPERATOR

The person who has the management responsibility over the treatment facility must hold a **Grade II** certificate (or higher) or must be a Maine Registered Professional Engineer pursuant to *Sewerage Treatment Operators*, Title 32 M.R.S.A., Sections 4171-4182 and *Regulations for Wastewater Operator Certification*, 06-096 CMR 531 (effective May 8, 2006). All proposed contracts for facility operation by any person must be approved by the Department before the permittee may engage the services of the contract operator.

## SPECIAL CONDITIONS

## **D. LIMITATIONS FOR INDUSTRIAL USERS**

Pollutants introduced into the wastewater collection and treatment system by a non-domestic source (user) must not pass through or interfere with the operation of the treatment system. The permittee must conduct an Industrial Waste Survey (IWS) any time a new industrial user proposes to discharge within its jurisdiction; an existing user proposes to make a significant change in its discharge; or at an alternative minimum, once every permit cycle and submit the results to the Department. The IWS must identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging into the POTW subject to Pretreatment Standards under section 307(b) of the federal Clean Water Act, 40 CFR Part 403 (general pretreatment regulations) or *Pretreatment Program*, 06-096 CMR 528 (last amended March 17, 2008).

## E. AUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with: 1) the permittee's General Application for Waste Discharge Permit, accepted for processing on July 29, 2014; 2) the terms and conditions of this permit; and 3) only from Outfall #001. Discharges of waste water from any other point source are not authorized under this permit, and shall be reported in accordance with Standard Condition B(5)(*Bypass*) of this permit.

## F. NOTIFICATION REQUIREMENT

In accordance with Standard Condition D, the permittee shall notify the Department of the following.

- 1. Any introduction of pollutants into the waste water collection and treatment system from an indirect discharger in a primary industrial category discharging process waste water; and
- 2. Any substantial change in the volume or character of pollutants being introduced into the waste water collection and treatment system by a source introducing pollutants into the system at the time of permit issuance. For the purposes of this section, notice regarding substantial change shall include information on:
  - (a) the quality and quantity of waste water introduced to the waste water collection and treatment system; and
  - (b) any anticipated impact caused by the change in the quantity or quality of the waste water to be discharged from the treatment system.

## Page 14 of 17

## SPECIAL CONDITIONS

## G. WET WEATHER FLOW MANAGEMENT PLAN

The treatment facility staff shall maintain a current written Wet Weather Flow Management Plan to direct the staff on how to operate the facility effectively during periods of high flow. The Department acknowledges that the existing collection system may deliver flows in excess of the monthly average design capacity of the treatment plant during periods of high infiltration and rainfall.

Within 90 days of completion of new and or substantial upgrades of the waste water treatment facility, the permittee shall submit to the Department for review and approval, a new or revised Wet Weather Management Plan which conforms to Department guidelines for such plans. The revised plan shall include operating procedures for a range of intensities, address solids handling procedures (including septic waste and other high strength wastes if applicable) and provide written operating and maintenance procedures during the events. The permittee shall review their plan annually and record any necessary changes to keep the plan up to date.

## H. OPERATION & MAINTENANCE (O&M) PLAN

This facility shall maintain a current written comprehensive Operation & Maintenance (O&M) Plan. The plan shall provide a systematic approach by which the permittee shall at all times, properly operate and maintain all facilities and systems of transport, treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit.

By December 31 of each year, or within 90 days of any process changes or minor equipment upgrades, the permittee shall evaluate and modify the O&M Plan including site plan(s) and schematic(s) for the waste water treatment facility to ensure that it is up-to-date. The O&M Plan shall be kept on-site at all times and made available to Department and EPA personnel upon request.

Within 90 days of completion of new and or substantial upgrades of the waste water treatment facility, the permittee shall submit the updated O&M Plan to their Department inspector for review and comment.

## SPECIAL CONDITIONS

# I. DISPOSAL OF TRANSPORTED WASTE INTO THE WASTE WATER TREATMENT FACILITY

The permittee is prohibited from accepting transported waste for disposal into any part or parts of the wastewater disposal system. "Transported wastes" means any liquid non-hazardous waste delivered to a wastewater treatment facility by a truck or other similar conveyance that has different chemical constituents or a greater strength than the influent described on the facility's application for a waste discharge license. Such wastes may include, but are not limited to septage, industrial wastes or other wastes to which chemicals in quantities potentially harmful to the treatment facility or receiving water have been added.

## J. 06-096 CMR 530(2)(D)(4) STATEMENT FOR REDUCED/WAIVED TOXICS TESTING

By December 31 of each calendar year, the permittee shall provide the Department with a certification describing any of the following that have occurred since the effective date of this permit *[ICIS Code 75305]*: See Attachment F of the <u>Fact Sheet</u> of this permit for an acceptable certification form to satisfy this Special Condition.

- 1. Changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge;
- 2. Changes in the operation of the treatment works that may increase the toxicity of the discharge; and
- 3. Changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge.

Further, the Department may require that annual WET or priority pollutant testing be reinstituted if it determines that there have been changes in the character of the discharge or if annual certifications described above are not submitted.

(d) Changes in storm water collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge.

(e) Increases in the type or volume of hauled wastes accepted by the facility.

The Department reserves the right to reinstate annual (surveillance level) testing or other toxicity testing if new information becomes available that indicates the discharge may cause or have a reasonable potential to cause exceedences of ambient water quality criteria/thresholds.

ME0100439 W002753-6C-F-R

## SPECIAL CONDITIONS

## K. MONITORING AND REPORTING

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report (DMR) forms provided by the Department and postmarked on or before the thirteenth (13<sup>th</sup>) day of the month or hand-delivered to a Department Regional Office such that the DMR's are received by the Department on or before the fifteenth (15<sup>th</sup>) day of the month following the completed reporting period. A signed copy of the DMR and all other reports required herein shall be submitted to the following address:

Department of Environmental Protection Eastern Maine Regional Office Bureau of Land and Water Quality Division of Water Quality Management 106 Hogan Road Bangor, Maine 04401

Alternatively, if you are submitting an electronic DMR (eDMR), the completed eDMR must be electronically submitted to the Department by a facility authorized DMR Signatory not later than close of business on the  $15^{\text{th}}$  day of the month following the completed reporting period. Hard Copy documentation submitted in support of the eDMR must be postmarked on or before the thirteenth  $(13^{\text{th}})$  day of the month or hand-delivered to the Department's Regional Office such that it is received by the Department on or before the fifteenth  $(15^{\text{th}})$  day of the month following the completed reporting period. Electronic documentation in support of the eDMR must be submitted not later than close of business on the  $15^{\text{th}}$  day of the month following the completed reporting period.

## L. REOPENING OF PERMIT FOR MODIFICATIONS

Upon evaluation of the tests results or monitoring requirements specified in Special Conditions of this permitting action, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at anytime and with notice to the permittee, modify this permit to; 1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded, (2) require additional effluent and or ambient water quality monitoring if results on file are inconclusive; or (3) change monitoring requirements or limitations based on new information.

## PERMIT

## SPECIAL CONDITIONS

## **M. SEVERABILITY**

In the event that any provision(s), or part thereof, of this permit is declared to be unlawful by a reviewing court, the remainder of the permit shall remain in full force and effect, and shall be construed and enforced in all aspects as if such unlawful provision, or part thereof, had been omitted, unless otherwise ordered by the court.

# STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

## **CONTENTS**

SECTI	ON	TOPIC	PAGE
А		GENERAL PROVISIONS	
	1	General compliance	2
	2	Other materials	
	3	Duty to Comply	2
	4	Duty to provide information	2
	5	Permit actions	2
	6	Reopener clause	2 2 2 2 2 2 2 3 3 3 3 3 3 3 3
	7	Oil and hazardous substances	2
	8	Property rights	3
	9	Confidentiality	3
		Duty to reapply	3
		Other laws	3
	12	Inspection and entry	3
в		OPERATION AND MAINTENANCE OF FACILITIES	
	1	General facility requirements	3
	2	Proper operation and maintenance	4
	3	Need to halt reduce not a defense	4
	4	Duty to mitigate	4
	5	Bypasses	4
	6	Upsets	5
С		MONITORING AND RECORDS	
	1	General requirements	6
	2	Representative sampling	6
	3	Monitoring and records	6
D		REPORTING REQUIREMENTS	
	1	Reporting requirements	7
	2	Signatory requirement	8
	3	Availability of reports	8
	4	Existing manufacturing, commercial, mining, and silvicultural dischargers	8
	5	Publicly owned treatment works	9
Е		OTHER PROVISIONS	
	1	Emergency action - power failure	9
	2	Spill prevention	10
	3	Removed substances	10
	4	Connection to municipal sewer	10
F		DEFINTIONS	10

\_\_\_\_\_

#### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

#### A. GENERAL PROVISIONS

1. General compliance. All discharges shall be consistent with the terms and conditions of this permit; any changes in production capacity or process modifications which result in changes in the quantity or the characteristics of the discharge must be authorized by an additional license or by modifications of this permit; it shall be a violation of the terms and conditions of this permit to discharge any pollutant not identified and authorized herein or to discharge in excess of the rates or quantities authorized herein or to violate any other conditions of this permit.

**2.** Other materials. Other materials ordinarily produced or used in the operation of this facility, which have been specifically identified in the application, may be discharged at the maximum frequency and maximum level identified in the application, provided:

- (a) They are not
  - (i) Designated as toxic or hazardous under the provisions of Sections 307 and 311, respectively, of the Federal Water Pollution Control Act; Title 38, Section 420, Maine Revised Statutes; or other applicable State Law; or
  - (ii) Known to be hazardous or toxic by the licensee.
- (b) The discharge of such materials will not violate applicable water quality standards.

**3.** Duty to comply. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of State law and the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- (a) The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act, and 38 MRSA, §420 or Chapter 530.5 for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
- (b) Any person who violates any provision of the laws administered by the Department, including without limitation, a violation of the terms of any order, rule license, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

4. Duty to provide information. The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

5. Permit actions. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

6. Reopener clause. The Department reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedule of compliance or other provisions which may be authorized under 38 MRSA, §414-A(5).

Revised July 1, 2002

#### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

7. Oil and hazardous substances. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under section 311 of the Federal Clean Water Act; section 106 of the Federal Comprehensive Environmental Response, Compensation and Liability Act of 1980; or 38 MRSA

8. Property rights. This permit does not convey any property rights of any sort, or any exclusive privilege.

9. Confidentiality of records. 38 MRSA §414(6) reads as follows. "Any records, reports or information obtained under this subchapter is available to the public, except that upon a showing satisfactory to the department by any person that any records, reports or information, or particular part or any record, report or information, other than the names and addresses of applicants, license applications, licenses, and effluent data, to which the department has access under this subchapter would, if made public, divulge methods or processes that are entitled to protection as trade secrets, these records, reports or information must be confidential and not available for public inspection or examination. Any records, reports or information may be disclosed to employees or authorized representatives of the State or the United States concerned with carrying out this subchapter or any applicable federal law, and to any party to a hearing held under this section on terms the commissioner may prescribe in order to protect these confidential records, reports and information, as long as this disclosure is material and relevant to any issue under consideration by the department."

**10.** Duty to reapply. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.

**11.** Other laws. The issuance of this permit does not authorize any injury to persons or property or invasion of other property rights, nor does it relieve the permittee if its obligation to comply with other applicable Federal, State or local laws and regulations.

**12.** Inspection and entry. The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the EPA Administrator), upon presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## **B. OPERATION AND MAINTENACE OF FACILITIES**

- 1. General facility requirements.
  - (a) The permittee shall collect all waste flows designated by the Department as requiring treatment and discharge them into an approved waste treatment facility in such a manner as to

§§ 1301, et. seq.

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

maximize removal of pollutants unless authorization to the contrary is obtained from the Department.

\_\_\_\_\_

- (b) The permittee shall at all times maintain in good working order and operate at maximum efficiency all waste water collection, treatment and/or control facilities.
- (c) All necessary waste treatment facilities will be installed and operational prior to the discharge of any wastewaters.
- (d) Final plans and specifications must be submitted to the Department for review prior to the construction or modification of any treatment facilities.
- (e) The permittee shall install flow measuring facilities of a design approved by the Department.
- (f) The permittee must provide an outfall of a design approved by the Department which is placed in the receiving waters in such a manner that the maximum mixing and dispersion of the wastewaters will be achieved as rapidly as possible.

2. Proper operation and maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

**3.** Need to halt or reduce activity not a defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

4. Duty to mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

## 5. Bypasses.

(a) Definitions.

- (i) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
- (ii) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- (b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this section.
- (c) Notice.
  - (i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

\_\_\_\_\_

Revised July 1, 2002

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D(1)(f), below. (24-hour notice).
- (d) Prohibition of bypass.
  - (i) Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
    - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
    - (C) The permittee submitted notices as required under paragraph (c) of this section.
  - (ii) The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in paragraph (d)(i) of this section.

#### 6. Upsets.

- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (c) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (ii) The permitted facility was at the time being properly operated; and
  - (iii) The permittee submitted notice of the upset as required in paragraph D(1)(f), below. (24 hour notice).
  - (iv) The permittee complied with any remedial measures required under paragraph B(4).
- (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

#### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

\_\_\_\_\_\_

#### C. MONITORING AND RECORDS

1. General Requirements. This permit shall be subject to such monitoring requirements as may be reasonably required by the Department including the installation, use and maintenance of monitoring equipment or methods (including, where appropriate, biological monitoring methods). The permittee shall provide the Department with periodic reports on the proper Department reporting form of monitoring results obtained pursuant to the monitoring requirements contained herein.

2. Representative sampling. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. If effluent limitations are based wholly or partially on quantities of a product processed, the permittee shall ensure samples are representative of times when production is taking place. Where discharge monitoring is required when production is less than 50%, the resulting data shall be reported as a daily measurement but not included in computation of averages, unless specifically authorized by the Department.

#### 3. Monitoring and records.

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.
- (c) Records of monitoring information shall include:
  - (i) The date, exact place, and time of sampling or measurements;
  - (ii) The individual(s) who performed the sampling or measurements;
  - (iii) The date(s) analyses were performed;
  - (iv) The individual(s) who performed the analyses;
  - (v) The analytical techniques or methods used; and
  - (vi) The results of such analyses.
- (d) Monitoring results must be conducted according to test procedures approved under 40 CFR part 136, unless other test procedures have been specified in the permit.
- (e) State law provides that any person who tampers with or renders inaccurate any monitoring devices or method required by any provision of law, or any order, rule license, permit approval or decision is subject to the penalties set forth in 38 MRSA, §349.

#### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

#### **D. REPORTING REQUIREMENTS**

## 1. Reporting requirements.

- (a) Planned changes. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
  - (i) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
  - (ii) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under Section D(4).
  - (iii) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
- (b) Anticipated noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- (c) Transfers. This permit is not transferable to any person except upon application to and approval of the Department pursuant to 38 MRSA, § 344 and Chapters 2 and 522.
- (d) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
  - (i) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Department for reporting results of monitoring of sludge use or disposal practices.
  - (ii) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR part 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Department.
  - (iii) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Department in the permit.
- (e) Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- (f) Twenty-four hour reporting.

(i) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- (ii) The following shall be included as information which must be reported within 24 hours under this paragraph.
  - (A) Any unanticipated bypass which exceeds any effluent limitation in the permit.
  - (B) Any upset which exceeds any effluent limitation in the permit.
  - (C) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit to be reported within 24 hours.
- (iii) The Department may waive the written report on a case-by-case basis for reports under paragraph (f)(ii) of this section if the oral report has been received within 24 hours.
- (g) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (d), (e), and (f) of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (f) of this section.
- (h) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

2. Signatory requirement. All applications, reports, or information submitted to the Department shall be signed and certified as required by Chapter 521, Section 5 of the Department's rules. State law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan or other document filed or required to be maintained by any order, rule, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

**3.** Availability of reports. Except for data determined to be confidential under A(9), above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. As required by State law, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal sanctions as provided by law.

4. Existing manufacturing, commercial, mining, and silvicultural dischargers. In addition to the reporting requirements under this Section, all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Department as soon as they know or have reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - (i) One hundred micrograms per liter (100 ug/l);
  - (ii) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
  - (iii) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or
  - (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

化体制发生素化学学学家学习学习学习学习学习学习学习和自由和自由和自由和自由和自由和自由和自由和自由和自己的不可能在实际学习学习

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (b) That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following ``notification levels":
  - (i) Five hundred micrograms per liter (500 ug/l);
  - (ii) One milligram per liter (1 mg/l) for antimony;
  - (iii) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or
  - (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

#### 5. Publicly owned treatment works.

- (a) All POTWs must provide adequate notice to the Department of the following:
  - (i) Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA or Chapter 528 if it were directly discharging those pollutants.
  - (ii) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
  - (iii) For purposes of this paragraph, adequate notice shall include information on (A) the quality and quantity of effluent introduced into the POTW, and (B) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (b) When the effluent discharged by a POTW for a period of three consecutive months exceeds 80 percent of the permitted flow, the permittee shall submit to the Department a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.

## E. OTHER REQUIREMENTS

1. Emergency action - power failure. Within thirty days after the effective date of this permit, the permittee shall notify the Department of facilities and plans to be used in the event the primary source of power to its wastewater pumping and treatment facilities fails as follows.

(a) For municipal sources. During power failure, all wastewaters which are normally treated shall receive a minimum of primary treatment and disinfection. Unless otherwise approved, alternate power supplies shall be provided for pumping stations and treatment facilities. Alternate power supplies shall be on-site generating units or an outside power source which is separate and independent from sources used for normal operation of the wastewater facilities.

(b) For industrial and commercial sources. The permittee shall either maintain an alternative power source sufficient to operate the wastewater pumping and treatment facilities or halt, reduce or otherwise control production and or all discharges upon reduction or loss of power to the wastewater pumping or treatment facilities.

------

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

2. Spill prevention. (applicable only to industrial sources) Within six months of the effective date of this permit, the permittee shall submit to the Department for review and approval, with or without conditions, a spill prevention plan. The plan shall delineate methods and measures to be taken to prevent and or contain any spills of pulp, chemicals, oils or other contaminates and shall specify means of disposal and or treatment to be used.

3. **Removed substances.** Solids, sludges trash rack cleanings, filter backwash, or other pollutants removed from or resulting from the treatment or control of waste waters shall be disposed of in a manner approved by the Department.

4. Connection to municipal sewer. (applicable only to industrial and commercial sources) All wastewaters designated by the Department as treatable in a municipal treatment system will be cosigned to that system when it is available. This permit will expire 90 days after the municipal treatment facility becomes available, unless this time is extended by the Department in writing.

**F. DEFINITIONS.** For the purposes of this permit, the following definitions shall apply. Other definitions applicable to this permit may be found in Chapters 520 through 529 of the Department's rules

Average means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For bacteria, the average shall be the geometric mean.

Average monthly discharge limitation means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. Except, however, bacteriological tests may be calculated as a geometric mean.

Average weekly discharge limitation means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

**Best management practices ("BMPs")** means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

**Composite sample** means a sample consisting of a minimum of eight grab samples collected at equal intervals during a 24 hour period (or a lesser period as specified in the section on monitoring and reporting) and combined proportional to the flow over that same time period.

**Continuous discharge** means a discharge which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or other similar activities.

**Daily discharge** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the day.

Page 10

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

**Discharge Monitoring Report ("DMR")** means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by approved States as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA's.

Flow weighted composite sample means a composite sample consisting of a mixture of aliquots collected at a constant time interval, where the volume of each aliquot is proportional to the flow rate of the discharge.

Grab sample means an individual sample collected in a period of less than 15 minutes.

**Interference** means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Maximum daily discharge limitation means the highest allowable daily discharge.

New source means any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:

(a) After promulgation of standards of performance under section 306 of CWA which are applicable to such source, or

(b) After proposal of standards of performance in accordance with section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

**Pass through** means a discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

**Permit** means an authorization, license, or equivalent control document issued by EPA or an approved State to implement the requirements of 40 CFR parts 122, 123 and 124. Permit includes an NPDES general permit (Chapter 529). Permit does not include any permit which has not yet been the subject of final agency action, such as a draft permit or a proposed permit.

**Person** means an individual, firm, corporation, municipality, quasi-municipal corporation, state agency, federal agency or other legal entity.

### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

**Point source** means any discernible, confined and discrete conveyance, including, but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation or vessel or other floating craft, from which pollutants are or may be discharged.

**Pollutant** means dredged spoil, solid waste, junk, incinerator residue, sewage, refuse, effluent, garbage, sewage sludge, munitions, chemicals, biological or radiological materials, oil, petroleum products or byproducts, heat, wrecked or discarded equipment, rock, sand, dirt and industrial, municipal, domestic, commercial or agricultural wastes of any kind.

**Process wastewater** means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

**Publicly owned treatment works ("POTW")** means any facility for the treatment of pollutants owned by the State or any political subdivision thereof, any municipality, district, quasi-municipal corporation or other public entity.

Septage means, for the purposes of this permit, any waste, refuse, effluent sludge or other material removed from a septic tank, cesspool, vault privy or similar source which concentrates wastes or to which chemicals have been added. Septage does not include wastes from a holding tank.

Time weighted composite means a composite sample consisting of a mixture of equal volume aliquots collected over a constant time interval.

**Toxic pollutant** includes any pollutant listed as toxic under section 307(a)(1) or, in the case of sludge use or disposal practices, any pollutant identified in regulations implementing section 405(d) of the CWA. Toxic pollutant also includes those substances or combination of substances, including disease causing agents, which after discharge or upon exposure, ingestion, inhalation or assimilation into any organism, including humans either directly through the environment or indirectly through ingestion through food chains, will, on the basis of information available to the board either alone or in combination with other substances already in the receiving waters or the discharge, cause death, disease, abnormalities, cancer, genetic mutations, physiological malfunctions, including malfunctions in reproduction, or physical deformations in such organism or their offspring.

Wetlands means those areas that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole effluent toxicity means the aggregate toxic effect of an effluent measured directly by a toxicity test.

# ATTACHMENT A

## Protocol for Total Phosphorus Sample Collection and Analysis for Waste Water Effluent

Approved Analytical Methods: EPA 200.7 (Rev. 44), 365.1 (Rev. 2.0), (Lachat), 365.3, 365.4; SM 3120 B, 4500-P B.5, 4500-P E, 4500-P F, 4500-P G, 4500-P H; ASTM D515-88(A), D515-88(B); USGS I-4471-97, I-4600-85, I-4610-91; OMAAOAC 973.55, 973.56 (laboratory must be certified for any method performed)

Sample Collection: The Maine DEP is requesting that total phosphorus analysis be conducted on composite effluent samples, unless a facility's Permit specifically designates grab sampling for this parameter. Facilities can use individual collection bottles or a single jug made out of glass or polyethylene. Bottles and/or jugs should be cleaned prior to each use with dilute HCL. This cleaning should be followed by several rinses with distilled water. Commercially purchased, pre-cleaned sample containers are an acceptable alternative. The sampler hoses should be cleaned, as needed.

Sample Preservation: During compositing the sample must be at 0-6 degrees C (without freezing). If the sample is being sent to a commercial laboratory or analysis cannot be performed the day of collection then the sample must be preserved using  $H_2SO_4$  to obtain a sample pH of <2 su and refrigerated at 0-6 degrees C (without freezing). The holding time for a preserved sample is 28 days.

Note: Ideally, Total P samples are preserved as described above. However, if a facility is using a commercial laboratory then that laboratory may choose to add acid to the sample once it arrives at the laboratory. The Maine DEP will accept results that use either of these preservation methods.

Laboratory QA/QC: Laboratories must follow the appropriate QA/QC procedures that are described in each of the approved methods.

Sampling QA/QC: If a composite sample is being collected using an automated sampler, then once per month run a blank on the composite sampler. Automatically, draw distilled water into the sample jug using the sample collection line. Let this water set in the jug for 24 hours and then analyze for total phosphorus. Preserve this sample as described above.

Maine DEP, July 1, 2014 Page C1

# ATTACHMENT B

# Maine Department of Environmental Protection Effluent Mercury Test Report

Name of Facility:	Federal Permit # ME
	Pipe #
Purpose of this test: Initial limit determina Compliance monitorin Supplemental or extra	ng for: year calendar quarter
SAMPLE COLLE	CTION INFORMATION
Sampling Date:	Sampling time: AM/PM
mm dd yy Sampling Location:	
Weather Conditions:	
Please describe any unusual conditions with the time of sample collection:	influent or at the facility during or preceding the
Optional test - not required but recommended we evaluation of mercury results:	here possible to allow for the most meaningful
Suspended Solidsmg/L Sam	ple type: Grab (recommended) or Composite
ANALYTICAL RESULT	FOR EFFLUENT MERCURY
Name of Laboratory:	· · · · · · · · · · · · · · · · · · ·
Date of analysis: Please Enter Effluent Limits	Result: ng/L (PPT)
Effluent Limits: Average = ng/I	
Please attach any remarks or comments from the their interpretation. If duplicate samples were ta	e laboratory that may have a bearing on the results or aken at the same time please report the average.
CERT	IFICATION
• • •	pregoing information is correct and representative of sample for mercury was collected and analyzed 1631 (trace level analysis) in accordance with
Ву:	Date:
Title:	

# PLEASE MAIL THIS FORM TO YOUR ASSIGNED INSPECTOR

## ATTACHMENT C

## MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION WHOLE EFFLUENT TOXICITY REPORT FRESH WATERS

Facility Name				MEPDES Permi	<b>#</b>	
Facility Representative	at to the best of m	y knowledge that the	Signature	d is true, accurate,	and complete.	
Facility Telephone #			Date Collected		Date Tested	
Chlorinated?		Dechlorinated?		mm/dd/yy		mm/dd/yy
Results A-NOEL C-NOEL	water flea	nuent trout			A-NOEL C-NOEL	Effluent Limitations
Data summary		water flea			trout	
QC standard	% : A>90	survival C>80	no. young >15/female	% s 	urvival C>80	final weight (mg) > 2% increase
lab control	11. 30					
receiving water control						
conc. 1 ( %) conc. 2 ( %)						
conc. 3 ( %)						-
conc. 4 ( %)						
conc. 5 ( %)						
conc. 6 ( %)	101 <b>I</b>					
stat test used nlace * nex	t to values stati	stically different	from controls			
P		-				r for both controls
Reference toxicant	wate		tro	ut		
<b>.</b> .	A-NOEL	C-NOEL	A-NOEL	C-NOEL	1	
toxicant / date limits (mg/L)						
results (mg/L)						
-		1				
Comments						
Laboratory conducting tes	:f					
Company Name	it.		Company Rep. Na	me (Printed)		
Mailing Address			Company Rep. Sig	;nature		
City, State, ZIP			Company Telepho	ne#	<u>.</u>	

## Report WET chemistry on DEP Form "ToxSheet (Fresh Water Version), March 2007."

## ATTACHMENT D

Printed 5/5/2014

## Maine Department of Environmental Protection

WET and Chemical Specific Data Report Form

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

	Facility Name			MEPDES # Pipe #		Facility R	epresentative Signature To the best of my kr	owledge this info	ormation is true	, accurate an	d complete.
	Licensed Flow (MGD) Acute dilution factor			Flow for	Day (MGD) <sup>(1)</sup>		Flow Avg. for M	onth (MGD) <sup>(2)</sup>		]	
	Chronic dilution factor			Date Samp	le Collected		Date San	ple Analyzed			
	Human health dilution factor Criteria type: M(arine) or F(resh)	f			Laboratory				Telephone		
	Cineria type. m(arme) or P(resit)	•			Address				relephone	<u>.</u>	
	Last Revision - April 24, 2014								•		
			ATER VER	SION	Lab Contact				Lab ID #		
	ERROR WARNING   Essential facility _ information is missing. Please check	110.00110			.	Receiving		l			
	required entries in bold above.	Please see the fo	otnotes on t	he last page.	•	Water or Ambient	Effluent Concentration (ug/L or as noted)				
	WHOLE EFFLUENT TOXICITY					oranga wanganga					
			Effluent Acute	Limits, % Chronic			WET Result, % Do not enter % sign	Reporting Limit Check	Possible	Exceede	ence <sup>(7)</sup>
	Trout - Acute										
	Trout - Chronic										
	Water Flea - Acute										
1719-999-939-95-95	Water Flea - Chronic	*****		217 2257 <b>2</b> 74 4 1 1 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1		Webellever and the second s		AND ADDRESSION FRAMEWORK TOTAL			
			provide la provide de la pr			an a	a de compression de la compression			an a	
	pH (S.U.) (9)										
	Total Organic Carbon (mg/L)					(8)				L	
	Total Solids (mg/L)									L'	
	Total Suspended Solids (mg/L)										
	Alkalinity (mg/L)					(8)					
	Specific Conductance (umhos)									L	
<u> </u>	Total Hardness (mg/L)					(8)				ļ'	
	Total Magnesium (mg/L)					(8)				ļ'	
REPORT	Total Calcium (mg/L)	MERCHARD MARCHINE	201202020202020		ound this which the state	(8)				AMMEDING	
	ANALYTICAL CHEMISTRY (3)		PROPERTY OF STREET		nde of deledente						
	Also do these tests on the effluent with	•	Fff	luent Limits,	ua/l		· · · ·		Possible	e Exceed	ence <sup>(7)</sup>
	WET. Testing on the receiving water is			Chronic <sup>(6)</sup>	Health <sup>(6)</sup>			Reporting			
	optional	Reporting Limit	Acute	Chronic	nealur ·			Limit Check	Acute	Chronic	Health
	TOTAL RESIDUAL CHLORINE (mg/L) (9)	0.05			<u> </u>	NA			ļ	<u>↓</u>	<b>├───</b> ┤
м		NA NA				(8)				<u> </u>	
M	ARSENIC	5 5			<b> </b>	(8)				<b>├</b> '	<u> </u>
M	CADMIUM					(8)				├───	
M	CHROMIUM	10				(8)			-		
M	COPPER	3			1	(8)	<b> </b>	[			
M	CYANIDE, TOTAL	5				(8).	·····			<u> </u>	
	CYANIDE, AVAILABLE <sup>(3a)</sup>	5				(8)					
M	LEAD	3			1	(8)					
м	NICKEL	5				(8)	<u> </u>				
М	SILVER	1				(8)					
М	ZINC	5				(8)	l		1		1

Revised April 24, 2014

DEPLW 0740-G2014

WET and Chemical Specific Data Report Form

## This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

	PRIORITY POLLUTANTS (4)				a second and a second						
				Effluent Limi	ts			Reporting	Possible	e Exceed	ence <sup>(7)</sup>
		Reporting Limit	Acute <sup>(6)</sup>	Chronic <sup>(6)</sup>	Health <sup>(6)</sup>			Limit Check	Acute	Chronic	Health
М	ANTIMONY	5									
м	BERYLLIUM	2									
M	MERCURY (5)	0.2		(menuntrational	liter and the second	NU MIMBOUR					THE REPORT
M	SELENIUM	5		· ·							
м	THALLIUM	4	Γ								
A	2,4,6-TRICHLOROPHENOL	5									
٩	2,4-DICHLOROPHENOL	5	·							r	
4	2,4-DIMETHYLPHENOL	5									
4	2,4-DINITROPHENOL	45	T	1					-		
4	2-CHLOROPHENOL	5									1
4	2-NITROPHENOL	5									
	4,6 DINITRO-O-CRESOL (2-Methyl-4,6-							······			
A	dinitrophenol)	25									
A.	4-NITROPHENOL	20		1							1
	P-CHLORO-M-CRESOL (3-methyl-4-		1								
Ą	chlorophenoi)+B80	5									
Ă.	PENTACHLOROPHENOL	20									
Ā	PHENOL	5	1	1		· · · ·					
3N	1,2,4-TRICHLOROBENZENE	5	+	1							<u>├</u> ────
BN	1,2-(O)DICHLOROBENZENE	5						<u> </u>	1	<u> </u>	
BN	1.2-DIPHENYLHYDRAZINE	20	+								
BN	1.3-(M)DICHLOROBENZENE	5			<u> </u>						+
BN	1,4-(P)DICHLOROBENZENE	5	+		<u> </u>			· · · · · ·			ł
BN	2,4-DINITROTOLUENE	6	<u> </u>		<u> </u>				 		
	2,6-DINITROTOLUENE	5						<u> </u>	<u> </u>		+
BN	2-CHLORONAPHTHALENE	5						· · · · ·			
	3,3'-DICHLOROBENZIDINE	16.5						<b> </b>			
	3.4-BENZO(B)FLUORANTHENE	5	╂────		<u> </u>					<u>↓.                                    </u>	
	4-BROMOPHENYLPHENYL ETHER	5			┣━━━━━		ł	<u> </u>	<u> </u>		╋━━━━━
	4-CHLOROPHENYL PHENYL ETHER	5									
*****		5	+							<u> </u>	
BN			+								
BN		5	+								+
	ANTHRACENE		+							<u> </u>	+
BN	BENZIDINE BENZO(A)ANTHRACENE	45	+					<u> </u>	·	<u> </u>	+
BN		8								<b></b>	
BN										<u> </u>	+
BN	BENZO(G,H,I)PERYLENE	5	<u> </u>		<u> </u>			┣───		<u> </u>	┿
BN		5	<u> </u>		<u> </u>		<u> </u>	╀────			<del> </del>
BN	BIS(2-CHLOROETHOXY)METHANE	5		·	┣_───					<u> </u>	
BN	BIS(2-CHLOROETHYL)ETHER	6	4				┠			<u> </u>	
BN	BIS(2-CHLOROISOPROPYL)ETHER	6				·	Į				
BN	BIS(2-ETHYLHEXYL)PHTHALATE	10						╉────			
BN	BUTYLBENZYL PHTHALATE	5			<u> </u>			┫			
BN	CHRYSENE	5		.l.	· ·			┫			4
BN	DI-N-BUTYL PHTHALATE	5					Į		·		
BN	DI-N-OCTYL PHTHALATE	5			<u> </u>	ļ	L			<u> </u>	
BN	DIBENZO(A,H)ANTHRACENE	5			1		l			<u> </u>	
₿N	DIETHYL PHTHALATE	5					L				4
ΒN	DIMETHYL PHTHALATE	5	1	1			<u>.</u>		1		

Revised April 24, 2014

DEPLW 0740-G2014

WET and Chemical Specific Data Report Form This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

DM 0	FLUORANTHENE	5			1		· · · · · · · · · · · · · · · · · · ·				
	FLUORENE	5			<u> </u>						
	HEXACHLOROBENZENE				<u> </u>			·			
	HEXACHLOROBUTADIENE	5			┣━━━			·			
		5									
BN	HEXACHLOROCYCLOPENTADIENE	10		<del></del>	<u> </u>						
BN	HEXACHLOROETHANE	5		-							
	INDENO(1,2,3-CD)PYRENE	5									
	ISOPHORONE	5									
BN	N-NITROSODI-N-PROPYLAMINE	10					· · ·				
	N-NITROSODIMETHYLAMINE	5									
	N-NITROSODIPHENYLAMINE	5									
	NAPHTHALENE	5									
	NITROBENZENE	5	1		<u> </u>						
	PHENANTHRENE	5									
	PYRENE	5									
	4,4'-DDD ·	0.05									
	4,4'-DDE	0.05	-								
Ρ	4,4'-DDT	0.05								1	
P	A-BHC	0.2			1		· · · · · · · · · · · · · · · · · · ·				
P	A-ENDOSULFAN	0.05			1		· · · · · · · · · · · · · · · · · · ·				
P	ALDRIN	0.15			t						
P	B-BHC	0.05				[			1		
Р	B-ENDOSULFAN	0.05									
	CHLORDANE	0.1			1						
P	D-BHC	0.05			1			······			
	DIELDRIN	0.05									· ·
	ENDOSULFAN SULFATE	0.1									[
Law and the second	ENDRIN	0.05			<u>                                     </u>						
	ENDRIN ALDEHYDE	0.05			┼────						
	G-BHC	0.15				<u> </u>					
	HEPTACHLOR	0.15	•						1		
Line and the second	HEPTACHLOR EPOXIDE	0.1							<u>k</u>		
P	PCB-1016	0.3			<u> </u>				<del> </del>	t	<u> </u>
	PCB-1221	0.3			┼────			<b> </b>			
· P	PCB-1232	0.3	· .								
P	PCB-1242	0.3			<u> </u>					· · · · · · · · · · · · · · · · · · ·	
P	PCB-1248	0.3			╆────		· · · · · · · · · · · · · · · · · · ·	<u> </u>			
F	PCB-1254	0.3			+				· .		
P	PCB-1260	0.2			┼────		<u> </u>				
P	TOXAPHENE	1			┼────			·	+		
V	1,1,1-TRICHLOROETHANE	5	·	<u> </u>	+	1	···		1		<u> </u>
	1,1,2,2-TETRACHLOROETHANE	7			+		·····				
₩	1,1,2,2-TETRACHLOROETHANE	5			- <u>+</u>	1					
	1,1-DICHLOROETHANE	5				+		<u> </u>	+		· · · · ·
<b>⊬</b>	1,1-DICHLOROETHANE	<u> </u>			<u> </u>			<b></b>	+		
		<b>^</b>									
V.	dichloroethene)	3		<u> </u>	<u> </u>						
V	1.2-DICHLOROETHANE	3						╉────			
<u>v</u>	1,2-DICHLOROPROPANE	6		ļ	┣───			·I			
1	1,2-TRANS-DICHLOROETHYLENE (1,2-	_				1.	1		1		
V	trans-dichloroethene)	5	<u> </u>		<u> </u>					Ļ	1
	1,3-DICHLOROPROPYLENE (1,3-					1		1			
	dichloropropene)	5	ļ	ļ	<u> </u>				.l	· ·	
V IV	2-CHLOROETHYLVINYL ETHER	20							l	l	

Revised April 24, 2014

DEPLW 0740-G2014

WET and Chemical Specific Data Report Form

#### This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

_						 
	ACROLEIN	NA		 		
V	ACRYLONITRILE	NA				
V	BENZENE	5				
V	BROMOFORM	5				
V	CARBON TETRACHLORIDE	5				
$\nabla$	CHLOROBENZENE	6				
$\overline{\nabla}$	CHLORODIBROMOMETHANE	3				
V	CHLOROETHANE	5				
	CHLOROFORM	5				
V	DICHLOROBROMOMETHANE	3				
V	ETHYLBENZENE	10				
V	METHYL BROMIDE (Bromomethane)	5				
V	METHYL CHLORIDE (Chloromethane)	5				
V_	METHYLENE CHLORIDE	5				
	TETRACHLOROETHYLENE					
lv –	(Perchloroethylene or Tetrachloroethene)	5				
₩	TOLUENE	5		 		 
	TRICHLOROETHYLENE			 		 
V.	(Trichloroethene)	3		1	1	Į
	VINYL CHLORIDE	5				

#### Notes:

٠ê

(1) Flow average for day pertains to WET/PP composite sample day.

(2) Flow average for month is for month in which WET/PP sample was taken.

(3) Analytical chemistry parameters must be done as part of the WET test chemistry.

(3a) Cyanide, Available (Cyanide Amenable to Chlorination) is not an analytical chemistry parameter, but may be required by certain discharge permits.

(4) Priority Pollutants should be reported in micrograms per liter (ug/L).

(5) Mercury is often reported in nanograms per liter (ng/L) by the contract laboratory, so be sure to convert to micrograms per liter on this spreadsheet.

(6) Effluent Limits are calculated based on dilution factor, background allocation (10%) and water quality reserves (15% - to allow for new or changed discharges or non-point sources).

(7) Possible Exceedence determinations are done for a single sample only on a mass basis using the actual pounds discharged. This analysis does not consider watershed wide allocations for fresh water discharges.

(8) These tests are optional for the receiving water. However, where possible samples of the receiving water should be preserved and saved for the duration of the WET test. In the event of questions about the receiving water's possible effect on the WET results, chemistry tests should then be conducted.

(9) pH and Total Residual Chlorine must be conducted at the time of sample collection. Tests for Total Residual Chlorine need be conducted only when an effluent has been chlorinated or residual chlorine is believed to be present for any other reason.

WET and Chemical Specific Data Report Form

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

Comments:

# ATTACHMENT E

. . .

. .

## Salmonid Survival and Growth Test

The Salmonid survival and growth test must follow the procedures for the fathead minnow larval survival and growth tests detailed in USEPA's freshwater acute and chronic methods manuals with the following Department modifications:

**Species** - Brook Trout, *Salvelinus fontinalis*, or other salmonid approved by the Department.

Age - Less than six months old for the first test each year and less than twelve months for subsequent tests.

Size - The largest fish must not be greater than 150% of the smallest.

Loading Rate - < 0.5 g/l/day

Feeding rate - 5% of body weight 3 times daily (15%/day)

**Temperature -**  $12^{\circ} \pm 1^{\circ}$ C

**Dissolved Oxygen -** 6.5 mg/l ,aeration if needed with large bubbles (> 1 mm diameter) at a rate of <100/min

**Dilution Water** - Receiving water upstream of discharge (or other ambient water approved by the Department)

**Dilution Series** - A minimum of 5 effluent concentrations (including the instream waste concentrations bracketing acute and chronic dilutions calculated pursuant to Section D); a receiving water control; and control of known suitable water quality

**Duration** - Acute = 48 hours

- Chronic = 10 days minimum

**Test acceptability** - Acute = minimum of 90% survival in 2 days

- Chronic = minimum of 80% survival in 10 days; minimum growth of 20 mg/gm/d dry weight in controls, (individual fish weighed, dried at 100°C to constant weight and weighed to 3 significant figures)

## MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

#### AND

#### MAINE WASTE DISCHARGE LICENSE

#### FACT SHEET

#### Date: January 13, 2015

PERMIT NUMBER: ME0100439

LICENSE NUMBER: W002753-6B-F-R

NAME AND ADDRESS OF APPLICANT:

## MILO WATER DISTRICT 146 Park Street Milo, Maine 04463

COUNTY:

**Piscataquis County** 

NAME AND ADDRESS WHERE DISCHARGE OCCURS:

## MILO WATER DISTRICT 146 Park Street Milo, Maine 04463

#### **RECEIVING WATER/CLASSIFICATION:** Piscataquis River/Class B

COGNIZANT OFFICIAL AND TELEPHONE NUMBER: Mr. Timothy Gormley (207) 943-2501 milowater@myfairpoint.net

## 1. APPLICATION SUMMARY

<u>Application</u>: The Milo Water District (MWD/District/permittee hereinafter) has submitted a timely and complete application to the Department for the renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0100439/ Maine Waste Discharge License (WDL) #W002753-6C-D-R (permit hereinafter) which was issued by the Department on December 4, 2009, for a five-year term. The 12/4/09 permit authorized the discharge of up to a monthly average flow of 0.39 million gallons per day (MGD) of secondary treated sanitary waste waters to the Piscataquis River, Class B, in Milo, Maine. See Attachment A of this Fact Sheet for a location map.

#### FACT SHEET

#### 1. APPLICATION SUMMARY (cont'd)

b. <u>Source Description</u>: - The waste water treatment facility receives sanitary waste water from approximately 740 residential and commercial users within the boundaries of the District. The District owns and maintains approximately 12 miles of collection system which is 100% separated. All former combined sewer overflows (CSOs) were eliminated in 2006.

The waste treatment facility is not currently authorized to accept transported wastes from local septage haulers. It is noted the facility accepts up to 1,500 to 2,000 gpd of waters from an oil/water separator from the local railroad maintenance facility located just to the northeast of the waste water treatment facility.

c. <u>Waste Water Treatment</u>: Waste waters conveyed to the treatment facility during normal operations receive a secondary level of treatment via three (3) aerated facultative lagoons that are two acres, one acre and one acre in size, respectively, providing approximately 30-days of detention time. Waste waters collected are conveyed to the lagoons via a force main (measuring eight inches in diameter) from the Ferry Road pumping station. After passing through the lagoons it is seasonally disinfected in a chlorine contact chamber with sodium hypochlorite and then de-chlorinated using sodium bi-sulfite. The flow is measured in two locations, with a mag flow meter at the pump station next to the lagoon and then again with an ultra-sonic meter at the chlorination building. The discharge is to the Piscataquis River via a ductile iron pipe measuring 12 inches in diameter. The end of the outfall pipe is fitted with a manhole base structure with a grate on the downstream side to enhance mixing of the treated waste water with the Piscataquis River. The waste water treatment facility is designed for the treatment of an average daily flow of 0.39 MGD. See Attachment B of the this Fact Sheet for a schematic of the facility.

## 2. PERMIT SUMMARY

- a. <u>Terms and Conditions</u>: This permitting action is carrying forward all the terms and conditions of the previous permit except that this permit is;
  - 1. Eliminating the option when calculating percent removal to report the NODI 9 code on the Discharge Monitoring Report (DMR) when the average influent concentration is less than 200 mg/L based on guidance from the U.S. Environmental Protection Agency (EPA).
  - 2. Eliminating the monthly average water quality based mass and concentration limits for ammonia as a statistical evaluation on the most current 60 months of test results submitted to the Departnment indicates the discharge no longer exceeds or has a reasonable potential to exceed the chronic ambient water quality criteria (AWQC) for ammonia.

#### FACT SHEET

### 2. PERMIT SUMMARY (cont'd)

- 3. Incorporating previously established average and maximum technology based concentration limits for total mercury so the results can be tracked in the federal Integrated Compliance Information System (ICIS).
- 4. Eliminating Special Condition C, *Disinfection*, from the permit as the Department has reconsidered the necessity of said condition.
- 5. Establishing a seasonal (June 1 September 30) total phosphorus monitoring requirement to obtain up-to-date test results for the discharge to assist the Department in evaluating the impact on ambient water quality in the Piscataquis River.
- b. <u>History</u>: The most current relevant licensing/permitting and other regulatory actions include the following:

*April 27, 1983* – The Department issued WDL #W002753 which authorized Milo to discharge 330,500 gallons per day of untreated waste water through nine (9) discharge locations on the Sebec, Pleasant and Piscataquis Rivers in Milo, Maine.

*February 28, 1986* – The U.S. Environmental Protection Agency (EPA) issued National Pollutant Discharge Elimination System (NPDES) permit #ME0100439 for five-year term.

January 1, 1991 – A new waste water treatment facility commenced operation with a single discharge location into the Piscataquis River.

*December 5, 1991* - The Department issued renewal #W002753-59-A-R for five-year term. The licensed flow limitation was increased from 0.33 MGD to 0.39 MGD, to reflect the design capacity of the new facility.

*February 5, 1995* - The Department administratively modified WDL #W002753-59-A-R to include whole effluent toxicity (WET) and chemical specific testing pursuant to Department regulation Chapter 530.5, *Surface Water Toxics Control Program.* 

*December 11, 1996* - The Department administratively modified WDL #W002753-59-A-R by suspending the limitations and monitoring requirements for bacteria and total residual chlorine bewtween May 15<sup>th</sup> and September 30<sup>th</sup> of each year.

*October 15, 1998* - Milo requested a modification to require CBOD testing in lieu of BOD testing.

#### 2. PERMIT SUMMARY (cont'd)

*April 27, 1999* – The Department denied Milo's request to substitute carbonaceous biochemical oxygen demand (CBOD) testing for biochemical oxygen demand (BOD) testing After reviewing historical discharge monitoring data, the Department made the determination that 97.3% of the time, the Milo facility was capable of meeting their existing monthly average license limitation of 30 mg/L for BOD. The Department's best practicable treatment (BPT) standard is based on a threshold of 95% compliance with the monthly average limitations.

December 6, 1999 - The Department issued WDL renewal #W002753-5L-B-R for five-year term.

May 25, 2000 – The Department unilaterally modified the 12/6/99 WDL by establishing interim average and maximum concentration limits for mercury.

*January 12, 2001* – The State of Maine received authorization from the EPA to administer the NPDES permitting program in Maine. The program has since been referred to as the Maine Pollutant Discharge Elimination System (MEPDES) program.

*October 5, 2004* – The Department issued combination MEPDES permit #ME0100439/WDL #W002753-6B-B-R for a five-year term.

*April 10, 2006* – The Department unilaterally modified the 10/5/04 MEPDES permit/WDL by establishing whole effluent toxicity and chemical specific testing pursuant to Department rule 06-096 CMR, Chapter 530, *Surface Water Toxics Control Program*, promulgated on October 12, 2005.

September 29, 2009 – The Department issued a letter to the MWD indicated they were no longer required to participate in the Department's CSO program.

*December 4, 2009* – The Department issued combination MEPDES permit #ME0100439/WDL #W002753-6B-C-R for a five-year term.

*February 3, 2012* - The Department unilaterally modified the 12/4/09 MEPDES permit/WDL by reducing the monitoring frequency for mercury from 4/Year to 1/Year.

July 28, 2014 – The MWD submitted a timely and complete application to the Department to renew the 12/4/09 MEPDES permit/WDL.

#### **3. CONDITIONS OF PERMITS**

Maine law, 38 M.R.S.A. Section 414-A, requires that the effluent limitations prescribed for discharges, including, but not limited to, effluent toxicity, require application of best practicable treatment (BPT), be consistent with the U.S. Clean Water Act, and ensure that the receiving waters attain the State water quality standards as described in Maine's Surface Water Classification System. In addition, 38 M.R.S.A., Section 420 and Department rule 06-096 CMR Chapter 530, *Surface Water Toxics Control Program*, require the regulation of toxic substances not to exceed levels set forth in Department rule 06-096 CMR Chapter 584, *Surface Water Quality Criteria for Toxic Pollutants*, and that ensure safe levels for the discharge of toxic pollutants such that existing and designated uses of surface waters are maintained and protected.

## 4. RECEIVING WATER STANDARDS

Maine law, 38 M.R.S.A., Section 467(7)(E)(1) classifies the Piscataquis River at and below the discharge from the MWD facility as a Class B waterbody.

Maine law, 38 M.R.S.A., Section 465(3 & 4) describes the classification standards for Class B waters as follows:

Class B waters must be of such quality that they are suitable for the designated uses of drinking water supply after treatment; fishing; agriculture; recreation in and on the water; industrial process and cooling water supply; hydroelectric power generation, except as prohibited under Title 12, section 403; navigation; and as habitat for fish and other aquatic life. The habitat must be characterized as unimpaired.

The dissolved oxygen content of Class B waters may not be less than 7 parts per million or 75% of saturation, whichever is higher, except that for the period from October 1st to May 14th, in order to ensure spawning and egg incubation of indigenous fish species, the 7-day mean dissolved oxygen concentration may not be less than 9.5 parts per million and the 1-day minimum dissolved oxygen concentration may not be less than 8.0 parts per million in identified fish spawning areas. Between May 15th and September 30th, the number of Escherichia coli bacteria of human and domestic animal origin in these waters may not exceed a geometric mean of 64 per 100 milliliters or an instantaneous level of 236 per 100 milliliters. In determining human and domestic animal origin, the department shall assess licensed and unlicensed sources using available diagnostic procedures.

Discharges to Class B waters may not cause adverse impact to aquatic life in that the receiving waters must be of sufficient quality to support all aquatic species indigenous to the receiving water without detrimental changes in the resident biological community.

#### FACT SHEET

## 5. RECEIVING WATER CONDITIONS

The Department conducted ambient water quality surveys in 1997, 1998 and 2001 on the Piscataquis River in an effort to assess the existing water quality and develop a water quality model to support the issuance of a total maximum daily load (TMDL) report. Ambient water quality sampling was conducted on 23 miles of the Piscataquis River from Guilford to Milo. The Department published a document entitled, *Piscataquis River Data Report, 2001 Survey, January 2002, DEPLW0465*, with the results of the sampling events.

The 2012 Integrated Water Quality Monitoring and Assessment Report, published by the Department (often referred to as the 305b Report) lists a 13.44 mile segment of the Piscataquis River below the Dover-Foxcroft waste water treatment facility in a table entitled, *Table 5-A: Rivers And Streams Impaired By Pollutants Other Than Those Listed in 5-B Through 5-D (TMDL Required).* The report cites the cause of the impairment is low dissolved oygen levels. Previous 305b reports listed low dissolved oxygen levels and bacteria as a result of municipal point sources, agricultural non-point sources and combined sewer overflows as being the cause of the impairment. The Department is scheduled to perform a comprehensive ambient water quality survey during the summer of 2015 and prepare a TMDL for the 13.44-mile segment during calendar year 2016. If the TMDL indicates that at full permitted discharge limits, the discharge from the Milo facility is causing or contributing to the non-attainment of ambient water quality standards, this permit will be re-opened per Special Condition L, *Reopening Of The Permit For Modifications*, to impose more stringent limitations to meet water quality standards.

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

a. <u>Flow</u>: The monthly average flow limitation of 0.39 MGD and the daily maximum reporting requirement in the previous permitting action are being carried forward in this permitting action. The monthly average limitation is considered to be representative of the monthly average design flow for the waste water treatment facility.

A review of the monthly DMR data for the period January 2011 – June 2014 indicates flow values have been reported as follows:

Value	Limit (MGD)	Range (MGD)	Mean (MGD)
Monthly Average	0.39	0.12 - 0.62	0.25
Daily Maximum	Report	0.17 - 1.2	0.47

#### Flow (42 DMRs)

b. <u>Dilution Factors</u> - The Department establishes applicable dilution factors for the discharge in accordance with freshwater protocols established in Department Rule Chapter 530 <u>Surface Water Toxics Control Program</u>, October 2005. With a permitted flow limit of 0.39 MGD, the dilution factors are as follows:

 $\frac{1}{4}$ Acute<sup>(1)</sup>: 1Q10 = 4.6 cfs
  $\Rightarrow (4.6 cfs)(0.6464) + (0.39 MGD) = 8.7:1$ (0.39 MGD)

 Acute: 1Q10 = 18.5 cfs
  $\Rightarrow (18.5 cfs)(0.6464) + (0.39 MGD) = 32:1$ (0.39 MGD)

 Chronic: 7Q10 = 27.7 cfs
  $\Rightarrow (27.7 cfs)(0.6464) + (0.39 MGD) = 47:1$ (0.39 MGD)

 Harmonic Mean: = 83.1 cfs<sup>(2)</sup>: $\Rightarrow (83.1 cfs)(0.6464) + (0.39 MGD) = 139:1$ 

#### Footnotes

(1) Chapter 530.5 (D)(4)(a) states that analyses using numeric acute criteria for aquatic life must be based on 1/4 of the 1Q10 stream design flow to prevent substantial acute toxicity within any mixing zone. The 1Q10 is the lowest one day flow over a ten-year recurrence interval. The regulation goes on to say that where it can be demonstrated that a discharge achieves rapid and complete mixing with the receiving water by way of an efficient diffuser or other effective method, analyses may use a greater proportion of the stream design, up to including all of it.

(0.39 MGD)

The previous permitting action made the determination that based on the lack of information provided by Milo as to the true mixing characteristics of the discharge of treated effluent with the receiving waters, the default stream flow of ¼ of the 1Q10 is applicable in acute statistical evaluations pursuant to Chapter 530. The MWD has not provided any new information at the time of this permit renewal. As a result, the Department continues to utilize the default value of ¼ of the 1Q10 as being applicable in acute statistical evaluations.

(2) The harmonic mean dilution factor is approximated by multiplying the 7Q10 receiving water flow by three (3). This multiplying factor is based on guidelines for estimation of human health dilution presented in the USEPA publication "Technical Support Document for Water Quality-based Toxics Control" (Office of Water; EPA/505/2-90-001, page 88), and represents an estimation of harmonic mean flow on which human health dilutions are based in a riverine 7Q10 flow situation.

c. <u>Biochemical Oxygen Demand (BOD5) & Total Suspended Solids (TSS):</u> - The previous permitting action established monthly and weekly average BOD5 and TSS best practicable treatment (BPT) concentration limits of 30 mg/L and 45 mg/L respectively, that were based on secondary treatment requirements as defined in Department rule, 06-096 CMR Chapter 525(3)(III). The maximum daily BOD5 concentration limits of 50 mg/L are based on a Department best professional judgment of BPT. All three concentration limits are being carried forward in this permitting action.

As for mass limitations, the previous permitting action established monthly average, weekly average and daily maximum limitations based on a monthly average limit of 0.39 MGD that are being carried forward in this permitting action. The limitations were calculated as follows:

Monthly average: (0.39 MGD)(8.34)(30 mg/L) = 98 lbs/dayWeekly average: (0.39 MGD)(8.34)(45 mg/L) = 146 lbs/dayDaily maximum: (0.39 MGD)(8.34)(50 mg/L) = 163 lbs/day

A review of the monthly DMR data for the period January 2011 – June 2014 indicates the permittee has reported BOD and TSS values as follows:

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	98	7 - 87	27
Daily Maximum	163	8 - 127	43

## BOD Mass (42 DMRs)

#### **BOD Concentration (42 DMRs)**

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	30	7 - 26	13
Daily Maximum	50	8 - 35	17

#### TSS mass (42 DMRs)

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	98	3 -116	28
Daily Maximum	163	3 - 200	45

#### TSS Concentration (42 DMRs)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	30 .	2 - 25	13
Daily Maximum	50	3 - 39	18

Minimum monitoring frequency requirements in MEPDES permits are prescribed by 06-096 CMR Chapter 523§5(i). The USEPA has published guidance entitled, *Interim Guidance for Performance Based Reductions of NPDES Permit Monitoring Frequencies* (USEPA Guidance April 1996). In addition, the Department has supplemented the EPA guidance with its own guidance entitled, *Performance Based Reduction of Monitoring Frequencies - Modification of EPA Guidance Released April 1996* (Maine DEP May 22, 2014). Both documents are being utilized to evaluate the compliance history for each parameter regulated by the previous permit to determine if a reduction in the monitoring frequencies are justified.

Although EPA's 1996 Guidance recommends evaluation of the most current two-years of effluent data for a parameter, the Department is considering 42 months of data (January 2011 – June 2014). A review of the monitoring data for BOD & TSS indicates the ratios (expressed in percent) of the long term effluent average to the monthly average limits can be calculated as 28%. According to Table I of the EPA Guidance, a 1/Week monitoring requirement can be reduced to 2/Month. Therefore, this permitting action is reducing the monitoring frequency for BOD & TSS to 1/Week.

The previous permitting action also established a requirement of 85% removal for BOD and TSS pursuant to Department rule, 06-096 CMR Chapter 525(3)(III)(a&b)(3) except in the circumstances where the influent concentration is less than 200 mg/L. Based on guidance from the USEPA, this permit is eliminating the exception for complying with the 85% removal requirement when influent is less 200 mg/L as weak influent to a treatment facility is an indication of excessive inflow and infiltration that should be addressed in the collection system. Compliance with the percent removal requirement is based on a 12-month rolling average basis to be consistent with all other Department permitting actions for lagoon systems with extended detention times.

A review of the DMR data for the period of January 2011 through March 2014 indicates values for BOD and TSS percent removal have been reported as follows:

DOD /0 Removal (DMRS - 14)							
Value	T 1 1/0/>	Range (%)	Average (%)				
Monthly Average	85	88 - 93	92				

#### BOD % Removal (DMRs = 14)

#### TSS % Removal (DMRs = 14)

Value	Limit (%)	Range (%)	Average (%)
Monthly Average	85	<u> 89 - 96 </u>	94

d. Escherichia coliform (*E. coli.*) bacteria: The previous permitting action established seasonal (between May 15<sup>th</sup> and September 30<sup>th</sup> of each year) monthly average and daily maximum concentration limits for *E. coli* bacteria of 64 colonies/100 ml (geometric mean) and 427 colonies/100 ml (instantaneous level), respectively, based on the State of Maine Water Classification Program criteria for Class B waters found at 38 M.R.S.A. §465(3)(B) at the time of permitting, and a minimum monitoring frequency requirement of 1/Week.

During calendar year 2005, Maine's Legislature approved a new daily maximum water quality standards of 236 colonies/100 ml for water bodies designated as Class B and Class C. In the 12/29/09 permit, the Department determined that end-of-pipe limitations for the instantaneous concentration standard of 427 colonies/100 mL would be achieved through available dilution of the effluent with the receiving waters and need not be revised in MEPDES permits for facilities with adequate dilution (at least 1.1:1 for facilities in Class B waters). The seasonal (May 15 – September 30) bacteria limits of 64 colonies/100 ml and 236 col/100 ml are being carried forward in this permit. The Department reserves the right to impose year-round bacteria limits, if necessary, to protect the health, safety and welfare of the public.

A review of the seasonal monthly DMR data for the period May 2011 - June 2014 indicates the permittee has reported *E. coli* bacteria test results as follows:

Value	Limit (col/100 ml)	Range (col/100 ml)	Mean (col/100 ml)
Monthly Average	64	3-64	19
Daily Maximum	427	7 - 205	87

E. coli bacteria (17 DMRs)

Although EPA's 1996 Guidance recommends evaluation of the most current two-years of effluent data for a parameter, the Department is considering 17 seasonal months of data (May 2011 – June 2014). A review of the monitoring data for BOD & TSS indicates the ratios (expressed in percent) of the long term effluent average to the monthly average limits can be calculated as 30%. According to Table I of the EPA Guidance, a 1/Week monitoring requirement can be reduced to 2/Month. Therefore, this permitting action is reducing the monitoring frequency for *E. coli* bacteria to 2/Month with at least ten (10) days between sampling events.

e. <u>Total Residual Chlorine</u> - The previous permitting action established a daily maximum water quality based concentration limit of 0.16 mg/L for the discharge that is being carried forward in this permitting action. Limits on total residual chlorine (TRC) are specified to ensure that ambient water quality standards are maintained and that BPT technology is being applied to the discharge. The Department imposes the more stringent of the water quality or technology based limits in permitting actions. End-of-pipe water quality based concentration thresholds may be calculated as follows:

Parameter	Acute	Chronic	Acute	Chronic	Acute	Chronic
	Criteria	Criteria	Dilution	Dilution	Limit	Limit
Chlorine	19 ug/L	11 ug/L	8.7:1	47:1	0.16 mg/L	0.52 mg/L

Example calculation: Acute -0.019 mg/L(8.7) = 0.16 mg/L

For facilities that need to de-chlorinate the discharge to meet water quality based thresholds (as is with the case with Milo), the Department has established daily maximum and monthly average BPT limits of 0.3 mg/L and 0.1 mg/L respectively. In the case of Milo, the acute water quality based threshold of 0.16 mg/L calculated above is lower than the BPT limit of 0.3 mg/L, thus the water quality based limit of 0.16 mg/L is being carried forward as a daily maximum limit. As for monthly average, the calculated chronic water quality based threshold of 0.52 mg/L is higher than the BPT limit of 0.1 mg/L, thus the technology-based limit of 0.1 mg/L is be imposed as a monthly average limitation.

TRC is potentially toxic at all times of the year. Therefore, whenever elemental chlorine or chlorine based compounds are used to disinfect the discharge from the waste water treatment plant, limitations and monitoring requirements are in effect and enforceable.

A review of the DMR data for the period September 2011 – June 2014 indicates the permittee has reported values as follows:

Total residual	chlorine	(11 DMRs)	

Value	Limit (mg/L)	Range (mg/L)	Mean (mg/L)
Daily Maximum	0.16	0.06 - 0.16	0.12

No monitoring frequency reduction for TRC is being considered as the ratio between the long term average and monthly average limits is 75%.

f. <u>Total phosphorus</u> – The October 2004 MEPDES permit established a 1/Month monitoring requirement for total phosphorus between June and September of each year to gather a statistically valid data set on phosphorus discharges. The data collected was to be utilized in any water modeling conducted by the Department to determine if phosphorus is causing or contributing to dissolved oxygen deficits in the Piscataquis River.

A review of the DMR data for the period June 2006 – September 2008 indicates values have been reported as follows:

Value	Range (mg/L)	Mean (mg/L)
Monthly Average	1.44 – 4.11	2.7
Daily Maximum	1.44 - 4.11	2.7

Total phosphorus (Concentration) (11 DMRs)

### ME0100439 W002753-6C-F-R

#### EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) 6.

## Total phosphorus (Mass) (11 DMRs)

Value	Range (lbs/day)	Mean (lbs/day)
Monthly Average	2.08 - 4.5	2.9
Daily Maximum	2.08 - 4.5	2.9

Department rule 06-096 CMR, Chapter 523 specifies that water quality based limits are necessary when it has been determined that a discharge has a reasonable potential to cause or contribute to an excursion above any State water quality standard including State narrative criteria.<sup>1</sup> In addition, 06-096 CMR Chapter 523 specifies that water quality based limits may be based upon criterion derived from a proposed State criterion, or an explicit State policy or regulation interpreting its narrative water quality criterion, supplemented with other relevant information which may include: EPA's Water Quality Standards Handbook, October 1983, risk assessment data, exposure data, information about the pollutant from the Food and Drug Administration, and current EPA criteria documents.2

USEPA's Quality Criteria for Water 1986 (Gold Book) puts forth an in-stream phosphorus concentration recommendation of less than 100 µg/L (0.1 mg/L) in streams or other flowing waters not discharging directly to lakes or impoundments, to prevent nuisance algal growth. The use of the 0.1 mg/L Gold Book value is consistent with the requirements of 06-096 CMR Chapter 523 noted above for use in a reasonable potential (RP) calculation.

Based on the above rationale, the Department has chosen to utilize the Gold Book value of 0.01 mg/L. It is the Department's intent to continue to make determinations of actual attainment or impairment based upon environmental response indicators from specific water bodies. The use of the Gold Book value of 0.1 mg/L for use in the RP calculation will enable the Department to establish water quality based limits in a manner that is reasonable and that appropriately establishes the potential for impairment, while providing an opportunity to acquire environmental response indicator data, numeric nutrient indicator data, and facility data as needed to refine the establishment of site specific water quality based limits for phosphorus. Therefore, this permit may be reopened during the term of the permit to modify any reasonable potential calculation, phosphorus limits, or monitoring requirements based on site-specific data.

The permittee conducted total phosphorus testing between June 2006 and September 2008 (n=11). The arithmetic mean concentration discharged for the period was 2.7 mg/L and 2.9 lbs/day and was considered representative of the discharge from the facility. For the background concentration in the Piscataquis River, 2014 data indicates the background total phosphorus concentration is 0.012 mg/L. Using the

<sup>1</sup> Waste Discharge License Conditions, 06-096 CMR 523(5)(d)(1)(i) (effective date January 12, 2001) <sup>2</sup> 06-096 CMR 523(5)(d)(1)(vi)(A)

FACT SHEET

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

following calculation and criteria, the Milo facility does not have a reasonable potential to exceed the EPA's Gold Book value of 0.100 ug/L for phosphorus but does have a reasonable potential to exceed the Department's Chapter 583 draft criteria of 0.030 mg/L. The calculations are as follows:

$$Cr = QeCe + QsCs$$
  
 $Qr$ 

Qe = effluent flow i.e. facility design flow	=	0.39 MGD
Ce = effluent pollutant concentration	=	2.7 mg/L
Qs = 7Q10 flow of receiving water		14.3 MGD
Cs = upstream concentration	=	0.012 mg/L
Qr = receiving water flow	=	17.9 MGD
Cr = receiving water concentration		

Cr = (0.39  MGD x  2.7  mg/L) + (17.9  mg/L)	9  MGD x  0.012  mg/L = 0.069  mg/L
18.3 MGD	
$Cr = 0.073 \text{ mg/L} > 0.1 \text{ mg/L} \Rightarrow$	No, Reasonable Potential
$Cr = 0.073 \text{ mg/L} > 0.030 \text{ mg/L} \Rightarrow$	Yes, Reasonable Potential

Pusuant to Department guidance issued via a letter to permittee's on July 1, 2014, this permit is not establishing water quality based mass limits at this time but is establishing a seasonal (June 1 – September 30) monitoring frequency of 2/Month for the five-year term of the permit. The data will be taken into consideration when the Department prepares its TMDL report in 2015-2016.

g. <u>pH Range</u>- The previous permitting action established a technology based BPT pH range limitation of 6.0 –9.0 standard units pursuant to a new Department rule, 06-096 CMR Chapter 525(3)(III)(c) that is being carried forward in this permitting action.

A review of the monthly DMR data for the period December 2011 – June 2014 indicates the following:

$p_{\rm H}$ ( $p_{\rm HRS} = 12$ )			
Value	Limit (su)	Minimum (su)	Maximum (su)
Range	6.0 - 9.0	6.3	8.8

pH (DMRs = 12)

## ME0100439 W002753-6C-F-R

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

h. <u>Whole Effluent Toxicity (WET) and Chemical Specific Testing</u> Maine law, 38 M.R.S.A., Sections 414-A and 420, prohibit the discharge of effluents containing substances in amounts that would cause the surface waters of the State to contain toxic substances above levels set forth in Federal Water Quality Criteria as established by the USEPA. Department Rules, 06-096 CMR Chapter 530, *Surface Water Toxics Control Program*, and Chapter 584, *Surface Water Quality Criteria for Toxic Pollutants* set forth ambient water quality criteria (AWQC) for toxic pollutants and procedures necessary to control levels of toxic pollutants in surface waters.

WET, priority pollutant and analytical chemistry testing as required by Chapter 530, is included in this permit in order to fully characterize the effluent. This permit also provides for reconsideration of effluent limits and monitoring schedules after evaluation of toxicity testing results. The monitoring schedule includes consideration of results currently on file, the nature of the wastewater, existing treatment and receiving water characteristics.

WET monitoring is required to assess and protect against impacts upon water quality and designated uses caused by the aggregate effect of the discharge on specific aquatic organisms. Acute and chronic WET tests are performed on invertebrate and vertebrate species. Priority pollutant and analytical chemistry testing is required to assess the levels of individual toxic pollutants in the discharge, comparing each pollutant to acute, chronic, and human health AWQC as established in Chapter 584.

Chapter 530 establishes four categories of testing requirements based predominately on the chronic dilution factor. The categories are as follows:

- 1) Level I chronic dilution factor of <20:1.
- 2) Level II chronic dilution factor of >20:1 but <100:1.
- 3) Level III chronic dilution factor  $\geq$ 100:1 but <500:1 or >500:1 and Q  $\geq$ 1.0 MGD
- 4) Level IV chronic dilution >500:1 and Q  $\leq 1.0$  MGD

Department rule Chapter 530 (1)(D) specifies the criteria to be used in determining the minimum monitoring frequency requirements for WET, priority pollutant and analytical chemistry testing. Based on the Chapter 530 criteria, the permittee's facility falls into the Level II frequency category as the facility has a chronic dilution factor of >20:1 but <100:1. Chapter 530(1)(D)(1) specifies that <u>routine</u> screening and surveillance level testing requirements are as follows:

Surveillance level testing – Beginning upon issuance of the permit and lasting through 24 months prior to permit expiration (Years 1, 2 & 3 of the term of the permit) and commencing again 12 months prior to permit expiration (Year 5 of the term of the permit).

Level	WET Testing	Priority pollutant testing	Analytical chemistry
II	1 per year	None required	2 per year

Screening level testing –Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement.

Level	WET Testing	Priority pollutant testing	Analytical chemistry
II	2 per year	1 per year	4 per year

A review of the data on file with the Department indicates that to date, the permittee has fulfilled the WET and chemical-specific testing requirements of Chapter 530. See **Attachment C** of this Fact Sheet for WET test results and **Attachment D** for chemical specific test dates.

Department rule Chapter 530(D)(3)(c) states in part "Dischargers in Level II may reduce surveillance testing to one WET or specific chemical series every other year provided that testing in the preceding 60 months does not indicate any reasonable potential for exceedence as calculated pursuant to section 3(E)."

Chapter 530 §(3)(E) states "For effluent monitoring data and the variability of the pollutant in the effluent, the Department shall apply the statistical approach in Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control" (USEPA Publication 505/2-90-001, March, 1991, EPA, Office of Water, Washington, D.C.) to data to determine whether water-quality based effluent limits must be included in a waste discharge license. Where it is determined through this approach that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action."

Chapter 530 §3 states, "The Department shall establish appropriate discharge prohibitions, effluent limits and monitoring requirements in waste discharge licenses if a discharge contains pollutants that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an ambient excursion in excess of a numeric or narrative water quality criteria or that may impair existing or designated uses. The licensee must also control whole effluent toxicity (WET) when discharges cause, have a reasonable potential to cause, or contribute to an ambient excursion above the narrative water quality criteria. "In determining if effluent limits are required, the Department shall consider all information on file and effluent testing conducted during the preceding 60 months. However, testing done in the performance of a Toxicity Reduction Evaluation (TRE) approved by the Department may be excluded from such evaluations."

<u>WET Evaluation</u> – The previous permitting action establish a C-NOEL limit of 2.1% for the water flea (*Ceriodaphnia dubia*) as a statistical evaluation at that time indicated the discharge exceeded or had a reasonable potential to exceed critical chronic WET threshold of 2.1%. The critical threshold is calculated as the mathematical inverse of the chronic dilution factor of 47:1.

For this permitting action, a statistical evaluation for the most current 60 months of data was conducted on 8/21/14 that indicates the discharge has two test results for the water flea (2.13% on 8/26/13 and 9/8/14) that have a reasonable potential to exceed the critical chronic water quality threshold of 2.1%. The evaluation indicates the test results for the brook trout during said period do not exceed or have a reasonable potential to exceed critical acute or chronic thresholds.

Therefore, pursuant to Chapter 530 §3, this permitting action carries forward the C-NOEL limit of 2.1%. Chapter 530 does not establish monitoring frequencies for test species that exceeed or have a reasonable potential to exceed critical acute or chronic thresholds. The Department establishes these frequencies based on the timing, severity and frequency of the tests of concern. Being that the one test of concern is the most recent test result submitted to the Department, this permitting action is establishing a default surveillance level monitoring frequency of 1/Year for the water flea.

As for the brook trout, the MWD qualifies for the reduced testing frequency provision found at Chapter 530 §2(D)(3) that states "Dischargers in Level II may reduce surveillance testing to one WET or specific chemical series every other year provided that testing in the preceding 60 months does not indicate any reasonable potential for exceedence as calculated pursuant to section 3(E)." Therefore, this permitting action establishes a monitoring frequency of 1/2 Years for the brook trout beginning upon issuance of the permit.

Chapter 530(2)(D)(4) states;

- (4) All dischargers having waived or reduced testing must file statements with the Department on or before December 31 of each year describing the following.
  - (a) Changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge;
  - (b)Changes in the operation of the treatment works that may increase the toxicity of the discharge; and
  - (c) Changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge.

Given the MWD qualifies for the reduced testing frequency provision for the brook trout found at Chapter 530 §2(D)(3), Special Condition J of this permit requires the permittee to file said statement. Therefore, beginning upon issuance of this permit and lasting through 24 months prior to permit expiration (Years 1, 2 & 3 of the term of the permit) and commencing again 12 months prior to permit expiration (Year 5 of the term of the permit), the permittee shall conduct surveillance level WET testing at a minimum frequency of once per year (1/Year) on the water flea (*Ceriodaphnia dubia*) and once every other year (1/2 Years) on the brook trout (*Salvelinus fontinalis*).

Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee shall revert to a default screening level of 2/Year WET testing in the Chapter 530 rule for both the water flea and brook trout.

Analytical chemistry and priority pollutant testing – Chapter 530 §4(C), states "The background concentration of specific chemicals must be included in all calculations using the following procedures. The Department may publish and periodically update a list of default background concentrations for specific pollutants on a regional, watershed or statewide basis. In doing so, the Department shall use data collected from reference sites that are measured at points not significantly affected by point and non-point discharges and best calculated to accurately represent ambient water quality conditions The Department shall use the same general methods as those in section 4(D) to determine background concentrations. For pollutants not listed by the Department, an assumed concentration of 10% of the applicable water quality criteria must be used in calculations." The Department has limited information on the background levels of metals in the water column in the Piscataquis River in the vicinity of the permittee's outfall. Therefore, a default background concentrations of this permitting action.

Chapter 530 (3)(E) states "... that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action."

Chapter 530 §4(F) states in part "Where there is more than one discharge into the same fresh or estuarine receiving water or watershed, the Department shall consider the cumulative effects of those discharges when determining the need for and establishment of the level of effluent limits. The Department shall calculate the total allowable discharge quantity for specific pollutants, less the water quality reserve and background concentration, necessary to achieve or maintain water quality criteria at all points of discharge, and in the entire watershed. The total allowable discharge quantity for pollutants must be allocated consistent with the following principles.

Evaluations must be done for individual pollutants of concern in each watershed or segment to assure that water quality criteria are met at all points in the watershed and, if appropriate, within tributaries of a larger river.

The total assimilative capacity, less the water quality reserve and background concentration, may be allocated among the discharges according to the past discharge quantities for each as a percentage of the total quantity of discharges, or another comparable method appropriate for a specific situation and pollutant. Past discharges of pollutants must be determined using the average concentration discharged during the past five years and the facility's licensed flow.

The amount of allowable discharge quantity may be no more than the past discharge quantity calculated using the statistical approach referred to in section 3(E) [Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control"] of the rule, but in no event may allocations cause the water quality reserve amount to fall below the minimum referred to in 4(E) [15% of the total assimilative capacity]. Any difference between the total allowable discharge quantity and that allocated to existing dischargers must be added to the reserve.

The Piscataquis River is a tributary to the Penobscot River. Three municipal waste water treatment facilities that are subject to the Department's Chapter 530 testing requirements discharge to the Piscataquis River. The waste water treatment facilities are the Milo Water District, the Town of Dover-Foxcroft and the Guilford-Sangerville Sanitary District. The Milo Water District facility is the most downstream facility and the Guilford Sangerville facility is the most upstream facility. As previously cited, Chapter 530 requires that AWQC must be met at the confluence of the Piscataquis River and the Penobscot River as well as at the individual discharge points on the Piscataquis River after taking into consideration historic discharge levels for all three facilities as well as an allocation dedicated to background (10% of AWQC) and a reserve (15% of AWQC).

On August 21, 2014, the Department conducted statistical evaluations based on 15% of the ambient water quality criteria reserve being withheld (Report ID 706) and 0% of the reserve of the criteria being withheld (Report ID 705) to determine if the unallocated assimilative capacity would avoid an exceedance or avoid a reasonable potential to exceed applicable ambient water quality criteria for toxic pollutants. Report ID 705 indicates Dover-Foxcroft would no longer has a reasonable potential to exceed the chronic ambient water quality criteria for lead. Therefore, the Department is utilizing the full 15% of the unallocated assimilative capacity in the statistical evaluation when establishing limits for toxic pollutants in waste discharge licenses for facilities in the Penobscot River watershed including the Piscatquis River watershed.

The statistical evaluation (Report ID 705) indicates the MWD has four test results that have a reasonable potential to exceed the AWQC for total copper and two test results that exceed the chronic AWQC for total copper.

The 8/21/14 statistical evaluation indicates all three facilities have discharged detectable levels of copper. Department guidance that establishes protocols for establishing waste load allocations (mass) can be found as **Attachment E** of this Fact Sheet. The guidance states that the most protective of water quality becomes the facility's allocation. According to the 8/21/14 statistical evaluation, copper is to be limited based on the segment allocation method for chronic and the individual method for acute because the acute dilution factor is based on ¼ of the 1Q10.

Chapter 530 §(3)(D)(1) states "For specific chemicals, effluent limits must be expressed in total quantity that may be discharged and in effluent concentration. In establishing concentration, the Department may increase allowable values to reflect actual flows that are lower than permitted flows and/or provide opportunities for flow reductions and pollution prevention provided water quality criteria are not exceeded. With regard to concentration limits, the Department may review past and projected flows and set limits to reflect proper operation of the treatment facilities that will keep the discharge of pollutants to the minimum level practicable."

#### Segment allocation methodology

#### Historical Average:

For the segment allocation methodology, the historical average quantity (mass) for each pollutant of concern for each facility is calculated utilizing the arithmetic mean of the concentrated values reported for each pollutant, a conversion factor of 8.34 lbs/gallon and the monthly average permit limit for flow. For the Milo facility, the historical average for copper and has been calculated as follows:

Copper

Mean concentration = 18.4 ug/L or 0.0184 mg/LPermit flow limit = 0.39 MGDHistorical average mass = (0.0184 ug/L)(8.34)(0.39 MGD) = 0.06 lbs/day

The statistical evaluation indicates the historical average mass of copper discharged by Milo is 39.84% of the copper discharged by the three facilities on the Piscataquis River. Therefore, Milo's segment allocation for copper is calculated as 39.84% of the chronic assimilative capacities of the river at Milo. The assimilative capacity at Milo is calculated as follows:

7Q10 = 27.7 cfs (0.6464) = 17.9 MGD

Chronic AWQC = 2.36 ug/L or 0.00236 mg/L

Taking into consideration 0% of the AWQC for reserve and 10% for background, the assimilative capacities are:

Chronic = (0.00236 mg/L)(0.90)(8.34 lbs/gal)(17.9 MGD) = 0.317 lbs/day

Monthly average (chronic) mass limitation for copper is calculated as follows:

Monthly average: (Chronic assimilative capacity mass)(% of total ammonia discharged) (0.317 lbs/day)(0.3984) = 0.126 lbs/day or 0.13 lbs/day

## Individual allocation

In the individual allocation, the Department continues to utilize the formula it has used in permitting actions since October 2005 taking into consideration background (10% of AWQC) and a reserve (0% of AWQC). The formula is as follows:

EOP concentration = [Dilution factor x 0.90 x AWQC] + [0.10 x AWQC]

Mass limit = (EOP concentration in mg/L)(8.34 lbs/gal)(Permit flow limit in MGD)

Acute AWQC= 3.07 ug/L Acute dilution factor = 8.7:1 EOP concentration = [Dilution factor x 0.90 x AWQC] + [0.10 x AWQC]

 $EOP = [8.7 \times 0.90 \times 3.07 \text{ ug/L}] + [0.10 \times 3.07 \text{ ug/L}] = 24.3 \text{ ug/L}$ 

Based on a permitted flow of 0.39 MGD, EOP mass limits are as follows:

Parameter	Calculated EOP Concentrations	Daily Max. <u>Mass Limit</u>
Copper	24.3 ug/L	0.25 lbs/day
Example Calc	culation: Copper - <u>(24.</u>	<u>3 ug/L)(8.34)(0.39 MGD)</u> = <b>0.08 lbs/day</b> 1,000 ug/mg

The calculations above are correct in that the monthly average limitation is greater than the daily maximum limit. This will occur when the ratio between the acute and chronic AWQC is smaller than the ratio between the acute (1Q10) and chronic (7Q10) receiving water flows.

In permitting actions prior to October 2009, the Department had a policy that all toxic pollutants limited in permits be limited in both mass and concentration. Concentration limits established in permits and effluent guidelines are established as technology based limits (best practicable treatment) and not water quality based limits. Water quality based limits are site specific or watershed specific. Being that the Department conducts statistical evaluations for toxic pollutants based on historic mass discharge levels given site specific or watershed specific water quality concerns, establishing concentration limits by back-calculating from mass limits is deemed to be no longer appropriate. In May 2012, Maine law 38 M.R.S.A. §464, ¶¶ K was enacted which reads as follows, "Unless otherwise required by an applicable effluent limitation guideline adopted by the department, any limitations for metals in a waste discharge license may be expressed only as mass-based limits." There are no applicable effluent limitation guidelines adopted by the Department or the USEPA for metals from a publicly owned treatment works.

Chapter 530 does not establish monitoring frequencies for parameters that exceed or have a reasonable potential to exceed AWQC. Monitoring frequencies are established on case by case basis given the timing, severity and frequency of occurrences of the exceedences or reasonable potential to exceed applicable critical water quality thresholds. Therefore, this permitting action is making a best professional judgment to establish the monitoring frequencies for the parameters of concern at the routine surveillance level frequency of 2/Year specified in Chapter 530.

## ME0100439 W002753-6C-F-R

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

As for the remaining chemical specific parameters tested to date, none of the test results in the 60-month evaluation period exceed or have a reasonable potential to exceed applicable acute, chronic or human health AWQC. Therefore, this permitting action is establishing a reduced surveillance level reporting and monitoring frequency for analytical chemistry of 1/2 Years for the first three years and the fifth year of the term of the permit. As with reduced WET testing, the MWD must file an annual certification with the Department pursuant to Chapter 530 §2(D)(3) and Special Condition J of this permit. It is noted Chapter 530 does not require surveillance level priority pollutant testing during the first four years of the term of the permit.

Beginning 12 months prior to the expiration date of the permit, the permittee shall conduct default screening level analytical chemistry testing at 1/Quarter and priority pollutant testing of 1/Year.

k. <u>Mercury</u>: Pursuant to *Certain deposits and discharges prohibited*, Maine law, 38 M.R.S.A. § 420 and Waste discharge licenses, 38 M.R.S.A. § 413 and Interim Effluent Limitations and Controls for the Discharge of Mercury, 06-096 CMR 519 (last amended October 6, 2001), the Department issued a Notice of Interim Limits for the Discharge of Mercury to the permittee on May 25, 2000, thereby administratively modifying MEPDES #ME0100439/WDL # W002753-5L-C-R by establishing interim monthly average and daily maximum effluent concentration limits of 29.1 parts per trillion (ppt) and 43.7 ppt, respectively, and a minimum monitoring frequency requirement of four (4) tests per year for mercury. On February 6, 2012, the Department issued a minor revision of the permit by reducing the monitoring frequency to 1/Year.

Maine law 38 M.R.S.A., §420 1-B,(B)(1) states that a facility is not in violation of the AWQC for mercury if the facility is in compliance with an interim discharge limit established by the Department pursuant to section 413, subsection 11. A review of the Department's database for the previous 60-month period indicates mercury test results reported have ranged from 2.5 ppt to 8.8 ppt with an arithmetic mean (n=18) of 5.6 ppt.

## 7. DISCHARGE IMPACT ON RECEIVING WATER QUALITY

The effluent limitations in this permit are equal to or more stringent than the limits in the previous permit. The Department has made a best professional judgment determination based on information gathered to date, that as permitted, the discharge will not cause or contribute the failure of the receiving water to meet the standards of its ascribed classification and the designated uses of the river will continue to be maintained and protected. The Department is scheduled to perform a comprehensive evaluation of more recent data collected, calibrate an existing model of the river and prepare a TMDL for the 12-mile segment during 2015-2016. If future modeling runs determine that at full permitted discharge limits, the discharge is causing or contributing to the non-attainment, this permit will be re-opened per Special Condition L, *Reopening of The License For Modifications*, to impose more stringent limitations to meet water quality standards.

#### FACT SHEET

### 8. PUBLIC COMMENTS

Public notice of this application was made in the Eastern Gazette newspaper on July 24, 2014. The Department receives public comments on an application until the date a final agency action is taken on that application. Those persons receiving copies of draft permits shall have at least 30 days in which to submit comments on the draft or to request a public hearing, pursuant to Chapter 522 of the Department's rules.

## 9. DEPARTMENT CONTACTS

Additional information concerning this permitting action may be obtained from and written comments should be sent to:


Gregg Wood Division of Water Quality Management Bureau of Land and Water Quality Department of Environmental Protection 17 State House Station Augusta, Maine 04333-0017 E-mail: gregg.wood@maine.gov

Telephone: (207) 287-7693

### **10. RESPONSE TO COMMENTS**

During the period of January 13, 2015, through the issuance date of the permit/license, the Department solicited comments on the proposed draft permit/license to be issued for the discharge(s) from the Milo facility. The Department did not receive comments from the permittee, state or federal agencies or interested parties that resulted in any substantive change(s) in the terms and conditions of the permit. Therefore, the Department has not prepared a Response to Comments.

# ATTACHMENT A



## ATTACHMENT B

Mile Pollution Control Facility #2 Piscataquís Lagoon Lagoan #2 ₽ŧ Reed River Bed Laguran #3 Puting Station Barserern . Chemical Gailding Contact Chamber

## ATTACHMENT C

11/7/2014

### WETTEST REPORT

# Data for tests conducted for the period

Mile of Mile

MILO		NPDES= ME010043	Effluer	nt Limit: Acute (%) =	3.162	Chronic (%) = 2.132	
	Species	Test	Percent	Sample date	Critical %	Exception	RP
	TROUT	A_NOEL	100	06/22/2011	3.162		
	TROUT	A_NOEL	100	08/26/2013	3.162		
	TROUT	C_NOEL	100	06/22/2011	2.132		
	TROUT	C_NOEL	50	08/26/2013	2.132		
	WATER FLEA	A_NOEL	100	11/02/2010	3.162		
	WATER FLEA	A_NOEL	100 .	05/22/2011	3.162		
	WATER FLEA	A NOEL	100	01/05/2012	3.162		
	WATER FLEA	A_NOEL	100	08/26/2013	3.162		
	WATER FLEA	A_NOEL	100	09/08/2014	3.162		
	WATER FLEA		10	11/02/2010	2.132		
	WATER FLEA	C_NOEL	10	06/22/2011	2.132		
	WATER FLEA	C_NOEL	100	01/05/2012	2.132		
	WATER FLEA	C_NOEL	2.13	08/26/2013	2.132	Y	
	WATER FLEA	C_NOEL	2.13	09/08/2014	2.132	Y	

State of Maine - Department of Environmental Protection

Pare

## ATTACHMENT D

.

### PRIORITY POLLUTANT DATA SUMMARY

Date Range: 07/Nov/2009-07/Nov/2014



Facility Name:	MILO				NPDES	5: M	E010	0439		
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	M	۷	BN	· p	0	Α	Clean	Hg
11/02/2010	0.32 0.17	23	10	0	0	0	13_	0	F	0
	Monthly Dally	Total Test		Те	st#E	βγ Gi	oup			
Test Date	(Flow MGD)	Number	M	V	BN	Р	0	A	Clean	Hg
06/22/2011	0.26 0.19	20	10	0	0	0	10	0	F	0
	Monthly Dally	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	M	٧	BN	р	0	A	Clean	Hg
08/24/2011	0.14 0.14	2	1	_0_	0	0	1	0	F	0
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	М	V	BN	Р	0	A	Clean	Hg
01/05/2012	0.14 0.19	19	10	0	0	0	9	0	F	0
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	M	۷	BN	P	0	A	Clean	Hg
07/18/2012	0.23 0.17	2	1	0	0	0	1	0	F	ō
								<b>~ ~ ~</b> ~,~	<b>.</b>	
T	Monthly Daily	Total Test Number			<u>st # B</u>				<b>6</b> 1	11-
Test Date	(Flow MGD)		M 0	V 0	BN 0	<b>Р</b> 0	0	A 0	Clean F	Hg 0
09/26/2012	0.12 0.10	<b>1</b>		<u>U</u> -	0				<u>r</u>	<u>v</u>
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	M	٧·	BN	Р	0'	Α	Clean	Hg
06/12/2013	0.29 0.34	2	1	0_	0	0	1	0	F	0
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	М	V	BN	Р	0	Α	Clean	Hg
08/26/2013	0.20 0.24	21	10	0	. 0	0	_11_	0	F	0
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	M	V	BN	P	0	A	Clean	Hg
02/04/2014	0.17 0.15	11	10	0	0	0	1	0	F	0
	Monthly Daily	Total Test		Toe	it # B	u Ge	014 <b>0</b>	•		
Test Date	(Flow MGD)	Number		V	BN	P	0 <u>000</u> 0		Clean	Hg
06/23/2014	0.19 0.15	21	10	ŏ	0	0	11	õ	F	0
		<u></u>							·····	
	Monthly Daily	Total Test	Test # By Group							
Test Date	(Flow MGD)	Number	м	V	BN	P	0	A	Clean	Hg
09/08/2014	0.09 0.09	20	9	0	0	0	_11	0	<b>F</b>	0

Keyt

A = Acid == Others == Pesticides BN = Base Neutral = M = Metals == V = Volatiles

State of Maine - Department of Environmental Protection

Page No. 1

11/7/2014

### FACILITY PRIORITY POLLUTANT DATA REPORT

Data Date Range: 07/Nov/2009-07/Nov/2014



Page

Facility name: MILO	Permit Number: ME0100439					
Parameter: COPPER	Test date Result (ug/l)					
	11/02/2010	11.000	N			
	06/22/2011	14.000	N			
	08/24/2011	13,000	N			
	01/05/2012	25,000	N			
	07/18/2012	23.300	N			
· ·	06/12/2013	19,800	N			
	08/26/2013	12.700	N			
	02/04/2014	40,500	N			
	06/23/2014	16.400	N			
	09/08/2014	20.000	N			

State of Maine + Department of Environmental Protection

## ATTACHMENT E

#### MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION

#### MEMORANDUM

DATE: October 2008

**TO:** Interested Parties

FROM: Dennis Merrill, DEP

SUBJECT: DEP's system for evaluating toxicity from multiple discharges

\*\*\*\*\*\*\*\*

Following the requirements of DEP's rules, Chapter 530, section 4(F), the Department is evaluating discharges of toxic pollutants into a freshwater river system in order to prevent cumulative impacts from multiple discharges. This is being through the use of a computer program known internally as "DeTox". The enclosed package of information is intended to introduce you to this system.

Briefly, the DeTox program evaluates each wastewater facility within a watershed in three different ways in order to characterize its effluent: 1) the facility's past history of discharges, 2) its potential toxicity at the point of discharge on an individual basis, and 3) the facility's contribution to cumulative toxicity within a river segment in conjunction with other facilities. The value that is most protective of water quality becomes the value that is held in the DeTox system as an allocation for the specific facility and pollutant.

The system is not static and uses a five-year "rolling" data window. This means that, over time, old test results drop off and newer ones are added. The intent of this process is to maintain current, uniform facility data to estimate contributions to a river's total allowable pollutant loading prior to each permit renewal.

Many facilities are required to do only a relatively small amount of pollutant testing on their effluent. This means, statistically, the fewer tests done, the greater the possibility of effluent limits being necessary based on the facility's small amount of data. To avoid this situation, most facilities, especially those with low dilution factors, should consider conducting more than the minimum number of tests required by the rules.

Attached you will find three documents with additional information on the DeTox system:

- Methods for evaluating the effects of multiple discharges of toxic pollutants
- Working definitions of terms used in the DeTox system
- Reviewing DeTox Reports
- Prototype facility and pollutant reports

If you have questions as you review these, please do not hesitate to contact me at <u>Dennis, L. Merrill@maine.gov</u> or 287-7788.

#### Maine Department of Environmental Protection

Methods for evaluating the effects of multiple discharges of toxic pollutants.

#### Reference: DEP Rules, Chapter 530, section 4(F)

To evaluate discharges of toxic pollutants into a freshwater river system and prevent cumulative impacts from multiple discharges, DEP uses a computer program called "DeTox that functions as a mathematical evaluation tool.

It uses physical information about discharge sources and river conditions on file with the Department, established water quality criteria and reported effluent test information to perform these evaluations. Each toxic pollutant and associated water quality criterion for acute, chronic and/or human health effects is evaluated separately.

Each facility in a river drainage area has an assigned position code. This "address" is used to locate the facility on the river segment and in relation to other facilities and tributary streams. All calculations are performed in pounds per day to allow analysis on a mass balance. Pollutants are considered to be conservative in that once in the receiving water they will not easily degrade and have the potential to accumulate.

The process begins with establishing an assimilative capacity for each pollutant and water quality criterion at the most downstream point in the river segment. This calculation includes set-aside amounts for background and reserve quantities and assumed values for receiving water pH, temperature and hardness. The resulting amount of assimilative capacity is available for allocation among facilities on the river.

Each facility is evaluated to characterize its past discharge quantities. The historical discharge, in pounds per day, is figured using the average reported concentration and the facility's permitted flow. As has been past practice, a reasonable potential (RP) factor is used as a tool to estimate the largest discharge that may occur with a certain degree of statistical certainty. The RP factor is multiplied by the historical average to determine an allocation based on past discharges. The RP factor is also multiplied by the single highest test to obtain a maximum day estimate. Finally, the direct average without RP adjustment is used to determine the facility's percent contribution to the river segment in comparison to the sum of all discharges of the pollutant. This percent multiplied by the total assimilative capacity becomes the facility's discharge allocation used in evaluations of the segment loadings.

Additionally, individual facility discharges are evaluated as single sources, as they have been in the past to determine if local conditions are more limiting than a segment evaluation.

With all of this information, facilities are evaluated in three ways. The methods are:

- 1. The facility's past history. This is the average quantity discharged during the past five years multiplied by the applicable RP factor. This method is often the basis for an allocation when the discharge quantity is relatively small in comparison to the water quality based allocation.
- 2. An individual evaluation. This assumes no other discharge sources are present and the allowable quantity is the total available assimilative capacity. This method may be used when a local condition such as river flow at the point of discharge is the limiting factor.
- 3. A segment wide evaluation. This involves allocating the available assimilative capacity within a river segment based on a facility's percent of total past discharges. This method would be used when multiple discharges of the same pollutant to the same segment and the available assimilative capacity is relatively limited.

The value that is most protective of water quality becomes the facility's allocation that is held in the system for the specific facility and pollutant. It is important to note that the method used for allocation is facility and pollutant specific and different facilities on the same segment for the same pollutant can have different methods used depending on their individual situations.

Discharge amounts are always allocated to all facilities having a history of discharging a particular pollutant. This does not mean that effluent limits will be established in a permit. Limits are only needed when past discharge amounts suggest a reasonable potential to exceed a water quality based allocation, either on an individual or segment basis. Similar to past practices for single discharge evaluations, the single highest test value is multiplied by a RP factor and if product is greater than the water quality allowance, an effluent limit is established. It is important to remember an allocation is "banking" some assimilative capacity for a facility even if effluent limits are not needed.

Evaluations are also done for each tributary segment with the sum of discharge quantities in tributaries becoming a "point source" to the next most significant segment. In cases where a facility does not use all of its assimilative capacity, usually due to a more limiting individual water quality criterion, the unused quantity is rolled downstream and made available to other facilities.

The system is not static and uses a five-year rolling data window. Over time, old tests drop off and newer ones are added on. These changes cause the allocations and the need for effluent limits to shift over time to remain current with present conditions. The intent is to update a facility's data and relative contribution to a river's total assimilative capacity prior to each permit renewal. Many facilities are required to do only minimal testing to characterize their effluents. This creates a greater degree of statistical uncertainty about the true long-term quantities. Accordingly, with fewer tests the RP factor will be larger and result in a greater possibility of effluent limits being necessary. To avoid this situation, most facilities, especially those with relatively low dilution factors, are encouraged to conduct more that a minimum number of tests. It is generally to a facility's long-term benefit to have more tests on file since their RP factor will be reduced.

#### Maine Department of Environmental Protection

Working Definitions of Terms Used in the DeTox System.

Allocation. The amount of pollutant loading set aside for a facility. Separate amounts are set for each water quality criterion. Each pollutant having a history of being discharged will receive an allocation, but not all allocations become *effluent limits*. Allocation may be made in three ways: *historical allocation, individual allocation* or *segment allocation*.

Assimilative capacity. The amount of a pollutant that river segment can safely accept from point source discharges. It is determined for the most downstream point in a river segment using the *water quality criterion* and river flow. Separate capacities are set for acute, chronic and human health criteria as applicable for each pollutant. Calculation of this capacity includes factors for *reserve* and *background* amounts.

*Background*. A concentration of a pollutant that is assumed to be present in a receiving water but not attributable to discharges. By rule, this is set as a rebuttable presumption at 10% of the applicable *water quality criterion*.

*Effluent limit*. A numeric limit in a discharge permit specifically restricting the amount of a pollutant that may be discharged. An effluent limit is set only when the highest discharge, including an adjustment for *reasonable potential*, is greater than a facility's water quality based *allocation* for a pollutant.

*Historical allocation* (or *RP history*). One of three ways of developing an *allocation*. The facility's average history of discharges, in pounds at design flow, is multiplied by the appropriate *reasonable potential* factor. An allocation using this method does not become an *effluent limit*.

*Historical discharge percentage*. For each pollutant, the average discharge concentration for each facility in a segment is multiplied by the permitted flow (without including a *reasonable potential* factor). The amounts for all facilities are added together and a percent of the total is figured for each facility. When a facility has no detectable concentrations, that pollutant is assumed to be not present and it receives no percentage.

*Individual allocation.* One of three ways of developing an *allocation*. The facility's single highest discharge on record multiplied by the appropriate *reasonable potential* factor is compared to a water quality based quantity with an assumption that the facility is the only point source to that receiving water. If the RP-adjusted amount is larger, the water quality amount may become an *effluent limit*.

*Less than.* A qualification on a laboratory report indicating the concentration of a pollutant was below a certain concentration. Such a result is evaluated as being one half of the Department's reporting limit in most calculations.


*Reasonable potential (RP).* A statistical method to determine the highest amount of a pollutant likely to be present at any time based on the available test results. The method produces a value or RP factor that is multiplied by test results. The method relies on an EPA guidance document, and considers the coefficient of variation and the number of tests. Generally, the fewer number of tests, the higher the RP factor.


*Reserve*. An assumed concentration of a pollutant that set aside to account for non-point source of a pollutant and to allow new discharges of a pollutant. By rule this is set at 15% of the applicable *water quality criterion*.


Segment allocation. One of three ways of developing an allocation. The amount is set by multiplying a facility's historical discharge percentage for a specific pollutant by the assimilative capacity for that pollutant and criterion. A facility will have different allocation percentages for each pollutant. This amount may become an *effluent limit*.

*Tributary.* A stream flowing into a larger one. A total pollutant load is set by adding the all facilities *allocations* on the tributary and treating this totaled amount as a "point source" to the next larger segment.

*Water quality criteria*. Standards for acceptable in-stream or ambient levels of pollutants. These are established in the Department's Chapter 584 and are expressed as concentrations in ug/L. There may be separate standards for acute and chronic protection aquatic life and/or human health. Each criterion becomes a separate standard. Different stream flows are used in the calculation of each.








IV. Determine Facility History Percentage By pollutant, identify facilities with *Historical Average* Sum all Historical Averages within segment By facility, calculate percent of total: Facility pounds / Total pounds = *Facility History %* 

).



VI. Individual Allocation Select individual facility and dilution factor (DF) Select pollutant and water quality criterion By pollutant and criterion, calculate individual allocations: [DF x 0.75 x criterion] + [0.25 x criterion] = Individual Concentration Determine individual allocation: Individual Concentration x license flow x 8.34 = Individual Allocation Save for comparative evaluation VII. Make Initial Allocation

> By facility, pollutant and criterion, get: Individual Allocation, Segment Allocation, RP Historical Allocation

> > Compare allocation and select the smallest

Save as Facility Allocation

VIII. Evaluate Need for Effluent Limits

By facility, pollutant and criterion select Segment Allocation, Individual Allocation and RP Maximum value

If RP Maximum value is greater than either Segment Allocation or Individual Allocation, use lesser value as Effluent Limit

Save Effluent Limit for comparison

IX. Reallocation of Assimilative Capacity

Starting at top of segment, get Segment Allocation, Facility Allocation and Effluent Limit

If Segment Allocation equals Effluent Limit, move to next facility downstream

If not, subtract Facility Allocation from Segment Allocation

Save difference

Select next facility downstream

Figure remaining Segment Assimilative Capacity at and below facility, less tributaries

Add saved difference to get an adjusted Segment Assimilative Capacity

Reallocate Segment Assimilative Capacity among downstream facilities per step V

Repeat process for each facility downstream in turn

## ATTACHMENT F



#### STATE OF MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION

#### CHAPTER 530.2(D)(4) CERTIFICATION

### GOVERNOR MEPDES#

Facility Name

Since the effective date of your permit, have there been; YES NO **Describe in comments** section 1 Increases in the number, types, and flows of industrial, commercial, or domestic discharges to the facility that in the judgment of the Department may cause the receiving water to become toxic? Changes in the condition or operations of the facility that may 2 Π increase the toxicity of the discharge? Changes in storm water collection or inflow/infiltration 3  $\Box$ affecting the facility that may increase the toxicity of the discharge? 4 Increases in the type or volume of hauled wastes accepted by  $\Box$ the facility?

COMMENTS:

Name (printed):

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

#### This document must be signed by the permittee or their legal representative.

This form may be used to meet the requirements of Chapter 530.2(D)(4). This Chapter requires all dischargers having waived or reduced toxic testing to file a statement with the Department describing changes to the waste being contributed to their system as outlined above. As an alternative, the discharger may submit a signed letter containing the same information.

#### Scheduled Toxicity Testing for the next calendar year

Test Conducted	1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3 <sup>rd</sup> Quarter	4 <sup>th</sup> Quarter
WET Testing				
Priority Pollutant Testing			D	
Analytical Chemistry				D
Other toxic parameters <sup>1</sup>		D	D	

Please place an "X" in each of the boxes that apply to when you will be conducting any one of the three test types during the next calendar year.

<sup>1</sup> This only applies to parameters where testing is required at a rate less frequently than quarterly.

AUGUSTA 17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017 (207) 287-7688 FAX: (207) 287-7826 RAY BLDG., HOSPITAL ST.

BANGOR 106 HOGAN ROAD, SUITE 6 BANGOR, MAINE 04401 (207) 941-4570 FAX: (207) 941-4584 PORTLAND 312 CANCO ROAD PORTLAND, MAINE 04103 (207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE 1235 CENTRAL DRIVE, SKYWAY PARK PRESQUE ISLE, MAINE 04769-2094 (207) 764-0477 FAX: (207)760-3143

PATRICIA W. AHO

Commissioner

.