



PAUL R. LEPAGE  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF  
ENVIRONMENTAL PROTECTION



MELANIE LOYZIM  
ACTING COMMISSIONER

November 14, 2018

Philip Pickering  
Ogunquit Sewer District  
P.O. Box 934  
Ogunquit, Me 03907  
[phil@ogunquitsewerdistrict.org](mailto:phil@ogunquitsewerdistrict.org)

*Sent via electronic mail  
Delivery confirmation requested*

**RE: ICIS Tracking Number # ME0100986  
Maine Waste Discharge License (WDL) Application # W000449-6D-K-R  
Finalized MEPDES License Renewal**

Dear Philip Pickering:

Enclosed please find a copy of your **final** MEPDES permit and Maine WDL which was approved by the Department of Environmental Protection. Please read this permit and its attached conditions carefully. Compliance with this permit will protect water quality.

Any interested person aggrieved by a Department determination made pursuant to applicable regulations, may appeal the decision following the procedures described in the attached DEP FACT SHEET entitled "*Appealing a Commissioner's Licensing Decision.*"

If you have any questions regarding the matter, please feel free to call me at (207)-592-7161.

Your Department compliance inspector copied below is also a resource that can assist you with compliance. Please do not hesitate to contact them with any questions.

Thank you for your efforts to protect and improve the waters of the great state of Maine!

Sincerely,

Aaron Dumont  
Division of Water Quality Management  
Bureau of Water Quality

Enc.

cc: Matt Hight, DEP/SMRO, Lori Mitchell, DEP/CMRO, Marelyn Vega, USEPA,  
Richard Carvalho, USEPA Shelley Puleo, USEPA

AUGUSTA  
17 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0017  
(207) 287-7688 FAX: (207) 287-7826

BANGOR  
106 HOGAN ROAD, SUITE 6  
BANGOR, MAINE 04401  
(207) 941-4570 FAX: (207) 941-4584

PORTLAND  
312 CANCO ROAD  
PORTLAND, MAINE 04103  
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE  
1235 CENTRAL DRIVE, SKYWAY PARK  
PRESQUE ISLE, MAINE 04769  
(207) 764-0477 FAX: (207) 760-3143



STATE OF MAINE  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017

DEPARTMENT ORDER

IN THE MATTER OF

|                                 |   |                           |
|---------------------------------|---|---------------------------|
| OGUNQUIT SEWER DISTRICT         | ) | MAINE POLLUTANT DISCHARGE |
| PUBLICALLY OWNED TREATMENT WORK | ) | ELIMINATION SYSTEM PERMIT |
| OGUNQUIT, YORK COUNTY, MAINE    | ) | AND                       |
| ME0100986                       | ) | WASTE DISCHARGE LICENSE   |
| W000449-6D-K-R                  | ) | <b>RENEWAL</b>            |
| <b>APPROVAL</b>                 | ) |                           |

In compliance with the applicable provisions of *Pollution Control*, 38 M.R.S. §§ 411 – 424-B, *Water Classification Program*, 38 M.R.S. §§ 464 – 470 and *Federal Water Pollution Control Act*, Title 33 U.S.C. § 1251, and applicable rules of the Department of Environmental Protection (Department), the Department has considered the application of the OGUNQUIT SEWER DISTRICT (OSD/permittee), with its supportive data, agency review comments, and other related materials on file and FINDS THE FOLLOWING FACTS:

**APPLICATION SUMMARY**

On January 2, 2018, the Department accepted as complete for processing, a renewal application from the OSD for Waste Discharge License (WDL) W000449-6D-I-R/Maine Pollutant Discharge Elimination System (MEPDES) permit ME0100986, which was issued on February 20, 2013, for a five-year term. The 2/20/13 MEPDES permit authorized OSD to discharge a monthly average flow of 1.28 million gallons per day (MGD) of secondary treated municipal wastewater from a publicly owned treatment works (POTW) to the Atlantic Ocean, Class SB, in Ogunquit, Maine.

**PERMIT SUMMARY**

This permitting action is carrying forward all the terms and conditions of the previous permitting action and subsequent minor revisions except that this permitting action is:

1. Eliminating the waiver that allows the percent removal for Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) to be waived when the monthly average influent concentration is less than 200 mg/L.

*This space intentionally left blank*

## CONCLUSIONS

Based on the findings summarized in the attached Fact Sheet dated November 9, 2018, and subject to the special and standard conditions that follow, the Department makes the following CONCLUSIONS:

1. The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
2. The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
3. The provisions of the State's antidegradation policy, *Classification of Maine waters*, 38 M.R.S. § 464(4)(F), will be met, in that:
  - a. Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
  - b. Where high quality waters of the State constitute an outstanding natural resource, that water quality will be maintained and protected;
  - c. Where the standards of classification of the receiving waterbody are not met, the discharge will not cause or contribute to the failure of the waterbody to meet the standards of classification;
  - d. Where the actual quality of any classified receiving waterbody exceeds the minimum standards of the next highest classification that higher water quality will be maintained and protected; and
  - e. Where a discharge will result in lowering the existing water quality of any waterbody, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
4. The discharge will be subject to effluent limitations that require application of best practicable treatment as defined in *Conditions of licenses*, 38 M.R.S. § 414-A(1)(D).

*This space intentionally left blank*

**ACTION**

Based on the findings and conclusions as stated above, the Department APPROVES the above noted application of the OGUNQUIT SEWER DISTRICT to discharge a monthly average flow of 1.28 MGD of secondary treated wastewater to Atlantic Ocean, Class SB, in Ogunquit, Maine, SUBJECT TO THE ATTACHED CONDITIONS, and all applicable standards and regulations including:


1. *Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable to All Permits*, revised July 1, 2002, copy attached.
2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
3. This permit and the authorization to discharge become effective upon the date of signature below and expire at midnight five (5) years from the effective date. If a renewal application is timely submitted and accepted as complete for processing prior to the expiration of this permit, the authorization to discharge and the terms and conditions of this permit and all modifications and minor revisions thereto remain in effect until a final Department decision on the renewal application becomes effective. [*Maine Administrative Procedure Act*, 5 M.R.S. § 10002 and *Rules Concerning the Processing of Applications and Other Administrative Matters*, 06-096 CMR 2(21)(A) (amended June 9, 2018)].

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

DONE AND DATED AT AUGUSTA, MAINE, THIS 12 DAY OF November 2018.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY:   
For MELANIE LOYZIM, Acting Commissioner



Date filed with Board of Environmental Protection \_\_\_\_\_

Date of initial receipt of application: December 27, 2017

Date of application acceptance: January 2, 2018

This Order prepared by Aaron Dumont, BUREAU OF WATER QUALITY

## SPECIAL CONDITIONS

### A.1 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning upon issuance of this permit, the permittee is authorized to discharge secondary treated municipal wastewater from a publicly owned treatment works via **OUTFALL #002** to the Atlantic Ocean. Such discharges are limited and must be monitored by the permittee as specified below<sup>(1)</sup>.

| Effluent Characteristic   | Discharge Limitations  |                       |                      |                                  |                       |                                 | Minimum Monitoring Requirements |                          |
|---|------------------------|-----------------------|----------------------|----------------------------------|-----------------------|---------------------------------|---------------------------------|--------------------------|
|   | <u>Monthly Average</u> | <u>Weekly Average</u> | <u>Daily Maximum</u> | <u>Monthly Average</u>           | <u>Weekly Average</u> | <u>Daily Maximum</u>            | <u>Measurement Frequency</u>    | <u>Sample Type</u>       |
| Flow<br>[50050]   | 1.28 MGD<br>[03]       | ---                   | Report MGD<br>[03]   | ---                              | ---                   | ---                             | Continuous<br>[99/99]           | Recorder [RC]            |
| BOD <sub>5</sub><br>[00310]   | 320 lbs./Day<br>[26]   | 480 lbs./Day<br>[26]  | 534 lbs./Day<br>[26] | 30 mg/L<br>[19]                  | 45 mg/L<br>[19]       | 50 mg/L<br>[19]                 | 1/Week [01/07]                  | 24 Hr. Composite<br>[24] |
| BOD5 % Removal <sup>(2)</sup><br>[81010]  | ---                    | ---                   | ---                  | 85% [23]                         | ---                   | ---                             | 1/Month [01/30]                 | Calculate [CA]           |
| TSS<br>[00530]  | 320 lbs./Day<br>[26]   | 480 lbs./Day<br>[26]  | 534 lbs./Day<br>[26] | 30 mg/L<br>[19]                  | 45 mg/L<br>[19]       | 50 mg/L<br>[19]                 | 1/Week [01/07]                  | 24 Hr. Composite<br>[24] |
| TSS % Removal <sup>(2)</sup><br>[81011]   | ---                    | ---                   | ---                  | 85% [23]                         | ---                   | ---                             | 1/Month [01/30]                 | Calculate [CA]           |
| Settleable Solids<br>[00545]  | ---                    | ---                   | ---                  | ---                              | ---                   | 0.3 ml/L [25]                   | 3/Week [03/07]                  | Grab [GR]                |
| Fecal Coliform Bacteria <sup>(3)(4)</sup><br>(Year-round)[74055]                              | ---                    | ---                   | ---                  | 15/100 ml <sup>(3)</sup><br>[13] | ---                   | 50/100 ml [13]                  | 1/Week [1/07]                   | Grab [GR]                |
| Total Residual Chlorine <sup>(5)</sup><br>(April – September)<br>(October – March)<br>[50060] | ---                    | ---                   | ---                  | 0.1 mg/L<br>[19]                 | ---                   | 0.3 mg/L [19]<br>0.65 mg/L [19] | 1/Day [01/01]<br>1/Day [01/01]  | Grab [GR]<br>Grab [GR]   |
| pH (Std. Units)<br>[00400]  | ---                    | ---                   | ---                  | ---                              | ---                   | 6.0-9.0 [12]                    | 5/Week [05/07]                  | Grab [GR]                |
| Mercury (Total) <sup>(6)</sup> [71900]  | ---                    | ---                   | ---                  | 19.3 ng/L<br>[3M]                | ---                   | 29.0 ng/L<br>[3M]               | 1/Year<br>[01/YR]               | Grab<br>[GR]             |

The italicized numeric values bracketed in the table and in subsequent text are code numbers that Department personnel utilize to code the monthly Discharge Monitoring Reports

**FOOTNOTES:** See Pages 6 – 9 of this permit for applicable footnotes.

## SPECIAL CONDITIONS

### A.2 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### SCREENING LEVEL TESTING

Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement.

| Effluent Characteristic   | Discharge Limitations  |                      | Minimum Monitoring Requirements |                          |
|---|------------------------|----------------------|---------------------------------|--------------------------|
|   | Monthly <u>Average</u> | Daily <u>Maximum</u> | <u>Measurement Frequency</u>    | <u>Sample Type</u>       |
| Whole Effluent Toxicity <sup>(7)</sup><br><u>Acute – NOEL</u><br><i>Americamysis bahia</i> (Mysid shrimp) [TDM3E] | ---                    | Report % [23]        | 1/Year [01/YR]                  | Composite [24]           |
| <u>Chronic – NOEL</u><br><i>Arbacia punctulata</i> (Sea urchin) [TBH3A]   | ---                    | Report % [23]        | 1/Year [01/YR]                  | Composite [24]           |
| Analytical Chemistry <sup>(8,10)</sup> [51477]  | ---                    | Report ug/L [28]     | 1/Quarter [01/90]               | Composite / Grab [24/GR] |
| Priority Pollutant <sup>(9,10)</sup> [50008]  | ---                    | Report ug/L [28]     | 1/Year [01/YR]                  | Composite / Grab [24/GR] |

The italicized numeric values bracketed in the table and in subsequent text are code numbers that Department personnel utilize to code the monthly Discharge Monitoring Reports.

**FOOTNOTES:** See Pages 6 – 9 of this permit for applicable footnotes.

## **SPECIAL CONDITIONS**

### **A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)**

#### **FOOTNOTES:**

- 1. Sampling** – The permittee must conduct all effluent sampling and analysis in accordance with; a) methods approved by 40 Code of Federal Regulations (CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, or c) as otherwise specified by the Department. Samples that are sent out for analysis must be analyzed by a laboratory certified for wastewater by the State of Maine's Department of Health and Human Services. Samples that are analyzed by laboratories operated by waste discharge facilities licensed pursuant to *Waste discharge licenses*, 38 M.R.S. § 413 are subject to the provisions and restrictions of *Maine Comprehensive and Limited Environmental Laboratory Certification Rules*, 10-144 CMR 263 (last amended April 1, 2010). Laboratory facilities that analyze compliance samples in-house are subject to the provisions and restrictions of 10-144 CMR 263. If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the DMR.
- 2. Percent Removal** – The permittee must achieve a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand for all flows receiving secondary treatment. The percent removal is calculated based on influent and effluent concentration values.
- 3. Fecal Coliform Bacteria – Monitoring requirements are in effect year-round at the request of the Maine Department of Marine Resources in order to protect local shellfish resources near the outfall and to protect the health, safety and welfare of the public.**
- 4. Fecal Coliform Bacteria Reporting** – The monthly average limitation is a geometric mean limitation and results shall be reported as such.
- 5. Total residual chlorine (TRC)** – Limitations and monitoring requirements are in effect any time elemental chlorine or chlorine-based compounds are utilized to disinfect the discharge(s). The permittee must utilize a USEPA-approved test method capable of bracketing the TRC limitations specified in this permitting action. Monitoring for TRC is only required when elemental chlorine or chlorine-based compounds are in use for effluent disinfection. For instances when a facility has not disinfected with chlorine-based compounds for an entire reporting period, the facility must report "N9" on the electronic DMR.

*This space intentionally left blank*

## SPECIAL CONDITIONS

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### **FOOTNOTES:**

- 6. Mercury** – The permittee must conduct all mercury sampling required by this permit or required to determine compliance with interim limitations established pursuant to 06-096 CMR 519 in accordance with the USEPA's "clean sampling techniques" found in USEPA Method 1669, *Sampling Ambient Water For Trace Metals At EPA Water Quality Criteria Levels*. All mercury analysis must be conducted in accordance with USEPA Method 1631, *Determination of Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Fluorescence Spectrometry*. See **Attachment A** for a Department report form for mercury test results. Compliance with the monthly average limitation established in Special Condition A.1 of this permit will be based on the cumulative arithmetic mean of all mercury tests results that were conducted utilizing sampling Method 1669 and analysis Method 1631E on file with the Department for this facility.
- 7. Whole Effluent Toxicity (WET)** – Definitive WET testing is a multi-concentration testing event (a minimum of five dilutions bracketing the critical acute and chronic thresholds of 2% and 1% respectively), which provides a point estimate of toxicity in terms of No Observed Effect Level, commonly referred to as NOEL or NOELC. A-NOEL is defined as the acute no observed effect level with survival as the end point. C-NOEL is defined as the chronic no observed effect level with fertilization as the end point. The critical acute and chronic thresholds were derived as the mathematical inverse of the applicable acute and chronic dilution factors of 50:1 and 102:1, respectively. See **Attachment B** of this permit for a copy of the Department's WET reporting form.
  - a. Screening level testing** – Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee must conduct screening level WET testing at a minimum frequency of once per year (1/Year). Acute tests must be conducted on the mysid shrimp (*Americamysis bahia*); chronic tests must be conducted on the sea urchin (*Arbacia punctulata*).
  - b. Surveillance level testing** – Surveillance level testing is waived pursuant to *Surface Water Toxics Control Program*, 06-096 CMR 530(2)(D)(3)(b) (effective March 12, 2012).

WET test results must be submitted to the Department no later than the next DMR required by the permit. The permittee may review the toxicity reports for up to 10 business days of their availability before submitting them. The permittee must evaluate test results being submitted and identify to the Department possible exceedances of the critical acute and chronic water quality thresholds of 2% and 1%.



## SPECIAL CONDITIONS

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

#### FOOTNOTES:

Toxicity tests must be conducted by an experienced laboratory approved by the Department. The laboratory must follow procedures as described in the following USEPA methods manuals.

- a. U.S. Environmental Protection Agency. 2002. *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, 5th ed. USEPA 821-R-02-012. U.S. Environmental Protection Agency, Office of Water, Washington, D.C., October 2002 (the acute method manual);
- b. U.S. Environmental Protection Agency. 2002. *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, 3rd ed. EPA 821-R-02-014. U.S. Environmental Protection Agency, Office of Water, Washington, D.C., October 2002 (the marine chronic method manual).

Results of WET tests must be reported on the “*Whole Effluent Toxicity Report Marine Waters*” form included as **Attachment B** of this permit each time a WET test is performed. Each time a WET test is performed, the permittee must sample and analyze for the parameters in the WET Chemistry and the Analytical Chemistry sections of the Department form entitled, *Maine Department of Environmental Protection, WET and Chemical Specific Data Report Form* included as **Attachment C** of this permit.

**8. Analytical chemistry** – Refers to a suite of chemicals in **Attachment C** of this permit.

- a. **Screening level testing** – Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee must conduct screening level analytical chemistry testing at a minimum frequency of once per calendar quarter (1/Quarter).
- b. **Surveillance level testing** – Surveillance level testing is not required pursuant to 06-096 CMR 530(2)(D)(3)(b).

*This space intentionally left blank*

## **SPECIAL CONDITIONS**

### **A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)**

#### **FOOTNOTES:**

- 9. Priority pollutant testing** – Priority pollutants are those parameters listed in **Attachment C** of this permit.
- a. **Screening level testing** – Beginning 24 months prior to permit expiration and lasting through 12 months prior to permit expiration (Year 4 of the term of the permit) and every five years thereafter if a timely request for renewal has been made and the permit continues in force, or is replaced by a permit renewal containing this requirement, the permittee must conduct screening level priority pollutant testing at a minimum frequency of once per year (1/Year).
- b. **Surveillance level testing** – Surveillance level testing is not required pursuant to 06-096 CMR 530(2)(D)(3)(b).
- 10. Analytical chemistry and priority pollutant** – Testing must be conducted on samples collected at the same time as those collected for whole effluent toxicity tests when applicable. Priority pollutant and analytical chemistry testing must be conducted using methods that permit detection of a pollutant at existing levels in the effluent or that achieve minimum reporting levels of detection as specified by the Department.

Test results must be submitted to the Department not later than the next DMR required by the permit. The permittee may review the toxicity reports for up to 10 business days of their availability before submitting them. The permittee must evaluate test results being submitted and identify to the Department, possible exceedances of the acute, chronic or human health Ambient Water Quality Criteria (AWQC) as established in *Surface Water Quality Criteria for Toxic Pollutants*, 06-096 CMR 584 (effective October 9, 2005). For the purposes of DMR reporting, enter a “1” for yes, testing done this monitoring period or “N-9” monitoring not required this period.

*This space intentionally left blank*

## **SPECIAL CONDITIONS**

### **B. NARRATIVE EFFLUENT LIMITATIONS**

1. The permittee must not discharge effluent that contains a visible oil sheen, foam or floating solids at any time which would impair the uses designated by the classification of the receiving waters.
2. The permittee must not discharge effluent that contains materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the uses designated by the classification of the receiving waters.
3. The permittee must not discharge effluent that imparts color, turbidity, toxicity, radioactivity or other properties which cause those waters to be unsafe for the designated uses and characteristics ascribed to their classification.
4. The permittee must not discharge effluent that lowers the quality of any classified body of water below such classification, or lower the existing quality of any body of water if the existing quality is higher than the classification.

### **C. TREATMENT PLANT OPERATOR**

The person who has management responsibility over the treatment facility must hold a minimum of a **Maine Grade III**, Biological Treatment certificate (or Registered Maine Professional Engineer) pursuant to *Sewage Treatment Operators*, 32 M.R.S. §§ 4171-4182 and *Regulations for Wastewater Operator Certification*, 06-096 CMR 531 (effective May 8, 2006). All proposed contracts for facility operation by any person must be approved by the Department before the permittee may engage the services of the contract operator.

### **D. LIMITATIONS FOR INDUSTRIAL USERS**

Pollutants introduced into the wastewater collection and treatment system by a non-domestic source (user) must not pass through or interfere with the operation of the treatment system. The permittee must conduct an Industrial Waste Survey (IWS) any time a new industrial user proposes to discharge within its jurisdiction; an existing user proposes to make a significant change in its discharge; or at an alternative minimum, once every permit cycle and submit the results to the Department. The IWS must identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging into the POTW subject to Pretreatment Standards under section 307(b) of the federal *Clean Water Act*, 40 CFR Part 403 (general pretreatment regulations) or *Pretreatment Program*, 06-096 CMR 528 (last amended March 17, 2008).

*This space intentionally left blank*

## **SPECIAL CONDITIONS**

### **E. AUTHORIZED DISCHARGES**

The permittee is authorized to discharge only in accordance with: 1) the permittee's General Application for Waste Discharge Permit, accepted for processing on January 2, 2018; 2) the terms and conditions of this permit; and 3) only from Outfall #002. Discharges of wastewater from any other point source(s) are not authorized under this permit, and must be reported in accordance with Standard Condition D(1)(f), *Twenty-four hour reporting*, of this permit.

### **F. NOTIFICATION REQUIREMENT**

In accordance with Standard Condition D, the permittee must notify the Department of the following:

1. Any introduction of pollutants into the wastewater collection and treatment system from an indirect discharger in a primary industrial category discharging process wastewater; and
2. Any substantial change in the volume or character of pollutants being introduced into the wastewater collection and treatment system by a source introducing pollutants to the system at the time of permit issuance.
3. For the purposes of this section, notice regarding substantial change must include information on:
  - a. the quality and quantity of wastewater introduced to the wastewater collection and treatment system; and
  - b. any anticipated impact caused by the change in the quantity or quality of the wastewater to be discharged from the treatment system.

### **G. WET WEATHER MANAGEMENT PLAN**

The treatment facility staff must have a current written Wet Weather Flow Management Plan to direct the staff on how to operate the facility effectively during periods of high flow. A specific objective of the plan must be to maximize the volume of wastewater receiving secondary treatment under all operating conditions. The revised plan must include operating procedures for a range of intensities, address solids handling procedures (including septic waste and other high strength wastes if applicable) and provide written operating and maintenance procedures for before, during and after the events.

**The permittee must review their plan at least annually and record any necessary changes to keep the plan up to date.** The Department may require review and update of the plan as it is determined to be necessary.

*This space intentionally left blank*

## **SPECIAL CONDITIONS**

### **H. OPERATIONS AND MAINTENANCE (O&M) PLAN**

**The permittee must maintain a current written comprehensive Operation & Maintenance (O&M) Plan for the facility.** The plan must provide a systematic approach by which the permittee must at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit.

**By December 31 of each year, or within 90 days of any process changes or minor equipment upgrades,** the permittee must evaluate and modify the O&M Plan including site plan(s) and schematic(s) for the wastewater treatment facility to ensure that it is up-to-date. The O&M Plan must be kept on-site at all times and made available to Department and USEPA personnel upon request.

**Within 90 days of completion of new and or substantial upgrades of the wastewater treatment facility,** the permittee must submit the updated O&M Plan to their Department inspector for review and comment.

### **I. DISPOSAL OF TRANSPORTED WASTES IN WASTEWATER TREATMENT FACILITY**

During the effective period of this permit, the permittee is authorized to receive and introduce into the treatment process or solids handling stream up to **a daily maximum of 3,000 gallons per day and not to exceed a monthly total of 20,000 gallons** of transported wastes, subject to the following terms and conditions:

1. "Transported wastes" means any liquid non-hazardous waste delivered to a wastewater treatment facility by a truck or other similar conveyance that has different chemical constituents or a greater strength than the influent described on the facility's application for a waste discharge license. Such wastes may include, but are not limited to septage, industrial wastes or other wastes to which chemicals in quantities potentially harmful to the treatment facility or receiving water have been added.
2. The character and handling of all transported wastes received must be consistent with the information and management plans provided in application materials submitted to the Department.

*This space intentionally left blank*

## **SPECIAL CONDITIONS**

### **I. DISPOSAL OF TRANSPORTED WASTES IN WASTEWATER TREATMENT FACILITY (cont'd)**

3. At no time, may the addition of transported wastes cause or contribute to effluent quality violations. Transported wastes may not cause an upset of or pass through the treatment process or have any adverse impact on the sludge disposal practices of the wastewater treatment facility. Wastes that contain heavy metals, toxic chemicals, extreme pH, flammable or corrosive materials in concentrations harmful to the treatment operation must be refused. Odors and traffic from the handling of transported wastes may not result in adverse impacts to the surrounding community. If any adverse effects exist, the receipt or introduction of transported wastes into the treatment process or solids handling stream must be suspended until there is no further risk of adverse effects.
4. The permittee must maintain records for each load of transported wastes in a daily log which must include at a minimum the following:
  - (a) The date;
  - (b) The volume of transported wastes received;
  - (c) The source of the transported wastes;
  - (d) The person transporting the transported wastes;
  - (e) The results of inspections or testing conducted;
  - (f) The volumes of transported wastes added to each treatment stream; and
  - (g) The information in (a) through (d) for any transported wastes refused for acceptance.

These records must be maintained at the treatment facility for a minimum of five years.

5. The addition of transported wastes into the treatment process or solids handling stream must not cause the treatment facilities design capacity to be exceeded. If, for any reason, the treatment process or solids handling facilities become overloaded, introduction of transported wastes into the treatment process or solids handling stream must be reduced or terminated in order to eliminate the overload condition.
6. Holding tank wastewater from domestic sources to which no chemicals in quantities potentially harmful to the treatment process have been added must not be recorded as transported wastes but should be reported in the treatment facility's influent flow.
7. During wet weather events, transported wastes may be added to the treatment process or solids handling facilities only in accordance with a current Wet Weather Flow Management Plan approved by the Department pursuant to Special Condition G that provides for full treatment of transported wastes without adverse impacts.

*This space intentionally left blank*

**SPECIAL CONDITIONS**

**I. DISPOSAL OF TRANSPORTED WASTES IN WASTEWATER TREATMENT FACILITY (cont'd)**

8. In consultation with the Department, chemical analysis is required prior to receiving transported wastes from new sources that are not of the same nature as wastes previously received. The analysis must be specific to the type of source and designed to identify concentrations of pollutants that may pass through, upset or otherwise interfere with the facility's operation.
9. The authorization is subject to annual review and, with notice to the permittee and other interested parties of record, may be suspended or reduced by the Department as necessary to ensure full compliance with Chapter 555 of the Department's rules and the terms and conditions of this permit.

**J. 06-096 CMR 530(2)(D)(4) STATEMENT FOR REDUCED/WAIVED TOXICS TESTING**

**By December 31 of each calendar year**, the permittee must provide the Department with a certification describing any of the following that have occurred since the effective date of this permit *[ICIS Code 75305]*. See **Attachment D** for an acceptable certification form to satisfy this Special Condition.

- a. Changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge;
- b. Changes in the operation of the treatment works that may increase the toxicity of the discharge;
- c. Changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge;

In addition, in the comments section of the certification form, the permittee must provide the Department with statements describing;

- d. Changes in stormwater collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge; and
- e. Increases in the type or volume of transported (hailed) wastes accepted by the facility.

The Department may require that routine surveillance level testing be re-instated if it determines that there have been changes in the character of the discharge or if annual certifications described above are not submitted.

*This space intentionally left blank*

## SPECIAL CONDITIONS

### K. MONITORING AND REPORTING

#### Electronic Reporting

*NPDES Electronic Reporting*, 40 C.F.R. 127, requires MEPDES permit holders to submit monitoring results obtained during the previous month on an electronic discharge monitoring report to the regulatory agency utilizing the USEPA electronic system.

Electronic Discharge Monitoring Reports (DMRs) submitted using the USEPA NetDMR system, must be:

1. Submitted by a facility authorized signatory; and
2. Submitted no later than **midnight on the 15<sup>th</sup> day of the month** following the completed reporting period.

Documentation submitted in support of the electronic DMR may be attached to the electronic DMR. Toxics reporting must be done using the DEP toxsheet reporting form. An electronic copy of the Toxsheet reporting document must be submitted to your Department compliance inspector as an attachment to an email. In addition, a hardcopy form of this sheet must be signed and submitted to your compliance inspector, or a copy attached to your NetDMR submittal will suffice. Documentation submitted electronically to the Department in support of the electronic DMR must be submitted no later than midnight on the 15<sup>th</sup> day of the month following the completed reporting period.

Toxsheet reporting forms must be submitted electronically as an attachment to an email sent to your Department compliance inspector. In addition, a signed hardcopy of your toxsheet must also be submitted.

A signed copy of the DMR and all other reports required herein must be submitted to the Department assigned compliance inspector (unless otherwise specified) following address:

Department of Environmental Protection  
Southern Maine Regional Office  
Bureau of Water Quality  
Division of Water Quality Management  
312 Canco Road  
Portland, Maine 04103

*This space intentionally left blank*



**SPECIAL CONDITIONS**

**L. REOPENING OF PERMIT FOR MODIFICATION**

In accordance with 38 M.R.S. § 414-A(5) and upon evaluation of the tests results or monitoring requirements specified in Special Conditions of this permitting action, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at any time and with notice to the permittee, modify this permit to: 1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded, (2) require additional monitoring if results on file are inconclusive; or (3) change monitoring requirements or limitations based on new information.

**M. SEVERABILITY**

In the event that any provision(s), or part thereof, of this permit is declared to be unlawful by a reviewing court, the remainder of the permit must remain in full force and effect, and must be construed and enforced in all aspects as if such unlawful provision, or part thereof, had been omitted, unless otherwise ordered by the court.

# **ATTACHMENT A**

**Effluent Mercury Test Report**

Name of Facility: \_\_\_\_\_ Federal Permit # ME \_\_\_\_\_

Purpose of this test: ☐ Initial limit determination  
☐ Compliance monitoring for: year \_\_\_\_\_ calendar quarter \_\_\_\_\_  
☐ Supplemental or extra test

**SAMPLE COLLECTION INFORMATION**

|  |                      |                      |                      |                |                      |       |
|--|----------------------|----------------------|----------------------|----------------|----------------------|-------|
| Sampling Date:   | <input type="text"/> | <input type="text"/> | <input type="text"/> | Sampling time: | <input type="text"/> | AM/PM |
|  | mm                   | dd                   | yy                   |                |                      |       |
| Sampling Location:   |                      |                      |                      |                |                      |       |
| Weather Conditions:  |                      |                      |                      |                |                      |       |
| Please describe any unusual conditions with the influent or at the facility during or preceding the time of sample collection:         |                      |                      |                      |                |                      |       |
| Optional test - not required but recommended where possible to allow for the most meaningful evaluation of mercury results:            |                      |                      |                      |                |                      |       |
| Suspended Solids <input type="text"/> mg/L      Sample type: <input type="text"/> Grab (recommended) or <input type="text"/> Composite |                      |                      |                      |                |                      |       |

**ANALYTICAL RESULT FOR EFFLUENT MERCURY**

|   |   |
|---|---|
| Name of Laboratory: _____   |   |
| Date of analysis: _____   | Result: <input type="text"/> ng/L (PPT) |
| Please Enter Effluent Limits for your facility  |   |
| Effluent Limits: Average = <input type="text"/> ng/L  | Maximum = <input type="text"/> ng/L     |
| Please attach any remarks or comments from the laboratory that may have a bearing on the results or their interpretation. If duplicate samples were taken at the same time please report the average. |   |

**CERTIFICATION**

|  |             |
|--|-------------|
| I certify that to the best of my knowledge the foregoing information is correct and representative of conditions at the time of sample collection. The sample for mercury was collected and analyzed using EPA Methods 1669 (clean sampling) and 1631 (trace level analysis) in accordance with instructions from the DEP. |             |
| By: _____  | Date: _____ |
| Title: _____   |             |

PLEASE MAIL THIS FORM TO YOUR ASSIGNED INSPECTOR

## **ATTACHMENT B**

**MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION  
WHOLE EFFLUENT TOXICITY REPORT  
MARINE WATERS**

Facility Name \_\_\_\_\_ MEPDES Permit # \_\_\_\_\_  
Pipe # \_\_\_\_\_

Facility Representative \_\_\_\_\_ Signature \_\_\_\_\_

By signing this form, I attest that to the best of my knowledge that the information provided is true, accurate, and complete.

Facility Telephone # \_\_\_\_\_ Date Collected \_\_\_\_\_ Date Tested \_\_\_\_\_  
mm/dd/yy mm/dd/yy

Chlorinated? \_\_\_\_\_ Dechlorinated? \_\_\_\_\_

| Results |  | % effluent   |            |
|---------|--|--------------|------------|
|         |  | mysis shrimp | sea urchin |
| A-NOEL  |  |              |            |
| C-NOEL  |  |              |            |

A-NOEL \_\_\_\_\_  
C-NOEL \_\_\_\_\_

| QC standard             | % survival | % fertilized |
|-------------------------|------------|--------------|
| lab control             | >90        | >70          |
| receiving water control |            |              |
| conc. 1 ( %)            |            |              |
| conc. 2 ( %)            |            |              |
| conc. 3 ( %)            |            |              |
| conc. 4 ( %)            |            |              |
| conc. 5 ( %)            |            |              |
| conc. 6 ( %)            |            |              |
| stat test used          |            |              |

brine \_\_\_\_\_  
sea salt \_\_\_\_\_  
other \_\_\_\_\_

place \* next to values statistically different from controls

|                 | A-NOEL | C-NOEL |
|-----------------|--------|--------|
| toxicant / date |        |        |
| limits (mg/L)   |        |        |
| results (mg/L)  |        |        |

Comments \_\_\_\_\_

**Laboratory conducting test**

Company Name \_\_\_\_\_ Company Rep. Name (Printed) \_\_\_\_\_

Mailing Address \_\_\_\_\_ Company Rep. Signature \_\_\_\_\_

City, State, ZIP \_\_\_\_\_ Company Telephone # \_\_\_\_\_

Report WET chemistry on DEP Form "ToxSheet (Marine Version), March 2007."

## **ATTACHMENT C**

**Maine Department of Environmental Protection**  
**WET and Chem**

**This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.**

Facility Name \_\_\_\_\_ MEPDES # \_\_\_\_\_  
Pipe # \_\_\_\_\_

Facility Representative Signature \_\_\_\_\_  
To the best of my knowledge this information is true, accurate and complete.

|                                    |   |
|------------------------------------|---|
| Licensed Flow (MGD)                |   |
| Acute dilution factor              |   |
| Chronic dilution factor            |   |
| Human health dilution factor       |   |
| Criteria type: M(arine) or F(resh) | m |

Flow for Day (MGD)<sup>(1)</sup> Flow Avg. for Month (MGD)<sup>(2)</sup> Date Sample Collected Date Sample Analyzed 

Laboratory \_\_\_\_\_ Telephone \_\_\_\_\_  
Address \_\_\_\_\_

Lab Contact \_\_\_\_\_ Lab ID # \_\_\_\_\_

Last Revision - July 1, 2015

ERROR WARNING ! Essential facility information is missing. Please check required entries in bold above.

MARINE AND ESTUARY VERSION

Please see the footnotes on the last page.

Receiving  
Water or  
Ambient

| Effluent<br>Concentration (ug/L or<br>as noted) |
|---|
|---|

| WHOLE EFFLUENT TOXICITY             |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|-------------------------------------|--|-----------------|-----------------------|------------------------|-----------------------|-----|--------------------------------------|--------------------------|------------------------------------|---------|--------|
|                                     |  |                 | Effluent Limits, %    |                        |                       |     | WET Result, %<br>Do not enter % sign | Reporting<br>Limit Check | Possible Exceedence <sup>(7)</sup> |         |        |
|                                     |  |                 | Acute                 | Chronic                |                       |     |                                      |                          | Acute                              | Chronic |        |
|                                     | Mysid Shrimp   |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     | Sea Urchin   |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
| WET CHEMISTRY                       |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     | pH (S.U.) <sup>(9)</sup>   |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     | Total Organic Carbon (mg/L)  |                 |                       |                        |                       | NA  |                                      |                          |                                    |         |        |
|                                     | Total Solids (mg/L)  |                 |                       |                        |                       | NA  |                                      |                          |                                    |         |        |
|                                     | Total Suspended Solids (mg/L)  |                 |                       |                        |                       | NA  |                                      |                          |                                    |         |        |
|                                     | Salinity (ppt.)  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
| ANALYTICAL CHEMISTRY <sup>(3)</sup> |  |                 |                       |                        |                       |     |                                      |                          |                                    |         |        |
|                                     | Also do these tests on the effluent with WET. Testing on the receiving water is optional | Reporting Limit | Effluent Limits, ug/L |                        |                       |     |                                      | Reporting<br>Limit Check | Possible Exceedence <sup>(7)</sup> |         |        |
|                                     |  |                 | Acute <sup>(6)</sup>  | Chronic <sup>(6)</sup> | Health <sup>(6)</sup> |     |                                      |                          | Acute                              | Chronic | Health |
|                                     | TOTAL RESIDUAL CHLORINE (mg/L) <sup>(9)</sup>  | 0.05            |                       |                        |                       | NA  |                                      |                          |                                    |         |        |
|                                     | AMMONIA  | NA              |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | ALUMINUM   | NA              |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | ARSENIC  | 5               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | CADMIUM  | 1               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | CHROMIUM   | 10              |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | COPPER   | 3               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | CYANIDE, TOTAL   | 5               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
|                                     | CYANIDE, AVAILABLE <sup>(3a)</sup>   | 5               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | LEAD   | 3               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | NICKEL   | 5               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | SILVER   | 1               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |
| M                                   | ZINC   | 5               |                       |                        |                       | (8) |                                      |                          |                                    |         |        |

**Maine Department of Environmental Protection  
WET and Chem**

**This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.**

| PRIORITY POLLUTANTS <sup>(4)</sup> |   | Effluent Limits |                      |                        |                       | Reporting Limit Check | Possible Exceedence <sup>(7)</sup> |         |        |
|------------------------------------|---|-----------------|----------------------|------------------------|-----------------------|-----------------------|------------------------------------|---------|--------|
|                                    |   | Reporting Limit | Acute <sup>(6)</sup> | Chronic <sup>(6)</sup> | Health <sup>(6)</sup> |                       | Acute                              | Chronic | Health |
| M                                  | ANTIMONY  | 5               |                      |                        |                       |                       |                                    |         |        |
| M                                  | BERYLLIUM   | 2               |                      |                        |                       |                       |                                    |         |        |
| M                                  | MERCURY (5)                                       | 0.2             |                      |                        |                       |                       |                                    |         |        |
| M                                  | SELENIUM  | 5               |                      |                        |                       |                       |                                    |         |        |
| M                                  | THALLIUM  | 4               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2,4,6-TRICHLOROPHENOL                             | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2,4-DICHLOROPHENOL                                | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2,4-DIMETHYLPHENOL                                | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2,4-DINITROPHENOL                                 | 45              |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2-CHLOROPHENOL                                    | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 2-NITROPHENOL                                     | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | 4,6 DINITRO-O-CRESOL (2-Methyl-4,6-dinitrophenol) | 25              |                      |                        |                       |                       |                                    |         |        |
| A                                  | 4-NITROPHENOL                                     | 20              |                      |                        |                       |                       |                                    |         |        |
| A                                  | P-CHLORO-M-CRESOL (3-methyl-4-chlorophenol)+B80   | 5               |                      |                        |                       |                       |                                    |         |        |
| A                                  | PENTACHLOROPHENOL                                 | 20              |                      |                        |                       |                       |                                    |         |        |
| A                                  | PHENOL  | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 1,2,4-TRICHLOROBENZENE                            | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 1,2-(O)DICHLOROBENZENE                            | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 1,2-DIPHENYLHYDRAZINE                             | 20              |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 1,3-(M)DICHLOROBENZENE                            | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 1,4-(P)DICHLOROBENZENE                            | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 2,4-DINITROTOLUENE                                | 6               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 2,6-DINITROTOLUENE                                | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 2-CHLORONAPHTHALENE                               | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 3,3'-DICHLOROBENZIDINE                            | 16.5            |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 3,4-BENZO(B)FLUORANTHENE                          | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 4-BROMOPHENYLPHENYL ETHER                         | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | 4-CHLOROPHENYL PHENYL ETHER                       | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | ACENAPHTHENE                                      | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | ACENAPHTHYLENE                                    | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | ANTHRACENE  | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BENZIDINE   | 45              |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BENZO(A)ANTHRACENE                                | 8               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BENZO(A)PYRENE                                    | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BENZO(G,H,I)PERYLENE                              | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BENZO(K)FLUORANTHENE                              | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BIS(2-CHLOROETHOXY)METHANE                        | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BIS(2-CHLOROETHYL)ETHER                           | 6               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BIS(2-CHLOROISOPROPYL)ETHER                       | 6               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BIS(2-ETHYLHEXYL)PHTHALATE                        | 10              |                      |                        |                       |                       |                                    |         |        |
| BN                                 | BUTYLBENZYL PHTHALATE                             | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | CHRYSENE  | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | DI-N-BUTYL PHTHALATE                              | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | DI-N-OCTYL PHTHALATE                              | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | DIBENZO(A,H)ANTHRACENE                            | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | DIETHYL PHTHALATE                                 | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | DIMETHYL PHTHALATE                                | 5               |                      |                        |                       |                       |                                    |         |        |
| BN                                 | FLUORANTHENE                                      | 5               |                      |                        |                       |                       |                                    |         |        |



**Maine Department of Environmental Protection  
WET and Chem**

**This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.**

|    |   |      |  |  |  |  |  |  |  |  |  |  |
|----|---|------|--|--|--|--|--|--|--|--|--|--|
| BN | FLUORENE  | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | HEXACHLOROBENZENE                                     | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | HEXACHLOROBUTADIENE                                   | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | HEXACHLOROCYCLOPENTADIENE                             | 10   |  |  |  |  |  |  |  |  |  |  |
| BN | HEXACHLOROETHANE                                      | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | INDENO(1,2,3-CD)PYRENE                                | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | ISOPHORONE  | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | N-NITROSODI-N-PROPYLAMINE                             | 10   |  |  |  |  |  |  |  |  |  |  |
| BN | N-NITROSODIMETHYLAMINE                                | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | N-NITROSODIPHENYLAMINE                                | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | NAPHTHALENE   | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | NITROBENZENE  | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | PHENANTHRENE  | 5    |  |  |  |  |  |  |  |  |  |  |
| BN | PYRENE  | 5    |  |  |  |  |  |  |  |  |  |  |
| P  | 4,4'-DDD  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | 4,4'-DDE  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | 4,4'-DDT  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | A-BHC   | 0.2  |  |  |  |  |  |  |  |  |  |  |
| P  | A-ENDOSULFAN  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | ALDRIN  | 0.15 |  |  |  |  |  |  |  |  |  |  |
| P  | B-BHC   | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | B-ENDOSULFAN  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | CHLORDANE   | 0.1  |  |  |  |  |  |  |  |  |  |  |
| P  | D-BHC   | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | DIELDRIN  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | ENDOSULFAN SULFATE                                    | 0.1  |  |  |  |  |  |  |  |  |  |  |
| P  | ENDRIN  | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | ENDRIN ALDEHYDE                                       | 0.05 |  |  |  |  |  |  |  |  |  |  |
| P  | G-BHC   | 0.15 |  |  |  |  |  |  |  |  |  |  |
| P  | HEPTACHLOR  | 0.15 |  |  |  |  |  |  |  |  |  |  |
| P  | HEPTACHLOR EPOXIDE                                    | 0.1  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1016  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1221  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1232  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1242  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1248  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1254  | 0.3  |  |  |  |  |  |  |  |  |  |  |
| P  | PCB-1260  | 0.2  |  |  |  |  |  |  |  |  |  |  |
| P  | TOXAPHENE   | 1    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,1,1-TRICHLOROETHANE                                 | 5    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,1,2,2-TETRACHLOROETHANE                             | 7    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,1,2-TRICHLOROETHANE                                 | 5    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,1-DICHLOROETHANE                                    | 5    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,1-DICHLOROETHYLENE (1,1-dichloroethene)             | 3    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,2-DICHLOROETHANE                                    | 3    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,2-DICHLOROPROPANE                                   | 6    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,2-TRANS-DICHLOROETHYLENE (1,2-trans-dichloroethene) | 5    |  |  |  |  |  |  |  |  |  |  |
| V  | 1,3-DICHLOROPROPYLENE (1,3-dichloropropene)           | 5    |  |  |  |  |  |  |  |  |  |  |
| V  | 2-CHLOROETHYL VINYL ETHER                             | 20   |  |  |  |  |  |  |  |  |  |  |
| V  | ACROLEIN  | NA   |  |  |  |  |  |  |  |  |  |  |
| V  | ACRYLONITRILE   | NA   |  |  |  |  |  |  |  |  |  |  |
| V  | BENZENE   | 5    |  |  |  |  |  |  |  |  |  |  |

**Maine Department of Environmental Protection  
WET and Chem**

**This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.**

|   |   |    |  |  |  |  |  |  |  |  |  |
|---|---|----|--|--|--|--|--|--|--|--|--|
| V | BROMOFORM   | 5  |  |  |  |  |  |  |  |  |  |
| V | CARBON TETRACHLORIDE  | 5  |  |  |  |  |  |  |  |  |  |
| V | CHLOROBENZENE   | 6  |  |  |  |  |  |  |  |  |  |
| V | CHLORODIBROMOMETHANE  | 3  |  |  |  |  |  |  |  |  |  |
| V | CHLOROETHANE  | 5  |  |  |  |  |  |  |  |  |  |
| V | CHLOROFORM  | 5  |  |  |  |  |  |  |  |  |  |
| V | DICHLOROBROMOMETHANE  | 3  |  |  |  |  |  |  |  |  |  |
| V | ETHYLBENZENE  | 10 |  |  |  |  |  |  |  |  |  |
| V | METHYL BROMIDE (Bromomethane)                                   | 5  |  |  |  |  |  |  |  |  |  |
| V | METHYL CHLORIDE (Chloromethane)                                 | 5  |  |  |  |  |  |  |  |  |  |
| V | METHYLENE CHLORIDE  | 5  |  |  |  |  |  |  |  |  |  |
| V | TETRACHLOROETHYLENE<br>(Perchloroethylene or Tetrachloroethene) | 5  |  |  |  |  |  |  |  |  |  |
| V | TOLUENE   | 5  |  |  |  |  |  |  |  |  |  |
| V | TRICHLOROETHYLENE<br>(Trichloroethene)                          | 3  |  |  |  |  |  |  |  |  |  |
| V | VINYL CHLORIDE  | 5  |  |  |  |  |  |  |  |  |  |

**Notes:**

- (1) Flow average for day pertains to WET/PP composite sample day.
- (2) Flow average for month is for month in which WET/PP sample was taken.
- (3) Analytical chemistry parameters must be done as part of the WET test chemistry.
- (3a) Cyanide, Available (Cyanide Amenable to Chlorination) is not an analytical chemistry parameter, but may be required by certain discharge permits .
- (4) Priority Pollutants should be reported in micrograms per liter (ug/L).
- (5) Mercury is often reported in nanograms per liter (ng/L) by the contract laboratory, so be sure to convert to micrograms per liter on this spreadsheet.
- (6) Effluent Limits are calculated based on dilution factor, background allocation (10%) and water quality reserves (15% - to allow for new or changed discharges or non-point sources).
- (7) Possible Exceedence determinations are done for a single sample only on a mass basis using the actual pounds discharged. This analysis does not consider watershed wide allocations for fresh water discharges.
- (8) These tests are optional for the receiving water. However, where possible samples of the receiving water should be preserved and saved for the duration of the WET test. In the event of questions about the receiving water's possible effect on the WET results, chemistry tests should then be conducted.
- (9) pH and Total Residual Chlorine must be conducted at the time of sample collection. Tests for Total Residual Chlorine need be conducted only when an effluent has been chlorinated or residual chlorine is believed to be present for any other reason.

Comments:

## **ATTACHMENT D**

STATE OF MAINE  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

CHAPTER 530.2(D)(4) CERTIFICATION

MEPDES# \_\_\_\_\_ Facility Name \_\_\_\_\_

| Since the effective date of your permit, have there been; |   | NO                       | YES<br>Describe in comments<br>section |
|---|---|--------------------------|--|
| 1   | Increases in the number, types, and flows of industrial, commercial, or domestic discharges to the facility that in the judgment of the Department may cause the receiving water to become toxic? | <input type="checkbox"/> | <input type="checkbox"/>               |
| 2   | Changes in the condition or operations of the facility that may increase the toxicity of the discharge?   | <input type="checkbox"/> | <input type="checkbox"/>               |
| 3   | Changes in storm water collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge?  | <input type="checkbox"/> | <input type="checkbox"/>               |
| 4   | Increases in the type or volume of hauled wastes accepted by the facility?  | <input type="checkbox"/> | <input type="checkbox"/>               |

COMMENTS:

Name (printed): \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**This document must be signed by the permittee or their legal representative.**

This form may be used to meet the requirements of Chapter 530.2(D)(4). This Chapter requires all dischargers having waived or reduced toxic testing to file a statement with the Department describing changes to the waste being contributed to their system as outlined above. As an alternative, the discharger may submit a signed letter containing the same information.

**Scheduled Toxicity Testing for the next calendar year**

| Test Conducted                      | 1 <sup>st</sup> Quarter  | 2 <sup>nd</sup> Quarter  | 3 <sup>rd</sup> Quarter  | 4 <sup>th</sup> Quarter  |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| WET Testing                         | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Priority Pollutant Testing          | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Analytical Chemistry                | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Other toxic parameters <sup>1</sup> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

*Please place an "X" in each of the boxes that apply to when you will be conducting any one of the three test types during the next calendar year.*

<sup>1</sup> This only applies to parameters where testing is required at a rate less frequently than quarterly.

**MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT  
MAINE WASTE DISCHARGE LICENSE**

**FACT SHEET**

DATE: **November 9, 2018**

PERMIT NUMBER: **ME0100986**

WASTE DISCHARGE LICENSE: **W000449-6D-K-R**

NAME AND ADDRESS OF APPLICANT:

**OGUNQUIT SEWER DISTRICT  
SCHOOL STREET, P.O. BOX 934  
OGUNQUIT, ME 03907**

COUNTY: **YORK**

NAME AND ADDRESS WHERE DISCHARGE(S) OCCUR(S):

**OGUNQUIT SEWER DISTRICT  
80 MARSHVIEW LANE  
OGUNQUIT, ME 03907**

RECEIVING WATER CLASSIFICATION: **ATLANTIC OCEAN/CLASS SB**

COGNIZANT OFFICIAL CONTACT INFORMATION:

**PHILIP PICKERING, SUPERINTENDENT  
(207)-646-3271  
[phil@ogunquitsewerdistrict.org](mailto:phil@ogunquitsewerdistrict.org)**

**1. APPLICATION SUMMARY**

On January 2, 2018, the Department of Environmental Protection (Department) accepted as complete for processing, a renewal application from the Ogunquit Sewer District (OSD/permittee) for Waste Discharge License (WDL) W000449-6D-I-R /Maine Pollutant Discharge Elimination System (MEPDES) permit ME0100986, which was issued on February 20, 2013, for a five-year term. The 2/20/13 MEPDES permit authorized OSD to discharge a monthly average flow of 1.28 million gallons per day (MGD) of secondary treated municipal wastewater from a publicly owned treatment works (POTW) to the Atlantic Ocean, Class SB, in Ogunquit, Maine.

## 2. PERMIT SUMMARY

- a. Terms and Conditions: This permitting action is carrying forward all the terms and conditions of the previous permitting action and subsequent minor revisions except that it:
1. Eliminating the waiver that allows the percent removal for Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) to be waived when the monthly average influent concentration is less than 200 mg/L.

- b. History: This section provides a summary of significant licensing/permitting actions and milestones that have been completed for the permittee.

*November 14, 1979* – The United States Environmental Protection Agency (USEPA) issued National Pollutant Discharge Elimination System (NPDES) permit #449 to the Ogunquit Sewer District for a five-year term.

*April 15, 1985* – The USEPA issued NPDES permit #ME0100986 for a five-year term.

*March 5, 1985* – The Department issued WDL #W000449-46-A-R for a five-year term.

*August 23, 1991* – The Department issued WDL #W00449-4-B-R for a five-year term.

*September 30, 1991* – The USEPA issued a renewal of NPDES permit #ME0100986 for a five-year term.

*July 15, 1993* – The USEPA issued a modification of NPDES permit #ME0100986. The modification reduced whole effluent toxicity (WET) testing from 1/Quarter to 1/Year and reduced the monitoring frequency for enterococci and fecal coliform bacteria from 1/Day to 3/Week between October 1<sup>st</sup> and March 31<sup>st</sup>.

*September 30, 1996* – The USEPA issued a renewal of NPDES permit #ME0100986/WDL for a five-year term.

*March 23, 1998* – The Department issued WDL #W000449-46-D-R for a five-year term.

*May 23, 2000* – The Department administratively modified the 3/23/98 WDL for the OSD facility by establishing interim monthly average and daily maximum concentration limits for mercury.

*February 25, 2003* – The Department issued combination MEPDES permit #ME0100986/WDL #W000449-5L-F-R for a five-year term.

*April 20, 2006* – The Department issued a modification of the 2/25/03 MEPDES permit by incorporating WET and chemical specific testing requirements pursuant to 06-096 CMR 530 promulgated on October 12, 2005.

*March 12, 2008* – The Department issued combination MEPDES permit #ME0100986/WDL #W000449-5L-G-R for a five-year term.

## 2. PERMIT SUMMARY (cont'd)

*February 6, 2012* – The Department issued a modification of MEPDES permit #ME0100986/WDL #W000449-5L-G-R for a reduction in the mercury testing frequency for total mercury from 4/Year to 1/Year based on *Certain deposits and discharges prohibited*, 38 M.R.S., § 420 sub-§1-B(F).

*November 15, 2012* – The permittee submitted a timely and complete application to the Department for the renewal of combination MEPDES permit #ME0100986/WDL #W000449-5L-G-R which was issued by the Department on March 12, 2008, for a five-year term.

*February 20, 2013* – The Department issued combination MEDES #ME0100986/WDL #W000449-5L-I-R for a five-year term.

*December 27, 2017* – The permittee submitted a timely and complete application to the Department to renew #ME0100986/WDL #W000449-5L-I-R for a publicly owned wastewater treatment facility located at 80 Marshview Lane in Ogunquit. The application was accepted for processing by the Department on January 2, 2018.

- c. Source Description: The wastewater treatment facility was originally constructed in 1963 and currently serves a population of approximately 1,400 users in the winter and up to 50,000 users during the summer months. The treatment facility receives sanitary wastewater generated by residential and commercial entities within the District's boundaries and does not have any industrial users contributing more than 10% of the flow or pollutant loading to the collection and/or wastewater treatment facility.

The sanitary sewer collection system consists of approximately eleven (11) miles of pipe with twelve (12) pump stations. Pumping stations #1, #2 and #4 have stand-by generators with an automatic transfer switch. All pumping stations have manual power transfer switches for the use of the District's three (3) portable generators. All pumping stations are equipped with visual and audio alarms as well as radio communication to the treatment facility where two (redundant) telemetry notification systems are engaged. The collection system is completely separated from the storm water collection system and as a result there are no combined sewer overflow (CSO) points in the collection system. The facility is authorized to receive up to 3,000 gallons per day and 20,000 gallons per month of transported from local haulers. Transported wastes means any liquid non-hazardous waste delivered to a wastewater treatment facility by a truck or other similar conveyance that has different chemical constituents or a greater strength than the influent described on the facility's application for a waste discharge license. Such wastes may include, but are not limited to septage, industrial wastes or other wastes to which chemicals in quantities potentially harmful to the treatment facility or receiving water have been added. The facility maintains an up-to-date transported waste management plan that has reviewed and approved by the Department.

- d. Wastewater Treatment: The facility provides a secondary level of treatment via an activated sludge system operated in an extended aeration mode from November through March of each year and in the conventional aeration mode from April through October of each year. The treatment process includes an influent flow meter, a bar screen, grit chamber, four aeration basins (totaling 532,000 gallons) with fine bubble diffused aeration, two secondary clarifiers (each 45 feet in diameter and 12 feet deep) and a serpentine chlorine contact tank with a volume of 66,000 gallons followed by a flow meter. Two of the aeration basins have been modified to incorporate selector technology that have created anoxic zones prior to aeration zones to alleviate operational problems with nitrification. The effluent is disinfected on a year-round basis with sodium hypochlorite and de-chlorinated with sodium bisulfite

## 2. PERMIT SUMMARY (cont'd)

before discharge to the receiving waters. The wastewater treatment facility is equipped with a 350-kilowatt generator that will enable the facility to maintain a secondary level of treatment in the event of a power outage. The treated effluent is conveyed to the Atlantic Ocean for discharge via a pipe measuring fourteen (14) inches in diameter extended offshore approximately 1,950 feet. The end of the pipe is fitted with a 3-port diffuser to enhance mixing of the treated effluent with the receiving water. The facility has been disinfecting the discharge on a year-round basis since 1997 due to the potential for the harvesting of surf clams.

Sludge handling equipment at the facility includes three aerobic digesters with a total holding capacity of 320,000 gallons. The sludge is de-watered via a two-meter belt filter press and is currently being hauled to a processing facility in Plymouth, Maine.

## 3. CONDITIONS OF PERMIT

*Conditions of licenses*, 38 M.R.S. § 414-A, requires that the effluent limitations prescribed for discharges, including, but not limited to, effluent toxicity, require the application of best practicable treatment (BPT), be consistent with the U.S. Clean Water Act, and ensure that the receiving waters attain the State water quality standards as described in Maine's Surface Water Classification System. In addition, *Certain deposits and discharges prohibited*, 38 M.R.S. § 420 and Department rule *Surface Water Toxics Control Program*, 06-096 CMR 530 (effective March 21, 2012), require the regulation of toxic substances not to exceed levels set forth in *Surface Water Quality Criteria for Toxic Pollutants*, 06-096 CMR 584 (effective July 29, 2012), and that ensure safe levels for the discharge of toxic pollutants such that existing and designated uses of surface waters are maintained and protected.

## 4. RECEIVING WATER QUALITY STANDARDS

*Classification of estuarine and marine waters*, 38 M.R.S. § 469(8) classifies all estuarine and marine water lying within the boundaries of York County that are not otherwise classified are Class SB waters. *Standards for classification of estuarine and marine waters*, 38 M.R.S. § 465-B(2), describes the standards for Class SB waters.

## 5. RECEIVING WATER QUALITY CONDITIONS

*The State of Maine 2016 Integrated Water Quality Monitoring and Assessment Report*, prepared by the Department pursuant to Sections 303(d) and 305(b) of the Federal Water Pollution Control Act, lists marine waters at the permittee's outfall (Waterbody ID 824) as "Category 5-B-1(a): Estuarine and Marine Water Impaired for Bacteria Only – TMDL Required."

The Maine Department of Marine Resources (MEDMR) closes shellfish harvesting areas if there are known sources of discharges with unacceptable bacteria levels (thresholds established in the National Shellfish Sanitation Program) or maintains shellfish harvesting closure areas due to lack of updated information regarding ambient water quality conditions and current shoreline surveys. In addition, the MEDMR prohibits shellfish harvesting in the immediate vicinity of all wastewater treatment outfall pipes as a precautionary measure in the event of a failure in the treatment plant's disinfection system.

*This space intentionally left blank*



## 5. RECEIVING WATER QUALITY CONDITIONS (cont'd)

Thus, shellfish harvesting area #5 is closed to the harvesting of shellfish due the location of the Town's wastewater treatment plant outfall. The shellfish closure area can be found at <http://www.maine.gov/dmr/shellfish-sanitation-management/closures/pollution.html>

Category 5-D: *Estuarine and Marine Waters Impaired by Legacy Pollutants*. All estuarine and marine waters capable of supporting American lobster are listed in Category 5-D, partially supporting fishing ("shellfish" consumption) due to elevated levels of polychlorinated biphenyls (PCBs) and other persistent, bioaccumulating substances in lobster tomalley.

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- a. **Flow:** The previous permitting action established, and this permitting action is carrying forward, a monthly average discharge flow limit of 1.28 MGD based on the design capacity for the treatment facility, and a daily maximum discharge flow reporting requirement.

The Department reviewed 61 Discharge Monitoring Reports (DMRs) that were submitted for the period February 2013 – May 2018. A review of the data indicates that following:

### Flow (DMRs=61)

| Value           | Limit (MGD) | Range (MGD) | Mean (MGD) |
|-----------------|-------------|-------------|------------|
| Monthly Average | 1.28        | 0.16 – 0.9  | 0.5        |
| Daily Maximum   | Report      | 0.22 – 1.8  | 0.8        |

- b. **Dilution Factors:** 06-096 CMR 530(4)(A)(2)(a) states that, "*For discharges to the ocean, dilution must be calculated as near-field or initial dilution, or that dilution available as the effluent plume rises from the point of discharge to its trapping level, at mean low water level and slack tide for the acute exposure analysis, and at mean tide for the chronic exposure analysis using appropriate models determined by the Department such as MERGE, CORMIX or another predictive model.*" With a permitted flow limitation of 1.28 MGD and the location and configuration of the outfall structure, the Department has established dilution factors as follows:

Acute = 50:1                      Chronic = 102:1                      Harmonic mean<sup>(1)</sup> = 306:1

### Notes:

<sup>1</sup>The harmonic mean dilution factor is approximated by multiplying the chronic dilution factor by three (3). This multiplying factor is based on guidelines for estimation of human health dilution presented in the U.S. EPA publication, "*Technical Support Document for Water Quality-Based Toxics Control*" (Office of Water; USEPA/505/2-90-001, page 88), and represents an estimation of harmonic mean flow on which human health dilutions are based in a riverine 7Q10 flow situation.

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

### c. Biochemical Oxygen Demand and Total Suspended Solids:

The previous permitting action established, and this permitting action is carrying forward, monthly average and weekly average technology-based effluent limits of 30 mg/L and 45 mg/L, respectively, for BOD<sub>5</sub> and TSS pursuant to the secondary treatment regulation at 40 CFR 133.102 and 06-096 CMR 525(3)(III). The previous permit also established the daily maximum effluent limit of 50 mg/L for both BOD<sub>5</sub> and TSS based on a Department best professional judgment of best practicable treatment for secondary treated wastewater.

As for mass limitations, the previous permitting action established monthly average, weekly average and daily maximum mass limitations that are being carried forward in this permitting action and are based on a monthly average flow of 1.28 MGD. The mass limits were derived as follows:

Monthly Average Mass Limit:  $(30 \text{ mg/L})(8.34 \text{ lbs./gallon})(1.28 \text{ MGD}) = 320 \text{ lbs./day}$

Weekly Average Mass Limit:  $(45 \text{ mg/L})(8.34 \text{ lbs./gallon})(1.28 \text{ MGD}) = 480 \text{ lbs./day}$

Daily Maximum Mass Limit:  $(50 \text{ mg/L})(8.34 \text{ lbs./gallon})(1.28 \text{ MGD}) = 534 \text{ lbs./day}$

This permitting action is carrying forward a requirement for a minimum of 85% removal of BOD<sub>5</sub> and TSS as required by 06-096 CMR 525(3)(III)(a)(3) and (b)(3) of the Department's rules. The permittee has not demonstrated that it qualifies for special considerations pursuant to 06-096 CMR 525(3)(IV) to maintain a waiver from the 85% removal requirement when influent concentration is less than 200 mg/L, which was established in the previous permit. Therefore, this permitting action is eliminating the waiver from the 85% removal requirement provided in the previous permitting action when influent concentration is less than 200 mg/L.

The Department reviewed 61 DMRs that were submitted for the period February 2013 – May 2018. A review of data indicates the following:

#### **BOD<sub>5</sub> Mass (DMRs=61)**

| Value           | Limit (lbs./day) | Range (lbs./day) | Mean (lbs./day) |
|-----------------|------------------|------------------|-----------------|
| Monthly Average | 320              | 6 – 218          | 29              |
| Weekly Average  | 480              | 8 – 310          | 43              |
| Daily Maximum   | 534              | 8 – 310          | 46              |

#### **BOD<sub>5</sub> Concentration (DMRs=61)**

| Value           | Limit (mg/L) | Range (mg/L) | Mean (mg/L) |
|-----------------|--------------|--------------|-------------|
| Monthly Average | 30           | 3.0 – 33.0   | 6.9         |
| Weekly Average  | 45           | 3.0 – 49.0   | 9.0         |
| Daily Maximum   | 50           | 4.0 – 49.0   | 10.0        |

#### **TSS Mass (DMRs=61)**

| Value           | Limit (lbs./day) | Range (lbs./day) | Mean (lbs./day) |
|-----------------|------------------|------------------|-----------------|
| Monthly Average | 320              | 3 – 125          | 24              |
| Weekly Average  | 480              | 5 – 155          | 35              |
| Daily Maximum   | 534              | 6 – 267          | 49              |

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

### TSS Concentration (DMRs=61)

| Value           | Limit (mg/L) | Range (mg/L) | Mean (mg/L) |
|-----------------|--------------|--------------|-------------|
| Monthly Average | 30           | 2 – 19.0     | 5.3         |
| Weekly Average  | 45           | 3 – 25.0     | 7.3         |
| Daily Maximum   | 50           | 3 – 42.0     | 9.4         |

- d. Settleable Solids: The previous permitting action established and this permitting action is carrying forward a daily maximum technology limit of 0.3 ml/L for settleable solids, which is considered by the Department as a best professional judgment of BPT for secondary treated wastewater, along with a minimum monitoring frequency requirement of 3/Month. The Department is considering 61 months of data (February 2013 – May 2018.). During this reporting period of February 2013 – May 2018 the permittee reported no excursions that exceeded the daily maximum of 0.3 ml/L for settleable solids.

### Settleable Solids Concentration (DMRs=61)

| Value         | Limit (ml/L) | Range (ml/L) | Average (ml/L) |
|---------------|--------------|--------------|----------------|
| Daily Maximum | 0.3          | 0.10 – 0.02  | 0.1            |

- e. Fecal Coliform Bacteria: The previous permitting action established monthly average and daily maximum concentration limits of 15 colonies/100 ml and 50 colonies/100 ml, respectively, for fecal coliform bacteria, which are consistent with the National Shellfish Sanitation Program.

A summary of effluent fecal coliform bacteria data as reported on the DMRs for the period February 2013 – May 2018 is as follows:

### Fecal coliform bacteria (DMR = 61)

| Value           | Limit (col/100 mL) | Range (col/100 mL) | Mean (col/100 mL) |
|-----------------|--------------------|--------------------|-------------------|
| Monthly Average | 15                 | 1 – 31             | 4                 |
| Daily Maximum   | 50                 | 1 – 165            | 14                |

The previous permit established and this permit is carrying forward a minimum monitoring frequency for fecal coliform bacterial of one time per week (1/Week) based on the Department best professional judgment (BPJ). At the request of the Maine Department of Marine Resources **fecal coliform bacteria and total residual chlorine (TRC) limits and monitoring requirements are in effect year-round whenever chlorine compounds are in use at the request of the Maine Department of Marine Resources in order to protect local shellfish resources near the outfall and to protect the health, safety and welfare of the public.**

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

- f. **Total Residual Chlorine (TRC):** Limits on total residual chlorine are specified to ensure attainment of the in-stream water quality criteria for chlorine and that Best Practicable Treatment (BPT) technology is utilized to abate the discharge of chlorine. Permits issued by this Department impose the more stringent of the calculated water quality based or BPT based limits. The previous permitting action established a monthly average technology based limit of 0.1 mg/L and a daily maximum technology based limitation of 0.3 mg/L. End-of-pipe water quality based thresholds for TRC were calculated as follows:

| Acute (A)<br>Criterion | Chronic (C)<br>Criterion | A & C Acute<br>Dilution Factors | Calculated         |                      |
|------------------------|--------------------------|---------------------------------|--------------------|----------------------|
|                        |                          |                                 | Acute<br>Threshold | Chronic<br>Threshold |
| 0.013 mg/L             | 0.0075 mg/L              | 50:1 (A)<br>102:1 (C)           | 0.65 mg/L          | 0.76 mg/L            |

The Department has established a daily maximum best practicable treatment (BPT) limitation of 1.0 mg/L for facilities that disinfect their effluent with elemental chlorine or chlorine based compounds unless the calculated acute water quality based threshold is lower than 1.0 mg/L. For facilities that need to de-chlorinate the discharge to meet water quality based thresholds, the Department has established daily maximum and monthly average best practicable treatment limits of 0.3 mg/L and 0.1 mg/L respectively. Because the facility needs to de-chlorinate the discharge from April – September of each year to meet the calculated water quality thresholds, this permitting action is carrying forward the daily maximum and monthly average BPT limitations of 0.3 mg/L and 0.1 mg/L.

For the period of October – March when influent flow to the treatment facility is significantly lower than April – September (tourist season) the permittee has demonstrated through testing that it can meet both the fecal coliform bacteria and water quality based TRC limits without utilizing dechlorination compounds. As a result, this permit is carrying forward the daily maximum water quality based limit of 0.65 mg/L for October – March.

The Department reviewed 61 DMRs that were submitted for the period February 2013 – May 2018. A review of data indicates the following:

### Total Residual Chlorine (DMRs=61)

| Value           | Limit (mg/L) | Range (mg/L) | Mean (mg/L) |
|-----------------|--------------|--------------|-------------|
| Monthly Average | 0.1          | 0.03 – 0.05  | 0.03        |
| Daily Maximum   | 0.3          | 0.03 – 0.65  | 0.112       |

- g. **pH:** The previous permitting action established, and this permitting action is carrying forward, a technology-based pH limit of 6.0 – 9.0 standard units (SU), which is based on 06-096 CMR 525(3)(III)(c) and a minimum monitoring frequency requirement of 5/Week.

A summary of pH data as reported on the monthly DMRs for the period of February 2013 – May 2018 (DMRs = 61) indicates the effluent pH has ranged from 6.20 to 7.10 (SU).

### pH (DMRs=61)

| Value           | Limit (SU) | Range (SU)  |
|-----------------|------------|-------------|
| Monthly Average | 6.0 – 9.0  | 6.20 – 7.10 |
| Daily Maximum   | 6.0 – 9.0  | 6.80 – 7.80 |

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

- h. Mercury: Pursuant to *Certain deposits and discharges prohibited*, 38 M.R.S. § 420 and *Waste Discharge Licenses*, 38 M.R.S. § 413 and *Interim Effluent Limitations and Controls for the Discharge of Mercury*, 06-096 CMR 519 (last amended October 6, 2001), the Department issued an interim average and daily maximum effluent concentration limits of 19.3 parts per trillion (ppt) and 29.0 ppt, respectively, and a minimum monitoring frequency requirement of two (2) tests per year for mercury. 38 M.R.S. § 420(1-B)(B)(1) provides that a facility is not in violation of the Ambient Water Quality Criteria (AWQC) for mercury if the facility is in compliance with an interim discharge limit established by the Department. A review of the Department's data base for the period April 1999 – June 2016 indicates the permittee has been in compliance with the interim limits for mercury as results have been reported as follows:

### Mercury (DMRs=56)

| Value         | Limit (ng/L) | Range (ng/L) | Mean (ng/L) |
|---------------|--------------|--------------|-------------|
| Average       | 4.8          | 1.00 – 34.00 | 4.8         |
| Daily Maximum | 34.0         |              |             |

The Department issued a minor revision on February 6, 2012, to the October 12, 2011, permit thereby revising the minimum monitoring frequency requirement from twice per year to once per year given the permittee has maintained at least 5 years of mercury testing data. Pursuant to 38 M.R.S. § 420(1-B)(F), this permitting action is carrying forward the 1/Year monitoring frequency established in the February 6, 2012, permit modification.

### i. Nitrogen:

The USEPA requested the Department evaluate the reasonable potential for the discharge of total nitrogen to cause or contribute to non-attainment of applicable water quality standards in marine waters, namely dissolved oxygen (DO) and marine life support. The permittee voluntarily participated in a Department-coordinated project using a Maine certified analytical lab to determine typical effluent nitrogen concentrations, and submitted monthly composite samples from June-October, 2015 (n = 5). The mean value of the permittee's five samples was 11.2 mg/L. For this reasonable potential evaluation, the Department considers 11.2 mg/L to be representative of total nitrogen discharge levels from the Ogunquit facility.

As of the date of this permitting action, the State of Maine has not promulgated numeric ambient water quality criteria for total nitrogen. According to several studies in USEPA's Region 1, numeric total nitrogen criteria have been established for relatively few estuaries, but the criteria that have been set typically fall between 0.35 mg/L and 0.50 mg/L to protect marine life using dissolved oxygen as the indicator. While the thresholds are site-specific, nitrogen thresholds set for the protection of eelgrass habitat range from 0.30 mg/L to 0.39 mg/L. Based on studies in USEPA's Region 1 and the Department's best professional judgment of thresholds that are protective of Maine water quality standards, the Department is utilizing a threshold of 0.45 mg/L for the protection of aquatic life in marine waters using dissolved oxygen as the indicator, and 0.32 mg/L for the protection of aquatic life using eelgrass as the indicator.

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Two known surveys have been completed along the Ogunquit shoreline that specifically documented presence/absence of eelgrass. The surveys were conducted by the ME DMR in 1995 and 2010, and delineated the nearest eelgrass bed at more than 10 km to the north of the discharge location. Based on the absence of historically identified eelgrass in the vicinity of the Ogunquit wastewater discharge, the use of 0.45 mg/L as a threshold value for dissolved oxygen as the indicator is appropriate for this receiving water.

With the exception of ammonia, nitrogen is not acutely toxic; thus, the Department is considering a far-field dilution to be more appropriate when evaluating impacts of total nitrogen to the marine environment. The permittee's facility has a chronic near-field dilution of 102:1. Far-field dilutions are significantly higher than the near-field dilutions, typically ranging from 10 – 100 times higher, depending on the location of the outfall pipe and nature of the receiving waterbody. The permittee's facility discharges into the open ocean, approximately 400 meters offshore. Situationally, this would imply a far field multiplication factor on the higher end of the range. A conservative factor of 50 was chosen for this site, which results in a far field dilution factor of 5,100:1 ( $102 \times 50 = 5,100$ ).

Using this far-field dilution factor, the increase in total nitrogen concentration in the relative vicinity of the Ogunquit discharge is estimated to be approximately 0.002 mg/L.

$$\begin{aligned}\text{Total nitrogen concentrations in effluent} &= 11.2 \text{ mg/L} \\ \text{Far-field dilution factor} &= 5,100:1\end{aligned}$$

$$\text{In-stream concentration after dilution: } \frac{11.2 \text{ mg/L}}{5,100} = 0.002 \text{ mg/L}$$

The Department and external partners have been collecting ambient total nitrogen data along Maine's coast. The Department has selected seven sites from the embayment adjacent to the towns of Wells and Ogunquit whose data from July, August and September of 2004 and 2009-2011 best represent the ambient conditions likely to occur in this nearshore marine environment during the summer months. From these sites, the Department has calculated a mean background surface water total nitrogen concentration of  $0.18 \pm 0.04$  mg/L (n=15). Accompanying these total nitrogen values are dissolved oxygen profiles and transparency and chlorophyll *a* data, none of which indicate water quality degradation illustrative of eutrophication. More specifically, dissolved oxygen concentrations ranged from 7.0-10.1 mg/L, transparency values ranged from 4.0-8.0 m depth, and all chlorophyll *a* values were less than 3.4 µg/L.

Based on the calculated ambient value for this receiving water, the estimated increase in ambient total nitrogen after reasonable opportunity for mixing in the far-field is  $0.18 \text{ mg/L} + 0.002 \text{ mg/L} = 0.182 \text{ mg/L}$ . The in-stream concentration value of 0.182 mg/L is considerably less than the Department and USEPA's best professional judgment based total nitrogen threshold of 0.45 mg/L for the protection of aquatic life using dissolved oxygen as an indicator. Using the reasonable potential calculations above and in the absence of any information that the receiving water is not attaining standards, the Department is making a best professional judgment determination that the discharge of total nitrogen from the Ogunquit POTW does not exhibit a reasonable potential to exceed applicable water quality standards for Class SB waters. This permitting action is not establishing limitations or monitoring requirements for total nitrogen.

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

- j. Whole Effluent Toxicity (WET) and Chemical-Specific Testing: 38 M.R.S. § 414-A and 38 M.R.S. § 420 prohibit the discharge of effluents containing substances in amounts that would cause the surface waters of the State to contain toxic substances above levels set forth in Federal Water Quality Criteria as established by the USEPA. 06-096 CMR 530 sets forth effluent monitoring requirements and procedures to establish safe levels for the discharge of toxic pollutants such that existing and designated uses of surface waters are maintained and protected and narrative and numeric water quality criteria are met. 06-096 CMR 584 sets forth ambient water quality criteria (AWQC) for toxic pollutants and procedures necessary to control levels of toxic pollutants in surface waters.

WET, priority pollutant and analytical chemistry testing, as required by 06-096 CMR 530, is included in this permit in order to characterize the effluent. WET monitoring is required to assess and protect against impacts upon water quality and designated uses caused by the aggregate effect of the discharge on specific aquatic organisms. Acute and chronic WET tests are performed on the mysid shrimp (*Americamysis bahia*) and the sea urchin (*Arbacia punctulata*). Chemical-specific monitoring is required to assess the levels of individual toxic pollutants in the discharge, comparing each pollutant to acute, chronic, and human health water quality criteria. Priority pollutant testing refers to the analysis for levels of priority pollutants listed under “Priority Pollutants” on the form included as Attachment C of the permit. Analytical chemistry refers to those pollutants listed under “Analytical Chemistry” on the form included as Attachment C of the permit.

06-096 CMR 530(2)(A) specifies the dischargers subject to the rule as:

All licensed dischargers of industrial process wastewater or domestic wastes discharging to surface waters of the State must meet the testing requirements of this section. Dischargers of other types of wastewater are subject to this subsection when and if the Department determines that toxicity of effluents may have reasonable potential to cause or contribute to exceedances of narrative or numerical water quality criteria.

Ogunquit Sewer District discharges domestic (sanitary) wastewater to surface waters and is therefore subject to the testing requirements of the toxics rule.

06-096 CMR 530(2)(B) categorizes discharges subject to the toxics rule into one of four levels (Level I through IV). The four categories for dischargers are as follows:

|           |  |
|-----------|--|
| Level I   | Chronic dilution factor of <20:1   |
| Level II  | Chronic dilution factor of $\geq 20:1$ but <100:1.                             |
| Level III | Chronic dilution factor $\geq 100:1$ but <500:1 or >500:1 and $Q \geq 1.0$ MGD |
| Level IV  | Chronic dilution factor >500:1 and $Q \leq 1.0$ MGD                            |

Based on the Chapter 530 criteria, the permittee’s facility falls into the Level III frequency category as the facility has a chronic dilution factor >100:1 but <500:1 or >500:1 and  $Q > 1.0$  MGD. 06-096 530(2)(D)(1) specifies that routine screening and surveillance level testing requirements are as follows:

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

### Screening level testing

| Level | WET Testing | Priority pollutant testing | Analytical chemistry |
|-------|-------------|----------------------------|----------------------|
| III   | 1 per year  | 1 per year                 | 4 per year           |

### Surveillance level testing

| Level | WET Testing | Priority pollutant testing | Analytical chemistry |
|-------|-------------|----------------------------|----------------------|
| III   | 1 per year  | None required              | 1 per year           |

This permit provides for reconsideration of effluent limits and monitoring schedules after evaluation of toxicity testing results. The monitoring schedule includes consideration of results currently on file, the nature of the wastewater, existing treatment, and receiving water characteristics.

k. Whole Effluent Toxicity (WET) Evaluation: 06-096 CMR 530(3)(E) states:

For effluent monitoring data and the variability of the pollutant in the effluent, the Department must apply the statistical approach in Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control" (USEPA Publication 505/2-90-001, March, 1991, EPA, Office of Water, Washington, D.C.) to data to determine whether water-quality based effluent limits must be included in a waste discharge license. Where it is determined through this approach that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedance of water quality criteria, appropriate water quality-based limits must be established in any licensing action.

On March 1, 2018, the Department conducted a statistical evaluation on the most recent 60 months of WET test results on file with the Department for the Town in accordance with the statistical approach outlined above. The 3/1/18 statistical evaluation indicates that none of the results had a reasonable potential to exceed the chronic or acute ambient water quality threshold. See **Attachment D** of this Fact Sheet for a summary of the WET test results.

Based on the provisions of 06-096 CMR 530 and Department best professional judgment, this permitting action is carrying forward the reduced surveillance level WET testing requirements for this facility. Special Condition G. 06-096 CMR 530(2)(D)(4) Statement For Reduced/Waived Toxics Testing of this Permit explains the statement required by the discharger to reduce WET testing.



## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

### 1. Analytical Chemistry & Priority Pollutant Testing Evaluation:

06-096 CMR 530(4)(C) states:

The background concentration of specific chemicals must be included in all calculations using the following procedures. The Department may publish and periodically update a list of default background concentrations for specific pollutants on a regional, watershed or statewide basis. In doing so, the Department must use data collected from reference sites that are measured at points not significantly affected by point and non-point discharges and best calculated to accurately represent ambient water quality conditions. The Department must use the same general methods as those in section 4(D) to determine background concentrations. For pollutants not listed by the Department, an assumed concentration of 10% of the applicable water quality criteria must be used in calculations.

06-096 CMR 530(3)(E) states, “Where it is determined through [the statistical approach referred to in USEPA's Technical Support Document for Water Quality-Based Toxics Control] that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedance of water quality criteria, appropriate water quality-based limits must be established in any licensing action.”

## 6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

06-096 CMR 530(3)(D) states, “Where the need for effluent limits has been determined, limits derived from acute water quality criteria must be expressed as daily maximum values. Limits derived from chronic or human health criteria must be expressed as monthly average values.”

### Chemical specific evaluation

As with WET test results, the Department conducted a statistical evaluation on March 1, 2018, for the most current 60 months of analytical chemistry and priority pollutant test results on file. The evaluation 3/1/18 statistical evaluation indicates that none of the results had a reasonable potential to exceed the chronic or acute ambient water quality thresholds. See **Attachment E** of this Fact Sheet for the individual test results.

As for the remaining chemical specific parameters tested to date, none of the test results in the 55-month evaluation period exceed or have a reasonable potential to exceed applicable acute, chronic or human health AWQC. Therefore, this permitting action carrying forward screening level reporting and monitoring frequency for analytical chemistry at 1/Year during the screening level year pursuant to 06-096 CMR 530(2)(D)(3)(c). As with reduced WET testing, the permittee must file an annual certification with the Department pursuant to Chapter 530 §2(D)(4) and Special Condition K of this permit.

## **7. DISPOSAL OF SEPTAGE WASTE IN WASTEWATER TREATMENT FACILITY**

The previous permitting action authorized the District to receive and introduce up to 3,000 gpd of septage. 06-096 CMR 555, *Standards For The Addition of Transported Wastes to Wastewater Treatment Facilities*, limits the quantity of septage received at a facility to 1% of the design capacity of treatment facility if the facility utilizes a side stream or storage method of introduction into the influent flow, or 0.5% of the design capacity of the facility if the facility does not utilize the side stream or storage method of introduction into the influent flow. A facility may receive more than 1% of the design capacity on a case-by-case basis. In their application for permit renewal, permittee has requested the Department carry forward the daily quantity of transported waste it is authorized to receive and treat (up to 3,000 gpd) as it does utilize the side stream/storage method of metering wastes into the facility's influent flow. With a design capacity of 1.28 MGD, 3,000 gpd only represents 0.23% of said capacity.

## **8. DISCHARGE IMPACT ON RECEIVING WATER QUALITY**

As permitted, the Department has determined the existing water uses will be maintained and protected and the discharge will not cause or contribute to the failure of the Atlantic Ocean in Ogunquit to meet standards for Class SB classification.

## **9. PUBLIC COMMENTS**

Public notice of this application was made in York County Coast Star newspaper on or about December 21, 2017. The Department receives public comments on an application until the date a final agency action is taken on the application. Those persons receiving copies of draft permits must have at least 30 days in which to submit comments on the draft or to request a public hearing, pursuant to *Application Processing Procedures for Waste Discharge Licenses*, 06-096 CMR 522 (effective January 12, 2001).

## **10. DEPARTMENT CONTACTS**

Additional information concerning this permitting action may be obtained from, and written comments sent to:

Aaron Dumont  
Bureau of Water Quality  
Department of Environmental Protection  
17 State House Station  
Augusta, Maine 04333-0017 Telephone: (207) 592-7161  
e-mail: [Aaron.A.Dumont@maine.gov](mailto:Aaron.A.Dumont@maine.gov)

## **11. RESPONSE TO COMMENTS**

During the period of October 11, 2018, through the effective date of this final agency action, the Department solicited comments on the draft MEPDES permit. The Department did not receive any substantive comment on the draft permit. It is noted that minor typographical and grammatical errors identified in comments were not summarized in this section, but were corrected, where necessary, in the final permit.

# **ATTACHMENT A**






Outfall Information: 2.

## **ATTACHMENT B**



# Ogunquit WWTF



Addition of Transported Wastes  
In WWTF: III. F.

Publicly Owned  
Treatment Facility: 2. A.

## **ATTACHMENT C**





## FACILITY WET EVALUATION REPORT

**Facility:** OGUNQUIT SEWER DISTRICT

**Permit Number:** ME0100986

**Report Date:** 3/22/2018

**Receiving Water:** ATLANTIC OCEAN

**Rapidmix:** Y

**Dilution Factors:** 1/4 Acute: N/A

Acute: 50.000

Chronic: 102

**Effluent Limits:** Acute (%): 2.000

Chronic (%): 0.980

**Date range for Evaluation:** From 22/Mar/2013 To: 22/Mar/2018

**Test Type:** A\_NOEL

**Test Species:** MYSID SHRIMP

**Test Date**  
10/19/2016

**Result (%)**  
100.000

**Status**  
OK

**Species Summary:**

**Test Number:** 1

**RP:** 6.200

**Min Result (%):** 100.000

**RP factor (%):** 16.129

**Status:** OK

**Test Type:** C\_NOEL

**Test Species:** SEA URCHIN

**Test Date**  
10/19/2016

**Result (%)**  
100.000

**Status**  
OK

**Species Summary:**

**Test Number:** 1

**RP:** 6.200

**Min Result (%):** 100.000

**RP factor (%):** 16.129

**Status:** OK



## **ATTACHMENT D**

# CHEMICAL EVALUATION REPORT (INDIVIDUAL)



3/1/2018

Report ID: 961

Data Date Range:

01/Mar/2013 -01/Mar/2018

Facility: **OGUNQUIT SEWER DISTRICT**

Permit Number: **ME0100986**

Receiving Water: **ATLANTIC OCEAN**

Fresh or Salt: **S**

Complete Mix: **Y**

Dilution Factors: Acute: **50.0** Chronic: **102.0** Health: **306.0** Licensed Flow: **1.3**

Water Quality Assumptions: Reserve (%): **0.0** Background (%): **10.0** Temperature: **25.0**

Hardness: **20.0**

PH: **7.0**

Salinity: **30.0**

Historical Average Date: **01/Mar/2018**

Specific pollutants with reasonable potential: Number of parameters found = 18

|                                      |   |                  |                         |
|--------------------------------------|---|------------------|-------------------------|
| Pollutant: <b>ACROLEIN</b>           |   | Reporting Limit: | Sample Number: <b>1</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                  |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                  |                         |
| Facility Allocation:                 | Acute                                   | Chronic          | Health                  |
| Pounds per day                       | N/A                                     | N/A              | N/A                     |
| Exceedence ug/L                      | ---                                     | ---              | ---                     |
| RP ug/L                              | ---                                     | ---              | ---                     |

## \*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <25           | ---  | ---   | ---     | ---    |

|                                      |   |                  |                         |
|--------------------------------------|---|------------------|-------------------------|
| Pollutant: <b>ACRYLONITRILE</b>      |   | Reporting Limit: | Sample Number: <b>1</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                  |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                  |                         |
| Facility Allocation:                 | Acute                                   | Chronic          | Health                  |
| Pounds per day                       | N/A                                     | N/A              | N/A                     |
| Exceedence ug/L                      | ---                                     | ---              | ---                     |
| RP ug/L                              | ---                                     | ---              | ---                     |

## \*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <25           | ---  | ---   | ---     | ---    |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>ALUMINUM</b>           | Reporting Limit:                        | Sample Number: <b>4</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>2.6</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

**\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\***

|             |                   |             |                      |             | Exceedence or Reasonable Potential and Basis |                |               |
|-------------|-------------------|-------------|----------------------|-------------|--|----------------|---------------|
| <b>Flag</b> | <b>Daily Flow</b> | <b>Date</b> | <b>Concentration</b> | <b>Mass</b> | <b>Acute</b>                                 | <b>Chronic</b> | <b>Health</b> |
| IN          | 0.5420            | 04/11/2016  | 36                   | 0.16273     | ---  | ---            | ---           |
| IN          | 0.3410            | 05/16/2016  | 37                   | 0.10523     | ---  | ---            | ---           |
| IN          | 0.6340            | 07/20/2016  | 29                   | 0.15334     | ---  | ---            | ---           |
| IN          | 0.2880            | 10/19/2016  | 44                   | 0.10568     | ---  | ---            | ---           |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>AMMONIA</b>            | Reporting Limit:                        | Sample Number: <b>4</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>2.6</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

**\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\***

|             |                   |             |                      |             | Exceedence or Reasonable Potential and Basis |                |               |
|-------------|-------------------|-------------|----------------------|-------------|--|----------------|---------------|
| <b>Flag</b> | <b>Daily Flow</b> | <b>Date</b> | <b>Concentration</b> | <b>Mass</b> | <b>Acute</b>                                 | <b>Chronic</b> | <b>Health</b> |
| IN          | 0.5420            | 04/11/2016  | 1400                 | 6.32839     | ---  | ---            | ---           |
| IN          | 0.3410            | 05/16/2016  | 510                  | 1.45041     | ---  | ---            | ---           |
| IN          | 0.6340            | 07/20/2016  | 0.22                 | 0.00116     | ---  | ---            | ---           |
| IN          | 0.2880            | 10/19/2016  | 160                  | 0.38431     | ---  | ---            | ---           |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>ARSENIC</b>            | Reporting Limit: <b>5.0</b>             | Sample Number: <b>5</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

**\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\***

|             |                   |             |                      |             | Exceedence or Reasonable Potential and Basis |                |               |
|-------------|-------------------|-------------|----------------------|-------------|--|----------------|---------------|
| <b>Flag</b> | <b>Daily Flow</b> | <b>Date</b> | <b>Concentration</b> | <b>Mass</b> | <b>Acute</b>                                 | <b>Chronic</b> | <b>Health</b> |
| IN          | 0.7460            | 07/22/2013  | <2                   | ---         | ---  | ---            | ---           |
| IN          | 0.5420            | 04/11/2016  | <2                   | ---         | ---  | ---            | ---           |

|    |        |            |     |         |     |     |     |
|----|--------|------------|-----|---------|-----|-----|-----|
| IN | 0.3410 | 05/16/2016 | <2  | ---     | --- | --- | --- |
| IN | 0.6340 | 07/20/2016 | <2  | ---     | --- | --- | --- |
| IN | 0.2880 | 10/19/2016 | 1.9 | 0.00456 | --- | --- | --- |

Pollutant: **BIS(2-ETHYLHEXYL)PHTHALATE** Reporting Limit: **10.0** Sample Number: **1**

Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**

Historical Average: **N/A** RP Historical Average: **N/A**

|                      |       |         |        |
|----------------------|-------|---------|--------|
| Facility Allocation: | Acute | Chronic | Health |
| Pounds per day       | N/A   | N/A     | N/A    |
| Exceedence ug/L      | ---   | ---     | ---    |
| RP ug/L              | ---   | ---     | ---    |

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | 7.5           | 0.03966 | ---   | ---     | ---    |

Pollutant: **CHLORODIBROMOMETHANE** Reporting Limit: **3.0** Sample Number: **1**

Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**

Historical Average: **N/A** RP Historical Average: **N/A**

|                      |       |         |        |
|----------------------|-------|---------|--------|
| Facility Allocation: | Acute | Chronic | Health |
| Pounds per day       | N/A   | N/A     | N/A    |
| Exceedence ug/L      | ---   | ---     | ---    |
| RP ug/L              | ---   | ---     | ---    |

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <3            | ---  | ---   | ---     | ---    |

Pollutant: **CHLOROFORM** Reporting Limit: **5.0** Sample Number: **1**

Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**

Historical Average: **N/A** RP Historical Average: **N/A**

|                      |       |         |        |
|----------------------|-------|---------|--------|
| Facility Allocation: | Acute | Chronic | Health |
| Pounds per day       | N/A   | N/A     | N/A    |
| Exceedence ug/L      | ---   | ---     | ---    |
| RP ug/L              | ---   | ---     | ---    |

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | 17            | 0.08989 | ---   | ---     | ---    |

Pollutant: **CHROMIUM** Reporting Limit: **10.0** Sample Number: **4**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.5420     | 04/11/2016 | <2            | ---  | ---   | ---     | ---    |
| IN   | 0.3410     | 05/16/2016 | <2            | ---  | ---   | ---     | ---    |
| IN   | 0.6340     | 07/20/2016 | <2            | ---  | ---   | ---     | ---    |
| IN   | 0.2880     | 10/19/2016 | <1            | ---  | ---   | ---     | ---    |

Pollutant: **COPPER** Reporting Limit: **3.0** Sample Number: **4**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **2.6**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.5420     | 04/11/2016 | 6             | 0.02712 | ---   | ---     | ---    |
| IN   | 0.3410     | 05/16/2016 | 6             | 0.01706 | ---   | ---     | ---    |
| IN   | 0.6340     | 07/20/2016 | 12            | 0.06345 | ---   | ---     | ---    |
| IN   | 0.2880     | 10/19/2016 | 13            | 0.03122 | ---   | ---     | ---    |

Pollutant: **DICHLOROBROMOMETHANE** Reporting Limit: **3.0** Sample Number: **1**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | 5.3           | 0.02802 | ---   | ---     | ---    |



Pollutant: **LEAD** Reporting Limit: **3.0** Sample Number: **4**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.5420     | 04/11/2016 | 1             | 0.00452 | ---   | ---     | ---    |
| IN   | 0.3410     | 05/16/2016 | 2             | 0.00569 | ---   | ---     | ---    |
| IN   | 0.6340     | 07/20/2016 | 2             | 0.01058 | ---   | ---     | ---    |
| IN   | 0.2880     | 10/19/2016 | 1.3           | 0.00312 | ---   | ---     | ---    |

Pollutant: **MERCURY** Reporting Limit: **0.0** Sample Number: **5**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **2.3**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass  | Acute | Chronic | Health |
|------|------------|------------|---------------|-------|-------|---------|--------|
| IN   | 0.7460     | 07/22/2013 | 0.0032        | 2E-05 | ---   | ---     | ---    |
| IN   | 1.2800     | 06/18/2014 | 0.0021        | 2E-05 | ---   | ---     | ---    |
| IN   | 1.2800     | 02/10/2016 | 0.0017        | 2E-05 | ---   | ---     | ---    |
| IN   | 1.2800     | 07/21/2016 | 0.00202       | 2E-05 | ---   | ---     | ---    |
| IN   | 1.2800     | 08/22/2017 | 0.00163       | 2E-05 | ---   | ---     | ---    |

Pollutant: **NICKEL** Reporting Limit: **5.0** Sample Number: **4**  
 Coefficient of Variation: **0.6** Reasonable Potential Factor: **6.2**  
 Historical Average: **N/A** RP Historical Average: **N/A**  
 Facility Allocation: Acute Chronic Health  
 Pounds per day N/A N/A N/A  
 Exceedence ug/L --- --- ---  
 RP ug/L --- --- ---

\*\*\*\*\* **INDIVIDUAL RESULTS** \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.5420     | 04/11/2016 | <2            | ---  | ---   | ---     | ---    |

|    |        |            |     |         |     |     |     |
|----|--------|------------|-----|---------|-----|-----|-----|
| IN | 0.3410 | 05/16/2016 | <2  | ---     | --- | --- | --- |
| IN | 0.6340 | 07/20/2016 | <2  | ---     | --- | --- | --- |
| IN | 0.2880 | 10/19/2016 | 2.2 | 0.00528 | --- | --- | --- |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>PHENOL</b>             | Reporting Limit: <b>5.0</b>             | Sample Number: <b>1</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <5            | ---  | ---   | ---     | ---    |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>TOLUENE</b>            | Reporting Limit: <b>5.0</b>             | Sample Number: <b>1</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <5            | ---  | ---   | ---     | ---    |

|                                      |   |                         |
|--------------------------------------|---|-------------------------|
| Pollutant: <b>TRICHLOROETHYLENE</b>  | Reporting Limit: <b>3.0</b>             | Sample Number: <b>1</b> |
| Coefficient of Variation: <b>0.6</b> | Reasonable Potential Factor: <b>6.2</b> |                         |
| Historical Average: <b>N/A</b>       | RP Historical Average: <b>N/A</b>       |                         |
| Facility Allocation:                 | Acute                                   | Chronic                 |
| Pounds per day                       | N/A                                     | N/A                     |
| Exceedence ug/L                      | ---                                     | ---                     |
| RP ug/L                              | ---                                     | ---                     |

\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\*

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass | Acute | Chronic | Health |
|------|------------|------------|---------------|------|-------|---------|--------|
| IN   | 0.6340     | 07/20/2016 | <3            | ---  | ---   | ---     | ---    |

Pollutant: **ZINC**Reporting Limit: **5.0**Sample Number: **4**Coefficient of Variation: **0.6** Reasonable Potential Factor: **2.6**Historical Average: **N/A**RP Historical Average: **N/A**

Facility Allocation:

Acute

Chronic

Health

Pounds per day

N/A

N/A

N/A

Exceedence ug/L

---

---

---

RP ug/L

---

---

---

**\*\*\*\*\* INDIVIDUAL RESULTS \*\*\*\*\***

Exceedence or Reasonable Potential and Basis

| Flag | Daily Flow | Date       | Concentration | Mass    | Acute | Chronic | Health |
|------|------------|------------|---------------|---------|-------|---------|--------|
| IN   | 0.5420     | 04/11/2016 | 42            | 0.18985 | ---   | ---     | ---    |
| IN   | 0.3410     | 05/16/2016 | 66            | 0.1877  | ---   | ---     | ---    |
| IN   | 0.6340     | 07/20/2016 | 110           | 0.58163 | ---   | ---     | ---    |
| IN   | 0.2880     | 10/19/2016 | 0.092         | 0.00022 | ---   | ---     | ---    |





# DEP INFORMATION SHEET

## Appealing a Department Licensing Decision

**Dated: November 2018**

**Contact: (207) 287-2452**

### **SUMMARY**

There are two methods available to an aggrieved person seeking to appeal a licensing decision made by the Department of Environmental Protection's (DEP) Commissioner: (1) an administrative process before the Board of Environmental Protection (Board); or (2) a judicial process before Maine's Superior Court. An aggrieved person seeking review of a licensing decision over which the Board had original jurisdiction may seek judicial review in Maine's Superior Court.

A judicial appeal of final action by the Commissioner or the Board regarding an application for an expedited wind energy development (35-A M.R.S. § 3451(4)) or a general permit for an offshore wind energy demonstration project (38 M.R.S. § 480-HH(1)) or a general permit for a tidal energy demonstration project (38 M.R.S. § 636-A) must be taken to the Supreme Judicial Court sitting as the Law Court.

This information sheet, in conjunction with a review of the statutory and regulatory provisions referred to herein, can help a person to understand his or her rights and obligations in filing an administrative or judicial appeal.

### **I. ADMINISTRATIVE APPEALS TO THE BOARD**

#### **LEGAL REFERENCES**

The laws concerning the DEP's *Organization and Powers*, 38 M.R.S. §§ 341-D(4) & 346; the *Maine Administrative Procedure Act*, 5 M.R.S. § 11001; and the DEP's *Rules Concerning the Processing of Applications and Other Administrative Matters* ("Chapter 2"), 06-096 C.M.R. ch. 2.

#### **DEADLINE TO SUBMIT AN APPEAL TO THE BOARD**

The Board must receive a written appeal within 30 days of the date on which the Commissioner's decision was filed with the Board. Appeals filed more than 30 calendar days after the date on which the Commissioner's decision was filed with the Board will be dismissed unless notice of the Commissioner's license decision was required to be given to the person filing an appeal (appellant) and the notice was not given as required.

#### **HOW TO SUBMIT AN APPEAL TO THE BOARD**

Signed original appeal documents must be sent to: Chair, Board of Environmental Protection, 17 State House Station, Augusta, ME 04333-0017. An appeal may be submitted by fax or e-mail if it contains a scanned original signature. It is recommended that a faxed or e-mailed appeal be followed by the submittal of mailed original paper documents. The complete appeal, including any attachments, must be received at DEP's offices in Augusta on or before 5:00 PM on the due date; materials received after 5:00 pm are not considered received until the following day. The risk of material not being received in a timely manner is on the sender, regardless of the method used. The appellant must also send a copy of the appeal documents to the Commissioner of the DEP; the applicant (if the appellant is not the applicant in the license proceeding at issue); and if a hearing was held on the application, any intervenor in that hearing process. All of the information listed in the next section of this information sheet must be submitted at the time the appeal is filed.

### **INFORMATION APPEAL PAPERWORK MUST CONTAIN**

Appeal materials must contain the following information at the time the appeal is submitted:

1. *Aggrieved Status.* The appeal must explain how the appellant has standing to maintain an appeal. This requires an explanation of how the appellant may suffer a particularized injury as a result of the Commissioner's decision.
2. *The findings, conclusions, or conditions objected to or believed to be in error.* The appeal must identify the specific findings of fact, conclusions regarding compliance with the law, license conditions, or other aspects of the written license decision or of the license review process that the appellant objects to or believes to be in error.
3. *The basis of the objections or challenge.* For the objections identified in Item #2, the appeal must state why the appellant believes that the license decision is incorrect and should be modified or reversed. If possible, the appeal should cite specific evidence in the record or specific licensing requirements that the appellant believes were not properly considered or fully addressed.
4. *The remedy sought.* This can range from reversal of the Commissioner's decision on the license or permit to changes in specific permit conditions.
5. *All the matters to be contested.* The Board will limit its consideration to those matters specifically raised in the written notice of appeal.
6. *Request for hearing.* If the appellant wishes the Board to hold a public hearing on the appeal, a request for public hearing must be filed as part of the notice of appeal, and must include an offer of proof in accordance with Chapter 2. The Board will hear the arguments in favor of and in opposition to a hearing on the appeal and the presentations on the merits of an appeal at a regularly scheduled meeting. If the Board decides to hold a public hearing on an appeal, that hearing will then be scheduled for a later date.
7. *New or additional evidence to be offered.* If an appellant wants to provide evidence not previously provided to DEP staff during the DEP's review of the application, the request and the proposed evidence must be submitted with the appeal. The Board may allow new or additional evidence, referred to as supplemental evidence, to be considered in an appeal only under very limited circumstances. The proposed evidence must be relevant and material, and (a) the person seeking to add information to the record must show due diligence in bringing the evidence to the DEP's attention at the earliest possible time in the licensing process; or (b) the evidence itself must be newly discovered and therefore unable to have been presented earlier in the process. Specific requirements for supplemental evidence are found in Chapter 2 § 24.

### **OTHER CONSIDERATIONS IN APPEALING A DECISION TO THE BOARD**

1. *Be familiar with all relevant material in the DEP record.* A license application file is public information, subject to any applicable statutory exceptions, and is made easily accessible by the DEP. Upon request, the DEP will make application materials available during normal working hours, provide space to review the file, and provide an opportunity for photocopying materials. There is a charge for copies or copying services.
2. *Be familiar with the regulations and laws under which the application was processed, and the procedural rules governing your appeal.* DEP staff will provide this information on request and answer general questions regarding the appeal process.
3. *The filing of an appeal does not operate as a stay to any decision.* If a license has been granted and it has been appealed, the license normally remains in effect pending the processing of the appeal. Unless a stay of the decision is requested and granted, a license holder may proceed with a project pending the outcome of an appeal, but the license holder runs the risk of the decision being reversed or modified as a result of the appeal.

## **WHAT TO EXPECT ONCE YOU FILE A TIMELY APPEAL WITH THE BOARD**

The Board will formally acknowledge receipt of an appeal, and will provide the name of the DEP project manager assigned to the specific appeal. The notice of appeal, any materials accepted by the Board Chair as supplementary evidence, any materials submitted in response to the appeal, and relevant excerpts from the DEP's application review file will be sent to Board members with a recommended decision from DEP staff. The appellant, the license holder if different from the appellant, and any interested persons are notified in advance of the date set for Board consideration of an appeal or request for public hearing. The appellant and the license holder will have an opportunity to address the Board at the Board meeting. With or without holding a public hearing, the Board may affirm, amend, or reverse a Commissioner decision or remand the matter to the Commissioner for further proceedings. The Board will notify the appellant, the license holder, and interested persons of its decision.

## **II. JUDICIAL APPEALS**

Maine law generally allows aggrieved persons to appeal final Commissioner or Board licensing decisions to Maine's Superior Court (see 38 M.R.S. § 346(1); 06-096 C.M.R. ch. 2; 5 M.R.S. § 11001; and M.R. Civ. P. 80C). A party's appeal must be filed with the Superior Court within 30 days of receipt of notice of the Board's or the Commissioner's decision. For any other person, an appeal must be filed within 40 days of the date the decision was rendered. An appeal to court of a license decision regarding an expedited wind energy development, a general permit for an offshore wind energy demonstration project, or a general permit for a tidal energy demonstration project may only be taken directly to the Maine Supreme Judicial Court. See 38 M.R.S. § 346(4).

Maine's Administrative Procedure Act, DEP statutes governing a particular matter, and the Maine Rules of Civil Procedure must be consulted for the substantive and procedural details applicable to judicial appeals.

## **ADDITIONAL INFORMATION**

If you have questions or need additional information on the appeal process, for administrative appeals contact the Board's Executive Analyst at (207) 287-2452, or for judicial appeals contact the court clerk's office in which your appeal will be filed.

---

**Note: The DEP provides this INFORMATION SHEET for general guidance only; it is not intended for use as a legal reference. Maine law governs an appellant's rights.**

---

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

CONTENTS

| SECTION | TOPIC   | PAGE |
|---------|---|------|
| A       | GENERAL PROVISIONS  |      |
| 1       | General compliance  | 2    |
| 2       | Other materials   | 2    |
| 3       | Duty to Comply  | 2    |
| 4       | Duty to provide information   | 2    |
| 5       | Permit actions  | 2    |
| 6       | Reopener clause   | 2    |
| 7       | Oil and hazardous substances  | 2    |
| 8       | Property rights   | 3    |
| 9       | Confidentiality   | 3    |
| 10      | Duty to reapply   | 3    |
| 11      | Other laws  | 3    |
| 12      | Inspection and entry  | 3    |
| B       | OPERATION AND MAINTENANCE OF FACILITIES                                   |      |
| 1       | General facility requirements   | 3    |
| 2       | Proper operation and maintenance  | 4    |
| 3       | Need to halt reduce not a defense   | 4    |
| 4       | Duty to mitigate  | 4    |
| 5       | Bypasses  | 4    |
| 6       | Upsets  | 5    |
| C       | MONITORING AND RECORDS  |      |
| 1       | General requirements  | 6    |
| 2       | Representative sampling   | 6    |
| 3       | Monitoring and records  | 6    |
| D       | REPORTING REQUIREMENTS  |      |
| 1       | Reporting requirements  | 7    |
| 2       | Signatory requirement   | 8    |
| 3       | Availability of reports   | 8    |
| 4       | Existing manufacturing, commercial, mining, and silvicultural dischargers | 8    |
| 5       | Publicly owned treatment works  | 9    |
| E       | OTHER PROVISIONS  |      |
| 1       | Emergency action - power failure  | 9    |
| 2       | Spill prevention  | 10   |
| 3       | Removed substances  | 10   |
| 4       | Connection to municipal sewer   | 10   |
| F       | DEFINITIONS   | 10   |

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

### A. GENERAL PROVISIONS

1. **General compliance.** All discharges shall be consistent with the terms and conditions of this permit; any changes in production capacity or process modifications which result in changes in the quantity or the characteristics of the discharge must be authorized by an additional license or by modifications of this permit; it shall be a violation of the terms and conditions of this permit to discharge any pollutant not identified and authorized herein or to discharge in excess of the rates or quantities authorized herein or to violate any other conditions of this permit.

2. **Other materials.** Other materials ordinarily produced or used in the operation of this facility, which have been specifically identified in the application, may be discharged at the maximum frequency and maximum level identified in the application, provided:

- (a) They are not
  - (i) Designated as toxic or hazardous under the provisions of Sections 307 and 311, respectively, of the Federal Water Pollution Control Act; Title 38, Section 420, Maine Revised Statutes; or other applicable State Law; or
  - (ii) Known to be hazardous or toxic by the licensee.
- (b) The discharge of such materials will not violate applicable water quality standards.

3. **Duty to comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of State law and the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- (a) The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act, and 38 MRSA, §420 or Chapter 530.5 for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
- (b) Any person who violates any provision of the laws administered by the Department, including without limitation, a violation of the terms of any order, rule license, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

4. **Duty to provide information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

5. **Permit actions.** This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

6. **Reopener clause.** The Department reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedule of compliance or other provisions which may be authorized under 38 MRSA, §414-A(5).

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

**7. Oil and hazardous substances.** Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under section 311 of the Federal Clean Water Act; section 106 of the Federal Comprehensive Environmental Response, Compensation and Liability Act of 1980; or 38 MRSA §§ 1301, et. seq.

**8. Property rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.

**9. Confidentiality of records.** 38 MRSA §414(6) reads as follows. "Any records, reports or information obtained under this subchapter is available to the public, except that upon a showing satisfactory to the department by any person that any records, reports or information, or particular part or any record, report or information, other than the names and addresses of applicants, license applications, licenses, and effluent data, to which the department has access under this subchapter would, if made public, divulge methods or processes that are entitled to protection as trade secrets, these records, reports or information must be confidential and not available for public inspection or examination. Any records, reports or information may be disclosed to employees or authorized representatives of the State or the United States concerned with carrying out this subchapter or any applicable federal law, and to any party to a hearing held under this section on terms the commissioner may prescribe in order to protect these confidential records, reports and information, as long as this disclosure is material and relevant to any issue under consideration by the department."

**10. Duty to reapply.** If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.

**11. Other laws.** The issuance of this permit does not authorize any injury to persons or property or invasion of other property rights, nor does it relieve the permittee of its obligation to comply with other applicable Federal, State or local laws and regulations.

**12. Inspection and entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the EPA Administrator), upon presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## **B. OPERATION AND MAINTENANCE OF FACILITIES**

### **1. General facility requirements.**

- (a) The permittee shall collect all waste flows designated by the Department as requiring treatment and discharge them into an approved waste treatment facility in such a manner as to

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

- maximize removal of pollutants unless authorization to the contrary is obtained from the Department.
- (b) The permittee shall at all times maintain in good working order and operate at maximum efficiency all waste water collection, treatment and/or control facilities.
  - (c) All necessary waste treatment facilities will be installed and operational prior to the discharge of any wastewaters.
  - (d) Final plans and specifications must be submitted to the Department for review prior to the construction or modification of any treatment facilities.
  - (e) The permittee shall install flow measuring facilities of a design approved by the Department.
  - (f) The permittee must provide an outfall of a design approved by the Department which is placed in the receiving waters in such a manner that the maximum mixing and dispersion of the wastewaters will be achieved as rapidly as possible.

**2. Proper operation and maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

**3. Need to halt or reduce activity not a defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**4. Duty to mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

### **5. Bypasses.**

- (a) Definitions.
  - (i) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
  - (ii) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- (b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this section.
- (c) Notice.
  - (i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

- (ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D(1)(f), below. (24-hour notice).
- (d) Prohibition of bypass.
  - (i) Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
    - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
    - (C) The permittee submitted notices as required under paragraph (c) of this section.
  - (ii) The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in paragraph (d)(i) of this section.

**6. Upsets.**

- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (c) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (ii) The permitted facility was at the time being properly operated; and
  - (iii) The permittee submitted notice of the upset as required in paragraph D(1)(f), below. (24 hour notice).
  - (iv) The permittee complied with any remedial measures required under paragraph B(4).
- (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.



# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

### C. MONITORING AND RECORDS

**1. General Requirements.** This permit shall be subject to such monitoring requirements as may be reasonably required by the Department including the installation, use and maintenance of monitoring equipment or methods (including, where appropriate, biological monitoring methods). The permittee shall provide the Department with periodic reports on the proper Department reporting form of monitoring results obtained pursuant to the monitoring requirements contained herein.

**2. Representative sampling.** Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. If effluent limitations are based wholly or partially on quantities of a product processed, the permittee shall ensure samples are representative of times when production is taking place. Where discharge monitoring is required when production is less than 50%, the resulting data shall be reported as a daily measurement but not included in computation of averages, unless specifically authorized by the Department.

### **3. Monitoring and records.**

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.
- (c) Records of monitoring information shall include:
  - (i) The date, exact place, and time of sampling or measurements;
  - (ii) The individual(s) who performed the sampling or measurements;
  - (iii) The date(s) analyses were performed;
  - (iv) The individual(s) who performed the analyses;
  - (v) The analytical techniques or methods used; and
  - (vi) The results of such analyses.
- (d) Monitoring results must be conducted according to test procedures approved under 40 CFR part 136, unless other test procedures have been specified in the permit.
- (e) State law provides that any person who tampers with or renders inaccurate any monitoring devices or method required by any provision of law, or any order, rule license, permit approval or decision is subject to the penalties set forth in 38 MRSA, §349.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

**D. REPORTING REQUIREMENTS**

**1. Reporting requirements.**

- (a) Planned changes. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
  - (i) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
  - (ii) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under Section D(4).
  - (iii) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
- (b) Anticipated noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- (c) Transfers. This permit is not transferable to any person except upon application to and approval of the Department pursuant to 38 MRSA, § 344 and Chapters 2 and 522.
- (d) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
  - (i) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Department for reporting results of monitoring of sludge use or disposal practices.
  - (ii) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR part 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Department.
  - (iii) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Department in the permit.
- (e) Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- (f) Twenty-four hour reporting.
  - (i) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance

## MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- (ii) The following shall be included as information which must be reported within 24 hours under this paragraph.

- (A) Any unanticipated bypass which exceeds any effluent limitation in the permit.

- (B) Any upset which exceeds any effluent limitation in the permit.

- (C) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit to be reported within 24 hours.

- (iii) The Department may waive the written report on a case-by-case basis for reports under paragraph (f)(ii) of this section if the oral report has been received within 24 hours.

- (g) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (d), (e), and (f) of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (f) of this section.

- (h) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

**2. Signatory requirement.** All applications, reports, or information submitted to the Department shall be signed and certified as required by Chapter 521, Section 5 of the Department's rules. State law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan or other document filed or required to be maintained by any order, rule, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

**3. Availability of reports.** Except for data determined to be confidential under A(9), above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. As required by State law, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal sanctions as provided by law.

**4. Existing manufacturing, commercial, mining, and silvicultural dischargers.** In addition to the reporting requirements under this Section, all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Department as soon as they know or have reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

- (i) One hundred micrograms per liter (100 ug/l);

- (ii) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

- (iii) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or

- (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

## MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

### STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

- (b) That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - (i) Five hundred micrograms per liter (500 ug/l);
  - (ii) One milligram per liter (1 mg/l) for antimony;
  - (iii) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or
  - (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

#### **5. Publicly owned treatment works.**

- (a) All POTWs must provide adequate notice to the Department of the following:
  - (i) Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA or Chapter 528 if it were directly discharging those pollutants.
  - (ii) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
  - (iii) For purposes of this paragraph, adequate notice shall include information on (A) the quality and quantity of effluent introduced into the POTW, and (B) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (b) When the effluent discharged by a POTW for a period of three consecutive months exceeds 80 percent of the permitted flow, the permittee shall submit to the Department a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.

#### **E. OTHER REQUIREMENTS**

**1. Emergency action - power failure.** Within thirty days after the effective date of this permit, the permittee shall notify the Department of facilities and plans to be used in the event the primary source of power to its wastewater pumping and treatment facilities fails as follows.

- (a) For municipal sources. During power failure, all wastewaters which are normally treated shall receive a minimum of primary treatment and disinfection. Unless otherwise approved, alternate power supplies shall be provided for pumping stations and treatment facilities. Alternate power supplies shall be on-site generating units or an outside power source which is separate and independent from sources used for normal operation of the wastewater facilities.
- (b) For industrial and commercial sources. The permittee shall either maintain an alternative power source sufficient to operate the wastewater pumping and treatment facilities or halt, reduce or otherwise control production and or all discharges upon reduction or loss of power to the wastewater pumping or treatment facilities.

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

**2. Spill prevention.** (applicable only to industrial sources) Within six months of the effective date of this permit, the permittee shall submit to the Department for review and approval, with or without conditions, a spill prevention plan. The plan shall delineate methods and measures to be taken to prevent and or contain any spills of pulp, chemicals, oils or other contaminants and shall specify means of disposal and or treatment to be used.

**3. Removed substances.** Solids, sludges trash rack cleanings, filter backwash, or other pollutants removed from or resulting from the treatment or control of waste waters shall be disposed of in a manner approved by the Department.

**4. Connection to municipal sewer.** (applicable only to industrial and commercial sources) All wastewaters designated by the Department as treatable in a municipal treatment system will be cosigned to that system when it is available. This permit will expire 90 days after the municipal treatment facility becomes available, unless this time is extended by the Department in writing.

**F. DEFINITIONS.** For the purposes of this permit, the following definitions shall apply. Other definitions applicable to this permit may be found in Chapters 520 through 529 of the Department's rules

**Average** means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For bacteria, the average shall be the geometric mean.

**Average monthly discharge limitation** means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. Except, however, bacteriological tests may be calculated as a geometric mean.

**Average weekly discharge limitation** means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

**Best management practices ("BMPs")** means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

**Composite sample** means a sample consisting of a minimum of eight grab samples collected at equal intervals during a 24 hour period (or a lesser period as specified in the section on monitoring and reporting) and combined proportional to the flow over that same time period.

**Continuous discharge** means a discharge which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or other similar activities.

**Daily discharge** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the day.

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

**Discharge Monitoring Report ("DMR")** means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by approved States as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA's.

**Flow weighted composite sample** means a composite sample consisting of a mixture of aliquots collected at a constant time interval, where the volume of each aliquot is proportional to the flow rate of the discharge.

**Grab sample** means an individual sample collected in a period of less than 15 minutes.

**Interference** means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

**Maximum daily discharge limitation** means the highest allowable daily discharge.

**New source** means any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:

- (a) After promulgation of standards of performance under section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

**Pass through** means a discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

**Permit** means an authorization, license, or equivalent control document issued by EPA or an approved State to implement the requirements of 40 CFR parts 122, 123 and 124. Permit includes an NPDES general permit (Chapter 529). Permit does not include any permit which has not yet been the subject of final agency action, such as a draft permit or a proposed permit.

**Person** means an individual, firm, corporation, municipality, quasi-municipal corporation, state agency, federal agency or other legal entity.

# MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

## STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

---

**Point source** means any discernible, confined and discrete conveyance, including, but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation or vessel or other floating craft, from which pollutants are or may be discharged.

**Pollutant** means dredged spoil, solid waste, junk, incinerator residue, sewage, refuse, effluent, garbage, sewage sludge, munitions, chemicals, biological or radiological materials, oil, petroleum products or byproducts, heat, wrecked or discarded equipment, rock, sand, dirt and industrial, municipal, domestic, commercial or agricultural wastes of any kind.

**Process wastewater** means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

**Publicly owned treatment works ("POTW")** means any facility for the treatment of pollutants owned by the State or any political subdivision thereof, any municipality, district, quasi-municipal corporation or other public entity.

**Septage** means, for the purposes of this permit, any waste, refuse, effluent sludge or other material removed from a septic tank, cesspool, vault privy or similar source which concentrates wastes or to which chemicals have been added. Septage does not include wastes from a holding tank.

**Time weighted composite** means a composite sample consisting of a mixture of equal volume aliquots collected over a constant time interval.

**Toxic pollutant** includes any pollutant listed as toxic under section 307(a)(1) or, in the case of sludge use or disposal practices, any pollutant identified in regulations implementing section 405(d) of the CWA. Toxic pollutant also includes those substances or combination of substances, including disease causing agents, which after discharge or upon exposure, ingestion, inhalation or assimilation into any organism, including humans either directly through the environment or indirectly through ingestion through food chains, will, on the basis of information available to the board either alone or in combination with other substances already in the receiving waters or the discharge, cause death, disease, abnormalities, cancer, genetic mutations, physiological malfunctions, including malfunctions in reproduction, or physical deformations in such organism or their offspring.

**Wetlands** means those areas that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

**Whole effluent toxicity** means the aggregate toxic effect of an effluent measured directly by a toxicity test.