



8431 Murphy Drive
Middleton, Wisconsin 53562

Telephone: 608-836-4400
Facsimile: 608-831-9279
www.intertek-etlsemko.com

Certificate of Compliance
No. CF 1219 05-12-08

This is to certify that the under mentioned manufacturer

CECO DOOR PRODUCTS

9159 Telecom Drive, Milan TN 38358
Tel: 1.731.686.4370; Fax: 1.731.723.1308

Is a Listed manufacturer or assembler of Product(s) specified below, under the
Warnock Hersey (WH) label service.

**FIRE RESISTANT
PRODUCT**

TESTING STANDARD(S)

Ceco Door Products Models Imperial & Versadoor Polyurethane Core Doors, Rated -1/3, 3/4, 1, 1-1/2 and 3 Hour	CAN4-S104 (ULC-S104) – Standard Method for Fire Tests of Door Assemblies NFPA 252 – Standard Methods for Fire Tests of Door Assemblies UL 10B – Fire Tests of Door Assemblies UL10C – Positive Pressure Fire Tests of Door Assemblies UBC 7-2 (1994) – Methods for Fire Tests of Door Assemblies UBC 7-2 (1997) – Methods for Fire Tests of Door Assemblies And installed in accordance with NFPA 80 – Standard for Fire Doors and Other Opening Protectives
--------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Additional Information:

Models *Imperial & Versadoor* Doors are classified for a maximum of 3 hours as single swing (4'0" x 8'0" max), standard pairs (8'0" x 8'0" max), and double egress pairs (8'0" x 7'2" max). Standard pairs (8'0" x 9'0" max) and double egress pairs (8'0" x 9'0" max) are classified for a maximum 1-1/2, 3/4, and 1/3 hours. Glazed areas are permitted as follows: 3 hour rating – 100 in² Firelite Classified Material per door, 1-1/2 hour rating 100 in² any classified glazing material per door, 3/4 and 1/3 hour rating – 1,296 in² per light.

Models *Imperial & Versadoor* Doors may be used with any Listed single point latches/bolts or fire exit hardware.

This certificate is only valid under Intertek/WH Testing, Inspection, and Labelling Services. Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by Intertek / Warnock Hersey Certification and Surveillance Services.

Bob Davison
Certification Manager

Issued: 28 May 2008

