



8431 Murphy Drive  
Middleton, Wisconsin 53562

Telephone: 608-836-4400  
Facsimile: 608-831-9279  
www.intertek-ettsemko.com

**Certificate of Compliance**  
**No. CF 1219 11-06-01**

This is to certify that the under mentioned manufacturer

**CECO DOOR PRODUCTS, AN ASSA ABLOY DOOR GROUP CO.**

9159 Telecom Drive, Milan, TN 38358  
Tel: 1.731.686.4370 Fax: 1.731.686.4285

Is a Listed manufacturer or assembler of Product(s) specified below,  
Under the Warnock Hersey (WH) label service

**FIRE RESISTANT  
PRODUCT**

**TESTING STANDARD(S)**

KD or Welded Three Piece Frames	UL 10B – Fire Tests of Door Assemblies UL10C – Standard for Positive Pressure Tests of Door Assemblies UBC 7-2 (1997) – Fire Tests of Door Assemblies ANSI/NFPA 80 – Installation of Standard Fire Doors & Fire Windows NFPA 252 – Standard for Fire Tests of Door Assemblies
---------------------------------	---

**Additional Information:**

KD or Welded Three piece frames in masonry conditions are listed for a maximum of 3 hours in single door openings (4'0" x 10'0" max.) and in standard pair openings (8'0" x 10'0" max.). KD or Welded Three piece frames in drywall conditions are listed for a maximum of 1-1/2 hours in single door openings (4'0" x 9'0" max.) and in standard pair openings (8'0" x 9'0" max.). Frames shall be a minimum of 16 gauge and maximum of 12 gauge steel.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by ITS – Warnock Hersey Listing and Follow-up Services.

Bob Davison  
Certification Manager

Issued: March 27, 2008

