


#### Frame Preparation

##### **Notes:**

1. Minimum Stile Width 4-1/2(114).
2. For recommended door reinforcements see template 7400-0000. Unreinforced doors require optional SNB to mount the device components.
3. Unless otherwise specified, door and frame preparation and dimensional tolerances must conform to ANSI A115.1. Lock support required as shown.
4. For outside trim preparation see appropriate trim template.
5. Prepare mounting holes when installing the device.
6. LHR door shown. Preparation is typical for both door hands.
7. Dimensions are in inches (mm). Do not scale drawing.



#### Door Preparation

8. Holes for optional SNB: 9/32 (7.00) Dia.inside door face; 3/8 (9.50) Dia.outside door face.
9. Dimensions given about a centerline are symmetrical.
10. Device mount to hinge stile (not shown) requires holes location and preparation during device installation.
11. For electrical device suffixes "-Safe", "-Secure", "-O-", or "-S-": 1/2 (12.70) diameter, this face, plus prep shown on template 7477-0001.
12. For electrical device suffixes "-B", "-G", "-P", or MELR also see template 7477-0001.
13. Latchbolt centerline is 23/32 (18.2) below & Auxbolt centerline is 3/16 (4.8) above the centerline of lockfront.

**RESPONSIBILITY**  
DOOR AND FRAME MANUFACTURERS ARE  
RESPONSIBLE FOR PROVIDING ADEQUATE  
CONSTRUCTION OR REINFORCEMENTS FOR  
PROPER INSTALLATION OF HARDWARE SHOWN.  
ALL ARCHITECTURAL BUILDERS HARDWARE MUST  
BE INSTALLED ON PROPERLY REINFORCED  
DOORS AND FRAMES, REGARDLESS OF TYPE,  
MATERIAL, OR METHOD OF CONSTRUCTION.

## 6130, 6135, 6130F, 7130, 7135 & 7130F

Mortise Exit Devices with ANSI A115.1 Strike

Application for Metal Door and Frame

1-855-557-5078 Ext. 2

[www.accentra-assaabloy.com](http://www.accentra-assaabloy.com)

**ACCENTRA®**

**ASSA ABLOY**

Experience a safer  
and more open world

Copyright © 2015, 2024, 2025, ASSA ABLOY ACCENTRA™ Access and Egress Hardware Group, Inc. All rights reserved. Reproduction in whole or in part without the express written permission of ASSA ABLOY Access and Egress Hardware Group, Inc. is prohibited.

SUPERSEDES 7470-0030 04/24 DO NOT SCALE DRAWING

TEMPLATE NUMBER 7470-0030 SHEET 1 of 1 DATE 09/25