

CE 0085



CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085BU0133

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Distributor <i>Vertreiber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Product Category <i>Produktart</i>	gas fittings: Pressure regulator for LPG (4302)
Product Description <i>Produktbezeichnung</i>	Pressure regulator for LPG with non adjustable outlet pressure
Model <i>Modell</i>	694, 694 D, 694 M
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: 544/3017/1453 from 07.02.2018 (FGL)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 16129 (01.08.2013)

Date of Expiry / File No. 03.04.2028 / 21-0391-GER
Ablaufdatum / AZ

14.10.2021 Kd A-1/2

Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wilmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

A-2/2

CE-0085BU0133

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>	
LPG		
Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
694	outlet pressure: 29 (B); 37, 50 (P); 29, 30, 50 (LPG) mbar inlet pressure range: 0,3...7,5 (B); 1,0...16,0 (P); 0,3...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 1,3 (B); 1,5/2,0 (P); 1,5 (LPG) kg/h	
694D; 694M	outlet pressure: 30 (LPG) mbar inlet pressure range: 0,3...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 0,8 kg/h	
Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>	
694	single stage regulator	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

optional: manometer, excess flow device with an automatic re-setting "EFV", overpressure (max. 150 mbar) relief valve of limited flow rate "PRV"
 ambient temperature range: 0...+50 °C (B); -20...+50 °C (P, LPG)
 connection: at the input side G.1, G.2, G.4, G.5, G.6, G.7, G.8, G.9, G.10, G.12, G.25, at the outlet side H.4, H.50, H.51, H.53; each according to DIN EN 16129
 PRV-response pressure: max. 150 mbar
 In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.
 The recognition of the CE mark in the United Kingdom is currently limited to Januar 1st, 2023.