

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

## Product

Type B residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)

## Name and address of the applicant

Zhejiang VeKON Technology Co. Ltd.  
No. 99 Binhai Nansan Rd.  
Economic Development Zone,  
Yueqing, Zhejiang, China

## Name and address of the manufacturer

Same as applicant

## Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

## Ratings and principal characteristics

See page 2

## Trademark (if any)



## Customer's Testing Facility (CTF) Stage used

-

## Model / Type Ref.

VDF-63

## Additional information (if necessary may also be reported on page 2)

This certificate replaces CB certificate SE-93858, dated 18 April 2019 due to standard update.

## A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010+A1+A2  
IEC 61008-2-1:1990  
IEC 62423:2009

## As shown in the Test Report Ref. No. which forms part of this Certificate

200702792SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature:



Henrik Wikström

Date: 03 December, 2020

**Ratings and principal characteristics**

$U_n=230/240V\sim(1P+N)$ ,  $400/415V\sim(3P+N)$ ; Switched Neutral pole, 50/60Hz

$U_{imp}=4kV$ ,  $U_i=500V$ ,  $-25\sim-40^{\circ}C$

$I_n=16, 25, 32, 40, 63A$

$I_{\Delta n}=30, 100, 300mA$ , Type B

$I_{\Delta m}=I_m=1000A$ ,  $I_{nc}=I_{\Delta c}=10kA$

Independent on line voltage for Type A part

Dependent on line voltage for Type B part

Date: 03 December, 2020

Signature:

A handwritten signature in black ink, appearing to be 'H. W. K.', written over a white background.