



# Certificate of compliance

**Applicant:** **ALTENERGY POWER SYSTEM INC.**  
No.1 Yatai Road,  
Jiaxing 314050 Zhejiang Province  
P.R. China

**Product:** **Photovoltaic (PV) inverter**

**Model:** **DS3**  
**DS3-H**  
**DS3-L**  
**DS3-S**  
**DS3-L-SPE**  
**DS3-M**

## Use in accordance with regulations:

Islanding prevention device in accordance with IEC 62116:2014 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The islanding prevention device is an integral part of the named inverters.

## Applied rules and standards:

IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** ZEK-ESH-P22071986      **Certification Program:** NSOP-0032-DEU-ZE-V01

**Certificate number:** U22-0470      **Date of issue:** 2022-08-01

**Certification body**



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH