



Ref. Certif. No.

HU-003449

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breaker

Name and address of the applicant

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Ratings and principal characteristics

Ui: 1500V; Uimp: 12kV; Reference temperature: +50°C; Cat.A;
In: SM8-320HPV:320A; SM8-400HPV:350/400A; SM8-630HPV:500/630A;
Ue: DC1000V, DC1250V, DC1500V; 4P appearance;
Ics: DC1000V:20kA; DC1250V, DC1500V:15kA; Icu: Same as Ics

Trademark (if any)

SUNTREE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SM8-320HPV SM8-400HPV SM8-630HPV

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN217F6K 001.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN217F6K 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2021-05-28

Signature:

Wencai Zhang