

CERTIFICATE OF ADMITTANCE

No. 4740/2022

Based on art. 7 paragraph 2 of the Act of 24 August 1991 on fire protection
Centrum Naukowo-Badawcze Ochrony Przeciwpożarowej im. Józefa Tuliszowskiego
Państwowy Instytut Badawczy at the request of:

Polska Korporacja Recyklingu Sp. z o.o.
ul. Metalurgiczna 15C
20-234 Lublin

states that product:

Sorbent type Re-absorbent oil

manufactured by:

Polska Korporacja Recyklingu Sp. z o.o.
ul. Metalurgiczna 15C
20-234 Lublin

in the manufacturing plants:

Polska Korporacja Recyklingu Sp. z o.o.
ul. Metalurgiczna 15C
20-234 Lublin

Polska Korporacja Recyklingu Sp. z o.o.
ul. Metalurgiczna 13F
20-234 Lublin

meets the requirements of:

**point 9.1 of annex to the Regulation of the Minister of the Interior and
Administration of 20 June 2007 on the list of products used for ensuring public
safety or protecting health, life and property, and the principles of issuing
admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002;
zm.: Dz. U. z 2010 r. nr 85, poz. 553 oraz z 2018 r. poz.984)**

Documentation:

1. Application for the process of product admittance No. 6589/2022 of 23.06.2022.
2. Test report No. 210/BU/22 of 11.04.2022 and test report No. 340/BU/22 of 22.06.2022 prepared by Zespół Laboratoriów Urządzeń i Środków Gaśniczych BU CNBOP-PIB.


The certificate of admittance is valid under the condition that the applicant fulfils the requirements defined in the agreement No. 4740/DC/CNBOP-PIB/2022.

Validity period of the admittance:

from **12.09.2022**

until **11.09.2027**

DIRECTOR OF CNBOP-PIB


pp. Deputy Director
for Certification and Admittance
st. bryg. Jacek Zbojna, PhD Eng.



Józefów: 12 September 2022

Page 1/2

CERTIFICATE OF ADMITTANCE

No. 4740/2022

TECHNICAL DATA IDENTIFYING THE PRODUCT

Sorbent type Re-absorbent oil

Intended use	for absorbing oil spills
Application	on solid surfaces and water surfaces
Form	loose material with different degrees of fineness
Basic ingredient	polyurethane foam (PUR)
Ability to absorb oil	not less than 50% by weight of the sorbent
Bulk density	53 g/l $\pm$ 10 %
Buoyancy	At least 95% of the sorbent remains on the surface of standing water for 24 hours
Granulation:	
of grains over 4 mm	< 0,05 %
of grains under 0,125 mm	< 5 %

ADDITIONAL TERMS AND COMMENTS:

According to § 17 of the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143, poz. 1002, z 2010 r., Nr 85, poz. 553 i z 2018 r., poz. 984) a product should be marked with the marking of the admittance body and also the number of the certificate of admittance.

DIRECTOR OF CNBOP-PIB


pp. Deputy Director
for Certification and Admittance
st. bryg. Jacek Zboina, PhD Eng.



Józefów: 12 September 2022

Page 2/2

ŚWIADECTWO DOPUSZCZENIA

Nr 4740/2022

DANE TECHNICZNE IDENTYFIKUJĄCE WYRÓB


Sorbent typ Re-absorbent oil

Przeznaczenie	do pochłaniania wycieków substancji ropopochodnych
Zastosowanie	na powierzchniach stałych i powierzchniach wód
Postać	materiał sypki o różnym stopniu rozdrobnienia
Podstawowy składnik	pianka poliuretanowa (PUR)
Zdolność pochłaniania oleju	nie mniej niż 50% wagowych w stosunku do masy sorbentu
Gęstość nasypowa	53 g/l $\pm$ 10 %
Pływalność	Co najmniej 95% sorbentu utrzymuje się na powierzchni wody stojącej przez 24 godziny
Granulacja:	
ziaren powyżej 4 mm	< 0,05 %
ziaren poniżej 0,125 mm	< 5 %

WARUNKI DODATKOWE I UWAGI:

Zgodnie z § 17 rozporządzenia Ministra Spraw Wewnętrznych i Administracji z dnia 20 czerwca 2007 r. w sprawie wykazu wyrobów służących zapewnieniu bezpieczeństwa publicznego lub ochronie zdrowia i życia oraz mienia, a także zasad wydawania dopuszczenia tych wyrobów do użytkowania (Dz. U. nr 143, poz. 1002, z 2010 r., Nr 85, poz. 553 i z 2018 r., poz. 984) wyrób powinien być oznakowany znakiem jednostki dopuszczającej i dodatkowo numerem niniejszego świadectwa.

DYREKTOR CNBOP-PIB



st. bryg. dr inż. Paweł Janik



Józefów, dnia: 12 września 2022 r.