



# Safeguarding renewable energy generation



**01 /** Camlin Energy Intro

---

**02 /** Why monitor transformers

---

**03 /** TOTUS solution

---

**04 /** Monitoring partnership

---

**05 /** Example of tailored solution

---

# Camlin Energy

For more than four decades, we have been innovating to protect and optimize the world's energy infrastructures.


We empower our customers with the insights to make strategic decisions that are crucial for protecting assets and networks, driving a resilient, flexible and sustainable future.

**Empowering Your Tomorrow**





# Empowering global energy infrastructure...



# ...locally, with Camlin Energy facilities across 17 countries

# Benefits of Camlin Energy's solutions



## Transformer Monitoring

Including EHV and HV Transformer, Bushing & LTC Monitoring



## Circuit Breaker Monitoring



## Overhead Lines

Fault Location & Management, LV & HV Overhead Network Monitoring & Management



## Low Voltage Networks

Fault Location & Management, LV Network Monitoring & Management



## Generator Monitoring



## In-Building Power Networks

Rising & Lateral Mains Large Commercial and Industrial

**Faults, Network resilience, Opex reductions and Safety**



**Capacity: Capacity & Network Planning**




**Asset: Asset Health & Investment Support**



# Why transformer monitoring?

In many projects this transformer is often a single point through which all the generation from the project passes through

Although these assets should have lifetimes that exceed the life of the project, they can and do fail, resulting in immediate loss of generation from the wind or solar project.



## A transformer failure could cost **\$75m** in lost revenues

**Example revenue loss if undetected issue leads to catastrophic failure and replacement transformer**

Project size	250 MW
Average loading rate	35%
Electricity price	\$50 per MWh
Transformer replacement lead time	24 months
<b>Revenue loss over lead time</b>	<b>\$75.6m</b>

Other costs and losses can include:

- Contractual penalties for failure to supply
- Cost of repair or replacement of the failed transformer
- Additional insurance costs
- Safety impacts

# Benefits of monitoring



## Risk Management

- Visibility of developing issues in transformer
- Real-time view of health across fleet



## Condition based maintenance

- Transition to condition-based maintenance
- Predictive Insights to support for long term scenario planning –suggested actions!
- Avoid unnecessary interventions and costs



## Financial security

- Mitigate financial and operational risks from loss of service
- Insurance cost reduction
- Informed investment decisions



## Increase asset availability

- Reduce unplanned outages and downtime
- Increased availability
- Long-term reliability (life extension/repowering)



## Protect your People

- Improve safety and protect against loss of life – bushing failures often cause fire or explode
- Minimise time spent on site
- Minimize public exposure and environmental risks



## Operational Efficiency

- Reduced & optimized O&M costs
- Reduce need for manual testing
- Independence from OEM
- Manage for loss of expertise and knowledge

# Complete transformer monitoring solutions, from install to expert insights



**TOTUS**  
The monitoring system: range of options to choose from to balance budget and risk



Installation & servicing  
Install and maintenance of your monitoring system



Asset Insights Software  
Delivers predictive analytics and prescriptive actions



Expert support  
Specialist transformer experts available to support

# Monitoring partnership

## Alignment to your transformer asset management strategy

- Our customer success consultants can work closely with your key stakeholders to support the development of your monitoring strategy

## Baseline health of your transformer fleet

- Our transformer experts can review the health of transformer fleet from available offline data. With knowledge of the criticality of each transformer, the monitoring program can be defined.

## Deployment of TOTUS systems

- TOTUS is a modular monitoring system, configured to maximize monitoring of each transformer within available budget. We, managing delivery and installation of your monitoring project.

## Data-drive maintenance actions

- Asset Insights software provides actionable insights using TOTUS and other data to determine condition index, identify failure mode and recommend the maintenance action. Our transformer experts can support with condition assessment reports, and alarms can come directly into our Sapien centre for immediate review.

## Review success

- Our customer success consultants can review the implementation of monitoring program, ensuring systems and process are optimized and all stakeholders are receiving expected value from monitoring project.



**Success**

Define  
monitoring  
strategy

Determine  
transformers  
to monitor

Install  
monitoring  
systems

Gain  
insights to  
health & risk  
across fleet

Data-driven  
maintenance  
actions

Realise  
value &  
refine  
monitoring  
program

# Project example

## Background:

- Customer's asset management strategy was updated to require monitoring following unexpected transformer failure and significant revenue lost.

## Customer requirements:

- With limited internal resource, they required a partner who could fully manage and run the monitoring program.

## Camlin Energy engaged to:

- Deploy **TOTUS systems** on all critical transformers
- Integrate with Camlin Energy's **Sapient centre** for immediate expert response following any alarms
- Provide transformer and fleet **condition assessment** reports
- Access to live view of transformer health and maintenance actions through asset insights software
- Be available to support with **expert support** as needed
- Review customer systems and processes to ensure monitoring program is a **success**



The image features a sunset background with several high-voltage power line towers and their associated cables. The sun is low on the horizon, creating a warm orange and yellow glow. Overlaid on this scene is a series of concentric white circles that form a grid-like pattern. In the center of this grid, the words "THANK YOU" are written in a clean, white, sans-serif font. The text is centered horizontally and vertically within the frame.

THANK YOU



# Annex 1: TOTUS



## TOTUS monitoring capabilities


### TOTUS Transformer Monitoring

A comprehensive solution designed for the real-time monitoring and management of power transformers.

TOTUS combines sensor technology and integrated analytics to maximise reliability, and longevity of transformers

# 80%+

of transformer failures are due to failings in the Bushings, Windings and OLTCs.



BUSHING  
MONITORING  
**+17% Failure Rate**




TAP CHANGER  
**+26% Failure Rate**



TRANSFORMER  
MAIN TANK  
**+40% Failure Rate**




# Main Tank



DGA	9 Gas + moisture in oil 5 Gas + moisture in oil Hydrogen + moisture in oil
Partial Discharges	Active PDs Arcing Events
Through Faults	Event Count Cumulative effect
Cooling System	Pump/Fan absorption Cooling Status Temperatures
Models	Hot Spots Ageing / Remaining Life Moisture in paper Bubbling Dynamic Loading Oil Breakdown Voltage
Others	Geomagnetic Induced Currents (GIC) Direct winding temperatures with fiber optics Analog and Digital Inputs Integration of any third party monitor/system



# Bushings



Partial Discharges	Active PDs Arcing Events
Leakage currents	Amplitude and phase angle Polar Plot / Sum of current
Capacitance/Tandelta (PF)	Tandelta/PF variations C1 variations C2 variations
Others	Temperature Load Humidity

# TOTUS Transformer Total Monitoring System




Example system (9-gas with partial discharge and bushing monitoring)


- Input/output
- Temperature
- Models

- Embedded Server
- Embedded Modem

- PD
- Bushing
- TFC




9 gas DGA



IEC61850  
MODBUS  
DNP3  
HTTPS  
RELAYS

# Example installation layout





# DGA

PhotoAcoustic

No consumables

Oxygen included


Accurate

Field Proven

Ester Oil compatible



<b>Technology</b>	PAS
<b>Gases</b>	H2, CO, CH4, C2H2, C2H4, C2H6, O2, N2 ,CO2
<b>Moisture in oil</b>	YES
<b>No consumables</b>	YES



Analysis Tool/Parameters	IEEE C57.104 2018	IEC 60599	TOTUS
TCG (Total Combustible Gas)	✓		✓
TDCG (Total Dissolved Combustible gas)	✓		✓
Key Gas Method	✓		✓
Doenenburg Ratios	✓		✓
Roger Ratios	✓		✓
Basic Gas Ratios		✓	✓
Duval Triangle	✓ NEW	✓	✓
Duval Pentagon	✓ NEW		✓
CO2/CO Ratio	✓ NEW	✓	✓
O2/N2 Ratio		✓	✓
C2H2/H2 ratio		✓	✓
NEI index	✓ NEW		✓



TOTUSPRO Access Portal Overall Status | TST002-0000... x

https://tst002-000006.camlin.totuspro.com/#totus-dashboard

Camlin Technologies Electric Energy Online TOTUS onedrive Confluence Benvenuto | FlyingBlu... FortiGate - FWCL Epoch Converter - Uni... il Resto del Carlino - N...  
TST002-000006-Mascatine-GSU Thu, Mar 9, 2017 7:19:28 PM CST

**CAMLIN Overall Status** Dashboards - Alarms Settings - About - Marco Tozzi

System Status

- Bell icon
- Wrench icon
- Power icon

Active Alarms

No active alarms

Transformer Condition Group

3 - Good

BM Messages

Capacitance Learning Period Completed

Tandelta Learning Period Completed

Overall Status

Misc	
Transformer Load	1.5 A
Ambient Temperature	10.2 °C
Ambient Humidity	48.6 %

DGA	
Hydrogen	2.4 ppm
Methane	1.2 ppm
Ethane	3.1 ppm
Ethylene	1.1 ppm
Acetylene	0.1 ppm
Carbon Monoxide	88.2 ppm
Carbon Dioxide	1397.4 ppm
Water	0.0 ppm

Partial Discharges	
Cap	0.55 %
TanD	0.28 %
PD	0.0 pps

Partial Discharges	
Minor	0 %
Medium	0 %
Severe	0 %
HEE	0 %

Top Oil Temperature 7.6 °C

Bottom Oil Temperature 4.6 °C

LTC Differential 0.0 °C

TOTUSPRO Access Portal Dashboard | TST002-00000... x

https://tst002-000006.camlin.totuspro.com/#dashboard/dga-diagnostics

Camlin Technologies Electric Energy Online TOTUS onedrive Confluence Benvenuto | FlyingBlu... FortiGate - FWCL Epoch Converter - Uni... il Resto del Carlino - N...  
TST002-000006-Mascatine-GSU Thu, Mar 9, 2017 7:20:32 PM CST

**CAMLIN Dashboard** Dashboards - Alarms Settings - About - Marco Tozzi

CO2 / CO: 15.849 O2 / N2: 0.000 C2H2 / H2: 0.038

Gas Ratios 3D

Duval's Triangle

Partial Discharges

- PD Partial discharges
- D1 Discharges of low energy
- D2 Discharges of high energy

TOTUSPRO Access Portal PD Triangle | BP001-00002... x

https://bp001-000025.camlin.totuspro.com/#dash-pd-triangle

Camlin Technologies Electric Energy Online TOTUS onedrive Confluence Benvenuto | FlyingBlu... FortiGate - FWCL Epoch Converter - Uni... il Resto del Carlino - N...  
BP001-000025-Martinetto TR3 Fri, Mar 10, 2017 2:23:09 AM CET

**CAMLIN PD Triangle** Dashboards - Alarms Settings - About - Marco Tozzi

PD Status

- H16 Intensive amplitude with intensive repetition rate
- H9 Intensive amplitude with moderate repetition rate
- H8 Moderate amplitude with intensive repetition rate
- H7 Moderate amplitude with moderate repetition rate
- H6 Intensive amplitude with small repetition rate
- H5 Small amplitude with intensive repetition rate
- H4 Moderate amplitude with small repetition rate
- H3 Small amplitude with moderate repetition rate
- H2 Small amplitude with small repetition rate
- H1 Minimal event
- H0 No meaningful event


# PD

HW Reliable

No false Alarms

Identifies Arcing

Easy Embedded Interpretation



PD Triangle identifies the Winding and Phase

- H10** Intensive amplitude with intensive repetition rate
- H9** Intensive amplitude with moderate repetition rate
- H8** Moderate amplitude with intensive repetition rate
- H7** Moderate amplitude with moderate repetition rate
- H6** Intensive amplitude with small repetition rate
- H5** Small amplitude with intensive repetition rate
- H4** Moderate amplitude with small repetition rate
- H3** Small amplitude with moderate repetition rate
- H2** Small amplitude with small repetition rate
- H1** Minimal event
- H0** No meaningful event

PD Intensity evaluated every hour



Reliable connection to the bushing >> 2000 installations

## Technical details

- 24/7 continuous monitoring
- Hourly PRPD Pattern
- Simultaneous acquisitions
- Automatic denoising
- Automatic cross coupling rejection
- 30 Vpp scale with 2 mV resolution
- IEC60270 compliant

# ADAPTORS


2000+  
installations

Stress life test in  
extreme  
conditions

Reliable and safe

Allows offline  
test without  
complete  
removal

Manufactured in  
Camlin



## Technical details




- IP 67
- No plastic exposed to sunlight
- No need to remove the head to do offline test
- Visual check of good connection



# ARCING

It identifies



- The winding
- The phase
- The exact moment of the event
- The arcing nature/cause



## Technical details

- 24/7 continuous monitoring
- Hourly PRPD Pattern
- Simultaneous acquisitions
- Automatic denoising
- Automatic cross coupling rejection
- 30 Vpp scale with 2 mV resolution

# PD in winding stress ring in 63 MVA transformer



- PD Pattern provided without noise and cross-coupling, automatically every hour

- TOTUS indicates 100% presence of Medium PD
- PD Triangle identifies phase U as the source



**DETECTED BY COMBINATION OF PD AND DGA, CONFIRMED BY VISUAL INSPECTION**






# Annex 2: Asset Insights



# Sapient™ | Asset Insights

## Dashboard





# Sapient™ | Asset Insights

## GIS View

SAI Alpha BM - Map - Sapient Insights

Sapient™ | Asset Insights Bushmills

Asset Explorer × TX GTX2 at Acacia Avenue × Map ×

File ▾

2 A Map offers spatial awareness, and an appreciation of asset health at your sites

**Dunloy**

Details

Type	Site
Location	Acacia Avenue
Condition	Short Term Risk
Tags	Grid Supply Point

Worst Asset

GTX4-replaced ⓘ

Company	Bushmills Electricity South
Condition	Short Term Risk
Last Measurement	2011-Dec-01
Type	Transformer

Assets

3 km mapbox

© Mapbox © OpenStreetMap Improve this map



# Sapient™ | Asset Insights

## Asset Explorer

SAI Alpha BM - Asset Explorer - Sapient Insights

Sapient™ | Asset Insights Bushmills

Asset Explorer X TX GTX2 at Acacia Avenue X Map X

File Actions Help Show on Map Asset Details Add to Dashboard Clear Search for text Transformer Fleet : 67 of 220

Company	Location	ID	Condition	Condition Index	Manufacturer	Year of Manufacture	Last Measurement	Tags	DI
Bushmills Electricity South	Acacia Avenue	GTX4-replaced	Short Term Risk	5.55	Verbano	1986	2011-Dec-01 00:00		24
Bushmills Electricity North	Sequoia Street	GTX1	Short Term Risk	5.12	Getra	2003	2022-May-01 00:00		55
Bushmills Electricity South	Acacia Avenue	GTX2	Medium Term Risk	4.47	Savigliano	1955	2022-Apr-01 00:00		24
Bushmills Electricity Transmission	Daisy Drive	GTX2	Medium Term Risk	4.44	Savigliano	1974	2022-Jul-01 00:00		22
Bushmills Electricity South	Grove Avenue	GTX2	Medium Term Risk	4.29	Parsons Peebles	1963	2023-Dec-01 00:00		14
Bushmills Electricity South	Hickory Lane	GTX1	Medium Term Risk	4.23	Parsons Peebles	1962	2023-Dec-01 00:00		17
Bushmills Electricity South	Elm Street	GTX2	Medium Term Risk	4.18	Parsons Peebles	1965	2023-Dec-01 00:00		24
Bushmills Electricity North	Juniper Road	TX1	Medium Term Risk	4.17	ABB Nitran	1993	2023-Dec-01 00:00		46
Bushmills Electricity South	Hickory Lane	GTX2	Medium Term Risk	4.14	Parsons Peebles	1960	2023-Dec-01 00:00		17
Bushmills Electricity South	Beech Street	TX2	Medium Term Risk	4.14	Bonar Long	1970	2023-Dec-01 00:00		18
Bushmills Electricity North	Juniper Road	TX2	Medium Term Risk	4.14	ABB	1993	2023-Dec-01 00:00		46
Bushmills Electricity South	Dogwood Drive	TX2	Medium Term Risk	4.12	Bonar Long	1978	2023-Dec-01 00:00		10
Bushmills Electricity North	Sequoia Street	GTX4	Medium Term Risk	4.1	Getra	1998	2022-May-01 00:00		55
Bushmills Electricity Transmission	Palm Boulevard	GTX2	Medium Term Risk	4.1	ABB	1996	2022-Apr-01 00:00		55
Bushmills Electricity Generation	Wind Place	GSU1	Medium Term Risk	4.1	Getra	2015	2022-Dec-01 00:00		17

Condition index automatically computed taking in account all available data sources

3 The Asset Explorer enables you to create different filtered views of your assets



# Sapient™ | Asset Insights

## Transformer Details

Sapient™ | Asset Insights Demo Andrew Hodgson

Asset Explorer x Dashboard x Map x **TX GTX1 at Coleraine** x

File Show on Map Last Month **Historical Data** << < > >> 🔍 📄

ID: GTX1 Company: Bushmills Electricity North Location: Coleraine Condition Index: 5.12 Latest Condition: **Short Term Risk** Latest Update: 2022-May-0

Condition Asset Information

Select View: Summary

Condition Index	Failure Modes	Confidence
2023-Dec-01 <b>5.12</b>	Arcing failure in the main tank	High
	Corrosive oil in the main tank	Medium

Maintenance Actions

Type	Action	Component	Urgency
🔧	Request expert diagnosis	Main tank	High: as soon as possible
🔧	Run internal inspection on the transformer	Main tank	High: as soon as possible
📅	Test oil corrosivity	Main tank	Low: add to next scheduled maintenance


4 Detailed view showing condition index for each component Failure Modes & Prescriptive Actions

- Based on Camlin expertise
- Customizable insights
- Automated & data driven



# Sapient™ | Asset Insights


## Transformer DGA





# Sapient™ | Asset Insights

## Transformer Models



Advanced Analytics models describing the status of the transformer, applying industry-standard and Camlin proprietary models to identify transformer behaviour

# Annex 3: Expert Services

# Transformer Supervision Package

Transformer Supervision Package (with Annual assessment)		
CA-2	Annual Condition Assessment w/ alarm review	•
CA-6	Emergency report within 24 hour (if required)	•
CA-5	Event Analysis (if required)	•
	Other support as required	•

## Summary:

The initial diagnostic assessment benchmarks the health of the transformer at the time of installing the monitoring system. It is included with the monitoring system.

Following this, the DGA alarm thresholds are optimized (annually) and a detailed annual condition assessment performed.

Should there be a transformer alarm or trip, our team will support with a rapid emergency report and a deeper analysis into the cause of the event. Other expert support as required is included.

These services are described in more detail on the following pages.



# CA-2 Annual Diagnosis

Data Required:

## Mandatory

- CA-1 report
- Recent DGA
- Recent Oil quality

## Recommended

- Online data
- Any other recent report available

## PURPOSE


Periodic assessment carried out every year, after the initial report (CA-1) is issued. It will update the initial calculated condition by adding recent DGA, oil quality and online monitors (if any) data. If electrical test and maintenance is necessary during the year a new CA-1 report will be needed.

## RESULT

Diagnostic Report in English Language, in pdf format (Translation to be quoted separately for Option 1).

## DELIVERY

2 working weeks after the submittal of the mandatory data set per each transformer



# CA-6 Emergency Report

Data Required:

## Mandatory

- Nameplate
- Online data
- Event description

## Recommended

- Historical DGA
- Historical Oil quality
- Historical electrical test results
- Any other available report



## PURPOSE

Identification of potential transformer issues upon alarm notification or customer concerns. Historical condition index is not included.

## RESULT

Diagnostic Report in English Language, in pdf format. It includes diagnostic assessment and recommended actions.

## LEAD TIME

24 hours from order receipt and submittal of mandatory data (only for reports in English)

**Document Classification:** [CONFIDENTIAL]  
**Document Ref:** ER-0000-2021-0000  
**Dated:** 03 January 2022  
**Document Author:** Transformer Expert

Parameter	Comment
Transformer	XXXX XXX, 5/N XXXXXXXX, XXX MVA, 345kV:22.8kV
Event	Online monitoring for capacitance/dissipation factor and partial discharge was requested by the XXXX for the XXX 2 generator step-up transformer at XXXXXXX during a unit start-up. The transformer is a XXX MVA. Monitoring during the unit start-up was planned following a surge arrester flashover incident, which occurred on B and C phases connected at the transformer HV winding. On XXXXXX, XXXXX began the load up on the XXX 2 transformer at approximately XXXX am. Camlin Energy provided analysis on archive files downloaded from the unit XXX by XXXX. The first data point from the online monitor was obtained around XXXXX, with loading at approximately XXXX MW. The highest loading during monitoring was XXX MW, on XXXXX.
Diagnosis	The bushing monitoring, Capacitance and Dissipation Factor values were stable throughout the monitoring period. Partial discharge data registered as having no meaningful events, and there were no high energy discharges recorded during the monitoring session. The discharge activity was low in both magnitude and repetition rate. Therefore, partial discharges throughout the monitoring period are considered not to be of any concern. No meaningful correlations with loading were observed in the BM data during unit load-up. Capacitance/Dissipation Factor, and partial discharges appear stable at both high and low loading.
Short Term Actions	No immediate actions necessary.
Planned Actions	XXXXX may consider periodic review of online monitoring data, and implementation of any alarm points, if desired.

>> CONFIDENTIALITY AND LIABILITY NOTICE <<  
 Recommendations contained herein are for the information and review of XXXX. Any subsequent action taken will be the total responsibility of XXXX, Camlin Energy accepts no liability.  
 The information contained in this report is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this document in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorized purpose. Neither Camlin Energy, nor any of its subsidiaries will be liable for any direct, special, punitive or consequential damages as a result of any virus being passed on or arising from the alteration of the contents of this message by a third party.  
 Page 2 of 2



# CA-5 Event Analysis

Data Required:

### Mandatory

- Nameplate
- Historical DGA
- Historical Oil quality
- Online data
- Event description

### Recommended

- Historical electrical test results
- Historical maintenance reports



## PURPOSE

Identification of potential transformer issues upon alarm notification or customer concerns.

## RESULT

Diagnostic Report in English Language, in pdf format (Translation to be quoted separately for Option 1).

## LEAD TIME

2 weeks from order receipt and submittal of mandatory data.

**Midway T11 On - Event Report**  
Customer: XXX

Parameter	Comment
<b>Transformer</b>	<b>Midway T11</b>
<b>Event</b>	H2 High alarm
<b>Diagnosis</b>	The alarm is caused by genuine gas increase after oil degassing in <a href="#">Mid 2018</a> . The H2 was about 60 ppm before degassing and then after the concentration reset to near zero it started steadily increase. There are no signs of imminent danger to the transformer reliability, but source of H2 to be clarified.
<b>Short Term Actions</b>	Change of DGA alarm settings ( <i>is planned to be done with all the ENW monitored fleet</i> ).
<b>Planned Actions</b>	<b>Actions required from ENW:</b> steady H2 level is high. To investigate reason: 1) test oil for stray gassing 2) if oil is not stray gassing with H2 - investigate possible discharges <a href="#">activity</a> - install Totus PD monitor/module

Document Classification: [CONFIDENTIAL]  
Document Ref: OE-2012-2021-0001  
Dated: 20 December 2021  
Document Author: Anatoly Mudryk

Fig 1. DGA trends.

The image features a sunset scene with several high-voltage power line towers and their associated power lines stretching across the horizon. The sky is a mix of orange, yellow, and blue, with scattered clouds. In the foreground, a series of white, concentric circles are overlaid on the image, creating a grid-like pattern. A single, larger white rounded square is centered in the middle of the image, containing the text.

The Power of the Possible