

R430 32 digital input module



Summary

The R430 digital input module is a microprocessor-controlled, communicative 32 binary inputs module. The module uses a RS485 bus with Modbus RTU, and can be easily integrated in a variety of supervision and control systems.

Application

• HVAC and industrial control systems – binary signal acquisition

Function

The inputs are designed for small voltage up to 50 V DC, 30 V AC. Inputs DI1 to DI24 have common ground – GND1. Inputs DI25 to DI32 have common ground – GND2. The GNDx terminals are not interconnected inside of the module and therefore each of them may host another potential. The inputs are optically separated from the rest of the circuitry.

The module communicates by means of a optically insulated RS485 data bus. The communication protocol ensures smooth and easy integration in a number of control and data acquisition systems. Removable connectors are used for incoming and outgoing data line so that mounting is fast and easy. As some communication cables include more pairs in one cable, free cores may be used for powering the module. The module is installed on a DIN rail.

The communication circuits are protected against overvoltage. If the module is terminating the communication bus, i.e. it is the last in line, a terminating 120 Ω resistor may be switched on by short-circuiting of the BUS END DIP switches (1, 2). Two LEDs located inside of the housing enable fast diagnostics — power up and communication. 32 LEDs at the inputs indicate the status of each of the inputs separately.

All settings are stored in a EEPROM. The module is equipped by a watchdog.

See domat - Technical application notes for connection examples.

Technical data

Power 24 V AC/DC ± 20 %

Consumption 1 W

Communication Modbus RTU RS485, 1200...115200 bit/s

Galvanic isolation 1 kV

Max. bus length 1200 m

Max. amount of modules on the bus 256

Number of digital inputs 32 × digital input

(logical zero is <5 VAC/DC, logical one is >18 VAC/DC, 7 mA)

Software ModComTool 4.2.3.9 or higher parameters setting,

Merbon IDE, SoftPLC IDE – predefined Modbus devices

Housing polycarbonate box (certification UL94V0)

Elbox 6

Terminals screw terminals M3 (bus, power), M2 (digital inputs)

Dimensions $105.6 \times 98.7 \times 64 \text{ mm}$

Protection degree IP20 (EN 60529)

Recommended wire 0.14...1.5 mm²

Ambient temperature external conditions: -5...45 °C; 5...95 % relative humidity;

non-condensing gases and chemically non-aggressive conditions (according to EN 60721-3-3 climatic class 3K5)

storage: $-5...45\,^{\circ}\text{C}$; $5...95\,\%$ relative humidity; non-condensing gases and chemically non-aggressive conditions

(according to EN 60721-3-1 climatic class 1K3)


Standards conformity EMC EN 61000-6-2 ed.3:2005, EN 61000-6-4 ed.2:2006 +

A1:2010 (industrial environment)

electrical safety EN 60950-1 ed.2:2006 + A11:2009 + A12:2011 + A1:2010 + A2:2014 + Opr.1:2012 + Z1:2016

hazardous substances reduction EN 50581:2012

Terminals



Terminals and connectors

RS485 K+ port COM - serial link RS485, terminals K+ RS485 K- port COM - serial link RS485, terminals K-

G G power supplyG0 G0 power supply

TE optional connection for shielding, technical ground

COM1 common terminals for DI1...DI24 **COM2** common terminal for DI25...DI32

DI1 ... DI32 inputs 1...32

LED indication

RUN orange LED – system cycle (OK: LED flashes periodically

1 s ON, 1 s OFF; ERROR: LED flashes in other pattern, LED

is still ON or OFF)

TxD red LED - RS485 transmitting data at COM (flashing:

transmitting data; OFF: no data traffic)

PWR green LED – power supply (ON: power OK; OFF: no power

applied, weak or damaged power supply, ...)

DIP switches

ADR AUTO – if all switches are OFF, the address is used

according to Modbus register 4 LSB

USER – address is set by DIP switches configuration INIT - if are all switches ON at power-up, configuration

parameters are set to defaults


DIP 8 = bit 0; switches increase their bit weight from

right to left, see below


BUS END

Switch for bus RS485 termination (located at the RS485 connector); ON = bus end; the first and last devices on bus should have bus end ON

Connection



Dimensions




Dimensions are in mm.

Installation

The R430 module is fixed by snapping on standard DIN rail.


When removing the module from the DIN rail proceed as follows: Place a screwdriver in the plastic slot which is in the middle of bottom part of the module (1). Then push the screwdriver upwards (2). After that, the module can be removed by tilting it upwards (3).




Addressing

The Modbus address can be set as follows:

hardwarewise: using DIP switches. The switches increase their bit weight from right to left, see image with example where address of 21 is set by activation of switches 4, 6, and 8 with bit weight of 16, 4, and 1 respectively. Valid settable range is 1 to 254. Address 0 (all switches OFF) means that the address is set as entered in the Modbus table. Address 255 (all switches ON) brings the module to INIT mode, where Modbus address is 1 and communication parameters are set to N, 8, 1, see image below. All changes apply after the module is switched off and on again.





- **softwarewise** using the ModComTool software, available for free at **www.domat.cz**. The default address (factory setting) is 1, default communication parameters are 9600, 8, N, 1. Parity and stopbits can be set in Modbus register 1005 LSB.

The software address is only active if the hardware addressing switch is set to 0.

All changes apply after the module is switched off and on again.

Safety note

The device is designed for monitoring and control of heating, ventilation, and air conditioning systems. It must not be used for protection of persons against health risks or death, as a safety element, or in applications where its failure could lead to physical or property damage or environmental damage. All risks related to device operation must be considered together with design, installation, and operation of the entire control system which the device is part of.

Changes in 09/2017 – First datasheet version.

versions 06/2018 – Minor changes, *Safety note* added.

08/2021 – Stylistic adjustments, change of logo.