Valid from: AR RO M121 8 10 OPU

AB-B8-M12L-8-10,0PUR



Description

17.09.2018

Sensor/actuator box

 Connection methods: rapid interlock with LED master cable, markers and single-assigned slots

• slots: 8, cable length: 10 m





Number of slots:

Nominal voltage U : $_{\mbox{N}}$ 24 V DC Max. current carrying capacity per path: 2 A Total current: \pm 12 A

Connection type: Individual wires

Current carrying capacity per slot: 4 A Number of poles: 4

Degree of protection: IP65/IP67/IP69K

Status display: LEDs Inflammability class acc. to UL 94: V0

Contact surface material:

Material, O-ring:

Material of the moulding mass:

PUR

Material of threaded sleeve: Zinc die-cast
Material of threaded sleeve surface: Nickel-plated
Tightening torque slot sensor/actuator 0.4 Nm

cable

Tightening torque screw plug: 0.4 Nm

Conductor data

Cable types: Master cable suitable for flexible

cable conduit

Outer diameter: 8.5 mm

Conductor structure, voltage supply: 42x0.15 mm

Conductor structure, signal line: 19x0.15 mm

AWG power supply: 19
AWG signal line: 22


Power supply cross section:3x0.75 mm²Signal line cross section:8x0.34 mm²Max. bending cycles:1500000Traversing path:2 mTraversing rate:2 m/s

Slot/position = Wire color or connection: 1 / 4 (A) = WH


Creator: FELI1/PDP Document: DB22260023EN
Released: IVSE1/PDP Version: 04
Page 1 of 3

22260023	DATA SHEET	Ω I ΔPP
Valid from: 17.09.2018	AB-B8-M12L-8-10,0PUR	

Technical drawing




Circuit diagram



Creator: FELI1/PDP	Document: DB22260023EN	Daga 2 of 2
Released: IVSE1/PDP	Version: 04	Page 2 of 3

22260023	DATA SHEET	Ω I ΔPP
Valid from: 17.09.2018	AB-B8-M12L-8-10,0PUR	

Schema drawings



Pin assignment

Slot/ position = Wire color or connection

1 / 4 (A) = WH

2 / 4 (A) = GN

3 / 4 (A) = YE

4 / 4 (A) = GY

5 / 4 (A) = PK

6 / 4 (A) = RD

7 / 4 (A) = BK

8 / 4 (A) = VT

1-8 / 1 (+ 24 V) = BN

1-8 / 3 (0 V) = BU

1-8 / 5 (PE) = GN/YE

Application range

Automation, industrial machinery and plant engineering

Note

Photographs are not true to scale and do not represent detailed images of the respective products.

Creator: FELI1/PDP	Document: DB22260023EN	Dogo 2 of 2
Released: IVSE1/PDP	Version: 04	Page 3 of 3