# **DATASHEET - HL-C10/1**



### Miniature circuit breaker (MCB), 10 A, 1p, characteristic: C

Part no. HL-C10/1 Catalog No. 194729



**Delivery program** 

| 71.3   |                 |    |  |
|--|-----------------|----|--|
| Basic function                                       |                 |    | Miniature circuit-breakers                             |
| Number of poles                                      |                 |    | 1 pole   |
| Tripping characteristic                              |                 |    | C  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 10   |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 4.5  |
| Product range  |                 |    | HL   |

## **Technical data**

#### **Electrical**

| IEC/EN 60898-1 I <sub>cn</sub> kA 4.5 |
|---------------------------------------|
|---------------------------------------|

### **Design verification as per IEC/EN 61439**

| Design verincation as per illo/liv 01455   |                   |    |   |
|--|-------------------|----|---|
| Technical data for design verification   |                   |    |   |
| Rated operational current for specified heat dissipation   | In                | Α  | 10  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0   |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 1.5   |
| Static heat dissipation, non-current-dependent   | $P_{vs}$          | W  | 0   |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0   |
| Operating ambient temperature min.   |                   | °C | -25   |
| Operating ambient temperature max.   |                   | °C | 75  |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity |
| IEC/EN 61439 design verification   |                   |    |   |
| 10.2 Strength of materials and parts   |                   |    |   |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.                                  |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.                                  |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.                                  |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.                                      |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.                                      |
| 10.9 Insulation properties   |                   |    |   |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.                                      |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.                                      |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.                                      |

| 10.10 Temperature rise              | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
|-------------------------------------|--|
| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

#### **Technical data ETIM 7.0**

| Technical data ETIM 7.0  |                    |            |   |  |  |
|--|--------------------|------------|---|--|--|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)   |                    |            |   |  |  |
| Electric engineering, automation, process control engineering / Electrical installa (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | tion, device / Min | iature cir | cuit breaker system (MCB) / Miniature circuit breaker (MCB) |  |  |
| Release characteristic   |                    |            | C   |  |  |
| Number of poles (total)  |                    |            | 1   |  |  |
| Number of protected poles  |                    |            | 1   |  |  |
| Rated current  |                    | A          | 10  |  |  |
| Rated voltage  |                    | V          | 230   |  |  |
| Rated insulation voltage Ui  |                    | V          | 440   |  |  |
| Rated impulse withstand voltage Uimp   |                    | kV         | 4   |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  |                    | kA         | 4.5   |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V $$   |                    | kA         | 4.5   |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V $$  |                    | kA         | 0   |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   |                    | kA         | 0   |  |  |
| Voltage type   |                    |            | AC  |  |  |
| Frequency  |                    | Hz         | 50 - 60   |  |  |
| Current limiting class   |                    |            | 3   |  |  |
| Suitable for flush-mounted installation  |                    |            | Yes   |  |  |
| Concurrently switching N-neutral   |                    |            | No  |  |  |
| Over voltage category  |                    |            | 3   |  |  |
| Pollution degree   |                    |            | 3   |  |  |
| Additional equipment possible  |                    |            | Yes   |  |  |
| Width in number of modular spacings  |                    |            | 1   |  |  |
| Built-in depth   |                    | mm         | 44  |  |  |
| Degree of protection (IP)  |                    |            | IP20  |  |  |
| Ambient temperature during operating   |                    | °C         | -25 - 75  |  |  |
| Connectable conductor cross section multi-wired  |                    | mm²        | 1 - 25  |  |  |
| Connectable conductor cross section solid-core   |                    | mm²        | 1 - 25  |  |  |