## DATASHEET - HL-C20/3N



Miniature circuit breaker (MCB), 20 A, 3p+N, characteristic: C





## **Delivery program**

| Derivery program   |                   |    |   |
|--|-------------------|----|---|
| Basic function   |                   |    | Miniature circuit-breakers  |
| Number of poles  |                   |    | 3 pole+N  |
| Tripping characteristic  |                   |    | С   |
| Application  |                   |    | Switchgear for residential and commercial applications  |
| Rated current  | I <sub>n</sub>    | A  | 20  |
| Rated switching capacity according to IEC/EN 60898-1   | I <sub>cn</sub>   | kA | 4.5   |
|  | ·cn               |    | HL  |
| Product range  |                   |    |   |
| Technical data   |                   |    |   |
| Electrical   |                   |    |   |
| Rated switching capacity according to IEC/EN 60898-1   | I <sub>cn</sub>   | kA | 4.5   |
|  |                   |    |   |
| Design verification as per IEC/EN 61439  |                   |    |   |
| Technical data for design verification   |                   |    |   |
| Rated operational current for specified heat dissipation   | In                | А  | 20  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0   |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 10.1  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0   |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0   |
| Operating ambient temperature min.   |                   | °C | -25   |
| Operating ambient temperature max.   |                   | °C | 75  |
| - Fer can 3 anna an Ann        |                   | -  | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity   |
| IEC/EN 61439 design verification   |                   |    |   |
| 10.2 Strength of materials and parts   |                   |    |   |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.  |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.  |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.  |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.  |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.  |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.  |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.  |
| 10.9 Insulation properties   |                   |    |   |
|  |                   |    | le the nanel huilder's responsibility   |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.  |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.  |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.  |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will<br>provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must b   |

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 7.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| Electric engineering, automation, process control engineering / Electrical installati (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | on, device / Miniature c | ircuit breaker system (MCB) / Miniature circuit breaker (MCB) |
|--|--------------------------|---|
| Release characteristic   |                          | C   |
| Number of poles (total)  |                          | 4   |
| Number of protected poles  |                          | 3   |
| Rated current  | А                        | 20  |
| Rated voltage  | V                        | 230   |
| Rated insulation voltage Ui  | V                        | 440   |
| Rated impulse withstand voltage Uimp   | kV                       | 4   |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  | kA                       | 4.5   |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  | kA                       | 4.5   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   | kA                       | 0   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   | kA                       | 0   |
| Voltage type   |                          | AC  |
| Frequency  | Hz                       | 50 - 60   |
| Current limiting class   |                          | 3   |
| Suitable for flush-mounted installation  |                          | Yes   |
| Concurrently switching N-neutral   |                          | Yes   |
| Over voltage category  |                          | 3   |
| Pollution degree   |                          | 3   |
| Additional equipment possible  |                          | Yes   |
| Width in number of modular spacings  |                          | 4   |
| Built-in depth   | mm                       | 44  |
| Degree of protection (IP)  |                          | IP20  |
| Ambient temperature during operating   | °C                       | -25 - 75  |
| Connectable conductor cross section multi-wired  | mm²                      | 1 - 25  |
| Connectable conductor cross section solid-core   | mm²                      | 1 - 25  |