

Copper Rope Class 2 - Stranded bare copper rope



Application: For use in electrical grounding systems

Construction: The conductor is made of copper wire according to EN 13602:2013 with the characteristics according to EN 60228: 2005 cl.2.

Standards: EN 13602-2013
EN 60228:2005

Cross-section [mm ²]	Number of wires	Outer Diameter (approx.) [mm]	Maximum electrical resistance at 20°C [Ω/km]
25	7	6	0.727
35	7	7.1	0.524
50	7	8.4	0.387
70	19	9.6	0.268
95	19	11.6	0.193