AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: National Flooring Distributors

> 13 Dulwich Street Loganholme QLD 4129

Test Number : 18-006051 **Issue Date** 5/02/2019

Print Date 5/02/2019

3

Mean

Clients Ref: "Discretion" **Sample Description**

Cut pile tufted carpet

Nominal Composition: 100% Nylon

Nominal Mass per Unit Area/Density:

Nominal Thickness: 8mm

AS/ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source

Date of Sample Arrival 10/10/2018 **Date Tested** 01/02/2019

1 Length 11.1 kW/m² Width 9.5 10.8 10.1 10.1 kW/m² Smoke Value 2 3 Mean 1 Length 14 % min Width 13 13 13 13 %.min

2

65oz/yd2

Observations:

CHF Value

Melting Yes

155558 31446 Page 1 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing - Mechanical Testing

: Accreditation No

983



Samples and their identifying descriptions have been provided by the client unless otherwise stated.

Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test

relate only to the sample or samples tested. This document shall not be reproduced except in full and

APPROVED SIGNATORY

. A. JACKSON B.Sc.(Hons)

AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: National Flooring Distributors

> 13 Dulwich Street Loganholme QLD 4129

Test Number : 18-006051 **Issue Date**

5/02/2019

Print Date 5/02/2019

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

155558 31446 Page 2 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing - Mechanical Testing

: Accreditation No.

983



Samples and their identifying descriptions have been provided by the client unless otherwise stated.

Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test

relate only to the sample or samples tested. This document shall not be reproduced except in full and

A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY