

# BRYLAND

## Fire Protection

Pear Tree Lane,  
Dudley, West Midlands  
DY2 0QY  
tel 01384 573350  
www.brylandfire.com

BRITISH APPROVALS FOR FIRE EQUIPMENT. SCHEME: SPI01/ST01 CONTRACT LICENSED. PORTABLE FIRE EXTINGUISHERS

This is to certify that:

# Bryland Fire Protection

Have inspected the portable fire extinguishers at your premises and have carried out a service in accordance with British Standard 5306 Part 3:2017 and to the requirements of BAFE SPI01/ST104

Location Quinton Motor Club

Engineer Name Paul Whittaker

Engineer Signature [Signature]

Date of Service Dec 2021

Next Service Due Dec 2022

### Recommendations to user

Monthly inspection should be made by the user or the user's representative, to make sure that appliances are correctly positioned and have not been tampered with in any way. Checks should also be made to ensure that the appliances have not been discharged or, where indicated by the gauge, lost pressure. In this event, it is advised that you contact Bryland Fire Protection Limited as soon as possible to bring your appliances to a satisfactory standard and maintain the coverage of your fire Risk Assessment.  
*(If you should require a Fire Risk Assessment please call us on 01384 - 573350)*

