



Unit 5, Durban Road Business Centre  
Durban Road  
Bognor Regis  
West Sussex, PO22 9FE

PHONE 01243 827469  
FAX 01243 829418  
E-MAIL sales@actuated-solutions.co.uk  
WEB www.actuated-solutions.co.uk

## Technical Specification

### 1. HQ-003

Model	Max. Torque (Nm)	Rated Current			Electric Motor Stop	Operating time	Bore Size	Base (ISO5211)
		110VAC	220VAC	24VDC				
HQ-003	30	0.12A	0.06A	0.46A	2.0A	12sec	11mm Star	F03/04/05

### 2. STANDARD SPECIFICATION

Enclosure Rated	Weather proof IP67
Motor	24V DC Motor
Supplying Voltage	Multi-Voltage(85~265VAC or 24VDC)
Limit Switches	2 x open/close SPDT, 250 VAC 6A rating
Auxiliary Limit Switches	2 x open/close SPDT, 250 VAC 6A rating
Torque Switch	N/A
Travel Angle	90 degree
Indicator	LED lamp Indicator(Open/Close)
Heater	N/A
Manual Override	Push Button with Manual lever
Conduit Entries	1 X PG11 with 3m flying lead. 11 wires
Ambient Temperature	-20°C ~ + 60°C
External Coating	Polyester Powder Coating
Net weight	1.2Kg
Base and Bore	ISO5211(F03/04/05) & 11mm Double Square

**ACTUATED SOLUTIONS LIMITED**

An ISO 9001 Registered Company  
CQS Certificate No GB2002893



Unit 5, Durban Road Business Centre  
Durban Road  
Bognor Regis  
West Sussex, PO22 9FE

PHONE 01243 827469  
FAX 01243 829418  
E-MAIL [sales@actuated-solutions.co.uk](mailto:sales@actuated-solutions.co.uk)  
WEB [www.actuated-solutions.co.uk](http://www.actuated-solutions.co.uk)

---

---

**ACTUATED SOLUTIONS LIMITED**  
An ISO 9001 Registered Company  
CQS Certificate No GB2002893