



## DIN Rail mounting Hours Run Meter

RS Stock No's:



896-6945, 896-6949 & 896-6958



### ⚠ Caution:-


- Always follow instructions stated in this leaflet.
- Before installation, ensure that the specifications agree with the intended application.
- Installation must be done by skilled electrician.
- Automation and control devices must be installed properly so that they are protected against involuntary actuations.
- Suitable dampers should be provided in the event of excessive vibrations.
- Wrong connection may cause product damage

### Terminal Details:--

 Ø3.5...4.0 mm	0.54 N.m (5 Lb.in) Terminal screw- M2.6
	1 x 0.2...3.3 mm <sup>2</sup> Solid Wire / Single Wire Ferrule
AWG	1 x 24 to 12

Use Cu wire of 60/75°C only.

### OVERALL DIMENSIONS & MOUNTING DETAILS :-



### Connection diagram for AC model

