



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING




Figure 1

AMT4001 (M22520/40-1) CRIMP TOOL FOR TERMINALS, SPLICES, AND ENDCAPS

INTRODUCTION

This datasheet explains the use of Astro's "Crimp Tool for Terminals" AMT4001 (M22520/40-01) (See Figure 1). This tool is intended to crimp

insulated terminals, splices, and endcaps manufactured to AS7928 (MIL-T-7928): including AS25036 (MS25036), AS17143 (MS17143), and AS25274 (MS25274).



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING

GENERAL DESCRIPTION

The AMT4001 crimp tool has color coded handles to help match the color of the terminal, splice, or endcap being crimped with the correct crimp cavity. Additional color code information is on the tool's side plate.

The AMT4001 has an adjustable insulation crimp cavity that can be set at any one of four height settings depending on the insulation diameter of the terminal, splice, or endcap and wire to be crimped.

The spring loaded locators assist in correctly positioning the terminals, splices, or endcaps in the crimp cavity.

The AMT4001 incorporates a tamper proof double action ratchet that once engaged will not release until the handles are closed fully and the crimp completed.

HANDLE AND DOT COLOR CODES

Note that the tools handles are color coded for the size terminal, splice, or endcap being crimped. The color coded terminal, splice, or endcap should be crimped in the corresponding colored cavity. For example, when crimping red coded insulated terminals the red/yellow crimp cavity on the red handle side of the tool should be used.

CRIMPING PROCEDURE

1. Strip wire to the dimension specified by the terminal, splice, or endcap manufacturer.
2. If the die cavity is not already open, close the tool handle until the ratchet releases and the die cavity opens.
3. Place the color coded terminal, splice, or endcap into the proper cavity of the crimp dies, so that the terminal tongue slides under the locator, the splice window slides under the locator, or endcap end rests against the recess in the locator.
4. Close the tool handles until the terminal, splice, or endcap is held in place, but not crimped.
5. Insert the stripped wire into the terminal until the conductor butts against the locator. Or insert the stripped wire into the splice or endcap until the conductor butts against the internal stop of the splice or endcap.
6. Hold the wire in position and complete the crimp by closing the handles fully until the ratchet releases.
7. If crimping a splice, rotate splice 180 degrees and repeat steps 3-6.



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING

INSULATION CRIMP ADJUSTMENT

Each tool has four insulation crimp positions.
(See Figure 1) To set the Insulation Crimp Height:

1. Loosen the insulation adjustment locking screw, and turn the indicator to position 4. (See Figure 1)
2. Load the terminal or splice into the crimp cavity.
3. Insert an un-stripped wire into ONLY the insulation barrel of the terminal or splice.
4. Perform a crimp, and remove the crimped terminal or splice.
5. Bend the wire back and forth once. The terminal or splice should retain a grip on the wire insulation.
6. If the wire pulls out, adjust to the next descending insulation crimp position.
7. Perform another crimp, and recheck the wire grip.
8. Repeat the adjustment as necessary until wire is gripped. DO NOT use a tighter setting than required.

9. Retighten the insulation adjustment locking screw.

INSPECTION AND GAGING

Astro recommends the user inspect and gage the tool periodically to ensure dependable and uniform terminations. Frequency of inspection and gaging is determined by the end user to suit their requirements through experience. Frequency of inspection and gaging is dependent upon:

1. The care, amount of use, and handling of the tool.
2. The type and size of the products being crimped.
3. The degree of operator skill.
4. The presence of abnormal amounts of dust, and dirt.
5. The user's own established standards.

GAGING THE CRIMP CAVITIES

<i>MS Part Number</i>	<i>Astro Part Number</i>	<i>Gage Type</i>	<i>Wire Size (AWG)</i>	<i>Gage Area</i>
M22520/43-01	AMTG4301	GO/NO-GO	22-16	Red Conductor Cavity
M22520/43-02	AMTG4302	GO/NO-GO	16-14	Blue Conductor Cavity
M22520/43-03	AMTG4303	GO/NO-GO	22-16	Red Insulation Cavity
M22520/43-04	AMTG4304	GO/NO-GO	16-14	Blue Insulation Cavity



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING

CONDUCTOR CAVITY

1. Close the tool handles fully, and hold them firmly closed.
2. Insert the appropriately sized GO gage (Green) member under the locator and into the conductor cavity, of the die (Red or Blue) you are trying to gage (See Figure 2).
3. The GO gage member should freely enter the die.
4. Attempt to insert the NO-GO gage (Red) member under the locator and into the conductor cavity, of the die (Red or Blue) you are trying to gage (See Figure 2).
5. The NO-GO gage (Red) member may enter slightly into the die cavity, but should not pass fully through the cavity. If the NO-GO gage (Red) member does enter the cavity fully, the die is worn and should be replaced.




FIGURE 2

**CAUTION: DO NOT CRIMP THE GAGE MEMBER.
DOING SO MAY SERIOUSLY DAMAGE THE DIE SET!**



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING

INSULATION CAVITY

1. With the Insulation Adjustment Indicator on setting #1, close the tool handles fully, and hold them firmly closed.
2. Insert the appropriately sized GO gage (Green) member into the insulation cavity, of the die (Red or Blue) you are trying to gage (See Figure 3).
3. The GO gage (Green) member should freely enter the die.
4. With the Insulation Adjustment Indicator on setting #4, close the tool handles fully, and hold them firmly closed.
5. Attempt to insert the NO-GO gage (Red) member into the insulation cavity, of the die (Red or Blue) you are trying to gage (See Figure 3).
6. The NO-GO gage (Red) member may enter slightly into the die cavity, but should not pass fully through the cavity. If the NO-GO gage (Red) member does enter the cavity fully, the die is worn and should be replaced.




FIGURE 3

**CAUTION: DO NOT CRIMP THE GAGE MEMBER.
DOING SO MAY SERIOUSLY DAMAGE THE DIE SET!**



ASTRO TOOL CORP.

CONNECTOR ASSEMBLY TOOLING

MAINTENANCE

Astro offers complete refurbishing, and recalibration services.

Astro strongly recommends that you:

1. DO NOT immerse the tool in cleaning solution.
2. DO NOT spray oil into the tool to lubricate it.
3. DO NOT attempt to disassemble the tool, or make repairs.

This is a precision crimp tool, and should be handled as such.

This hand tool must not be used in any powered "press" as defined by OSHA CFR 1910.211 (46)

Limitation of Liability

ASTRO TOOL CORPORATION IS NOT LIABLE FOR CONSEQUENTIAL OR SPECIAL DAMAGES OF ANY NATURE OR KIND RESULTING FROM THE USE, OR MISUSE, OF ANY OF ITS PRODUCTS. OWNERS AND USERS OF ASTRO PRODUCTS ASSUME FULL RESPONSIBILITY FOR INSTRUCTING THEIR EMPLOYEES IN THE PROPER AND SAFE USE OF SUCH PRODUCTS.

Limited Liability

Astro Tool Corporation (Astro) warrants each new product sold by it to be free from defects in material and workmanship under normal use and service. Astro's obligation under this warranty is limited to the free correction or, at Astro's option, the refund of the purchase price of any such product which proves defective in normal service within ninety (90) days after delivery to the first user, provided that the product is returned to Astro with all transportation charges prepaid and which shall appear to Astro's satisfaction, after Astro's inspection, to have been defective in material and workmanship, it being understood that Astro products are not consumer products. This warranty shall not cover any damage to any product which, in the opinion of Astro, was caused by normal wear, misuse, improper operation, tampering, neglect or accident. This warranty is in lieu of all other warranties express or implied. No warranty, express or implied, is made or authorized to be made or assumed with respect to products of Astro Tool Corporation other than those herein set forth.