



- 1.) Strip conductors 8mm.
- 2.) Insert stripped wire into screw-in pin, tighten. [2.0 Nm]
- 3.) Type 600VAC

Number of cond.	AWG Size
3	8

- 4.) A Marking: Not for interrupting current

The RS PRO Seal of Approval is only awarded after a rigorous quality process to demanding international standards.