



Certificate of Test

We hereby declare that the item described below
has been tested by BSI and
complies with the requirements of
BS EN 60529:1992, IEC 529:1989, DIN VDE 0470 TEIL 1/11/92 Specification for degrees of
protection provided by enclosure for a classification of IP67 (Dust tight/Temporary immersion)

The full details of the tests and the results are given
in our Report No: LS001786 Dated: 30 October 1996
Issue 2


Description of item tested:

One 32 mm stainless steel conduit inspection T piece
being representative of the range of 20mm, 25mm and 32mm conduit fittings

Submitted by:

Electrix (Northern) Ltd
1A, 1B South Church Industrial Estate
Bishop Auckland
County Durham
DL14 6XP

Certificate authorized by:


R M Rollason
Title Senior Engineer - Lighting Technology Laboratory
Date 30 October 1996



Attention is drawn to the conditions upon which this declaration is issued, namely:

1 The general and specific conditions of the BSI Testing House, Test Leader II apply in all respects. Copies of this leaflet are available on request.

2 This Declaration applies only to the particular sample tested and to the specific tests carried out as detailed in the report referred to above.
3 This declaration does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.