



## GOVERNMENT OF WEST BENGAL

Health & Family Welfare Department

### SANITARY CONDITION CERTIFICATE

Date: 30-10-2019

It is certified that the NARAYANA SCHOOL BARASAT, 43/1 GHOLA ROAD, MADHYAMGRAM, NORTH 24 PARAGANAS, PIN: 700124, WEST BENGAL (run and managed by Rama Narayana Education Trust) has and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of 1 (one) year from the date of issuing of the certificate.

*[Signature]*  
Office of the Dy. CMOH-II  
Salt Lake, Kolkata

Chief Medical Officer of Health  
SwasthyaBhawan,  
Sector V  
Salt Lake  
Kolkata -700091  
(Deputy CMOH-II)

TO  
NARAYAN SCHOOL, BARASAT  
C/O RAMA NARAYANA EDUCATION TRUST  
43/1 GHOLA ROAD  
MADHYAMGRAM  
North 24 Parganas  
Kolkata-700124



## GOVERNMENT OF WEST BENGAL

### OFFICE OF THE ASSISTANT ENGINEER ,P.H.E.Dte

Barrackpore,

Barrackpore -700122

Memo No. 5632.KWB

Dated, Kolkata, the 06/11/2019

To

**Narayana School Barasat  
43/1 Ghola Road, Madhyamgram,  
North 24 Paraganas,  
WB: 700124**

Sub: Submission of result of **Chemical & Bacteriological** analysis of water sample of "Narayana School in Barasat"

Sample received from **NARAYANA SCHOOL BARASAT, 43/1 GHOLA ROAD, MADHYAMGRAM, NORTH 24 PARAGANAS, PIN: 700124, WEST BENGAL.**

Samples collected by concerned authority

Sample received on 16.10.2019

Ref: Your letter dated on 22.10.2019

Dear Sir / Madam,

As desired by you vide your letter I am submitting herewith the result of Chemical & Bacteriological analysis of water sample of above subject in original. In this connection it may be stated herewith that the approved charges for the testing of water sample amounting to Rs.1400.00(Rupees one thousand four hundred only)received by the Office of the Executive Engineer,P.H.E. Dte. Vide money receipt No. 3251 dt. 22.10.2019.

Thanking You,

Enclosed : Result sheet

Copy forwarded for information to :-

1. The Executive Engineer

Yours faithfully\*

Office of the Executive Engineer  
North 24 Parganas Division  
Assistant Engineer

Kolkata, P.H.E. Dte.

Kolkata, P.H.E. Dte.

Dated, Kolkata, the 06/11/2019

GOVERNMENT OF WEST BENGAL  
OFFICE OF THE ASSISTANT ENGINEER ,P.H.E.Dte

Barrackpore -700122

**Result of chemical & Bacteriological analysis of water sample**

Water sample of -----

Narayana School Barasat

Sample received from -----

Narayana School Barasat

43/1 Ghola Road, Madhyamgram,

North 24 Parganas,

WB: 700124.

Sample collected by -----

Concern Authority.

Sample Received on -----

16.10.2019

Sample Reference No.-----

5632

Parameters	Observed Value	Limits as per IS 10500-2012 (Second Revision)	
		Acceptable Limit	Permissible Limit
<b>Chemical Analysis</b>			
pH Value	7.98	6.5 to 8.5	6.5 to 8.5
Turbidity(NTU)	0.04	1	5
Total Dissolved Solids(mg/l)	241	500	2000
Total Hardness as CaCO(mg/l)	211	200	600
Iron(mg/l)	0.07	0.03	1.00
Manganese(mg/l)	0	0.10	0.30
Arsenic(mg/l)	0.000	0.01	0.05
<b>Bacteriological analysis</b>			
Total Coliform Count (CFU/100 ML)	0	0	0
E.coli Count (CFU/100 ML)	0	0	0

*D. Larson*

Office of the Executive Engineer

North 24 Parganas Division

Assistant Engineer

Kolkata,

P.H.E. Dte.

Chemical / Bactriologist

Kolkata. Laboratory

P.H.E. Dte.