



## ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 700

Date - 27/11/2024

### FIRE SAFETY CERTIFICATE

Certified that the Narayana E-Techno School (name of the building or Premises) at S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (address) Comprised of Ground + 6th floors owned / occupied by Narayana E-Techno School, S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 06/11/2024 (date of inspection) in the presence of Sai Safety System (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X / XII) With effect from 25.11.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- |                                     |       |                                    |       |
|-------------------------------------|-------|------------------------------------|-------|
| 1. Single Hydrant Valve             | - Yes | 8. ABC Fire Extinguisher 6Kg Cap.  | - Yes |
| 2. Double Hydrant Valve             | - Yes | 9. CO2 Fire Extinguisher 4.5Kg Cap | - Yes |
| 3. Hose Reel Drum Complete Set      | - Yes | 10. Main Hydrant Pump              | - Yes |
| 4. 4 way fire brigade inlet         | - Yes | 11. Main Sprinkler Pump            | - Yes |
| 5. Fire Alarm Pannel With PA System | - Yes | 12. Sprinkler Jockey Pump          | - Yes |
| 6. MCP With Hooter                  | - Yes | 13. Fire Pump Control Panel        | - Yes |
| 7. Smoke Detector                   | - Yes | 14. Sprinkler                      | - Yes |

Issued on 25 / 11 / 2024 (date of issue) at Thane (place) by

Signature with seal: -----

Name : **Mr. Girish. M. Zalke**

Designation : **Chief Fire Officer, Thane**

Name & Address of Department/ Office : **Chief Fire Officer, Thane**  
**Municipal Fire Brigade, Thane.**

To

Narayana E-Techno School  
S.no 47/1,6,8,9 & 48/1B,1C,1D&1E,  
Dhokali Village, Thane (w) – 400608.  
(Name & Address of the Institution)

### ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)



# ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 559


Date - 08/11/2023

## FIRE SAFETY CERTIFICATE

Certified that the Narayana E-Techno School (name of the building or Premises) at S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (address) Comprised of Ground + 6th floors owned / occupied by Narayana E-Techno School, S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24/08/2023 (date of inspection) in the presence of Jivdani Fire Services (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X / XII) With effect from 06.11.2023 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- |                                     |       |                                    |       |
|-------------------------------------|-------|------------------------------------|-------|
| 1. Single Hydrant Valve             | - Yes | 8. ABC Fire Extinguisher 6Kg Cap.  | - Yes |
| 2. Double Hydrant Valve             | - Yes | 9. CO2 Fire Extinguisher 4.5Kg Cap | - Yes |
| 3. Hose Reel Drum Complete Set      | - Yes | 10. Main Hydrant Pump              | - Yes |
| 4. 4 way fire brigade inlet         | - Yes | 11. Main Sprinkler Pump            | - Yes |
| 5. Fire Alarm Pannel With PA System | - Yes | 12. Sprinkler Jockey Pump          | - Yes |
| 6. MCP With Hooter                  | - Yes | 13. Fire Pump Control Panel        | - Yes |
| 7. Smoke Detector                   | - Yes | 14. Sprinkler                      | - Yes |

Issued on 06 / 11 / 2023 (date of issue) at Thane (place) by



Signature with seal: -----

Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane  
Municipal Fire Brigade, Thane.

To

Narayana E-Techno School  
S.no 47/1,6,8,9 & 48/1B,1C,1D&1E,  
Dhokali Village, Thane (w) – 400608.  
(Name & Address of the Institution)

## ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)



# ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE .

Ref/T.M.C./CFO/M - ५५९


Date - ०८/११/२०२३

## FIRE SAFETY CERTIFICATE

Certified that the Narayana E-Techno School (name of the building or Premises) at S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400607. (address) Comprised of Ground + 6th floors owned / occupied by Narayana E-Techno School, S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400607. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24/08/2023 (date of inspection) in the presence of Jai Jivdani Fire Services (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X /XII) With effect from 06.11.2023 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- |                                     |       |                                    |       |
|-------------------------------------|-------|------------------------------------|-------|
| 1. Single Hydrant Valve             | - Yes | 8. ABC Fire Extinguisher 6Kg Cap.  | - Yes |
| 2. Double Hydrant Valve             | - Yes | 9. CO2 Fire Extinguisher 4.5Kg Cap | - Yes |
| 3. Hose Reel Drum Complete Set      | - Yes | 10. Main Hydrant Pump              | - Yes |
| 4. 4 way fire brigade inlet         | - Yes | 11. Main Sprinkler Pump            | - Yes |
| 5. Fire Alarm Pannel With PA System | - Yes | 12. Sprinkler Jockey Pump          | - Yes |
| 6. MCP With Hooter                  | - Yes | 13. Fire Pump Control Panel        | - Yes |
| 7. Smoke Detector                   | - Yes | 14. Sprinkler                      | - Yes |

Issued on 06 / 11/ 2023 (date of issue) at Thane (place) by



Signature with seal: \_\_\_\_\_

Name : Mr. Girish M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane  
Municipal Fire Brigade, Thane.

To


**Narayana E-Techno School**  
S.no 47/1,6,8,9 & 48/1B,1C,1D&1E,  
Dhokali Village, Thane (w) – 400607.  
 (Name & Address of the Institution)

## ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)



Phone No. 25331211

25331590


Thane Municipal Corporation Thane

Municipal Corporation Building, Sarsenani General Arunkumar Vaidya Road, chandanwadi  
Panchpakhadi, thane 400602

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref: T.M.C./CFO/M - S7  
27/11/2024

Date



FIRE SAFETY CERTIFICATE

Certified that the Narayana E-Techno School (name of the building or premises) located at S.no 47/1,6,8,9 & 48/1B, 1C, 1D & 1E, Dhokali Village, Thane (W) - 400608 (address), Comprised Ground + 6 floors, owned/occupied by Narayana E-Techno School, S.no 47/1,6,8,9 & 48/1B, 1C, 1D & 1E, Dhokali Village, Thane (W) - 400608 (name of institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rule, and verified by the officers concerned of Fire Service on 24/08/2023 (date of inspection) in the presence of Jai Jivdani Fire Services (name and addresses of the Manager / Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X / XII) With effect from 27.11.2024 for a period of One year on accordance with rule and subject to compliance of specific conditions as appended :-

- |                                      |     |   |     |
|--------------------------------------|-----|---|-----|
| 1. Single Hydrant Valve -            | Yes | 8. ABC Fire Extinguisher (6kg capacity) -   | Yes |
| 2. Double Hydrant Valve -            | Yes | 9. CO2 Fire Extinguisher (4.5kg capacity) - | Yes |
| 3. Hose Reel Drum Complete Set -     | Yes | 10. Main Hydrant Pump -                     | Yes |
| 4. 4-Way Fire Brigade Inlet -        | Yes | 11. Main Sprinkler Pump -                   | Yes |
| 5. Fire Alarm Panel with PA system - | Yes | 12. Sprinkler Jockey Pump -                 | Yes |
| 6. MCP with Hooter -                 | Yes | 13. Fire Pump Control Panel -               | Yes |
| 7. Smoke Detector -                  | Yes | 14. Sprinklers -                            | Yes |

Issued on 25/11/2024 at Thane by:

Name : Mr. Girish M. Zalke

Designation : Chief Fire Officer, Thane

Office Address: Chief Fire Officer, Municipal Fire Brigade, Thane.

ENDORSEMENT

This Fire Safety Certificate is subject to the submission of Form B every six months as per the Maharashtra Fire Prevention & Life Safety Act, 2006.

Failure to comply with fire safety norms laid by the state government will result in the certificate being cancelled.

10 DEC 2024

ATTESTED BY ME  
A. P. PANDEY  
NOTARY  
Maharashtra  
(Govt of India)

Transliterated by  
S. Goyal



Scanned with OKEN Scanner



## ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, मर्गसेनानी जनरल अरणकूमार वेद्य मार्ग, चंदनवाडी पांचपालाडी, ठाणे 400 602  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 700


Date - 27/11/2024

### FIRE SAFETY CERTIFICATE

Certified that the Narayana E-Techno School (name of the building or Premises) at S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (address) Comprised of Ground + 6th floors owned / occupied by Narayana E-Techno School, S.no 47/1,6,8,9 & 48/1B,1C,1D&1E, Dhokali Village, Thane (w) – 400608. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 06/11/2024 (date of inspection) in the presence of Sai-Safety System (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X / XII) With effect from 25.11.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- |                                     |       |                                    |       |
|-------------------------------------|-------|------------------------------------|-------|
| 1. Single Hydrant Valve             | - Yes | 8. ABC Fire Extinguisher 6Kg Cap.  | - Yes |
| 2. Double Hydrant Valve             | - Yes | 9. CO2 Fire Extinguisher 4.5Kg Cap | - Yes |
| 3. Hose Reel Drum Complete Set      | - Yes | 10. Main Hydrant Pump              | - Yes |
| 4. 4 way fire brigade inlet         | - Yes | 11. Main Sprinkler Pump            | - Yes |
| 5. Fire Alarm Pannel With PA System | - Yes | 12. Sprinkler Jockey Pump          | - Yes |
| 6. MCP With Hooter                  | - Yes | 13. Fire Pump Control Panel        | - Yes |
| 7. Smoke Detector                   | - Yes | 14. Sprinkler                      | - Yes |

Issued on 25 / 11 / 2024 (date of issue) at Thane (place) by

Signature with seal: ----- 

Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane  
Municipal Fire Brigade, Thane.

To

Narayana E-Techno School  
S.no 47/1,6,8,9 & 48/1B,1C,1D&1E,  
Dhokali Village, Thane (w) – 400608.  
(Name & Address of the Institution)

### ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)