



Office of the District Fire Officer, Hebbal Fire Station,
Karnataka Fire & Emergency Services,
Manyata Embassy Business Park, Nagawara Ring Road,
Bengaluru-560 045.



No.11/DFO/HBFS/2024

Dated: 12-02-2024.

ANNEXURE – B
Group - B Educational Building

To,
The Secretary,
Narayana E-Techno School,
Sy.No. 86/4, Chalakere Village,
K R Puram Hobli,
Bangalore- 560043
Sir,

Sub : Issue of "**Renewal of Fire Safety Compliance report**" with respect to fire prevention, fire fighting and evacuation measures required at "Narayana E-Techno School" situated at Sy.No. 86/4, Chalakere Village, K R Puram Hobli, Bangalore-560043.

Ref : 1) This Office fire safety Compliance report No.02/DFO/HBFS/2023
Dated: 14-01-2023.
2) Your request letter dated: 08-02-2024.
3) DFO Hebbal Compliance report No.11/DFO/HBFS/2023.Dated:12-02-2024.


<<<>>>

With reference to the subject cited (1) above, a fire safety Compliance report was issued for Narayana E-Techno School situated at Sy.No. 86/4, Chalakere Village, K R Puram Hobli, Bangalore-560043.

In your letter cited in reference (2) above, it is informed that all the recommendations stipulated in Fire safety recommendation has been fulfilled & hence requested to issue "**Renewal of Fire Safety Compliance report**" In this regard the building was inspected by me on 12-02-2024 to check the compliance of all the recommendations stipulated in Fire safety recommendation & Submitted the Compliance report cited in reference (3) above & recommended to issue Compliance certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "**Renewal of Fire Safety Compliance report**" to Narayana E-Techno School situated at Sy.No. 86/4, Chalakere Village, K R Puram Hobli, Bangalore-560043. Subject to proper maintenance of fire fighting measures & fire fighting installations in good working condition, and to impart training for 40% of employees/staff in basic fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bangalore within 90 days from the date of issue of this report. "**This report is valid for one year from the date of issue up to 11-02-2025 and is renewable without fail.**"

Yours faithfully,


DISTRICT FIRE OFFICER 12/2/24
Hebbal Fire Station
Bengaluru - 560045

