



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SP/1009

27/04/2024

Dated: 26 APRIL 2024

It is certified that an inspection team headed by DR. Unawane B.G.

(Name of Officers with designation) from Corporation

(Name of Department/ Office) inspected the NARAYANA E TECHNO SCHOOL, SURVEY NO. 42, NEAR KAMALNAYAN BAJAJ HOSPITAL, SATARA PARISAR, AURANGABAD. TALUKA. DISTRICT: AURANGABA 431005

(Name & Address of the school) on 26/04/2024(date of inspection) and found that the NARAYANA E TECHNO SCHOOL AURANGABAD 431005....(Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 26/04/2024 TO 26/04/2025 (ONE YEAR)

Signature with Seal:

Name : DR. Unawane B.G.

Designation : medical officer


Name & Address of the Office / Department :

To

PRINCIPAL
 NARAYANA E TECHNO SCHOOL, AURANGABAD 431 005
 Survey No. 42, Near Kamalnayan Bajaj Hospital,
 Satara Parisar, Aurangabad, Tal. Dist.Aurangabad.
 (Name & Address of the Institution)

वैद्यकीय अधिकारी
 शहरी आरोग्य वर्धनी केंद्र सातारा
 महानगरपालिका, छत्रपती चंभांडीनगर

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



APPENDIX XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SP/1009

27/04/2024


Dated: 26 APRIL 2024

It is certified that an inspection team headed by DR. Unawane B.G.
(Name of Officers with designation) from Corporation

(Name of Department/ Office) inspected the HOSPITAL, SATARA PARISAR, AURANGABAD TALUKA, DISTRICT: AURANGABA
431005

(Name & Address of the school) on 26/04/2024 (date of inspection) and found that the
NARAYANA E TECHNO SCHOOL AURANGABAD 431005 (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of 26/04/2024 TO 26/04/2025 (ONE YEAR)


Signature with Seal: 

Name

DR. Unawane B.G.

Designation

Medical Officer



Name & Address of the Office / Department: 

वैद्यकिय अधिकारी
शहरी आरोग्य वर्धनी केंद्र सातारा
महानगरपालिका, उत्तरपंथी संभाजीनगर

To

PRINCIPAL.....
NARAYANA E TECHNO SCHOOL, AURANGABAD 431 005
Survey No. 42, Near Kamalnayan Bajaj Hospital,
Satara Parisar, Aurangabad, Tal. Dist. Aurangabad.
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
translated notarized version in English be uploaded along with the original vernacular certificate
as a single pdf.



Attested

28/04/2024

ADV. ZULPNEKHAR S. BAGWAN
NOTARY GOVT. OF INDIA
Aurangabad Dist.
Regd. No. 11132
ADV. Zulpnekhara S. Bagwan
Notary, Govt. of India
Aurangabad Dist.
Reg. No. 11132



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SP/1009

27/04/2024

Dated: 26 APRIL 2024

It is certified that an inspection team headed by DR. Unawane B.G

(Name of Officers with designation) from Corporation

(Name of Department/ Office) inspected the NARAYANA E TECHNO SCHOOL, SURVEY NO. 42, NEAR KAMALNAYAN BAJAJ HOSPITAL, SATARA PARISAR, AURANGABAD TALUKA. DISTRICT: AURANGABA 431005

(Name & Address of the school) on 26/04/2024(date of inspection) and found that the NARAYANA E TECHNO SCHOOL AURANGABAD 431005....(Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 26/04/2024 TO 26/04/2025 (ONE YEAR)

Signature with Seal:

Name

: DR. Unawane B.G

Designation

: medical officer

Name & Address of the Office / Department:

To

PRINCIPAL
 NARAYANA E TECHNO SCHOOL, AURANGABAD 431 005
 Survey No. 42, Near Kamalnayan Bajaj Hospital,
 Satara Parisar, Aurangabad, Tal. Dist.Aurangabad.
 (Name & Address of the Institution)

वैद्यकीय अधिकारी
 शहरी आरोग्य वर्धनी केंद्र सातारा
 महानगरपालिका, उत्तरपश्चिमी संभागीय नगर

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

APPENDIX-XIII



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SP/1009

Dated: 27/04/2024

It is certified that an inspection team headed by **DR. Unawane B.G** (Name of Officers with designation) from **Corporation** (Name of Department/ Office) **NARAYANA E TECHNO SCHOOL, SURVEY NO. 42, NEAR KAMALNAYAN BAJAJ** inspected the **HOSPITAL, SATARA PARISAR, AURANGABAD TALUKA.DISTRICT: AURANGABA 431005** (Name & Address of the school) on **26/04/2024** (date of inspection) and found that the **NARAYANA E TECHNO SCHOOL, AURANGABAD 431005....** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of **26/04/2024-TO-26/04/2025 (ONE YEAR)**.



Signature with Seal:

Name: **DP. Unawane B.G**

Designation: **Medical Officer.**

Name & Address of the Office /

Department:

Medical Officer

Urban Health Promotion Centre Satara
Municipal Corporation, Chatrapati Sambhaji Nagar

To

PRINCIPAL....

NARAYANA E TECHNO SCHOOL, AURANGABAD 431 005 Survey. No. 42. Near Kamalnayan

Bajaj Hospital. Satara Parisar, Aurangabad, Tal. Dist. Aurangabad.

(Name & Address of the Institution)

ATTESTED BY ME

5-7-24

ADV. SUDHAKAR H. SALVE

Advocate, Notary Public, Notary Govt. of India, Reg. No. 15852, Railway Station, Aurangabad

Adv. S. H. Salve, M.A., LL.B.

* The filled-up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Adv. S. H. Salve

M.A., LL.B.

Adv. S. H. Salve

M.A., LL.B.

Adv. S. H. Salve



GOVERNMENT OF MAHARASHTRA

Maharashtra State Public Health Services

Regional Public Health Laboratory, Chhatrapati Sambhajinagar 431002
Officer In-charge, Nijam bangla, Containment Area, Chhawani Chhatrapati Sambhajinagar (M.S.)

E-mail - rphlabd@gmail.com

Phone/ Fax : (0240)2991876

No.RPHL/Chh.SambajiNgr/Water/

3501

Dtd. 30 / 07 / 2024

Report of Sample : water sample

**Sent by : Narayana eTechno School, Gut No. 42, Beed Bypass,
Chhatrapati Sambhajinagar.**

Date of Collection 26/07/2024

Date of Receipt 26/07/2024

Date of Exam 26/07/2024 onwards

With reference to letter No. ---

Lab.Ref.No.P66

Fees: Rs. 600/- Receipt No. 7366276

(Analytical Result in mg/litre (except pH and Turbidity)


Sr. N o	Tests	R O Water	BIS Specification 10500:2012	
			Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear	---	---
2	Colour	Colourless	Colourless	Colourless
3	Odour	Odourless	Agreeable	Agreeable
4	Turbidity (as N.T.U.)	0.23	1.0	5.0
5	pH	7.2	6.5 to 8.5	No relaxation
6	Chloride (as Cl)	50	250	1000
7	Nitrates (as NO ₃)	---	45	No relaxation
8	Total Hardness	54	200	600
9	Alkalinity (as CaCO ₃)	62	200	600
10	Total Dissolved Solids	140	500	2000
11	Iron (as Fe)	0.02	1.0	No relaxation
12	Fluoride (as F)	0.01	0.16	1.5

REMARKS:- Above submitted Water sample is chemically fit for drinking as per BIS – Specification 10500-2012 and after ascertaining its bacterial quality.

NOTE : This laboratory has not collected sample (s).The results of analysis contained in this report relate only to the sample(s) submitted by party.

Forwarded with compliments to

Narayana eTechno School, Gut No. 42, Beed Bypass,
Chhatrapati Sambhajinagar.


Officer incharge CI-1
Regional Public Health Laboratory
Chhatrapati Sambhajinagar