



SALEM CITY MUNICIPAL CORPORATION SANITARY CERTIFICATE

ROC: F1/907/2024

Date:01.08.2024

This is to certify that NARAYANA E-TECHNO SCHOOL, Nagarmalai Adivaram Road, Reddiyur, Salem – 636 004 has been inspected. The building, the premises and the accommodation provided for the inmates is sufficient.

- It is properly ventilated and lighted,
- The building is maintained in substantial repair,
- It is neat and clean,
- The supply of drinking water is wholesome,
- In all other necessary respects the sanitation is good.

This certificate is valid for a period of one year from the date of issue and Subject to the following Conditions:

1. One time use throw away plastic banned by Govt. should not be used.
2. One Sanitary worker should be appointed on rotation to keep the toilet clean at all times
3. The general instructions given in the annexure has to be followed scrupulously without any lapses.
4. Dengue (Aedes) free campus certification has to be submitted every Thursday.
5. The following sticker should be affixed on the building walls.

“NO SMOKING AREA SMOKING HERE IS AN OFFENCE”
under section 4 of COTPA 2003

The certificate is liable to be cancelled if the conditions given in Annexure-I&II as guidelines for preventing COVID-19 & Dengue are not satisfied within 1 month of issuing or if there is violation of rules on subsequent inspection.

This Certificate is valid till **31.07.2025** only.




City Health Officer,
Salem City Municipal Corporation.


1/8/24



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
TWAD Board, No.397,ANBU NAGAR GORIMEDU,SALEM – 636 008.
Phone: 0427-240567
E-mail: twadboardsalem@gmail.com

TEST REPORT

Sample Receipt No/Date :	59735-59736/Dt.12.06.2024
Invoice Details :	7127/Dt.12.06.2024
Customer Name and Address :	The Principal , Narayana e-Techno School,SF.No:28/4, Nagaramalai Adivaram Road, Reddiyur Village, Salem-4.
Test Commenced on :	12.06.2024
Test Completed on :	13.06.2024
Test Report Date :	14.06.2024
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	Bore Well Water.
Location :	Bore Well Water @ Narayana e-Techno School ,Salem.
Sample drawn by/Date :	Customer/Dt.12.06.2024
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
The test result of sample received is as follows.	

S.No	I. CHEMICAL EXAMINATION	Method of Testing	Unit	Sample No.	Specification as per IS 10500 : 2012
				59735 Result	Permissible Limit
1	pH at 25°C	IS 3025 Part 11-1983	-	7.57	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025-Part 23-1986	mg/L	472	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009	mg/L	500	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	148	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	92	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO2 B	mg/L	30	45
7	Fluoride as F	APHA 23rd Edition 2017 – 4500- F-D	mg/L	0.8	1.5

.....End of the report.....


Authorised Signatory,
TWAD Board, R.W.S,
Salem.

Note:

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

TWAD Board, No.397 ANBU NAGAR GORIMEDU,SALEM-636 008.

Phone: 0427 - 2405687

E-mail: twadboardsalemlab@gmail.com

TEST REPORT

Sample Receipt No/Date :	59735-59736/Dt.12.06.2024
Invoice Details :	7127/Dt.12.06.2024
Customer Name and Address :	The Principal , Narayana e-Techno School,SF.No:28/4, Nagaramalai Adivaram Road, Reddiyur Village,Salem-4.
Test Commenced on :	12.06.2024
Test Completed on :	13.06.2024
Test Report Date :	14.06.2024

SAMPLE DETAILS FURNISHED BY CUSTOMER

Source :	Bore Well Water.
Location :	Bore Well Water @ Narayana e-Techno School ,Salem.
Sample drawn by/Date :	Customer/Dt.12.06.2024
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
Appearance, Colour, Odour :	Clear/Colourless/Agreeable.

The test result of sample received is as follows.

S.No	<u>I. Physical Examination</u>	Method of Testing	Unit	Sample No.	Specification as per IS 10500 : 2012
				59735 Result	Permissible Limit
8	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	5
9	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	1137	2000
10	Electrical Conductivity	APHA 23 rd Edition 2017 - 2510 B	µS/cm	1624	-
<u>II. Chemical Examination</u>					
11	Ph. Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	0	-
12	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	104	200
13	Magnesium as Mg	APHA 23rd Edition 2017- 3500 Mg B	mg/L	58	100
14	Sodium as Na	APHA 23rd Edition 2017 - 3500 Na B	mg/L	-	-
15	Potassium as K	APHA 23rd Edition 2017 - 3500 K B	mg/L	-	-
16	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0.00	1
17	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.3
18	Free Ammonia as NH ₃	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.00	0.5
19	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO3 B	mg/L	0.00	-
20	Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.00	-
21	Free residual chlorine	BIS 10500:2012	mg/L	0.00	-
<u>III. Bacteriological Examination</u>				59736	
22	Feecal Coliform per 100 ml	IS/APHA	CFU	0	0

.End of the report.....



Authorised Signatory,
TWAD Board,R.W.S,
Salem.

Note:

1. The test results relate only to the tested sample.