



PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 67/2024-2025

Date : 18/04/2024

It is certified that an inspection team headed by Dr. Pooja R. Jadhav (Name of Officers

with designation) from PRIMARY HEALTH CENTRE LIMBGAON (Name of Department/Office) inspected the NARAYANA E-TECHNO SCHOOL

S. NO 212/A WADI (BK) NANDED TO NANDED DIST NANDED (Name & Address of the School) on 18/04/2024 and found that the NARAYANA E-TECHNO SCHOOL WADI (BK) NANDED - 431602 (Name of school) has safe

drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 18/04/2024 to 18/04/2025 (ONE YEAR)

Signature with Seal : [Signature]

Name

Dr. Pooja R. Jadhav

Designation

: Dr.

To

PRINCIPAL

NARAYANA E-TECHNO

SCHOOL WADI (BK) NANDED

(Name & Address of the Institution)

S. NO. 212/A, OPP. D-MART, NEW
CANAL ROAD, WADI (BK) NANDED
PIN - 431602.

MEDICAL OFFICER
P.H.C., Limbgaoon
Tq. Dist. Nanded

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection 1/8/24 Date of Receipt-1/8/24 Date of / Examination 1/8/2024 onwards
Lr. No.128

(All the Analytical Results are in mg. / liter except pH & Turbidity)

SR.NO	TEST PARAMETER	Sample No. 1 Water Narayana E- Techno School Wadi Bk. Nanded	BIS Specifications 10500 : 2012 Normal Values	
			Desirable Limits	Permissible Limits
1	Physical Appearance	Clear	--	--
2	Odour	odourless	Agreeable	Agreeable
3	Turbidity(asN.T.U.)	0.12	1.0	5.0
4	pH Value	7.18	6.5 to 8.5	No Relaxation
5	Chlorides (as Cl)	20.0	250	1000
6	Nitrates (as NO ₃)	2.14	45	No Relaxation
7	Total Hardness (as CaCO ₃)	48.0	200	600
8	Alkalinity (as CaCO ₃)	50.0	200	600
9	Total Dissolved Solids	172.0	500	2000
10	Iron (asFe)	0.05	0.3	No Relaxation
11	Fluoride (asF)	0.21	1.0	1.5
12	Other Tests (if any)	----	----	----

- This Report is restricted only for the sample/s submitted to this laboratory.
- This Sample/is/are not collected by this Laboratory.

The analysis report pertains to the sample as submitted by the party.

REMARKS

A) Sample No .One(1) is/are Potable/chemically fit for drinking purposes on the basis of analyzed parameters only. However, this/these water source/s can be used for drinking purposes only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. contains ----- How ever,if there is no any other alternate Source available nearby then this/these Water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it.s bacteriological quality frequently or regularly.

C) Sample - -----
Hence, this/these water source(s) is / are chemically non-potable/unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

NO 158.5 / 2024
Date: - 08/08/2024

Forwarded With Compliments To;- Principal Narayana e-Techno School Survey No.2121A
Wadi (bk) Nanded .

With reference to letter no. Nil .

Dated-1/8/2024.

Fee Rs.600/-

Receipt No. and Date;-7555692/1/8/2024.


Junior Scientific Officer
District Public Health Laboratory
NANDED.