

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01

Dated: 17/05/24

It is certified that an inspection team headed by Santosh Dayma Sub Engineer
(Name of Officers with designation) from P.H.E. Mait Subdiv No 1 N.Ujjain,
inspected the **NARAYANA E-TECHNO SCHOOL, Nagziri, Dewas Road, Ujjain (M.P.)** (Name &
Address of the school) on 16/05/24 (Date of inspection) and on the basis of Water Test Report
(Attached) bearing no. dated 16/05/24 Of (PHED Lab) certified that the **NARAYANA E-TECHNO SCHOOL** (name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/U.T. Govt.

This certificate is valid till 2024 - 2025

Signature with Seal

Name

Designation

Name & Address of the Office /Department :

To

NARAYANA E-TECHNO SCHOOL
Nagziri, Dewas Road,
Ujjain (M.P.)
(Name & Address of the Institution)

Note : The certificate is to be issued by authorized officer / PHED Lab / local bodies

LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
MAINTENANCE SUB DIVISION NO. 2, P.H.E. DEPTT. , UJJAIN

Sample from : Narayana E-Techno School, Mahalakshmi Nagar, Nagjhiri, Ujjain

Particular of sample : Sample No. 1) Tubewell Water

Date of collection : 09-05-24

Date of Analysis : 09-05-24

S. NO.	Characteristics	Unit	Appendix-23 (a) As per manual on water supply Treatment prepared published by CPHEEO-MANUAL		Result				
			Acceptable	Cause for rejection	(1)	2	3	4	5
1.	Physical								
1.	Turbidity	NTU	2.5	10.0	0.2	✓			
2.	Colour	PICobalt Scale	5.0	25.0	NIL	✓			
3.	Taste and odour	-	Unobjectionable	Unobjectionable	NIL	✓			
4.	Chemical								
4.	PH	PH Scale	7.0 to 8.5	<6.5 to 9.2>	7.6	✓			
5.	Total Alkalinity	Mg/1	200	600	280	✓			
6.	Chloride	-	Up to 200	1000	190	✓			
7.	Total Hardness	Mg/1	200as CaCO ₃	600as CaCO ₃	232	✓			
8.	Calcium Hardness	-							
9.	Magnesium Hard.	-							
10.	Total Dissolved Solid	-	500	2000	400	✓			
11.	Iron	Mg/1	0.1	1.0	NIL	✓			
12.	Fluoride	-	1.0	1.5	0.32	✓			
13.	Maganese	-	0.3	1.0	-				
14.	Dissolved oxygen	-	-	-	-				
15.	C.O.D.	-	10	-	-				
16.	B.O.D	-	06	-	-				
17.	Residual chlorine	-	02	1.0	NIL				
18.	Coagulant dose at test	-	-	-	-				

NOTE : 1. The figure indicated under the column acceptable are the limits upto which the water is generally acceptable to the consumers.

2. Figure in excess of those mentioned under acceptable render the water not acceptable but still tolerated in the absence of alternative and better source but upto the limits indicated under column 'cause for rejection' above which the supply will have to be rejected.

Biological

Bacteriological (M. P. N.) of coli form per 100 ml of sample - 1) NIL

Special Test

(1)

(2)

(3)

Chemist :

Remarks : All the tested parameter results are under limits as per CPHEEO manual.

So, water can be used for the drinking purpose.

Assistant Engineer
H.E. Maint. Sub Div. No. 2
L.P.N. Ujjain (M.P.)

H. Parui
Chemist
Laboratory Incharge
WATER TREATMENT & FILTRATION PLANT
GAU GHAT, UJJAIN

Note :

East : Water sample is collected by consumer.

ON INDIA GOVERNMENT SERVICE

TO,

No. _____

Narayana E-Techno School

STAMP

Mahalakshmi Nagar, Nagjhiri

Ujjain (M.P.)