



BRUHAT BENGALURU MAHANAGARA PALIKE
Health Officer, Dasarahalli Zone, Bangalore-73

NO: BBMP/DZ/H.O/PR/262/24-25

Date: 05-09-2024

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

It is certified that an inspection team headed by Senior Health Inspector Ward No.13-BBMP have inspected the **NARAYANA e-TECHNO SCHOOL, MALLASANDRA VILLAGE YESHWANTHAPURA HOBLI, BANGALORE-560057** on 05-09-2024 and found at the time of inspection that **NARAYANA e-TECHNO SCHOOL**, has safe drinking water facilities for the students and members of staff of the institution and are maintaining the hygienic sanitation, condition, in the school building and the campus there are Separate toilet to facilities Boys and Girls as per the norms prescribed by the State Government.

The above is valid for a period of - 1 year

Signature with seal
Name: Dr. Surendra B
Designation: Health Officer

ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಬೆಂಗಳೂರು-560 073

To,

**NARAYANA e-TECHNO SCHOOL,
YESHWANTHAPURA HOBLI
BANGALORE-560057**



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.

NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location :- NARAYANA E-TECHNO SCHOOL				Report date: 06/07/2024	
Mallasandra Village, Yeshwanthpura Hobli,				Report Number: 0543	
Bengaluru North Taluk				Reference: TRF	
Bengaluru-560057.				Sample code: 0543	
				Date of Sample collection: 05/07/2024	
				Analysis start date: 05/07/2024	
				Analysis completion date: 06/07/2024	
				Sample quantity: 1 Liter	
Sample Particulars: R.O water					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.8	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	110.0	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	70.0	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	12.9	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	44.5	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	13	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	11.4	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	1.8	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 rd Edition
14	Nitrate as NO_3 , mg/l	Nil	45	No relaxation	APHA 24 rd Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst			Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S RDWSD/WQMSP/TeR/01		



Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---