

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/50146

DATE: 03/04/2020

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

NARAYANA SCHOOL

**EXISTING TWO STORIED EDUCATIONAL BUILDING UNDER THE NAME AND STYLE
NARAYANA SCHOOL AT SAHID SUKUMAR BANERJEE SARANI OVER CS PLOT NO.
215(P), KH NO. 147,151,163, JL NO.85, MOUZA-GOPINATHPUR, PS- DURGAPUR, DIST-
PASCHIM BARDHAMAN-713212**

**Durgapur F.S., Durgapur PS,
Paschim Bardhaman - 713212 .**

**Sub :Fire Safety Certificate for the occupancy of an existing construction of G + 1
storied building under group Educational at the premises no.- EXISTING TWO
STORIED EDUCATIONAL BUILDING UNDER THE NAME AND STYLE NARAYANA
SCHOOL AT SAHID SUKUMAR BANERJEE SARANI OVER CS PLOT NO. 215(P), KH
NO. 147,151,163, JL NO.85, MOUZA-GOPINATHPUR, PS- DURGAPUR, DIST- PASCHIM
BARDHAMAN-713212, Durgapur PS, Paschim Bardhaman - 713212**

This is in reference to your Application No.IND/WB/FES/20192020/50146, dated 03/04/2020, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.- EXISTING TWO STORIED EDUCATIONAL BUILDING UNDER THE NAME AND STYLE NARAYANA SCHOOL AT SAHID SUKUMAR BANERJEE SARANI OVER CS PLOT NO. 215(P), KH NO. 147,151,163, JL NO.85, MOUZA-GOPINATHPUR, PS- DURGAPUR, DIST- PASCHIM BARDHAMAN-713212, Durgapur PS, Paschim Bardhaman - 713212.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.



**Principal
Narayana School**



**Manager
Narayana School**

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. CONDITION APPLIED FOR FSC/RFSC

1. Maintenance/checking /testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
3. Good housekeeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.
5. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated:-
6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
7. No parking will be allowed on the Driveway.
8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
9. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
10. Existing Electrical wiring of the hole building shall have to be carefully checked for any wear and tear in them , particularly lines above false ceiling and ducts.
11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
14. Switch gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers confirming I.S. specification.
15. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
16. First-Aid Fire Fighting system shall be provided as per I.S. specification.
17. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
18. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
19. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials. (If any)
20. Periodical flashing of water from the Hydrant and Sprinkler pipe lines shall be made to



Principal
Narayana School



Manager
Narayana School

maintain the efficient working performance of above mentioned system.

21. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.

22. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

23. Another stair case shall be made positively in case of emergency evacuation.

24. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled .

25. This certificate shall remain valid upto three years as per latest GOVT Notification in 2017.

**Divisional Fire Officer
West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by NITAI
CHATTOPADHAY

Date: 2019.04.03 03:41:32 PDT


Principal
Narayana School

Page 1 of 2


Manager
Narayana School