























## Fire Extinguisher Details – S-BLOCK

LEVEL	Type		Sticker	Pressure	Safety Pin	Nozzle	Pipe	Handle	Paint of Bottle
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
2nd level	Fire Extinguisher CO2	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
2nd level	Fire Extinguisher CO3	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
2nd level	Fire Extinguisher CO4	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
3rd level	Fire Extinguisher CO5	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
3th level	Fire Extinguisher CO6	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
3th level	Fire Extinguisher CO7	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint







7th level	Fire Extinguisher CO25	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
7th level	Fire Extinguisher CO26	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO27	2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO28	2.2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	Fire Extinguisher CO29	2.2 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	DCP	9KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
6th level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
7th level	DCP	4.5 KG	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	WATER	9L	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	WATER	9L	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	WATER	9L	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint
1st level	WATER	9L	Outdated and needs to be renewed	Pressure a little less and need pressurization	Pin there but not sure of the safety status	In good condition	In good condition	Handle okay	No need to paint





