



INFORMATION SHEET FOR PROCUREMENT OF 1200kW GENERATOR SET(S)

Reference No.: FNK-I/IUL/2022/093

Issued on 04th April 2022

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives

Section I: Instruction to Bidders

A. General	
1. Scope of Bid	1.1 Fenaka Corporation Limited requests quotations for 1200kW generator set(s) in accordance with <i>Section III, Technical Specifications</i>
	1.2 It is in Fenaka Corporation Limited's discretion to cancel the bid invitation mentioned in 1.1 at any time.
2. Eligible Participants	2.1 Local companies registered in Maldives are eligible to participate in the tender
	2.2 Foreign companies are eligible to participate in the tender only if the total bid value is above 2,500,000 Maldivian Rufiyaa.
B. Preparation of the Bid	
3. Bid Prices	3.1 The unit price of each item and the total price shall be clearly indicated in the quotation
	3.2 All items shall be quoted in the bid (please refer to <i>Section III, Technical Specifications</i> for the details of required items)
	3.3 Quotation shall separately indicate the additional charges such as freight charges and Insurance.
	3.4 The bidder shall submit quotation on CIF basis to Male' port
4. Currency	4.1 The bidder shall quote entirely in Maldivian Rufiyaa
5. Alternative Bids	5.1 Bidders can submit a maximum of two (2) options
6. Validity of Bids	6.1 Quotation shall remain valid for minimum sixty (60) days from the date of bid opening
7. Bid Security	7.1 All bids should be accompanied with a bid security of USD 2,000 (Two Thousand US Dollars) or its equivalent in Maldivian Rufiyaa
	7.2 The bid security should be: <ul style="list-style-type: none"> - Original bank guarantee letter (or) - Bank guaranteed and stamped check (or) - An insurance policy from Maldives Monetary Authority (MMA) registered insurance company
	7.3 Any bid not accompanied by a Bid Security shall be rejected during bid opening

	7.4 The bid security must be valid for a minimum of twenty (20) additional days beyond the validity of quotation
8. Technical Compliance	<p>8.1 All relevant information including the brand shall be given to enable technical evaluation of quoted items</p> <p>8.2 The documents required for technical evaluation are:</p> <ul style="list-style-type: none"> - Technical data sheets of engine and the alternator - Datasheets specifying cooling system rated at ambient temperature 50°C - Certificate of Authenticity specifying manufacturer/assembler is an OEM or a genuine reputed international engine brand <p>8.3 If the manufacturer or assembler is not the same as the bidder, a document indicating that manufacturer or assembler is willing to sell the generator set to the bidder is required</p> <p>8.4 Technical compliance letter will be required to enable technical evaluation</p> <p>8.5 If the goods do not comply with the requirements mentioned in <i>Section III, Technical Specifications</i>, the bid will be rejected during evaluation.</p> <p>8.6 Generator set should comply with our requirements, if not the bid will be rejected</p>
9. Documents Comprising the Bid	<p>9.1 Quotation (inclusive of the delivery period and payment terms)</p> <p>9.2 Specifications of the offered product</p> <p>9.3 Certificate of Authenticity specifying that manufacturer / assembler is an OEM of a genuine reputed international engine brand</p> <p>9.4 Details of the company</p> <ul style="list-style-type: none"> - Company profile/background - Company registration certificate - GST registration certificate (for local bidders only) - TAX clearance report (6 months validity) - Contact details (name, designation, mobile number and e-mail address) <p>9.5 Experience letters, if available</p> <ul style="list-style-type: none"> - Letters within past five (5) years - Relevant experience letters - Letters with project name and value <p>9.6 One (1) compact disc with original bid document scanned and written</p>

	9.7 Bids lacking the documents above are subjected to be rejected during the bid opening
10. Format of Bid	10.1 The Bidder shall submit two (2) sets of the bid document (1 original and 1 copy), enclosed separately in two envelopes and sealed with company stamp 10.2 All pages of the bid document shall be stamped and bound properly (excluding the bid security)
C. Bid Submission	
11. Sealing and Marking Bid Document	11.1 The bid document shall be sealed properly in an envelope clearly marked 'ORIGINAL' or 'COPY', with the name of the company and the tender reference number (FNK-I/IUL/2022/093)
12. Bid Opening	12.1 The bids will be opened on 10 th April 2022, 11:30am in the presence of bidders 12.2 Bids will be opened at: Fenaka Corporation Limited Hilaalee Magu, K. Male', Republic of Maldives 12.3 Bids received electronically will not be accepted
13. Bid Rejection	13.1 Bidders that arrive after bid submission deadline shall not be able to participate in the bid 13.2 Bidders that do not register for the tender are unable to participate in the bid opening 13.3 Bids lacking the documents mentioned in 9. <i>Documents Comprising the Bid</i> (except 9.5 <i>Experience letters</i>) and that do not comply with 10. <i>Format of Bid</i> are subjected to be rejected
D. Awarding of Contract	
14. Payment Terms	14.1 An advance will not be released for this project 14.2 Proposed payment terms should not be tied with submission of Bill of Lading.
15. Factory Acceptance Testing	15.1 The generator(s) shall be fully tested at the manufacturer workshop in the presence of Client's appointees. 15.2 The testing shall be conducted at internationally accepted testing standards 15.3 Generator(s) should be tested to run at 25%, 50%, 75%, 100%, and 110% of rated load and power factor until the engine temperature stabilized for 30 minutes, and should check the protections below:

- Lub oil low level (alarm testing)
- Lub oil low pressure (alarm testing)
- Earth fault (alarm testing)
- Over current (alarm testing)
- High temperature (alarm testing)
- Cooling system (alarm testing)
- High voltage pressure (alarm testing)
- All the functioning tests and routine tests should be done

15.4 All the protections should work properly, it should be examined for oil and coolant leaks, and it should be visually tested and secured

15.5 The remote radiator should operate continuously 100% in a 50-degree ambient temperature

- It should be designed with vertical air discharge remote radiator with motor and fan
- It should include all the generator connection pipes, accessories, joints and diagrams
- The radiator should be developed remotely from the engine providing an added flexibility cooling system, and to be installed at the desired location
- It should be designed with lower power consumption, and high efficiency aero foil designed fans are used
- It must be designed with lower noise levels
- The radiator core should be formed using high efficiency fin profile
- The thickness of connection pipes must be in a range of 2mm to 4mm

15.6 Two (2) engineers from Fenaka Corporation Limited shall carry out necessary inspection and testing of equipment prior to shipment in supplier's warehouse to validate the items

15.7 The bidder shall arrange airfare, transportation, stipend (as per the Client's policy), accommodation and lodging for two of Client's engineers for the testing (minimum two days for testing)

Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

- $(\text{Lowest price} / \text{proposed price}) \times 70$

Delivery: 20 points for the lowest delivery period

- $(\text{Lowest delivery period} / \text{proposed delivery period}) \times 20$
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

- $(\text{Proposed credit period} / \text{longest credit period}) \times 10$

Note: Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.

Section III: Technical Specifications

*Please note that the below specifications are for one unit only.

Information of 1200 kW Generator Set

#	Description	Unit	Qty
1	<p><i>Diesel Generator set 1200 kW prime rated (open type) with parameters 0.8 P.F, 415Volts, 3 Phase, 4 wires, 50 Hz at 1500 r.p.m. The Generator set shall be powered by a branded an Original Company's Licensed OEM manufactured. The engine must produce a mechanical power output (kW) which should meet the required electric power (kW) of 1200kW and must be coupled with a 1200kW Stamford Alternator with pre-installed Droop CT and Control connection (terminal box to connect)</i></p> <p>Engine to be complete with following auxiliary items :</p> <ul style="list-style-type: none"> • Heavy electrical flywheel • SAE flywheel housing • Air filters, Lubricating Oil Filters, Fuel Filters and all other such filter required for operation of the engine • Low lubricating oil pressure switch • High engine temperature switch • lube oil sender • Water Temperature Sender • All necessary items to run and to protect the engine • Starting equipment fitted to engine, consisting of : • 24 Volt charging alternator (Brushless) • 24 Volt starting motor • Fuel Shut-off solenoid • Heavy duty lead acid batteries, supplied in a dry charged condition • Governing System <p><i>The engine to be fitted with a close tolerance Electronic Governing system, which should include efc, actuators, magnetic pickups, etc, including wiring</i></p> <p>Cooling Equipment</p> <p><i>Cooling equipment comprising a heavy-duty tropical type W type remote radiator, With fan driven by the Electric Motor (ABB or Equivalent) The radiator core should be electroplated with silver solder tin plated to prevent early failure due to corrosion.</i></p> <p><i>Radiator must be designed to adequately cool the generator at an ambient temperature of 50°C Coupon blue coated radiator is acceptable.</i></p> <ul style="list-style-type: none"> • Exhaust system <p><i>450 mm of stainless steel below type flexible exhaust, together with suitable flanges and fittings shall be supplied for each silencer.</i></p>	I	No

Handwritten signature

	<p>• Alternator The alternator shall be brushless revolving type alternator (0.8 P.F, 415kV, 3 Phase, 4 wires, 50 Hz), Having class H insulation on both the stator and field windings. It shall be built and rated to BS 5000, tropically impregnated with voltage regulation being in the order of +/- 1.5% from no load to full load under the steady state conditions assuming a speed variation not exceeding 4% on the engine. Anti-Condensation Coil to be fitted in the Alternator.</p> <p>• Generator arrangement and drive The simplex type base plate is of heavy duty rolled steel constructed, bolted and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a base plate and vibration mounts to be mounted underside of the base plate.</p> <p>• Finishing After assembling the genset zinc coated self-etching primer should be applied to the complete set.</p>		
1.2	<p>Fuel system A fuel day tank capacity 4000 liters complete with level indicator, drain plug, filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet connection is to be mounted. These mounts are to be supplied as loose item. All necessary fittings to be supplied in conformity with fuel flow diagram.</p>	1	No
1.3	<p>Factory testing The generator should be fully tested at the manufacturer workshop in the presence of client/appointees to check the ratings, overload, functional tests on a dummy load prior to dispatch.</p>	1	No
1.4	<p>Literature and drawings consisting of : (Optional)</p> <ul style="list-style-type: none"> • 1 No x Manual on How to handle the generation equipment • 1 No x Electrical wiring diagram • 1 No x Engine operation and maintenance manual • 1 No x Engine parts catalogue • 1 No x Generator parts catalogue • 1 No x Generator operation and maintenance manual • 1 No x Generator AVR manual • 1 No x Governor control unit manual • 1 No x Engine shop manual 	1	Lot
1.5	<p>Accessories The Components shall meet the British Standard and ISO standards. Items are for the below mentioned generator sets. Primary silencer barrel (to match engine exhaust) Secondary silencer barrel (to match engine exhaust) 3m Exhaust pipe dia (to match engine exhaust) Elbows having dia (to match the engine exhaust) Flanges having dia (to match the engine exhaust) Bolts, Nuts and Washers for the Flanges. (Each set shall include 1 bolt, 2 washers, 1 spring washer 2 Nuts) Split type Rockwool insulation lagging suitable for 75 to 125mm dia. Exhaust pipes. The lagging shall be covered with High Quality Aluminum foil.</p>		Lot
1.6	<p>Warranty Generator set should carry a warranty of one year from the date of commissioning.</p>	1	Lot

Documents required for technical Evaluation

Handwritten signature

- Technical data sheet of generator.
- Technical data sheet of Dynamo.
- Data sheet specifying cooling system rated ambient temperature 50 degree.
- Certificate of Authenticity specifying Assembler or Manufacture.
- Technical specification of remote Radiator.

[Handwritten signature]

TECHNICAL SPECIFICATIONS OF W TYPE REMOTE RADIATOR

The cooling equipment consisting W type radiator with heavy-duty structure, suitable for tropical weather, and equipped with vertical air flow fans driven by electric motor .Standard IP55 or IP65 (7.5HP) (ABB or equivalent). With VCD

Cooling circuit and pipe line should be designed for two separate circuits for jacket water and after cooler water of the engine. Primary FCW-140(LT+HT) Secondary FCW-180.

All installation accessories must be BS standard and include seamless pipes, gauges, gate valves, flanges, bolts elbows and expansion tank.

The radiator must be designed and sized to adequately cool CUMMINS KTA50-G8 engine and meet the specs below.

Cores	Tin Coated
Motor controller	Automatic
Low Coolant Level Protection	Engine Shutdown
Air Flow	Vertical
Ambient Temperature	50C
Inlet Coolant Temperature	90C
Outlet Coolant Temperature	84C
Heat Rejection	676 kW
Maximum Coolant Friction Head	69 kPa
Maximum Static Head	18.3m
Electric Motor	3ph, 400V, 5.6kW
Motor Starter	Soft Starter
Motor Protection	IP 54
Insulation	Class F
No. of Fans	3
Noise Level	75dB (A) @ 7m
Overall Dimensions (L x W x H),	4660 x 2030 x 2495mm

Cooling water pipe line should be designed to install at 6meters distance from the engine.

[Handwritten signature]