



**INFORMATION SHEET FOR
SEWERAGE OUTFALL RECTIFICATION
REPAIR WORK
GN.FUVAHMULAH**

Reference No.: FNK-I/IUL/2023/150

Issued on 09th May 2023

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives

Section I: Instruction to Bidders

| A. General | |
|----------------------------------|---|
| 1. Scope of Bid | <p>1.1 Fenaka Corporation Limited requests proposal / quotations for repair work of sewerage outfall rectification in accordance with <i>Section III, Technical Information</i></p> <p>1.2 It is in Fenaka Corporation Limited's discretion to cancel this bid invitation at any time.</p> |
| 2. Eligible Participants | <p>2.1 Local companies registered in Maldives are eligible to participate in the tender.</p> <p>2.2 Foreign companies are eligible to participate in the tender only if the total bid value is above 2,500,000 Maldivian Rufiyaa.</p> |
| B. Preparation of the Bid | |
| 3. Bid Prices | <p>3.1 The unit price of each work and the total price shall be clearly indicated in the quotation</p> <p>3.2 All items shall be quoted in the bid (please refer to <i>Section III, Technical Information</i> for the details of required items)</p> <p>3.3 Quotation shall separately indicate the additional charges such as freight charges, insurance, etc. (If required)</p> |
| 4. Currency | 4.1 The bidder shall quote entirely in Maldivian Rufiyaa |
| 5. Alternative Bids | 5.1 Bidders can submit a maximum of two (2) options |
| 6. Validity of Bids | 6.1 Quotation shall remain valid for minimum sixty (60) days from the date of bid opening |

| | |
|---|--|
| <p>7. Technical Compliance</p> | <p>7.1 If the service does not comply with the requirements mentioned in <i>Section III, Technical Information</i>, the bid will be rejected during evaluation.</p> <p>7.2 All the equipment and consumables should comply with our requirements, if not the bid will be rejected</p> |
| <p>8. Documents Comprising the Bid</p> | <p>8.1 Quotation (inclusive of the Duration / delivery period and payment terms)</p> <p>8.2 Details of the company</p> <ul style="list-style-type: none"> - Company profile/background - Company registration certificate - GST registration certificate (for local bidders only) - Tax clearance report (6 months validity is advised) - Contact details (name, designation, mobile number, and e-mail address) <p>8.3 Experience letters, if available</p> <ul style="list-style-type: none"> - Letters within past five (5) years - Relevant experience letters - Letters with project name and value <p>8.4 Work Schedule</p> <p>8.5 One (1) compact disc with original bid document scanned and written</p> <p>8.6 Bids lacking the documents above are subjected to be rejected during the bid opening</p> |
| <p>9. Format of Bid</p> | <p>9.1 The Bidder shall submit two (2) sets of the bid document (1 original and 1 copy), enclosed separately in two envelopes, and sealed with company stamp</p> <p>9.2 All pages of the bid document shall be stamped and bound properly</p> |
| <p>C. Bid Submission</p> | |

| | |
|--|---|
| <p>10. Sealing and Marking Bid Document</p> | <p>10.1 The bid document shall be sealed properly in an envelope clearly marked 'ORIGINAL' or 'COPY', with the name of the company and the tender reference number (FNK-I/IUL/2023/150)</p> |
| <p>11. Bid Opening</p> | <p>11.1 The bids will be opened on 16th May 2023, 1300hrs in the presence of bidders 11.2 Bids will be opened at: Fenaka Corporation Limited Hilaalee Magu, K. Male', Republic of Maldives 11.3 Bids received electronically will not be accepted</p> |
| <p>12. Bid Rejection</p> | <p>12.1 Fenaka Corporation Limited shall not consider any bidders that arrive after the deadline for submission 12.2 Bidders that do not register for the tender are unable to participate in the bid opening 12.3 Bids lacking the documents mentioned in 9. Documents Comprising the Bid (except 9.5 Experience letters) and that do not comply with 10. Format of Bid are subjected to be rejected</p> |
| <p>D. Awarding of Contract</p> | |
| <p>13. Payment Terms</p> | <p>13.1 An advance will not be released for this project</p> |

Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

- $(\text{Lowest price} / \text{proposed price}) \times 70$

Delivery: 20 points for the lowest delivery period

- $(\text{Lowest delivery period} / \text{proposed delivery period}) \times 20$

Credit Period: 10 points for the maximum credit period

- $(\text{Proposed credit period} / \text{longest credit period}) \times 10$

Section III: Technical Information

Information Sheet – Gn.Fuvahmulah Outfall Rectification

Objective of the project is to refurbish the existing sewer system in Gn.Fuvahmulah. Under the scope of works is laying of new outfall line by horizontal drilling method as per the specification mentioned below. And, connecting to existing outfall line and removal of existing pipeline and blocks from lagoon.

Scope of works

- Contractor shall price for all materials, pipes fitting, transportation, labour, equipment's, site clearance, drilling, anchoring of outfall pipe, laying of pipes etc.
- HDPE Black Pipe and fitting PN16, and SDR11 shall be used.
- It is the sole responsibility of the contractor to obtain the necessary approvals from the relevant Government authorities, however the Client will assist the contractor in obtaining the relevant approvals.
- Drilling and laying 331m of DN250mm HDPE pipe adjacent to the existing sea outfall pipe in STP. And casting and fixing of anchor blocks at diffuser point.
- Outfall pipeline must be butt welded and joined in flanged connected sections.
- Fixing of diffuser at pipe end at a depth of 5.5m from mean sea level.
- Connection of newly laid outfall line to old line near the shoreline point as instructed by engineer.
- Clearance of old outfall pipe and damaged/old blocks from the lagoon area as instructed by site engineer.
- The following technical documents are attached with information sheet.
 - Location of sea outfall.
- Contractor shall provide the following documents after completion of civil works.
 - As-built drawings of newly laid pipeline.
 - Pictures and videos of fixed pipeline and diffuser.