

# INFORMATION SHEET FOR PROCUREMENT OF 01 UNITS OF 250kW GENERATOR SETS

Reference No.: FNK-I/IUL/2023/227

Issued on 13<sup>th</sup> June 2023

Issued by:

Fenaka Corporation Limited Male', Republic of Maldives





# **Section I: Instruction to Bidders**

A. General		
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for 250KW generator set in
		accordance with Section III, Technical Specifications
	1.2	It is in Fenaka Corporation Limited's discretion to cancel the bid invitation
		mentioned in 1.1 at any time.
2. Eligible	2.1	Local companies registered in Maldives are eligible to participate in the tender
Participants	2.2	Foreign companies are eligible to participate in the tender only if the total bid
		value is above 2,500,000 Maldivian Rufiyaa.
B. Preparation	of the	Bid
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly indicated in the
		quotation
	3.2	All items shall be quoted in the bid (please refer to Section III, Technical
		Specifications for the details of required items)
	3.3	Quotation shall separately indicate the additional charges such as freight
		charges and Insurance.
	3.4	The bidder shall submit quotation on CIF basis to Male' port
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa
5. Alternative Bids	5.1	Bidders can submit a maximum of two (2) options
6. Validity of Bids	6.1	Quotation shall remain valid for minimum sixty (60) days from the date of bid
		opening
7. Bid Security	7.1	All bids should be accompanied with a bid security of USD 1,000 (One
		Thousand US Dollars) or its equivalent in Maldivian Rufiyaa
	7.2	The bid security should be:
		- Original bank guarantee letter (or)
		- Bank guaranteed and stamped check (or)
		- An insurance policy from Maldives Monetary Authority (MMA) registered
		insurance company
	7.3	Any bid not accompanied by a Bid Security shall be rejected during bid opening
	1	

Port Complex Building, 7th Floor, Hilaalee Magu, Male, 20207, Maldives















	7.4	The bid security must be valid for a minimum of twenty (20) additional days
		beyond the validity of quotation
8. Technical	8.1	All relevant information including the brand shall be given to enable technica
Compliance		evaluation of quoted items
	8.2	The documents required for technical evaluation are:
		- Technical data sheets of engine and the alternator
		- Datasheets specifying cooling system rated at ambient temperature 50°C
		- Certificate of Authenticity specifying manufacturer/assembler is an OEM or
		a genuine reputed international engine brand
	8.3	If the manufacturer or assembler is not the same as the bidder, a document
		indicating that manufacturer or assembler is willing to sell the generator set to
		the bidder is required
	8.4	Technical compliance letter will be required to enable technical evaluation
	8.5	If the goods do not comply with the requirements mentioned in Section III,
		Technical Specifications, the bid will be rejected during evaluation.
	8.6	Generator set should comply with our requirements, if not the bid will be
		rejected
9. Documents	9.1	Quotation (inclusive of the delivery period and payment terms)
Comprising the	9.2	Specifications of the offered product
Bid	9.3	Certificate of Authenticity specifying that manufacturer / assembler is an OEM
		of a genuine reputed international engine brand
	9.4	Details of the company
		- Company profile/background
		- Company registration certificate
		- GST registration certificate (for local bidders only)
		- TAX clearance report (6 months validity)
		- Contact details (name, designation, mobile number and e-mail address)
	9.5	Experience letters, if available
		- Letters within past five (5) years
		- Relevant experience letters















		- Letters with project name and value
	9.6	One (1) compact disc with original bid document scanned and written
	9.7	Bids lacking the documents above are subjected to be rejected during the bid
		opening
10. Format of Bid	10.1	The Bidder shall submit two (2) sets of the bid document (1 original and 1
		copy), enclosed separately in two envelopes and sealed with company stamp
	10.2	All pages of the bid document shall be stamped and bound properly (excluding
		the bid security)
C. Bid Submissi	on	
11. Sealing and	11.1	The bid document shall be sealed properly in an envelope clearly marked
Marking Bid		'ORIGINAL' or 'COPY', with the name of the company and the tender
Document		reference number (FNK-I/IUL/2023/227)
12. Bid Opening	12.1	The bids will be opened 19 <sup>th</sup> June 2023, 10:30am in the presence of bidders
	12.2	Bids will be opened at:
		Fenaka Corporation Limited
		Hilaalee Magu, K. Male', Republic of Maldives
	12.3	Bids received electronically will not be accepted
13. Bid Rejection	13.1	Bidders that arrive after bid submission deadline shall not be able to participate
		in the bid
	13.2	Bidders that do not register for the tender are unable to participate in the bid
		opening
	13.3	Bids lacking the documents mentioned in 9. Documents Comprising the Bid
		(except 9.5 Experience letters) and that do not comply with 10. Format of Bid
		are subjected to be rejected
D. Awarding of	Contr	act
14. Payment	14.1	An advance will not be released for this project
Terms	14.2	Proposed payment terms should not be tied with submission of Bill of Lading.
15. Factory	15.1	The generator(s) shall be fully tested at the manufacturer workshop in the
Acceptance		presence of Client's appointees.
Testing	15.2	The testing shall be conducted at internationally accepted testing standards















	15.3	Generator(s) should be tested to run at 25%, 50%, 75%, 100%, and 110% of
		rated load and power factor until the engine temperature stabilized for 30
		minutes, and should check the protections below:
		- Lub oil low level (alarm testing)
		- Lub oil low pressure (alarm testing)
		- Earth fault (alarm testing)
		- Over current (alarm testing)
		- High temperature (alarm testing)
		- Cooling system (alarm testing)
		- High voltage pressure (alarm testing)
		- All the functioning tests and routine tests should be done
	15.4	All the protections should work properly, it should be examined for oil and
		coolant leaks, and it should be visually tested and secured
	15.5	The remote radiator should operate continuously 100% in a 50-degree ambient
		temperature
		- It should be designed with vertical air discharge remote radiator with motor
		and fan
		- It should include all the generator connection pipes, accessories, joints and
		diagrams
		- The radiator should be developed remotely from the engine providing an
		added flexibility cooling system, and to be installed at the desired location
		- It should be designed with lower power consumption, and high efficiency aero
		foil designed fans are used
		- It must be designed with lower noise levels
		- The radiator core should be formed using high efficiency fin profile
		- The thickness of connection pipes must be in a range of 2mm to 4mm
	15.6	Two (2) engineers from Fenaka Corporation Limited shall carry out necessary
		inspection and testing of equipment prior to shipment in supplier's warehouse
		to validate the items
I		

Phone: +960 3007555 | Fax: +960 3327555 | Email: info@fenaka.mv | Website: www.fenaka.mv





0











 15.7 The bidder shall arrange airfare, transportation, stipend (as per the Client's
policy), accommodation and lodging for two of Client's engineers for the
testing (minimum two days for testing)

### Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

- (Lowest price / proposed price) x 60

Delivery: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 30
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

- (Proposed credit period / longest credit period) x 10

**Note:** Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.

Port Complex Building, 7th Floor, Hilaalee Magu, Male, 20207, Maldives
Phone: +960 3007555 | Fax: +960 3327555 | Email: info@fenaka.mv | Website: www.fenaka.mv





Description	Quantity
Generator Set 250KW	01

## **Section III: Technical Specifications**

\*Please note that the below specifications are for one unit only.

#### SPECIFICATION FOR 250kW Generator Set (2019)

S/N:	Description	Unit	Qt
1	250 kW prime rated diesel generator set with parameters 0.8 P.F. 415kV, 3 Phase, 4 wires, 50 Hz at 1500 r.p.m. Powered by Internationally reputed brand engine coupled with internationally reputed brand Alternator. The Generator set shall be powered by a Branded engine origin or assembled/manufactured by an Original Company's Licenced OEM manufactured/assembler. The engine must produce a mechanical power output (kW <sub>m</sub> ) which should meet the required electric power ( kW <sub>e</sub> ) of 250kW and must be coupled with a 250kW Alternator with pre-installed Droop CT and a control connection box.(termination box to connect control cables and power cables)	1	No
	Engine to be complete with following auxilliary items : • Heavy electrical flywheel • SAE flywheel housing • Air filters, Lubricating Oil Filters, Fuel Filters and all other such filter required for operation of the engine • Low lubricating oil pressure switch • High engine temperature switch • lub oil sender • Water Temperature Sender • All necessary items to run and to protect the engine		
	Starting equipment fitted to engine, consisting of :         24 Volt charging altenator (Brushless)         24 Volt starting motor         Fuel Shut-off solenoid         Heavy duty lead acid batteries, supplied in a dry charged condition         Governing System		
	The engine to be fitted with a close tolerance Electronic Governing system, which should include efc, actuators, magnetic pickups, etc, including wiring • Cooling Equipment		
	Cooling equipment compromising a heavy-duty tropical radiator, together with pusher type cooling fan and guards to be fitted. The radiator core should be elecroplated with silver solder tin plated to prevent early failure due to corrosion. Coupon plated radiators are acceptable. Radiator has to be mounted on vibration mounts with enough strength to withstand the radiator and vibrations.		
	Radiator must be designed to adequately cool the generator at an ambient temperature of 50°C • Exhaust system		
	450 mm of stainless steel bellow type flexible exhaust, together with suitable flanges and fittings shall be supplied for each silencer.		
	Alternator		

Port Complex Building, 7th Floor, Hilaalee Magu, Male, 20207, Maldives





1.6	Warranty Generator set should carry a warranty of one year from the date of commisioning		
	The lagging shall be covered with High Quality Aluminium foil.	1	Lot
1.5.7	washers, 1spring washer 2 Nuts) Split type rockwool insulation lagging suitable for 75 to 125mm dia. Exhaust pipes.	1	Lot
1.5.6	Bolts, Nuts and Washers for the Flanges. (Each set shall include 1 bolt, 2		1000
1.5.5	Flanges having dia (to match the engine exhaust)	4	No
1.5.4	Elbows having dia (to match the engine exhaust)	6	No
1.5.3	3m Exhaust pipe dia ( to match engine exhaust)	2	No
1.5.2	Secondary silencer barrel (to match engine exhaust)	1	No
1.5.1	above mentioned generator sets. Primary silencer barrel (to match engine exhaust)	1	No
4.3	The Components shall meet the British Standard and ISO standards. Items are for the		
1.5	1 No x Governor control unit manual     1 No x Engine shop manual Accessories		
	1 No x Generator AVR manual		
	<ul> <li>1 No x Generator operation and maintenace manual</li> </ul>		
	<ul> <li>1 No x Generator parts catalogue</li> </ul>		
	1 No x Engine parts catalogue		
	1 No x Engine operation and maintenance manual		
	<ul> <li>1 No x Manual on How to handle the generation equipment</li> <li>1 Nos x Electrical wiring diagram</li> </ul>		
4.4	1 No x Manual on How to handle the generation equipment	1	Lot
1.4	Literature and drawings consisting of :	1	Lat
	bidder shall provide an extended warranty of one extra year than mentioned in item no 1.6 of this document.		
	prior to dispatch in case the bidder is unable to provide factory test as required the		
	of client/apointees to check the ratings,overload,functional tests on a dummy load		
	The generator should be fully tested at the manufacturer workshop in the presence		
1.3	Factory testing	1	No
	All necessary fittings to be supplied in conformity with fuel flow diagram.		
	connection is to be mounted. These mounts are are to be supplied as loose item.		
	filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet		
	A fuel day tank of 12 hours capacity complete with level indicator, drain plug,		1
1.2	Fuel system	1	No
	applied to the complete set.		I
	After assembling the genset zinc coated self-etching primer should be		
	Finishing		1
	The vibration mounts are to be supplied as loose item.		
	base plate and vibration mounts to be mounted underside of the base plate.		1
	and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a		1
	The simplex type base plate is of heavy duty rolled steel constructed, bolted		
	Generator arrangement and drive		
	a Consister areas and data		
	assuming a speed variation not exceeding 4% on the engine. Anti- Condensation Coil to be fitted in the Alternator.		
	of +/- 1.5% from no load to full load under the steady state conditions		
	BS 5000, tropically impregnated with voltage regulation being in the order		
	insulation on both the stator and field windings. It shall be built and rated to		
	The alternator shall be brushless revolving type altenator, having class H		





Note : Proposal that do not conform to the given technical specification shall be rejected.

Prepared and checked by :

Technical Services & Green Energy Department

Port Complex Building, 7th Floor, Hilaalee Magu, Male, 20207, Maldives

