

# INFORMATION SHEET FOR PROCUREMENT OF AIR CIRCUIT BREAKER PANEL(S)

Reference No.: FNK-I/IUL/2023/281

Issued on: 30<sup>TH</sup> October 2023

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





# **Section I: Instruction to Bidders**

A. General					
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for Air Circuit Breaker panel			
		in accordance with Section III, Technical Specifications			
2. Eligible	2.1	Local companies registered in Maldives are eligible to participate in the tender			
<b>Participants</b>	2.2	Foreign companies are eligible to participate in the tender only if the total bid			
		value is above 2,500,000 Maldivian Rufiyaa.			
B. Preparation of the Bid					
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly indicated in the			
		quotation			
	3.2	All items shall be quoted in the bid (please refer to Section III, Technical			
		Specifications for the details of required items)			
	3.3	Quotation shall separately indicate the additional charges such as freight			
		charges and insurance. GST for mentioned charges should be omitted in grand			
		total.			
	3.4	The bidder shall submit quotation on CIF basis to Male' port			
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa			
5. Alternative	5.1	Bidders can submit a maximum of two (2) options			
Bids					
6. Validity of	6.1	Quotation shall remain valid for minimum sixty (60) days from the date of bid			
Bids		opening			
7. Bid Security	7.1	All bids should be accompanied with a bid security of USD 3,000 (Three			
		Thousand US Dollars) or its equivalent in Maldivian Rufiyaa			
	7.2	The bid security should be:			
		- Original bank guarantee letter (or)			
		- Bank guaranteed and stamped check (or)			
		- An insurance policy from Maldives Monetary Authority (MMA)			
		registered insurance company			
	7.3	Any bid not accompanied by a Bid Security shall be rejected during bid			
		opening			

Page 2 of 6

















	7.4	The bid security must be valid for a minimum of twenty (20) additional days
		beyond the validity of quotation
8. Technical	8.1	All relevant information including the brand shall be given to enable technical
Compliance		evaluation of quoted items
	8.2	If the manufacturer or assembler is not the same as the bidder, a document
		indicating that manufacturer or assembler is willing to sell the item to the
		bidder is required
	8.3	Manufacturer's Authorization letter will be required to enable technical
		evaluation
	8.4	If the goods do not comply with the requirements mentioned in Section III,
		Technical Specifications, the bid will be rejected during evaluation.
9. Documents	9.1	Quotation (inclusive of the delivery period and payment terms)
Comprising the	9.2	Specifications of the offered product
Bid	9.3	Single-line diagram
	9.4	Details of the company
		- Company profile/background
		- Company registration certificate
		- GST registration certificate (for local bidders only)
		- TAX clearance report (6 months validity)
		- Manufacturer's Authorization letter
		- Contact details (name, designation, mobile number and e-mail address)
	9.5	Experience letters, if available
		- Letters within past five (5) years
		- Relevant experience letters
		- Letters with project name and value
	9.6	One (1) compact disc with original bid document scanned and written
	9.7	Bids lacking the documents above are subjected to be rejected during the bid
		opening
10. Format of	10.1	The Bidder shall submit two (2) sets of the bid document (1 original and 1
Bid		copy), enclosed separately in two envelopes and sealed with company stamp
	1	

Page 3 of 6















	10.2	All pages of the bid document shall be stamped and bound properly (excluding		
		the bid security)		
C. Bid Submission				
11. Sealing and	11.1	The bid document shall be sealed properly in an envelope clearly marked		
Marking Bid		'ORIGINAL' or 'COPY', with the name of the company and the tender		
Document		reference number (FNK-I/IUL/2023/281)		
12. Bid Opening	12.1	The bids will be opened on 07 <sup>th</sup> November 2023, 11:30am in the presence of		
		bidders		
	12.2	Bids will be opened at:		
		Fenaka Corporation Limited		
		Hilaalee Magu, K. Male', Republic of Maldives		
	12.3	Bids received electronically will not be accepted		
13. Bid Rejection	13.1	Bidders that arrive after bid submission deadline shall not be able to		
		participate in the bid		
	13.2	Bidders that do not register for the tender are unable to participate in the bid		
		opening		
	13.3	Bids lacking the documents mentioned in 9. Documents Comprising the Bid		
		(except 9.5 Experience letters) and that do not comply with 10. Format of Bid		
		are subjected to be rejected		
D. Awarding of Contract				
14. Payment	14.1	An advance payment will not be released for this project		
Terms	14.2	Proposed payment terms should not be tied with submission of Bill of Lading.		
15. Factory	15.1	The panel(s) shall be fully tested at the manufacturer workshop in the presence		
Acceptance		of Client's appointees via video conferencing		
Testing	15.2	The testing shall be conducted at internationally accepted testing standards		
	15.3	The panel(s) shall undergo protection testing and operation testing		
	15.4	The panel(s) shall be checked for dimension and the supplier shall provide the		
		dimensions of the panel(s) during the virtual factory acceptance testing.		
	15.5	Recorded video clips while operating the units will not be accepted as virtual		
		factory acceptance testing.		
	l			

Page 4 of 6















### **Section II: Evaluation Criteria**

Proposal Cost: 70 points for the lowest price

(Lowest price / proposed price) x 70

**Delivery**: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 20
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

(Proposed credit period / longest credit period) x 10

Note: Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.















## **Section III: Technical Specifications**



FENAKA CORPORATION LIMITED MALE, MALDIVES

#### SPECIFICATION FOR AIR CIRCUIT BREAKER PANEL

- Free standing <u>Air Circuit Breaker Panel</u> consisting of
- 1200A TPN motorized Air Circuit Breaker (brand: Schneider, ABB or equivalent), rated at 600/1000V complete with 240 Volt under Voltage Trip Coil and auxiliary switches.
- 2000A TPN Tin/Copper coated copper busbar suitably braced for 30-80kA one second fault ratings.
- Indicating Lights
  - 1 set x indicating lights for incoming (R,Y,B)
  - 1 set x indicating lights for outgoing (R,Y,B)
  - ACB ON/OFF LED Indicators ( Red/Green)
- Measuring and Protection Devices
  - o 1 nos x Overcurrent Relay, brand : Delab or equivalent
  - o 1 nos x Earth Leakage Relay, brand : Delab or equivalent
  - o 3 nos x Analogue Ampere Meters 0-2000A (one for each phase -R,Y,B)
  - Multifunctional Digital meter capable of measuring
    - Voltage ( 0-500V) shall display Line-to-Line and Line-to-neutral voltages
    - Phase Ampere ( 0-2000A) shall measure the phase currents.
    - Frequency (40-65Hz) generator frequency measurement
    - Power, kW-shall display power of L1, L2, L3 and total power
    - · Power factor, shall display p.f of L1, L2, L3 and average
- 2Nos x 4 Way Terminal blocks for 630sqmm Cable (incoming and outgoing)
- Enclosure: Free standing manufactured using high quality galvanised MS Plates powder coated with epoxy resin to withstand high saline and high temperature weather conditions. Enclosure shall be of Bottom cable entry type.
- The panel dimensions shall meet or be similar to the given minimum dimensions (2055 X 660 X 880 mm)
- Busbar shall be arranged at the back of the cubicles and must be made of hard drain high conductivity copper which meets with relevant BS and IEC Standard
- The panel shall be manufactured using high quality electro galvanized MS plates of atleast 1.6mm thickness, treated and powder coated upto 80 micron or higher.
- The panel internal wiring shall be wired using 2.5sqmm thick flexible copper cables. All the
  wires shall be properly labelled and terminated with suitable terminal.
- Components such as relays, isolators, switches, meters and instruments shall be from reputable brands and shall fully comply with relevant international standards.
- A single line diagram must be provided together with technical specification of the main components of the panel









