

Information Sheet for Procurement Generator Sets

a) Bid Information

#	Description	Size	Quantity
1	Distribution Box 18c Complete (Fibre)	18c	415
	Distribution Box 24c Complete (Fibre)	24c	77
	Distribution Box 36c Complete (Fibre)	36c	58

Quotation shall indicate the following;

a) Price

- The bidder shall quote for Door step delivery value to Fenaka Corporation
- All items shall be quoted in the bid, please refer section (b) specifications
- Quotation shall indicate the unit price, total price for each item and total price of the quotation. The quotation shall separately indicate additional charges such as freight charges, insurance, taxes, etc.

b) Delivery Period

- The delivery period shall be stated in ‘calendar days’.
- If the delivery period indicates ‘ex-stock’, or if the duration is not specified, it shall be taken same as the party offering the longest delivery period.

c) Payment Terms

- The payment terms shall be stated in ‘days or months’, and the payments will be released in equal monthly instalments.
- No points will be given for payment terms if the bidder requests for Letter of Credit (LC).
- A maximum of 15% of the entire project can be provided as an advance if requested in the bid, however, it cannot be tied to the project starting date.
- For 15% advance bid awarded party has to submit bank guarantee letter along with performer invoice.



d) Technical Specifications

- All the relevant information including the brand shall be given to enable technical evaluation of the items quoted.
- Distribution boxes should comply our requirements, if not the bid will be rejected
- The documents required for technical evaluation are:
 - Drawings

e) Quotation validity should be a minimum of 60 days from the date of quotation opening.

f) If there is any clarification regarding bid you may send email to tender@fenaka.com.mv from 03rd March 2019 to 06th March 2019

g) Bid Security validity is valid for Twenty (20) days beyond the validity of the bid, Bidder has to submit bid security original as per announcement

Note: It is in FENAKA Corporation Limited’s discretion to reject/cancel any quotation which does not fulfil or comply the above terms.

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



ފެނަކާ ޖަނަރޭޓަރ ސެޓް ޖަހަވާ ޖަހަވާ
ޖަހަވާ ޖަހަވާ

b) Generator Set Specifications



18 Distribution Box Complete with:

1Nos x MCCB x 3POLE x 160A

1Nos x MCB x 3POLE x 63A

15Nos x MCB x 1POLE x 40A

1Nos x MAIN CONNECTION TERMINAL x 4POLE x 250A.

1Nos x NEUTRAL BUSBER x 18 HOLE

1Nos x EARTH BUSBER x 18 HOLE

SIZE: H-650 x B-500 x W-250 mm

DOUBLE LOCK, STANDERD (IP 65) WEATHER PROOF

It complete with wiring. And all the wiring. Copper Cable should be soft and flexible.

MCB must be equivalent with ABB, HAGGER. Material: GRP Polytheist (Fiber)

Main terminal outgoing copper cable 35sqmm connect to main MCCB

MCCB incoming 35sqmm copper cable.

Remarks: Back Plate must be attached with four numbers of bolt with nut

In design Customer cable should be connect bottom entry to the connector terminal.

All the cable ends should be using sleeve and I lug



24 Distribution Box Complete with:

1Nos x MCCB x 3POLE x 200A

1Nos x MCB x 3POLE x 63A

21Nos x MCB x 1POLE x 40A

2Nos x MAIN CONNECTION TERMINAL x 4POLE x 250A.

1Nos x NEUTRAL BUSBER x 24 HOLE.

1Nos x EARTH BUSBER x 24 HOLE

SIZE: H-800 x B-600 x W-300 mm

DOUBLE LOCK, STANDERD (IP 65) WEATHER PROOF

It complete with wiring. And all the wiring. Copper Cable should be soft and flexible.

MCB must be equivalent with ABB, HAGGER. Material: GRP Polytheist (Fiber)

Main terminal 1 outgoing copper cable 70sqmm connect to Main terminal 2

MCCB incoming 35sqmm copper cable.

Remarks: Back Plate must be attached with four numbers of bolt with nut

In design Customer cable should be connect bottom entry to the connector terminal.

All the cable ends should be using sleeve and I lug



36 Distribution Box Complete with:

1Nos x MCCB x 3POLE x 200A

1Nos x MCB x 3POLE x 63A

33Nos x MCB x 1POLE x 40A

2Nos x MAIN CONNECTION TERMINAL x 4POLE x 250A.

1Nos x EARTH BUSBER x 36 HOLE

1Nos x NEUTRAL BUSBER x 36 HOLE.

SIZE: H-800 x B-600 x W-300 mm

DOUBLE LOCK, STANDERD (IP 65) WEATHER PROOF

It complete with wiring. And all the wiring. Copper Cable should be soft and flexible.

MCB must be equivalent with ABB, HAGGER. Material: GRP Polytheist (Fiber)

Main terminal 1 outgoing copper cable 70sqmm connect to Main terminal 2

MCCB incoming 35sqmm copper cable.

Remarks: Back Plate must be attached with four numbers of bolt with nut

In design Customer cable should be connect bottom entry to the connector terminal.

All the cable ends should be using sleeve and I lug

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



ފެނަކާ ޖަނަރަލް ޕްރޮޖެކްޓްސް ޕްރައިވޭޓް ލިމިޓެޑް
ދިވެހިރާއްޖެ

c) Required Document and Evaluation criteria



Required Documents

- Quotation (inclusive of the delivery period and the payment terms)
- 3 copy set of the bid (One Original and 2 copy set)
- Specification of the offered product (Generator set)
- Drawings
- Bid Security (As per Announcement), Original
- Experience Letter
- Details of the company
 - Company profile
 - Company registration certificate
 - GST registration certificate
 - Contact details

Important Note:

- It is in FENAKA's discretion to reject/cancel any bid which does not fulfil or comply the above terms, at any time during the bid evaluation process. Also it is in FENAKA's discretion to cancel this invitation to bid at any time.
- Bids lacking the documents above are subjected to fail.

Evaluation Criteria

- **Proposal Cost:** 40 points
 - (Lowest proposed price / proposed price) x 40 points
- **Delivery:** 30 Point
 - (Shortest Delivery Period) / (Quoted Delivery Period) x 30
- **Payment Terms:** 20 points for the maximum days given for payment
 - (Proposed credit period / longest credit period) x 20
- **Experience** 10 points (Point will be given by analyzing Related Experience letters)

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



ފަނަކާ ޕޯޓް ސަފްޓް ޕްލެކްޝަން ޕްރައިވެޓް ލިމިޓެޑް

މާލެ ސަރަޕްޓް ބިލްޑިންގ

Please submit your bids by 14th March 2019, Thursday 11:00am. (Maldivian time), addressed to;

Tender Ref No: FNK-I/IUL/2019/054

Managing Director

Fenaka Corporation Ltd

Port Complex Building, 7th Floor

Hilaalee Magu, Maafannu

K. Male'

The proposal and the envelope must bear the reference number of the tender. All envelopes must be duly sealed and stamped. Fenaka Corporation will not be liable for the misplacement or premature opening of unlabelled sealed proposals. The bids will be opened on 14th March 2019, Thursday 11:00am (Maldivian time), in the presence of the bidders. The bids received after the stated time, and the bids received via email will not be accepted.

For more information and clarifications, please email us at tender@fenaka.com.mv

28th February 2019