

Parliament Check List

1	Firefighting Equipment	Frequency	Minimum checks and maintenance items
1.1	Extinguishers	3 Months	
			<ul style="list-style-type: none"> • Check 'Stored Pressure' / Weight of the fire extinguishers • Safety seals, bands are intact • Last date of inspection labeled correctly • Check if fire extinguishers are located correctly and clearly
1.2	Dry Riser	3 Months	
	Complete Dry Riser System		<ul style="list-style-type: none"> • Ensure the Dry Riser System is maintained and functioning correctly at all times
1.3	Wet Riser	3 Months	
	Fire Pump		<ul style="list-style-type: none"> • Check fire pump pressure if it is working as desired
	Jockey Pump		<ul style="list-style-type: none"> • Check jockey pressure if it is working as desired
	Diesel Pump		<ul style="list-style-type: none"> • Check diesel pump fuelled and working as desired
	Pump Electric Panels		<ul style="list-style-type: none"> • Visible Indicators • Test switching systems and ensure is working
	Well Water Supply		<ul style="list-style-type: none"> • Check ground water storage tanks/ wells for adequate water level. Refill if desired
	Hose Reel System		<ul style="list-style-type: none"> • Recoil and Check for damages in the hose • Check nozzle for desired sprinkling.
1.4	CO2 Flooding Systems	monthly	
	Panel 1		<ul style="list-style-type: none"> • Is in working condition?
	Cylinders and Distribution System		<ul style="list-style-type: none"> • Is in working condition?
	Smoke/Heat detectors		<ul style="list-style-type: none"> • Is in working condition?
	Visual and audio alarm		<ul style="list-style-type: none"> • Is in working condition?
1.5	Fire alarm Systems		
	Main Panel	Monthly	<ul style="list-style-type: none"> • Is the indicator panel showing 'normal'?
	Repeater Panel	Monthly	<ul style="list-style-type: none"> • Is the repeater panel showing 'normal'?
	smoke Detector	Monthly	<ul style="list-style-type: none"> • Is in working condition?
	Manual call point	Monthly	<ul style="list-style-type: none"> • Does testing a manual call point send a signal to the indicator panel? • Did the Alarm system work correctly when tested? • Did staff and other people hear fire alarm?
	Heat Detectors	Monthly	<ul style="list-style-type: none"> • Is in working condition? (found on pantries)