



**Ministry of Health**  
Male', Republic of Maldives

**Technical specification for the ceiling mount air conditions**

The vendor should supply the indoor and outdoor Air-conditioner units and the quality of the air-con units are Daikin brand, LG brand, or Equivalent (INVERTER TYPE)

#	Description	Yes / No	LG <i>(mention the country of Origin)</i>	Daikin <i>(mention the country of Origin)</i>	Equivalent <i>(mention the brand and country of Origin)</i>
1	18,000 BTU, single spilt type Ceiling cassette air conditioner unit				
2	The proposed Indoor and outdoor set with the manufacturer's specifications provided, Recommended Energy Efficiency Ratio (EER) of kw/kw 3.0 or above				
3	The vendor should Provide a minimum 1 Year parts warranty				

The vendor should submit the Authorized sales partner or distributor letter.