

Information Sheet for supply of transformers

Section A

a) Bid Information

#	Description	Quantity
1	2000 KVA Step-up transformers with switch gear	02 Nos
2	500 KVA step-down transformer with RMU & LV Penal	03 Nos
	Total	05 Nos

Quotation shall indicate the following;

a) **Price**

- The bidder shall submit quotation on CIF basis to Male' port
- All items shall be quoted in the bid, please refer section (b) specifications
- Price shall include travel/ accommodation charges for factory testing
- Quotation shall indicate the unit price, total price for each item and total price of the quotation and the quoted currency shall be clearly specified. The quotation shall separately indicate additional charges such as freight charges, insurance, taxes, etc.
- The unit rates and prices shall be quoted.

b) **Delivery Period**

- The delivery period shall be stated in 'calendar days'.
- If the delivery period indicates 'ex-stock', or if the duration is not specified, it shall be taken same as the party offering the longest delivery period.

c) **Payment Terms**

- The payment terms shall be stated in 'days or months', and the payments will be released in equal monthly instalments.
- No points will be given for payment terms if the bidder requests for Letter of Credit (LC).
- 5% of the bid value will be held as retention till the due of warranty period.



- A maximum of 15% of the project value can be provided as an advance payment if requested in the bid, however, this cannot be tied to the project starting date (agreement sign date).
- For 15% advance bid awarded party shall submit a bank guarantee letter or an insurance policy from Maldives Monetary Authority registered insurance company along with a pro-forma invoice.

d) Technical Specifications

- All the relevant information including the brand shall be given to enable technical evaluation of the quoted items.
- Technical compliance letter will be required to enable technical evaluation.
- Transformers and transformer accessories should comply with the attached requirements in order to avoid bid rejection.

e) Factory Testing

- The transformer shall be fully tested at the manufacturer workshop in the presence of client's appointees to check the load, protection, routine and functional tests. The transformer shall be checked for paint quality also shall undergo a physical inspection.
- The supplier shall provide the bill of materials of the transformers.
- The testing shall be conducted at internationally accepted testing standards.
- The bidder shall arrange airfare, transportation, accommodation and lodging for two of client's engineers for the testing (minimum of two day for testing).
- 02 engineers from Fenaka Corporation shall carry out necessary inspection and testing of equipment prior to shipment in supplier's warehouse in order to validate the items.

f) Quotation validity should be a minimum of 60 days from the date of quotation opening.

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Section B

ފެނަކާ ޖަނަވަރުގެ ޖަނަރަލް ޖަނަރަލް
ޖެނެރަލް ޖެނެރަލް

Specifications

A) Step-Down Transformer 11kV/415V, 500kVA

3 phase 50Hz 500kVA Dyn11, core type double wound with copper conductor, mineral oil immersed ONAN cooled distribution transformer with corrugated tank or conservator arrangement having a no load voltage ratio of 11/0.433 KV. Tappings +5% to -5% in steps of 2.5% shall be provided at line end of HV winding. Changing of taps shall be carried out by means of OFF Load Tap Changer.

Temperature rise shall be 50/60°C in oil/winding respectively over a maximum ambient of 40°C. The transformer shall be manufactured as per latest IEC.

HV Insulation Level 12kV Power frequency 28kV. r.m.s. Basic Impulse Level 75kV. Peak.

HV/LV Connection Delta/ Star N. pt

Dial type thermometer with contacts and control box for relays. Level indicator and pressure relief valve and oil drain valve. Hermetically sealed without gas cushion.

Relevant testing standards: IEC / BS standards.

B) Separate LV Panel for Transformer

Free standing LV Panel with 1200A, PVC sleeved Cu busbar, complete with measuring, indication and protection (ELR)

Incoming

1 Nos x 800A ACB motorized - main circuit breaker (Mechanical drawer type)

Outgoing

1 Nos x Outgoing feeder with 630A MCCB

2 Nos x Outgoing feeder with 400A MCCB

5 Nos x Outgoing feeder with 200A MCCB

Bottom entry Cable Termination arrangement.

C) 1 Nos x 3 Way Non Extensible Unit with 2 Nos. Isolators as Incomers and 1 No. Circuit Breaker as Outgoing to 500kVA Transformer (TYPE Ringmaster: Merlin Gerin RM6 NE-IIIDI or equivalent)

3 Way, 11kV, indoor extensible free standing metal clad SF6 insulated ring main unit comprising of three numbers 630A fault making/ load breaking switches and one number 200A tee-off circuit breakers complete with all necessary measurement and protection devices.

Step-Up 2000 kVA Power Transformer

3 Phase 50 Hz 2000 kVA Ynd1, core type double wound with copper conductor oil immersed ONAN cooled power transformer with the corrugated tank and conservator arrangement having a no load voltage ratio of 0.415/11 KV. Tapings +5% to -5% in steps of 2.5% shall be provided at line end of HV winding. Changing of taps shall be carried out by means of OFF load Tap Changer. Temperature rise shall be 50/60°C in oil/winding respectively over a maximum ambient of 40°C.

Transformer shall have metal cover for termination area with lifting eye.

The transformer shall be manufactured as per latest IEC, conforming to following parameters:

- HV Insulation level 12 KV
- Power Frequency 28 Kv r.m.s
- Basic impulse level 75 Kv – Peak.
- Hermetically sealed, without gas cushion.
- Insulating Liquid Type Oil to B.S. 148: 1998. Hermetically sealed

Dial Type thermometer with contacts and control box for relays. Oil level indicator and pressure relief valve and oil drain valve.

Paint class: for extreme weather conditions, salty, hot and humid environment.

Relevant testing standards: IEC / BS Standards.

Terminal Box cover LV n HV connection

All the terminal should be mark in color code.

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Section C

ފެނާކާ ޕްރޮޕްޔެރްޓީޕްރޮޖެކްޓްޕްރޮޖެކްޓް
ޕްރޮޖެކްޓްޕްރޮޖެކްޓް

Required Document and Evaluation criteria



Required Documents

- Quotation (inclusive of the delivery period and the payment terms)
- 1 compact disc (original bid document scanned and written), along with 2 sets of the bid documents (1 original and 1 copy set) separately packed and sealed with company stamp.
All the pages in bid documents should be stamped and bound properly
- Specification of the offered product
- Certificate of authenticity
- Original bid security (as per announcement)
- Details of the company
 - Company profile (a background of the company)
 - Company registration certificate
 - GST registration certificate (for local suppliers only)
 - Tax clearance report (6 months validity)
 - Contact details (name, designation, mobile number, e-mail address)
- Experience letters (If available - letters beyond 5 years / irrelevant experience letters / letters without project and value will not be accepted)

Evaluation Criteria

- Proposal Cost: 70 points for the lowest price
 - $(\text{Lowest price} / \text{proposed price}) \times 70$
- Delivery: 20 points for the minimum days to deliver the items
 - $(\text{Lowest delivery period} / \text{proposed delivery period}) \times 20$
- Credit Period: 10 points for the maximum credit period
 - $(\text{Proposed credit period} / \text{longest credit period}) \times 10$



Note:

- Bidders can submit maximum of 2 options.
- Bids lacking the documents above are subjected to be rejected during bid opening. Fenaka Corporation Limited will only accept items that meet OEM standards. In case the items do not meet the required standards, they will be rejected / returned.
- Please make sure the items are properly packaged and labelled separately as specifications given above.
- It is in Fenaka Corporation Limited's discretion to reject/cancel any quotation which does not fulfil or comply the above terms.
- It is in Fenaka's discretion to cancel this invitation to bid at any time.

Please submit your proposals addressed to:

Fenaka Corporation Limited
Port Complex Building, 7th Floor
Hilaalee Magu, Maafannu
K. Male', Republic of Maldives
Reference No: FNK-I/IUL/2019/239

The bids will be opened on 10th November 2019, Sunday, 11:00am (Male' time) at Fenaka Corporation 7th floor meeting room, in the presence of the bidders. The bids received after the stated time will not be accepted.

For further information, please contact us at tender@fenaka.com.mv

22nd October 2019