

# INFORMATION SHEET FOR PROCUREMENT OF 1.2mW GENERATOR SETS

Reference No.: FNK-I/IUL/2019/290

Issued on: 18th December 2019

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





### **Section I: Instruction to Bidders**

A. General							
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for a					
		1.2mW generator set in accordance to Section III,					
		Technical Specifications					
B. Preparation of the I	Bid						
2. Bid Prices	2.1	The unit price of each item and the total price shall be					
		clearly indicated in the quotation					
	2.2	All items shall be quoted in the bid (please refer to					
		Section III, Technical Specifications for the details of					
		required items)					
	2.3	Quotation shall separately indicate the additional					
		charges such as freight charges, insurance, etc.					
	2.4	The bidder shall submit quotation on CIF basis to Male'					
		port					
3. Currency	3.1	The bidder shall quote entirely in Maldivian Rufiyaa or					
		US Dollars					
4. Alternative Bids	4.1	Bidders can submit a maximum of two (2) options					
5. Validity of Bids	5.1	Quotation shall remain valid for minimum sixty (60)					
		days from the date of bid opening					
6. Bid Security	6.1	All bids should be accompanied with a bid security of					
		USD 9,000 (Nine Thousand US Dollars) or its					
		equivalent in Maldivian Rufiyaa					
	6.2	The bid security should be:					
		- Original bank guarantee letter (or)					
		- Bank guaranteed and stamped check (or)					
		- An insurance policy from Maldives Monetary					
		Authority (MMA) registered insurance company					
	6.3	Any bid not accompanied by a Bid Security shall be					
		rejected during bid opening					





# وسرکا کریری کری کرد و درجان و در کردی

	6.4	The bid security must be valid for a minimum of twenty						
		(20) additional days beyond the validity of quotation						
7. Technical Compliance	7.1	All relevant information including the brand shall be						
		given to enable technical evaluation of quoted items						
	7.2	The documents required for technical evaluation are:						
		- Technical data sheets of engine and the alternator						
		- Datasheets specifying cooling system rated at						
		ambient temperature 50°C						
		- Certificate of Authenticity specifying						
		manufacturer/assembler is an OEM or a genuine						
		reputed international engine brand						
	7.3	If the manufacturer or assembler is not the same as the						
		bidder, a document indicating that manufacturer or						
		assembler is willing to sell the generator set to the						
		bidder is required  Technical compliance letter will be required to enable						
	7.4	Technical compliance letter will be required to enable						
		technical evaluation						
	7.5	If the goods do not comply with the requirements						
		mentioned in Section III, Technical Specifications, the						
		bid will be rejected during evaluation.						
	7.6	Generator set should comply with our requirements, if						
		not the bid will be rejected						
8. Documents	8.1	Quotation (inclusive of the delivery period and						
Comprising the Bid		payment terms)						
	8.2	Specifications of the offered product						
	8.3	Certificate of Authenticity specifying that manufacturer						
		/ assembler is an OEM of a genuine reputed						
		international engine brand						
	8.4	Details of the company						
		- Company profile/background						
		- Company registration certificate						





## وُسْرَا الْمَرِيْ يُرْمِيْ مِنْ مِرْمِعَ الْمَرْمِ الْمُرْمِعِينَ مِرْمِعَ الْمُرْمِينَ مِرْمِعِينَا مِرْفُرِمِيْرِمْجَةَ

		- GST registration certificate (for local bidders only)
		- TAX clearance report (6 months validity)
		- Contact details (name, designation, mobile number
		and e-mail address)
	8.5	Experience letters, if available
		- Letters within past five (5) years
		- Relevant experience letters
		- Letters with project name and value
	8.6	One (1) compact disc with original bid document
		scanned and written
	8.7	Bids lacking the documents above are subjected to be
		rejected during the bid opening
9. Format of Bid	9.1	The Bidder shall submit two (2) sets of the bid
		document (1 original and 1 copy), enclosed separately
		in two envelopes and sealed with company stamp
	9.2	All pages of the bid document shall be stamped and
		bound properly (excluding the bid security)
C. Bid Submission		
10. Sealing and Marking	10.1	The bid document shall be sealed properly in an
Bid Document		envelope clearly marked 'ORIGINAL' or 'COPY',
		with the name of the company and the tender reference
		number (FNK-I/IUL/2019/290)
11. Bid Opening	11.1	The bids will be opened on 29 <sup>th</sup> December 2019,
		1000hrs in the presence of bidders
	11.2	Bids will be opened at:
		Fenaka Corporation Limited
		Hilaalee Magu, K. Male', Republic of Maldives
	11.3	Bids received electronically will not be accepted
12. Bid Rejection	12.1	Bidders that arrive after bid submission deadline shall
		not be able to participate in the bid





# 

	12.2	Bidders that do not register for the tender are unable to				
		participate in the bid opening				
	12.3	Bids lacking the documents mentioned in 8. Documents				
		Comprising the Bid (except 8.5 Experience letters) and				
		that do not comply with 9. Format of Bid are subjected				
		to be rejected				
D. Awarding of Contract						
13. Payment Terms	13.1	An advance will not be released for this project				
14. Factory Acceptance	14.1	All generators should be tested to run at 25%, 50%,				
Testing		75%, 100%, and 110% of rated load and power facto				
		until the engine temperature stabilized for 30 minutes,				
		and should check the protections below:				
		- Lub oil low level (alarm testing)				
		- Lub oil low pressure (alarm testing)				
		- Earth fault (alarm testing)				
		- Over current (alarm testing)				
		- High temperature (alarm testing)				
		- Cooling system (alarm testing)				
		- High voltage pressure (alarm testing)				
		- All the functioning tests and routine tests should be				
		done				
	14.2	All the protections should work properly, it should be				
		examined for oil and coolant leaks, and it should be				
		visually tested and secured				
	14.3	The remote radiator should operate continuously 100%				
		in a 50 degree ambient temperature				
		- It should be designed with vertical air discharge				
		remote radiator with motor and fan				
		- It should include all the generator connection pipes,				
		accessories, joints and diagrams				
	l					





وُسْرَنَا كَامِرِي مُنْ سَفِيشَ وِحِرَفَا اللَّهِ اللَّهِ مِنْ اللَّهِ اللَّهِ مِنْ اللَّهِ اللَّهُ اللَّالِي اللَّهُ اللَّا اللَّهُ اللَّا اللَّهُ اللَّهُ اللَّا اللَّهُ اللَّهُ اللَّا اللَّا اللّل

- The radiator should be developed remotely from the engine providing an added flexibility cooling system, and to be installed at the desired location
- It should be designed with lower power consumption, and high efficiency aero foil designed fans are used
- It must be designed with lower noise levels
- The radiator core should be formed using high efficiency fin profile
- The thickness of connection pipes must be in a range of 2mm to 4mm





وُسِرًا کی بری بر مفیر بروع یا برور بروغ

### **Section II: Evaluation Criteria**

**Proposal Cost**: 70 points for the lowest price

- (Lowest price / proposed price) x 70

Delivery: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 20
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

- (Proposed credit period / longest credit period) x 10
- No points will be given for payment terms if the supplier requests for Letter of Credit (LC)





### **Section III: Technical Specifications**

\*Please note that the below specifications are for one unit only.

S/N:	Description	Unit	Qty
	2 companie	Oint	QLY
1	1200 kW prime rated diesel generator set with parameters 0.8 P.F, 415kV, 3 Phase, 4 wires, 50 Hz at 1500 r.p.m. Powered by Internationally reputed brand engine coupled with internationally reputed brand Alternator.  The Generator set shall be powered by a Branded engine origin (UK, USA) or assembled/manufactured by an Original Company's Licenced OEM manufactured/assembler.  The engine must produce a mechanical power output (kW <sub>m</sub> ) which should meet the required electric power (kW <sub>e</sub> ) of 1200kW and must be coupled with a 1200kW Alternator with pre-installed Droop CT and a control connection box.(termination box to connect control cables and power cables)	1	No
	Engine to be complete with following auxilliary items:  • Heavy electrical flywheel  • SAE flywheel housing  • Air filters, Lubricating Oil Filters, Fuel Filters and all other such filter required for operation of the engine  • Low lubricating oil pressure switch  • High engine temperature switch  • lub oil sender  • Water Temperature Sender  • All necessary items to run and to protect the engine  • Starting equipment fitted to engine, consisting of:		
	• 24 Volt charging altenator (Brushless)     • 24 Volt starting motor     • Fuel Shut-off solenoid     • Heavy duty lead acid batteries, supplied in a dry charged condition      • Governing System     The engine to be fitted with a close tolerance Cummins Electronic     Governing system, which should include efc, actuators, magnetic pickups, etc, including wiring     • Cooling Equipment		
	Cooling equipment compromising a heavy-duty tropical remote radiator, with fans driven by Electric Motors (ABB or equivalent). The radiator core should be electroplated with silver solder tin plated to prevent early failure due to corrosion. Coupon plated radiators are acceptable.		
	Radiator must be designed to adequately cool the generator at an ambient temperature of 50°C		
	Exhaust system		





### وُسُرُمُ مُرَيِّةُ مُنْ مُنْ مُرْجِعَةً وَوْرِيْرُمْجُ

1.5.7	pipes. The lagging shall be covered with High Quality Aluminium foil.	1	Lot
F 7	washers,1spring washer 2 Nuts) Split type rockwool insulation lagging suitable for 75 to 125mm dia. Exhaust		
1.5.6	Bolts, Nuts and Washers for the Flanges. (Each set shall include 1 bolt, 2	1	Lot
1.5.5	Flanges having dia (to match the engine exhaust)	8	No
1.5.4	Elbows having dia (to match the engine exhaust)	6	No
1.5.3	3m Exhaust pipe dia ( to match engine exhaust)	4	No
1.5.2	Secondary silencer barrel (to match engine exhaust)	2	No
1.5.1	Primary silencer barrel (to match engine exhaust)	2	No
	The Components shall meet the British Standard and ISO standards. Items are for the above mentioned generator sets.		
1.5	Accessories		
	<ul> <li>1 No x Engine operation and maintenance manual</li> <li>1 No x Engine parts catalogue</li> <li>1 No x Generator parts catalogue</li> <li>1 No x Generator operation and maintenace manual</li> <li>1 No x Generator AVR manual</li> <li>1 No x Governor control unit manual</li> <li>1 No x Engine shop manual</li> </ul>		
24	<ul> <li>1 No x Manual on How to handle the generation equipment</li> <li>1 Nos x Electrical wiring diagram</li> </ul>	1	LOC
1.4	prior to dispatch in case the bidder is unable to provide factory test as required the bidder shall provide an extended warranty of one extra year than mentioned in iteme no 10 of this document.  Literature and drawings consisting of:	1	Lot
1.3	Factory testing The generator should be fully tested at the manufacturer workshop in the presence of client/apointees to check the ratings, overload, functional tests on a dummy load	1	No
	A fuel day tank of 12 hours capacity complete with level indicator, drain plug, filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet connection is to be mounted. These mounts are are to be suuplied as loose item. All necessary fittings to be supplied in conformity with fuel flow diagram.		
1.2	After assembling the genset zinc coated self-etching primer should be applied to the complete set.  Fuel system	1	No
	and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a base plate and vibration mounts to be mounted underside of the base plate. The vibration mounts are to be supplied as loose item.  • Finishing		
	Generator arrangement and drive  The simplex type base plate is of heavy duty rolled steel constructed, bolted		
	The alternator shall be brushless revolving type altenator, having class H insulation on both the stator and field windings. It shall be built and rated to BS 5000, tropically impregnated with voltage regulation being in the order of +/- 1.5% from no load to full load under the steady state conditions assuming a speed variation not exceeding 4% on the engine. Anti-Condensation Coil to be fitted in the Alternator. The output voltage of alternator should be 415V.		

Generator set should carry a warranty of one year from the date of commissioning	1	Lot
	-	LUC

#### **Documents Required for technical evaluation**

- technical data sheets of engine
- · technical data sheets of Alternator
- datasheets specifying cooling system rated at ambient temperature 50°C
- Certificate of Authenticity specifying Assembler is a Cummins OEM