



INFORMATION SHEET FOR PROCUREMENT OF POWER DISTRIBUTION SPARES

Reference No.: FNK-I/IUL/2026/136

Issued on 31st August 2026

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives

Section I: Instruction to Bidders

A. General	
1. Scope of Bid	1.1 Fenaka Corporation Limited requests quotations for power distribution Spare parts in accordance with Section III, Technical Specifications of this Bid Document, and all bidders are required to submit quotations in full conformity with these specifications/Packing List 1.2 Fenaka Corporation Limited reserves the right to cancel this bid invitation, at any stage prior to award, if deemed to be in the best interest of the Company. In such an event, bidders will be formally notified in writing.
2. Eligible Participants	2.1 Participants of this tender must be distributors or suppliers of genuine spare parts and equipment under this bid. Bidders must submit manufacturer's authorization letter or distributor certificate. 2.2 Local bidders must be legally registered in the Maldives and shall provide a valid company registration certificate, GST registration certificate, and a current tax clearance certificate 2.3 Foreign bidders must be legally registered in their country of origin and shall provide official company registration documents issued by the relevant government authority. All company registration documents submitted by foreign bidders must be notarized by a licensed Public Notary in the country of origin.
B. Preparation of the Bid	
3. Bid Prices	3.1 Bidders shall clearly state both the unit price of each item and the overall total price in their quotation. 3.2 Bidders must submit quotations for all items listed in Section III, (Technical Specifications/Packing List for the details of required items): partial or incomplete bids will not be accepted. 3.3 All bids shall be quoted on a CIF Male' Port basis, inclusive of all applicable duties, taxes, and charges up to delivery at Male' Port.
4. Currency	4.1 Local bidders shall quote prices entirely in Maldivian Rufiyaa (MVR).

	4.2 Foreign bidders shall quote their prices entirely in United States Dollars (USD). For evaluation purposes, all foreign currency quotations shall be converted into Maldivian Rufiyaa (MVR) at the official exchange rate published by the Maldives Monetary Authority (MMA) on the date of bid submission.
5. Alternative Bids	5.1 Each bidder shall submit only one (1) bid in response to this tender. Submission of multiple or alternative bids by the same bidder will not be accepted.
6. Validity of Bids	6.1 Each bid shall remain valid for a minimum of sixty (60) days from the date of bid opening.
7. Technical Compliance	7.1 Technical evaluation will be conducted solely based on written documents submitted by the bidder, and incomplete or missing submissions will result in disqualification. The following documents must be submitted for technical evaluation: - Manufacturer's Technical data sheets of the spares 7.2 Bidders shall provide all written technical information, documents, and certifications specified in Section III (Technical Specifications) to enable technical evaluation. 7.3 Any bid failing to demonstrate compliance with Section III (Technical Specifications) shall be rejected as non-responsive.
8. Documents Comprising the Bid	8.1 The bid shall include the proposed delivery period and payment terms 8.2 Detailed technical specifications of the offered product in accordance with Section III (Technical Specifications). 8.3 Company details, which shall include, - Company profile and background information - Company registration certificate - Memorandum of Association / Articles of Association - GST registration certificate (for local bidders only)

	- Valid Tax Clearance Report (issued within the last six months) - Contact details (name, designation, mobile number and e-mail address) - Proof of authority of the signatory: • For local bidders: Board Resolution or Power of Attorney signed and stamped by the company. • For foreign bidders: Authorization document notarized by a licensed Public Notary in the country of origin 8.4 - Experience letters: - Bidders may submit certificates or reference letters from clients covering the past five (5) years, specifying project name, contract value, scope of work/supply, and completion status. - Bidders that have previously supplied goods/services to Fenaka Corporation Limited within the past five (5) years shall provide contract title, reference number, contract value, year of supply, and description of goods/services supplied - Only relevant experience in the supply/installation or servicing of distribution spares will be considered for evaluation scoring. Absence of such documents will not result in disqualification but may reduce the bidder's technical evaluation score. 8.5 One (1) USB drive containing a scanned, read-only copy (PDF) of the complete bid document shall be submitted by each bidder (local and foreign bidders). The electronic version must be identical to the signed and stamped hard copy. In the event of inconsistency, the hard copy shall prevail. (Compact disk will not be accepted.) 8.6 Any bid failing to comply with the above requirements or lacking any of the mandatory documents listed under Section 7 (Technical Compliance), shall be rejected as non-responsive and excluded from further evaluation.
9. Format of Bid	9.1 Every page of the bid document shall be signed by the authorized signatory of the company, stamped with the company seal, and sequentially numbered.

	All required sections and annexes must be clearly indicated and properly arranged. Bids failing to comply with this requirement may be rejected as non- responsive.
C. Bid Submission	
10. Sealing and Marking Bid Document	10.1 Local bidders shall submit two (2) complete sets of the bid document: one (1) original and one (1) copy. Each set shall be enclosed separately in its own sealed envelope, clearly marked as “ORIGINAL” or “COPY.” The sealed envelopes shall then be placed in a single outer envelope, which shall be sealed and clearly marked with the tender reference number (FNK-I/IUL/2026/136) and the name of the bidder. In the event of any discrepancy, the signed and stamped “ORIGINAL” version shall prevail. 10.2 Foreign bidders may submit their bids electronically via the official tender email address specified in Section I, Clause 11.4. The bid documents must be encrypted with a password, and the password must be submitted separately within the specified time window on the day of bid opening. The subject line of the submission email shall include the tender reference number (FNK-I/IUL/2026/136). Any bid or password received after the specified time shall not be accepted. 10.3 Foreign bidders shall submit two (2) complete sets of the bid document: one (1) original and one (1) copy. Each set shall be enclosed separately in its own sealed envelope, clearly marked as “ORIGINAL” or “COPY.” The sealed envelopes shall then be placed in a single outer envelope, which shall be sealed and clearly marked with the tender reference number (FNK-I/IUL/2026/136) and the name of the bidder. In the event of any discrepancy, the signed and stamped “ORIGINAL” version shall prevail.
11. Bid Opening	11.1 All bids will be opened on <u>06th September 2026 (Sunday) at 1100hrs</u> (Maldivian Time) at: Fenaka Corporation Limited, 7th Floor Meeting Room, Port Complex Building, Hilaalee Magu, Malé 20207.

11.2 Only foreign bidders shall have the option of submitting their Bids electronically. Bids submitted electronically by a company registered in the Maldives will be rejected as non-responsive.

11.3 Physical Bid Submission - Local Bidders

Submission Address:

- Fenaka Corporation Limited,
- 7th Floor Meeting Room, Port Complex Building,
- Hilaalee Magu, Male' 20207

Submission Deadline: **06th September 2026 (Sunday) at 1100hrs** (Maldivian Time) - A - A representative for each local bidder shall attend the bid opening session. Failure to attend the bid opening session will render disqualification. The local bidder's representatives who are present shall sign a register evidencing their attendance.

11.4 Electronic Bid Submission –Foreign Bidders

Submission Email: tender.registration@fenaka.mv

Subject Line: Tender Reference Number

Bid Submission Deadline: **Encrypted bid documents must be emailed on the same day as the bid opening 30 minutes before 11:00hrs (Maldivian time). Password Submission Deadline: Passwords must be emailed between 11:00hrs to 11:15hrs.**

The electronic bids and the passwords received after **11:15hrs** will be rejected.

- Foreign bidders are required to be present via online video call during the bid opening (**Camera is a must**).
- The link for the bid opening session will be provided to foreign bidders 15 minutes before the bid opening.
- Foreign Bidders shall be online bid opening at **11:00hrs (Maldivian time)**.
- Failure to attend the bid opening session virtually at the Mentioned time will result in the rejection of the bid.

	- Each Bid shall have different passwords. - Foreign bidders submitting electronically shall dispatch the original physical bid documents to Fenaka Corporation Limited Head Office within seven (7) calendar days from the date of opening. - Bidders shall provide verifiable tracking details (e.g., courier or postal service tracking number) by email at the time of dispatch, as proof of timely submission of the original documents.
12. Bid Rejection	12.1 Bids received after the submission deadline shall not be accepted or opened. 12.2 Bidders that fail to complete the mandatory registration process for this tender shall not be eligible to participate. 12.3 Bids lacking any of the mandatory documents listed under Section 8 (Documents Comprising the Bid) or not prepared in accordance with Section 9 (Format of Bid), shall be rejected as non-responsive.
D. Awarding of Contract	
13. Packing	13.1 Materials must be packed in accordance with the packing list given in <i>Section III: Technical Specifications/Packing List</i> to avoid rejection
14. Payment Terms	14.1 Each proposal shall clearly specify the total cost of the goods and the credit period offered. These elements will form an integral part of the financial evaluation and must be explicitly stated in the bid. Payments shall be made in line with the agreed credit period, subject to satisfactory delivery, inspection, and acceptance of the goods by Fenaka Corporation Limited.
15. Performance Guarantee	15.1 The successful bidder shall, within fourteen (14) days of receiving the Notification of Award and prior to signing the contract, furnish a Performance Guarantee equivalent to fifteen percent (15%) of the contract value, in Maldivian Rufiyaa (MVR). The Performance Guarantee shall be provided in one of the following forms: - An original unconditional bank guarantee; or

	- A cash deposit; or - An insurance bond. 15.2 The Performance Guarantee shall cover the supplier's obligations for the supply and installation of the goods and must remain valid until successful completion of these obligations and final acceptance by Fenaka Corporation Limited. 15.3 Failure of the successful bidder to submit the Performance Guarantee within the stipulated period shall constitute sufficient grounds for cancellation of the award. 15.4 The Performance Guarantee will be released by Fenaka Corporation Limited only upon satisfactory completion of the contract and issuance of the final acceptance certificate.
--	---

Section II: Evaluation Criteria

Proposal Cost: 90 points for the lowest price

- $(\text{Lowest price} / \text{proposed price}) \times 90$

- **Delivery:** 05 points for the lowest delivery period
- $(\text{Lowest delivery period} / \text{proposed delivery period}) \times 05$
- Full marks for up to 75days delivery

Credit Period: 05 points for the maximum credit period

- $(\text{Proposed credit period} / \text{longest credit period}) \times 05$

Note: Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.

Section III: Technical Specifications

DESCRIPTION	PART NUMBER	UOM	QTY
MCCB 3P 160A		NOS	50.00
MCCB 3P 200A		NOS	100.00
MCB 3P 63A		NOS	200.00
MCB 1P 40A		NOS	3,000.00
TERMINAL BLOCK 250A X 4POLE		NOS	100.00
TERMINAL BLOCK 4 POLE 300A		NOS	200.00
24 hole, Insulated Neutral link		NOS	300.00
24 hole, Insulated Earth link		NOS	300.00
BUSBAR 100A 3P (I TYPE) (DISTRIBUTION BOX)		NOS	200.00
COPPER CABLE LUG 95SQMM		NOS	1,000.00
COPPER CABLE LUG 70SQMM		NOS	1,000.00
COPPER CABLE LUG 50SQMM		NOS	1,000.00
LUG SLEEVE 95SQMM (RED)		NOS	1,000.00
LUG SLEEVE 95SQMM (BLUE)		NOS	1,000.00
LUG SLEEVE 95SQMM (YELLOW)		NOS	1,000.00
LUG SLEEVE 95SQMM (BLACK)		NOS	1,000.00
LUG SLEEVE 70SQMM (RED)		NOS	1,000.00
LUG SLEEVE 70SQMM (BLUE)		NOS	1,000.00
LUG SLEEVE 70SQMM (YELLOW)		NOS	1,000.00
LUG SLEEVE 70SQMM (BLACK)		NOS	1,000.00
LUG SLEEVE 50SQMM (RED)		NOS	1,000.00
LUG SLEEVE 50SQMM (BLUE)		NOS	1,000.00
LUG SLEEVE 50SQMM (YELLOW)		NOS	1,000.00
LUG SLEEVE 50SQMM (BLACK)		NOS	1,000.00
Copper Cable Lug 50sqmm- (Pin Type)		NOS	1,000.00

DESCRIPTION	PART NUMBER	UOM	QTY
HV CABLE JOINT KIT 3C X 70SQMM(HEAT SHRINKABLE)		NOS	60.00
HV TERMINATION KIT 70SQMM		NOS	60.00
70sqmm HV COLD APPLIED BOOT KIT RIGHT ANGLE		NOS	60.00
HV GLAND KIT 3C X 70SQMM		NOS	15.00
HV LUG 70SQMM		NOS	200.00
HV FERRULE 70SQMM		NOS	50.00
EARTH CLIP 3/4 THREAD TYPE		NOS	50.00
EARTH ROD 3/4" 6FT		NOS	500.00
EARTH JOINT SOCKET 3/4"		NOS	500.00
HAMMERING BOLT 3/4"		NOS	20.00
HV JOINT KIT 185sqmm		NOS	15.00
HV TERMINATION KIT 185SQMM		NOS	20.00
185sqmm HV Cold Applied Boot Kit		NOS	20.00
HV GLAND KIT 3C X 185SQMM		NOS	10.00
HV LUG 185SQMM		NOS	50.00
HV CABLE FERRULE 185SQMM		NOS	15.00
TRANSFORMER REPAIR KIT		NOS	20.00
Cork Gasket Sheet 6mm (1 Mtr x 1 Mtr)		NOS	20.00
Cork Gasket Sheet 9mm (1 Mtr x 1 Mtr)		NOS	20.00

160 A MCCB Specification

160 A Rated Moulded Case Circuit breaker with adjustable thermal and magnetic trip settings meeting the following technical specifications:

Number of Poles	3 Pole
Type	Fixed
Rated Insulation Voltage	>750 V
Tripping Supply Voltage	24 Vdc
Frequency	50 Hz
Rated Voltage	415 V
Rated Current	160 A (Adjustable to 0.63 Ir)
Rated Short Circuit Breaking Current	25kA RMS
Control Mechanism	Local
Conforming Standard	IEC 60947-2

200 A MCCB Specification

200 A Rated Moulded Case Circuit breaker with adjustable thermal and magnetic trip settings meeting the following technical specifications:

Number of Poles	3 Pole
Type	Fixed
Rated Insulation Voltage	>750 V
Tripping Supply Voltage	24 Vdc
Frequency	50 Hz
Rated Voltage	415 V
Rated Current	200 A (Adjustable to 0.63 Ir)

Rated Short Circuit Breaking Current	25kA RMS
Control Mechanism	Local
Conforming Standard	IEC 60947-2

63A MCB Specification

Three-pole 63A MCB conforming to the specifications below. Brand must be internationally recognized and one of either ABB/Schneider/Hager/Chint/Entek/General Electric/Siemens.

Number of Poles	3 pole
Rated Current	63 A
Voltage	240/415 V _{AC}
Tripping Curve	Type C
Rated Breaking Capacity	10 kA
Operating Temperature	-40 to +70 °C
Conforming Standard	IEC 60898-1

40A MCB Specification

Single-pole 40A MCB conforming to the specifications below. Brand must be internationally recognized and one of either ABB/Schneider/Hager/Chint/Entek/General Electric/Siemens.

Number of Poles	1 pole
Rated Current	40 A
Voltage	240/415 V _{AC}
Tripping Curve	Type C
Rated Breaking Capacity	10 kA

Operating Temperature	-40 to +70 °C
Conforming Standard	IEC 60898-1

Copper Cable Lugs (50 sqmm, 70 sqmm and 95 sqmm)

Heavy duty tinned copper cables lugs of hole and minimum wall thickness sizes as follows:

Cross-sectional Area	Hole Size	Wall Thickness
50sqmm	10 mm	2.2 mm
70sqmm	12 mm	2.8 mm
95sqmm	12 mm	3.5 mm

High Voltage Joints, termination, boot kit, gland kit

High voltage joint, termination, boot and gland kits suitable for 11 kV, 3 core, XLPE copper armored cables. Manufacturer must be internationally reputed, and one of either Raychem/Cell Pack/3M/Nexans. All kits must be complete with all necessary accessories.

Transformer Repair Kit Specification

Sealant, along with dispensing tool, for patching active oil leaks from power transformers. Sealant should be fast cure with suitable properties for bonding with typical transformer materials (steel, ceramic, porcelain, rubber etc) and having characteristics suitable for long term operation of transformer once applied (UV and weather resistant, maintains integrity under high temperature > 100 °C, chemically inactive, high breakdown voltage > 30 kV). Coverage area of each kit should be at least 400 cm²