



ސަރުކާރުގެ ނަންބަރު: FNK-K(T)/FNK/IUL/2017/017

ދިވެހިސަރުކާރުގެ ގެޒެޓް

ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާގެ ސަރުކާރުގެ ގެޒެޓް ގައި 2017 ވަނަ އަހަރުގެ 01 ވަނަ ޖުލައިގައި 600 ޕްރައިމަރީ ރޭޓެޑް ދީސެލް ޖެނަރޭޓަރ ސެޓް ބޭނުންކުރާ ބޭނުންކުރާ ފަރާތްތަކަށް ބޭނުންކުރާ ޖެނަރޭޓަރ ސެޓް ބޭނުންކުރާ ފަރާތްތަކަށް.

#	Description	Unit	Quantity
1	The Standard of the genset shall meet the relevant British Standards. 600 kW prime rated diesel generator set. 0.8 P.F, 415 Volts, 3 Phase, 4 Wires, 50 Hz at 1500 r.p.m. Powered by Cummins engine origin (UK, USA) And supplier must submit certificate conforming they are Licenced OEM cummins manufacturer or assembler. The Engine Must be Produce a mechanical Power output wich should meet the required 600 KW and must be coupled with 600 kW stamford Altenator with pre Installed Droop CT, with remote mounted control panel. The controller should be Deepsea model: 8810 engine controller. Motorised TP,1000 A, ACB c/w UVT Coil AC 230 V, ("MERLIN GERIN") or equivalent.	Nos.	1
1.1	Engine to be complete with Heavy electrical flywheel SAE flywheel housing Air filters Lubricating oil filters Low lubricating oil pressure switch High engine temperature switch lub oil sender water Temperature Sender Together with all necessary items to run and to protect the engine		
1.1.1	Starting equipment The engine should be fitted with the following equipment 24 Volt charging altenator (Brushless) 24 Volt starting motor Fuel Shut-off solenoid Heavy duty lead acid batteries, supplied in a dry charged condition		
1.1.2	Governing The engine to be fitted with a close tolerance Cummins Electronic Governing system, which should include efc, actuators, magnetic pickups, etc, including wiring		
1.1.3	Cooling Equipment		

	<p>Cooling equipment comprising a heavy-duty tropical radiator, together with pusher type cooling fan and guards to be fitted. The radiator core should be electroplated with silver solder tin plated to prevent early failure due to corrosion. Coupon plated radiators are acceptable. the radiator has to be mounted on the vibration mounts and it should have enough strength to with stand the radiator.</p>	
<p>1.1.4 Exhaust system</p>	<p>450 mm of stainless steel below type flexible exhaust, together with suitable flanges and fittings shall be supplied for each silencer.</p>	
<p>1.1.5 Alternator</p>	<p>The alternator shall be brushless revolving type alternator, having class H insulation on both the stator and field windings. It shall be built and rated to BS 5000, tropically impregnated with voltage regulation being in the order of +/- 1.5% from no load to full load under the steady state conditions assuming a speed variation not exceeding 4% on the engine.</p> <p>Anti-Condensation Coil to be fitted in the Alternator.</p>	
<p>1.1.6 Generator arrangement and drive</p>	<p>The simplex type base plate is of heavy duty rolled steel constructed, bolted and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a base plate and vibration mounts to be mounted underside of the base plate. The vibration mounts are to be supplied as loose item.</p>	
<p>1.1.7 Fuel system</p>	<p>A fuel day tank of 12 hours capacity complete with level indicator, drain plug, filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet connection is to be mounted. These mounts are to be supplied as loose item. All necessary fittings to be supplied in conformity with fuel flow diagram.</p>	<p>Nos. 1</p>
<p>1.2 Factory testing</p>	<p>The generator should be fully tested at the manufacturer workshop in the presence of client/apointees to check the ratings, overload, functional tests on a dummy load prior to dispatch in case the bidder is unable to provide factory test as mentioned, the bidder shall provide an extended warranty of one extra year than mentioned in item no 10 of this document.</p>	
<p>1.3 Finishing</p>	<p>After assembling the genset zinc coated self-etching primer should be applied to the complete set.</p>	
<p>1.4 Warranty</p>	<p>Generator set should carry a warranty of one year from the date of commissioning the equipment.</p>	
<p>1.5 Literature and drawings</p>		



		ދަތުރުފުޅުގެ ނަންބަރު	
1.5.1	How to handle the generation equipment	Nos.	1
1.5.2	Electrical wiring diagram	Nos.	1
1.5.3	Engine operation and maintenance manual	Nos.	1
1.5.4	Engine parts catalogue	Nos.	1
1.5.5	Generator parts catalogue	Nos.	1
1.5.6	Generator operation and maintenance manual	Nos.	1
1.5.7	Generator AVR manual	Nos.	1
1.5.8	Governor control unit manual	Nos.	1
1.5.9	Engine shop manual	Nos.	1
<p>*Two separate manuals for the generator set shall be supplied and all the manuals to be enclosed in a fiber box file and the file should be labeled as "FENAKA CORP. LTD.600kW Generator Manuals".</p>			
1.6	Accessories		
<p>The Components shall meet the British Standard and ISO standards. Items are for the above mentioned generator sets.</p>			
1.6.1	Primary silencer barrel(to match engine exhaust)	Nos.	2
1.6.2	Secondary silencer barrel(to match engine exhaust)	Nos.	2
1.6.3	3m Exhaust pipe dia(to match engine exhaust)	Nos.	8
1.6.4	Elbows having dia (to match the engine exhaust)	Nos.	8
1.6.5	Flanges having dia (to match the engine exhaust)	Nos.	16

އަދި ސަރުކާރުގެ އިދާރާތުގެ ނަންބަރު: ފަނ/އ/އި/މ/އ/އެ/އ/2014.

ހުށަހަޅާ ވަނަ ކަށަވަރު:

- ހުށަހަޅާ ވަނަ ކަށަވަރު ސަރުކާރުގެ އިދާރާތުގެ ނަންބަރު: ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014.
- (ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014.)
- ސަރުކާރުގެ އިދާރާތުގެ ނަންބަރު: ފަނ/އ/އި/މ/އ/އެ/އ/2014.
- ސަރުކާރުގެ އިދާރާތުގެ ނަންބަރު: ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014.
- ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014.
- ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014. ފަނ/އ/އި/މ/އ/އެ/އ/2014.

